

Report for the Periodic Monitoring of Emissions to Air

Part 1. Executive Summary



Permit Number: PPC/156

Operator: Meggit Aircraft Braking Systems

Installation: Coventry

Monitoring Date(s): 28 August 2013

E.E. Report Ref.: 65490

Client Name: Meggit Aircraft Braking Systems

Client Address: Holbrook Lane
Coventry
CV6 4QY

Monitoring Organisation: Environmental Evaluation Ltd. (Head Office)
Lawton Square
Delph
Oldham
OL3 5DT

Date of Report: 16 September 2013

Report Written by: P Waters

Function: MCERTS Level 2 Team Leader

Report Approved By: P Waters

MCERTS Registration No.: MM 04 527

MCERTS Level: MCERTS Level 2

Technical Endorsements: TE1, TE2, TE3, TE4

Signed:

_____ 

Contents

Part 1. Executive Summary

1.1	Monitoring Objectives	3
1.2	Monitoring Results	4
1.3	Operating Information	4
1.4	Monitoring Deviations	4

Part 2. Supporting Information

Appendix A: General Information

A1	Environmental Evaluation Limited Staff Details	6
A2	Environmental Evaluation Limited Method Details	6
A3	Sub-Contract	6
A4	Equipment Used in the Monitoring Campaign	6

Appendix B: Emission Information

B1 Plating Area Main Stack Information

B1.1	Diagrams Showing the Dimensions and Monitoring Facilities	7
B1.2	Preliminary Velocity and Temperature Measurement	7
B1.3	Gaseous Fluorides to BS ISO 15713:2006	8
B1.4	Total NO _x (as NO ₂) to USEPA Method 7d	11
	Test Certificates	14
	MCERTS Certificates	19

1 Part 1: Executive Summary

1.1 Monitoring Objectives

Meggit Aircraft Braking Systems has been permitted under the Environmental Protection Act and associated legislation to operate various processes at the Coventry site, and a condition of that permit is that emission monitoring is undertaken on a regular basis to prove compliance or otherwise against prescribed emission limit values.

This report details the testing undertaken on the 28 August 2013

The substance monitoring requirements for each emission point are detailed below.

Substances Monitored	Emission Point Identification
	<i>Plating Area Main Stack</i>
Flow	✓
Temperature	✓
Fluorides	✓
Total NOx	✓
Water vapour	✓

1.2 Monitoring Results

Emission Point	Substance to be Monitored	Emission Limit Value	Measured Concentration	Uncertainty	Units	Reference Conditions	Date of Monitoring	Start and End Times	Monitoring Method Reference	Accreditation for use of Method	Operating Status
Plating Area Main Stack	Fluorides	5	0.3	± 0.03	mgm ⁻³	273K and 101.3 kPa, No Oxygen Correction, Wet Basis	28/08/2013	11:16 - 11:46	BS ISO 15713:2006	UKAS MCERTS	Normal
Plating Area Main Stack	Total NOx (as NO ₂)	200	4.0	± 0.4	mgm ⁻³	273K and 101.3 kPa, No Oxygen Correction, Wet Basis	28/08/2013	10:32 - 11:02	USEPA Method 7d	None	Normal

1.3 Operating Information

Emission Point Reference	Date	Process Type	Process Duration	Feedstock	Abatement
Plating Area Main Stack	28 August 2013	Plating Baths	Continuous	Metal Components	Wet Scrubber System

1.4 Monitoring Deviations

Emission Point Reference	Substance Deviations	Monitoring Deviations	Other Relevant Issues
Plating Area Main Stack	None	None	None

Report for the Periodic Monitoring of Emissions to Air

Part 2. Supporting Information



Permit Number: PPC/156

Operator: Meggit Aircraft Braking Systems

Installation: Coventry

Monitoring Date: 28 August 2013

E.E. Report Ref.: 65490

Client Name: Meggit Aircraft Braking Systems

Client Address: Holbrook Lane
Coventry
CV6 4QY

Monitoring Organisation: Environmental Evaluation Ltd. (Head Office)
Lawton Square
Delph
Oldham
OL3 5DT

Date of Report: 16 September 2013

Report Written by: P Waters


Function: MCERTS Level 2 Team Leader

Report Approved By: P Waters

MCERTS Registration No.: MM 04 527

MCERTS Level: MCERTS Level 2

Technical Endorsements: TE1, TE2, TE3, TE4

Signed: _____ 

APPENDICES

Appendix A: General Information

A1. Environmental Evaluation Limited Staff Details

Team Leader: P Waters
MCERTS No. MM 04 527
Certification Level: MCERTS Level 2
Technical Endorsements: TE1, TE2, TE3, TE4

Site Technician: P Soley
MCERTS No. MM 12 1187
Certification Level: MCERTS Level 1
Technical Endorsements: None

A2. Environmental Evaluation Limited Method Details

The indicated substances were measured by the standards and in house methods specified in the table below:

Substance	Standard	EE. Reference
Flow	BS EN 13284:2002	EE/P/001 & 2
Temperature	BS EN 13284:2002	EE/P/001 & 2
Fluorides	BS ISO 15713:2006	EE/P/017
Total NO _x (as NO ₂)	USEPA Method 7d	EE/P/029
Water vapour	BS EN 14790:2005	EE/P/013

A3. Sub-Contract

Analysis was subcontracted to a UKAS accredited laboratory.

A4. Equipment Used in the Monitoring Campaign


Equipment checklists appropriate to the methods were used.

Equipment Type	EE Equipment Reference Code
Low Flow Kit	LCL44
Pitot	LCL 20 1M L Type
Manometer	LCL 26
Thermosensor	LCL 15
Thermocouple	LCL 17
Tape Measure	LCL 18
Barometer	LCL 23
Stop Watch	LCL 25
Scales	LCL69
Check Weight	LCL27

Appendix B: Emission Information

B1 - Plating Area Main Stack Information

B1.1 Diagrams Showing the Dimensions and Monitoring Facilities of Plating Area Main Stack



B1.2 Preliminary Velocity and Temperature Measurement of Plating Area Main Stack

Traverse Point	Sample Line A			Sample Line B			Sample Line C			Sample line D		
	Stack Temp. (°C)	ΔP (Pa)	Swirl Angle (°)	Stack Temp. (°C)	ΔP (Pa)	Swirl Angle (°)	Stack Temp. (°C)	ΔP (Pa)	Swirl Angle (°)	Stack Temp. (°C)	ΔP (Pa)	Swirl Angle (°)
1	21	91	0	21	80	0						
2	21	85	0	21	85	0						
3	21	85	0	21	87	0						
4	21	87	0	21	87	0						
5	21	88	0	21	89	0						
6	21	86	0	21	91	0						
7	21	84	0	21	90	0						
8	21	83	0	21	90	0						
9	21	83	0	21	85	0						
10	21	82	0	21	86	0						
	ΣΔP _A	854		ΣΔP _B	870		ΣΔP _C			ΣΔP _D		

Barometric Pressure (mmHg)	765	Stack velocity (actual) ms ⁻¹	12
Static Pressure (mmH ₂ O)	5.10	Volumetric Flow (actual) m ³ min ⁻¹	1344
Diameter (m)	1.50	Assumed CO ₂ (%)	0.0
---		Assumed O ₂ (%)	20.9
Stack Area (m ²)	1.767	Assumed CO (%)	0.0
Port Size (mm)	100	Assumed H ₂ O (%)	2.0

Appendix B1.3 - Gaseous Fluorides to BS ISO 15713:2006 - Plating Area Main Stack

Company	Meggit Aircraft Braking System	Test Conducted by	P Waters & P Soley
Site	Coventry	Date of Test	28 August 2013
Plant Identification	Plating Area Main Stack		
Volume of Water Vapour at Standard Conditions V_{wstd}			
$V_{wstd} = (0.00124) \times V_{lc}$	=	Blank	Test 1
			Test 2
		0.0043	
			Units
			m³
Where:			
Constant	=	---	0.00124
Initial Dryer mass	=	---	839.1
Final Dryer mass	=	---	842.6
V_{lc} is the mass of water collected	=	---	3.5
			g
Volume of Gas Metered, Standard Conditions V_{mstd}			
$V_{mstd} = Y_d \times V_m \times 0.3592 \times \frac{P_m}{(273 + T_m)}$	=	Blank 1	Test 1
		0.0589	0.0589
			m³
Sample reference number - first Impinger	=	65490-HF3-280813	65490-HF1-280813
Sample reference number - second Impinger	=	---	65490-HF2-280813
Meter calibration factor Y_d	=	1.05	1.05
Test start time	=	---	11:16
Test end time	=	---	11:46
Test Duration	=	30	30
			minutes
Initial meter reading	=	---	0
Final meter reading	=	---	60.4
Total meter volume V_m	=	0.0604	0.0604
Meter Pressure P_m	=	765	765
			mm.Hg
Final meter temperature	=	---	26.0
Initial meter temperature	=	---	20.0
Average meter temperature T_m	=	23.0	23.0
			(°C)
Correction to standard conditions	=	0.3592	0.3592
			(°C)
Hydrogen Fluoride Concentration $C_{mgm^{-3}}$ - Dry Basis			
$C_{mgm^{-3}} = \frac{M_n}{V_{mstd}}$	=	Blank	Test 1
		0.2	0.3
			mgm⁻³
Where:			
Impinger reference numbers	=	65490-HF3-280813	65490-HF1-280813
Solution Concentration Impinger 1		0.05	0.05
Solution Volume Impinger 1		180	180
Mn1 is the Hydrogen Fluoride mass in Impinger	=	0.009	0.009
			mg
Second impinger reference number	=	---	65490-HF2-280813
Solution Concentration Impinger 1		---	0.05
Solution Volume Impinger 1		---	180
Mn2 is the Hydrogen Fluoride mass in Impinger	=	---	0.009
			mg
Absorption efficiency	=	---	50.0
			%
V_{mstd} is the volume of gas metered, standard con	=	0.0589	0.0589
			m ³

Appendix B1.3 - Gaseous Fluorides to BS ISO 15713:2006 - Plating Area Main Stack

Gaseous Fluoride Concentration at STP - Wet Basis - mgm^{-3}				
$C_{\text{mgm}^{-3}(\text{wet})} = C_{\text{mgm}^{-3}} \times \frac{(100 - W_v)}{100}$	=	Blank 1 0.1	Test 1 0.3	mgm^{-3}
Gaseous concentration at STP - Dry Basis	=	0.2	0.3	mgm^{-3}
Wv is the water vapour content	=	6.9	6.9	%

Concentration at 273k and 101.3kPa, Uncorrected for Oxygen, Wet Basis				
$C_{\text{atX}\%} = C_{\text{mgm}^{-3}} \frac{20.9 - O_{2\text{ref}}}{20.9 - O_{2\text{meas}}}$	=	Blank 1 0.1	Test 1 0.3	mgm^{-3}
Gaseous concentration at STP	=	0.1	0.3	mgm^{-3}
Atmospheric oxygen concentration	=	20.9	20.9	%
$O_{2\text{ref}}$ is the reference oxygen concentration	=	N/A	N/A	%
$O_{2\text{meas}}$ is the measured oxygen concentration	=	N/A	N/A	%

Gaseous Fluoride Rate of Discharge ghr^{-1}				
$E_{\text{g/hr}} = C \times Q_{\text{std}} \times \frac{60}{1000}$	=	Blank 1 10	Test 1 20	ghr^{-1}
Gaseous concentration at STP - Dry Basis	=	0.1	0.3	mgm^{-3}
Dry Total Flow Rate of Stack Gas Q_{std}	=	1113.1	1113.1	$\text{m}^3 \text{min}^{-1}$
60/1000 Conversion factor	=	0.06	0.06	

Comments on Compliance with BS ISO 15713:2006	
Hydrogen Fluoride absorption efficiency >95%	N/A
Temperature maintained above 150°C	Pass
Leak Rate <2%	Pass
Overall Blank Value <10% of the LV ^a	Pass
Duct gas flow with regard to stack axis <15°	Pass
Duct gas flow: negative velocity - not permitted	Pass
Duct gas flow: differential pressure at the pitot tube >5pa	Pass
Duct gas flow: ratio of max to min velocity <3:1	Pass

Were all of the requirements of BS ISO 15713:2003 fulfilled during the test?



Yes



No

Appendix B1.3 - Gaseous Fluorides to BS ISO 15713:2006 - Plating Area Main Stack

Uncertainty Calculations						
Measurement Data						
Measured Quantities	Symbol	Value	Standard Uncertainty		Units	
Sampled Volume	V_m	0.0604	(1%) uV_m	0.00060	m^3	
Sampled Gas Temperature	T_m	296.0	uT_m	3	k	
Sampled Gas Pressure	ρ_m	102.0	$u\rho_m$	0.1	kPa	
Sampled Gas Humidity	H_m	6.9	uH_m	0.1	% by volume	
Oxygen Content	$O_{2,m}$	N/A	$uO_{2,m}$	0.01	% by volume	
Mass	m	0.28	um_m	0.01	mg	
Leak	L	2	%	0.02		
Uncollected Mass	UCM	0			mg	
Intermediate Calculation to Correct for Standardisation of Conditions						
Factor for Std Conditions	f_s	0.86				
Uncertainty Components	symbol	Sensitivity Coefficient		u (in units of f_s)		
	ρ_m	0.008		0.001		
	H_m	0.009		0.001		
	T_m	0.003		0.009		
	u_{f_s}			0.009		
Corrected Volume	V	0.05	uV	0.001	m^3	
Intermediate Calculation to Correct for Oxygen Correction						
Factor for O ₂ Correction	f_c	1.00				
Uncertainty Components	symbol	Sensitivity Coefficient		u (in units of f_c)		
	$O_{2,m}$	1.00		0.010		
Factor for O ₂ Correction	u_{f_c}	1.00		0.010	%	
Calculation of Expanded Uncertainty						
Parameter		Value	Units	Sensitivity Coefficient	Uncertainty in Result	
Volume (Std conditions)	V	0.05	m^3	5.45	0.00	$mg.m^{-3}$
Mass	m	0.28	mg	1.00	0.01	$mg.m^{-3}$
Factor for O ₂ Correction	f_c	1.00		0.28	0.00	$mg.m^{-3}$
Leak	L	0.00	$mg.m^{-3}$	1.00	0.00	$mg.m^{-3}$
Uncollected mass	UCM	0.00	mg	0.00	0.00	$mg.m^{-3}$
Combined uncertainty					0.02	$mg.m^{-3}$
Expanded Uncertainty K=2					10.90	%
Expanded Uncertainty K=2					0.03	$mg.m^{-3}$

Appendix B1.4 - Total Nox (as NO₂) to USEPA Method 7d - Plating Area Main Stack

Company	Meggit Aircraft Braking System	Test Conducted by	P Waters & P Soley	
Site	Coventry	Date of Test	28 August 2013	
Plant Identification	Plating Area Main Stack			
Volume of Water Vapour at Standard Conditions V_{wstd}				
$V_{wstd} = (0.00124) \times V_{lc}$	=	Blank 0.00124	Test 1 0.0026	Units m ³
Where:				
Constant	=	---	0.00124	
Initial Dryer mass	=	---	713.5	g
Final Dryer mass	=	---	715.6	g
V_{lc} is the mass of water collected	=	---	2.1	g
Volume of Gas Metered, Standard Conditions V_{mstd}				
$V_{mstd} = Y_d \times V_m \times 0.3592 \times \frac{P_m}{(273 + T_m)}$	=	Blank 1 0.0148	Test 1 0.0148	m ³
Sample reference number - first Impinger	=	65490-N3-280813	65490-N1-280813	---
Sample reference number - second Impinger	=	---	65490-N2-280813	---
Meter calibration factor Y_d	=	1.05	1.05	---
Test start time	=	---	10:32	---
Test end time	=	---	11:02	---
Test Duration	=	30	30	minutes
Initial meter reading	=	---	0	litres
Final meter reading	=	---	15.1	litres
Total meter volume V_m	=	0.0151	0.0151	m ³
Meter Pressure P_m	=	765	765	mm.Hg
Final meter temperature	=	---	24.0	(°C)
Initial meter temperature	=	---	18.0	(°C)
Average meter temperature T_m	=	21.0	21.0	(°C)
Correction to standard conditions	=	0.3592	0.3592	
Total NOx (as NO₂) Concentration at STP - Dry Basis - mgm^{-3}				
$C_{mgm^{-3}} = \frac{M_n}{V_{mstd}}$	=	Blank 5.4	Test 1 4.7	mgm^{-3}
Where:				
Impinger reference numbers	=	65490-N3-280813	65490-N1-280813	
Solution Concentration Impinger 1	=	0.14	0.11	mg l ⁻¹
Solution Volume Impinger 1	=	571	388	ml
Mn1 is the Nitrate mass in Imp 1	=	0.07994	0.04268	mg
Second impinger reference number	=	---	65490-N2-280813	
Solution Concentration Impinger 1	=	---	0.14	mg l ⁻¹
Solution Volume Impinger 1	=	---	189	ml
Mn2 is the Nitrate mass in imp 2	=	---	0.02646	mg
Absorption efficiency	=	---	61.7	%
V_{mstd} is the volume of gas metered, standard cor	=	0.0148	0.0148	m ³

Appendix B1.4 - Total Nox (as NO₂) to USEPA Method 7d - Plating Area Main Stack

Total NOx (as NO₂) Concentration at STP - Wet Basis - mgm⁻³				
$C_{mgm-3(wet)} = C_{mgm-3} \times \frac{(100 - Wv)}{100}$	=	Blank 1 4.6	Test 1 4.0	mgm⁻³
Gaseous concentration at STP - Dry Basis	=	5.4	4.7	mgm ⁻³
Wv is the water vapour content	=	14.9	14.9	%

Concentration at 273k and 101.3kPa, Uncorrected for Oxygen, Wet Basis				
$C_{atX\%} = C_{mgm-3} \frac{20.9 - O_{2ref}}{20.9 - O_{2meas}}$	=	Blank 1 4.6	Test 1 4.0	mgm⁻³
Gaseous concentration at STP	=	4.6	4.0	mgm ⁻³
Atmospheric oxygen concentration	=	20.9	20.9	%
O _{2ref} is the reference oxygen concentration	=	N/A	N/A	%
O _{2meas} is the measured oxygen concentration	=	N/A	N/A	%

Total NOx (as NO₂) Rate of Discharge ghr⁻¹				
$E_{g/hr} = C \times Q_{std} \times \frac{60}{1000}$	=	Blank 1 306	Test 1 311	ghr⁻¹
Gaseous concentration at STP - Dry Basis	=	4.6	4.7	mgm ⁻³
Dry Total Flow Rate of Stack Gas Q _{std}	=	1113.1	1113.1	m ³ min ⁻¹
60/1000 Conversion factor	=	0.06	0.06	

Comments on Compliance with USEPA Method 7d	
Total NOx (as NO ₂) absorption efficiency >95%	N/A
Temperature maintained above 150°C	Pass
Leak Rate <2%	Pass
Overall Blank Value <10% of the LV ^a	Pass
Duct gas flow with regard to stack axis <15°	Pass
Duct gas flow: negative velocity - not permitted	Pass
Duct gas flow: differential pressure at the pitot tube >5pa	Pass
Duct gas flow: ratio of max to min velocity <3:1	Pass

Were all of the requirements of USEPA Method 7d fulfilled during the test?



Yes



No

Appendix B1.4 - Total Nox (as NO₂) to USEPA Method 7d - Plating Area Main Stack

Uncertainty Calculations					
Measurement Data					
Measured Quantities	Symbol	Value	Standard Uncertainty		Units
Sampled Volume	V _m	0.0151	(1%) uV _m	0.00015	m ³
Sampled Gas Temperature	T _m	294.0	uT _m	3	k
Sampled Gas Pressure	ρ _m	102.0	uρ _m	0.1	kPa
Sampled Gas Humidity	H _m	14.9	uH _m	0.1	% by volume
Oxygen Content	O _{2,m}	N/A	uO _{2,m}	0.01	% by volume
Mass	m	3.97	um _m	0.20	mg
Leak	L	2	%	0.02	
Uncollected Mass	UCM	0			mg
Intermediate Calculation to Correct for Standardisation of Conditions					
Factor for Std Conditions	fs	0.80			
Uncertainty Components	symbol	Sensitivity Coefficient		u (in units of fs)	
	ρ _m	0.008		0.001	
	H _m	0.009		0.001	
	T _m	0.003		0.008	
	ufs			0.008	
Corrected Volume	V	0.01	uV	0.000	m ³
Intermediate Calculation to Correct for Oxygen Correction					
Factor for O ₂ Correction	fc	1.00			
Uncertainty Components	symbol	Sensitivity Coefficient		u (in units of fc)	
	O _{2,m}	1.00		0.010	
Factor for O ₂ Correction	ufc	1.00		0.010	%
Calculation of Expanded Uncertainty					
Parameter:		Value	Units	Sensitivity Coefficient	Uncertainty in Result
Volume (Std conditions)	V	0.01	m ³	330.36	0.06
Mass	m	3.97	mg	1.00	0.20
Factor for O ₂ Correction	fc	1.00		3.97	0.04
Leak	L	0.05	mg.m ⁻³	1.00	0.05
Uncollected mass	UCM	0.00	mg	0.00	0.00
Combined uncertainty					0.22
Expanded Uncertainty K=2				10.95	%
Expanded Uncertainty K=2				0.43	mg.m⁻³

Test Certificates



Scientific Analysis Laboratories is a limited company registered in England and Wales (No 2514788) whose address is at Hadfield House, Hadfield Street, Manchester M16 9FE

Scientific Analysis Laboratories Ltd Certificate of Analysis

Hadfield House
Hadfield Street
Combrook
Manchester
M16 9FE
Tel : 0161 874 2400
Fax : 0161 874 2404

Report Number: 347921-1

Date of Report: 06-Sep-2013

Customer: Environmental Evaluation
Unit 10
Greenwood Court
Ramridge Road
Luton
LU2 0TN

Customer Contact: Mr Neil Teixeira

Customer Job Reference: 65490
Customer Purchase Order: STA12892PJ
Date Job Received at SAL: 30-Aug-2013
Date Analysis Started: 02-Sep-2013
Date Analysis Completed: 06-Sep-2013

The results reported relate to samples received in the laboratory
Opinions and interpretations expressed herein are outside the scope of UKAS accreditation
This report should not be reproduced except in full without the written approval of the laboratory
Tests covered by this certificate were conducted in accordance with SAL SOPs
All results have been reviewed in accordance with QP22



Report checked
and authorised by :
Kayleigh McCann
Project Manager

Issued by :
Kayleigh McCann
Project Manager

Validity unknown
Digitally signed by Kayleigh
McCann
Date: 2013.09.11 17:36 BST
Reason: Issued
Location: SAL

Page 1 of 2

SAL Reference: 347921						
Customer Reference: 65490						
Impinger (sodium hydroxide)		Analysed as Impinger (sodium hydroxide)				
Miscellaneous						
SAL Reference			347921 001	347921 002	347921 003	
Customer Sample Reference			65490/28/08/13/ HF1	65490/28/08/13/ HF2	65490/28/08/13/ HF3	
Test Sample			AR	AR	AR	
Determinand	Method	LOD	Units	Symbol		
Hydrogen Fluoride	IC (acetate separation method)	0.05	mg/l	U	(13) <-0.05	(13) <-0.05
Volume	Vol	1	ml	U	180	180

Index to symbols used in 347921-1

Value	Description
AR	As Received
13	Results have been blank corrected.
U	Analysis is UKAS accredited





Test Certificate

Date 05/09/2013

Client	Environmental Evaluation Ltd 10 Greenwood Court Ramridge Road Luton LU2 0TN	Order No.	STA12893PS
		Certificate No.	WK13-5410
		Issue No.	1

Contact	Mr Philip Waters	Date Received	30/08/2013
Description	3 solutions for NOX	Technique	IC

Sample No.	757803	65490/280813/N1	Method
Oxides of Nitrogen	<0.11 ug/ml	388 ml	C27(U)
Sample No.	757804	65490/280813/N2	Method
Oxides of Nitrogen	<0.14 ug/ml	189 ml	C27(U)
Sample No.	757805	65490/280813/N3	Method
Oxides of Nitrogen	<0.14 ug/ml	571 ml	C27(U)



Test Certificate

Date 05/09/2013

Client	Environmental Evaluation Ltd	Certificate No.	WK13-5410
		Issue No.	1

Tested By Nicholas Lynch **Date** 04/09/2013

Approved By [Redacted] **Date** 05/09/2013

Joanne Dewhurst
Laboratory Manager

For and on authority of RPS Laboratories Ltd.

Method Symbols (U) Analysis is UKAS Accredited
(N) Analysis is not UKAS Accredited

Concentration values (mg/m³ and ppm) are provided to assist with interpretation only, they are not covered by the scope of UKAS accreditation.

Results stated as ml are referring to the sample volume.

RPS Laboratories terms and conditions apply - a copy is available on request.

Analysis carried out on samples 'as received'

This document may not be reproduced other than in full, except with the written approval of the issuing laboratory.

MCERTS Certificates



Certificate of Personnel Competence

This is to certify that

Phil Waters

has been assessed by Sira Certification Service and
has demonstrated competence to the required standard of

Level 2 (team leader)

as defined in

**MCERTS Personnel Competency Standard
for Manual Stack-Emission Monitoring : February 2010, Version 7**

for the following Technical Endorsements:

TE1 - Particulate monitoring by isokinetic sampling techniques	expires Jun 2016
TE2 - Multi-phase sampling techniques	expires Jun 2016
TE3 - Gases/vapours by manual techniques	expires Jun 2016
TE4 - Gases/vapours by instrumental techniques	expires Jun 2016

Level 2 personnel may be required to retake the oral examination if the MCERTS Examination Board receives and upholds a complaint about them of a serious nature. The use of this certificate and the Sira Certification Mark are subject to the Regulations Applicable to Holders of Sira Certificates. The certificate holder agrees to comply with the MCERTS Code of Conduct. This certificate remains valid until the expiry date shown below.

Certificate issued :	Mar 2011	Certificate No :	Sira MP05	272 /2
Level 2 renewal date :	Mar 2016	Registration No :	MM04	527
H&S renewal date :	Jul 2014			
Certificate expiry date :	Jul 2014			


R. Cooper Eng MInstMC
Technical Director

This certificate remains the property of Sira and shall be returned when requested. It may only be reproduced in its entirety and without change.

MCERTS is operated on behalf of the Environment Agency by

Sira Certification Service

12 Acorn Industrial Park, Crayford Road,
Crayford, Dartford, Kent DA1 4AL
Tel:+44 (0)1322 520500 Fax:+44 (0)1322 520501



Certificate of Personnel Competence

This is to certify that

Phillip Soley

has been assessed by Sira Certification Service and
has demonstrated competence to the required standard of

Level 1 (technician)

as defined in

**MCERTS Personnel Competency Standard
for Manual Stack-Emission Monitoring : October 2012, Version 8.1**

The use of this certificate and the Sira Certification Mark are subject to the Regulations Applicable to Holders of Sira Certificates. The certificate holder agrees to comply with the MCERTS Code of Conduct. This certificate remains valid until the expiry date shown below.

Certificate issued : Dec 2012
Level 1 renewal date : Dec 2017
H&S renewal date : May 2017

Certificate expiry date : Dec 2017

Certificate No : Sira-692 /
Registration No : MM12 1187

R Cooper
Technical Director

MCERTS is operated on behalf on the Environment Agency by

Sira Certification Service

12 Acorn Industrial Park, Crayford Road,
Crayford, Dartford, Kent DA1 4AL
Tel: +44 (0)1322 520500 Fax: +44 (0)1322 520501

This certificate remains the property of Sira and shall be returned when requested.
It may only be reproduced in its entirety and without change.
Registered Office: Rake Lane, Eccleston, Chester CH1 9JN



End of Report