

MAINTENANCE SUMMARY SHEET FOR WORKSHOP HEATER AT 400 [PERIOD JAN 2014-JAN 2015]

JAN 03 2014 Heater cleaned & ash bagged plus oil line cleaned & combustion dish ordered. Smoke checked [OK].

JAN 10 2014 Heater stripped & cleaned, new [modified dish]/combustion pan fitted. Heater tested & smoke tested [OK] Outer cabinet also cleaned plus floor standing area.

JAN 17 2014 Oil spillage cleaned from floor,ash bagged & disposed of.

JAN 24 2014 Heater checked plus smoke checked [OK].

FEB 07 2014 Heater cleaned internally, run & checked. Smoke stack re-aligned & smoke checked [OK].

FEB 14 2014 Heater cleaned,ash bagged,heater tested [OK].

FEB 21 2014 Ash pan cleaned thoroughly & smoke tested & ash disposed of. Smoke test [OK].

FEB 28 2014 Full clean & inspection carried out. No problems found.

MARCH 07 2014 Inspected but no problems found.

MARCH 14 2014 Outside cabinet cleaned & stack strap re-placed , not run.

MARCH 21 2014 Oil supply tank drained.

NOV 07 2014 Heater run & tested [OK] Smoke [OK].

NOV 14 2014 Heater run drip tube cleaned, smoke test [OK].

NOV 20 2014 Heater internally & externally cleaned,smoke tested [OK] [Ash bagged].

DEC 05 2014 Heater tested ,supply tank checked & re-filled,run smoke tested [OK].

DEC 11 2014 Run, ash disposed of , ash pan scrapped clean, smoke [OK] [Run for only 2 days.

DEC 19 2014 Stripped & cleaned, not run at all.

JAN 05 2015 Heater check . Combustion seal part re-placed,outer cabinet cleaned& floor area.Smoke tested [OK].


Staff trained to operate & maintain heater ; STEPHEN BENTON

GRAHAM WHITE

NEVILLE BENTON

NO SMOKE EMISSION PROBLEMS NOTED OR RECORDED FOR PERIOD JAN2014-JAN20

ENDERMERE GARAGE LTD. UNIT 11, ALBION IND ESTATE, ENDEMERE ROAD, FOLESHILL



COVENTRY. CV6 5PY. M.D. MR N.E. BENTON

