



Replacing Metals
with Advanced Composites



NP Aerospace Ltd

473 Foleshill Road,
Coventry CV6 5AQ
England, UK

Tel :+44 (0)24 7670 2802
Fax:+44 (0)24 7668 7313

E-mail: info@np-aerospace.co.uk
Web site: www.np-aerospace.co.uk

Neil Chaplin
Coventry City Council
Environmental Heath
Coventry City Council
3rd Floor Broadgate House
Broadgate
Coventry
CV1 1NH

01 February 2012

Dear Neil,

RE: PPC/190 NP Aerospace - Emissions Testing Results (Sites 1 and 3)

Please find attached the results of a recent emissions testing programme at NP Aerospaces Foleshill Road Site, In Coventry.

Please accept our apologies for not getting this report to you late last year, however a combination of emissions monitoring contractor delays, reporting delays and production plant availability has meant that despite the work all being scheduled to take place prior to the October deadline, did not take place until later in the year. Please also note that a significant proportion of the production within the Site 1 has been relocated to Site 3 and as such, a number of the regulated operations (namely A1, A2 and A3) have not been in regular use during 2011.

We would like to make you aware of a breach in the emission levels of VOC for emission point A1. The sampling indicated that the average emissions of VOC from A1 were 374mg/m³ against an ELV of 100mg/m³. As you are aware Spray Booth 1 is the newest and most modern booth on site and has an integral carbon filtration (VOC abatement) fitted as an integral part of the extraction system. This emission level is therefore anomalous and completely unexpected.

Upon discovery of this situation, NP Aerospace have immediately called in the OEM maintenance engineer and carried out an internal investigation of which the findings are provided below:

Condition of filters: All of the filters were removed and inspected. The maintenance schedule for the carbon cartridges requires that they are replaced approximately every six months. All carbon filters were inspected and did not appear to be in poor / unserviceable condition. All filters were replaced with new units as a precautionary measure.

Condition of booth: The booth was dismantled and all filters removed. A couple of minor air gaps were noted along the edges of the filter mounts. Although these gaps are unlikely to be causing a significant preferential pathway , they have been sealed to ensure that extracted air cannot by-pass the carbon filter bank.



Sampling Technique: It has come to light that the sampling was carried out during both the spray-cycle and the baking cycle. Due to the configuration and design of the spray booth, emissions are only extracted and released to atmosphere during the spray cycle. A concern was raised

Sampling during the bake cycle is likely to give very unrepresentative results as the pitot tube flow measurements used to calculate the emissions concentrations and sampling rates prior to the commencement of sampling (during extraction) will not represent the conditions during the baking cycle (when there is no flow or releases). Understandable this would give rise to a very significant error in the concentrations calculated for the process.

Therefore it is the conclusion of this investigation that likely cause for the breach in emissions is not due to a maintenance or equipment failure, but instead due to the fact that the sampling was carried out during the bake cycle and not actually whilst the plant was extracting to atmosphere. This conclusion has been supported by the service engineer that was called out to attend the immediate maintenance of the plant.

NP Aerospace will notify their sampling contractor of these findings and ensure that in future all sampling is carried out during the next monitoring period.

We hope that this letter meets with your requirements, should you have any questions please do not hesitate to contact us.

Yours sincerely,

A solid black rectangular box used to redact the signature of the sender.

G Sandhu

Quality Manager

EMISSIONS MONITORING SURVEY (Annual Compliance – Site 1 & Site 3)

Prepared for:

NP Aerospace Ltd
Foleshill Road
Coventry
West Midlands
CV6 5AQ

| | |
|--------------------------|--|
| Permit Number | : PPC 189 & PPC 190 |
| Job Number | : P1098 |
| Report Number | : R001 |
| Report Issue Date | : 07/02/12 |
| Survey Dates: | : 23/08/11, 13/09/11 & 28/11/11 |

Prepared by:

Environmental Compliance Limited
Unit G1
Main Avenue
Treforest Industrial Estate
Pontypridd
CF37 5YL.

Tel: 01443 841760
Fax: 01443 841761

| | | | |
|----------------------------|--------------------|--|-------------|
| Report Issue: | | FINAL | |
| Report Prepared by: | | Report Reviewed & Approved by MCERTS Level Two Technical Endorsements TE1, TE2, TE3 & TE4 | |
| Name: | Jonathan Litterick | Name: | Andy Barnes |
| | | MCERTS No: | MM 03 235 |
| | | Signature: | [REDACTED] |
| Date: | 05/02/12 | Date: | 07/02/12 |

This report is not to be used for contractual or engineering purposes unless this approval sheet is signed where indicated by the approver and the report is designated "FINAL".



This report has been prepared by Environmental Compliance Limited (ECL) in their professional capacity as Environmental Consultants. The contents of the report reflect the conditions that prevailed and the information available or supplied at the time of its preparation. The report, and the information contained therein, is provided by ECL solely for use and reliance by the Client in performance of ECL's duties and liabilities under its contract with the Client. Until ECL has received payment in full as detailed in the quotation or contract the contents of this report remain the legal property of ECL. The contents of the report do not, in any way, purport to include any manner of legal advice or opinion.

Should the Client wish to release this report to a Third Party for the party's reliance, Environmental Compliance Ltd may, at its discretion, agree to such release provided that:

- Environmental Compliance Ltd gives written agreement prior to such release and ECL has received payment in full for all works/services undertaken;
- By release of the report to the Third Party, that Third Party does not acquire any rights, contractual or otherwise, whatsoever against Environmental Compliance Ltd and, accordingly, Environmental Compliance Ltd assume no duties, liabilities or obligations to that Third Party;
- Environmental Compliance Ltd accepts no responsibility for any loss or damage incurred by the Client or for any conflict of Environmental Compliance Ltd interests arising out of the Client's release of this report to the Third Party.

In the event that a report is revised and re-issued, the client shall ensure that any earlier versions of the report, and any copies thereof, are void and such copies should be marked with the words "superseded and revised".

Opinions and Interpretation expressed within this report are outside the scope of the UKAS accreditation.

MCERTS requirements mean that comparison of results with emissions limit values is not permitted within this report.

TABLE OF CONTENTS

| Section | Description | Page Number |
|---------------|--|-------------|
| | Document Control Sheet | |
| PART 1 | EXECUTIVE SUMMARY | 4 |
| 1 | MONITORING OBJECTIVES | 4 |
| 1.1 | Monitoring Results | 5 |
| 1.2 | Operating Information | 6 |
| 2 | MONITORING DEVIATIONS | 7 |
| PART 2 | SUPPORTING INFORMATION | 8 |
| 3 | SAMPLING STAFF DETAILS | 8 |
| 4 | SAMPLING PROTOCOLS / METHODOLOGIES | 9 |
| 5 | SAMPLE POINT DESCRIPTIONS | 11 |
| | EQUIPMENT IDs | 14 |
| | FIGURES | 16 |
| | TABLES | 20 |
| | VELOCITY TRAVERSE PROFILES | 31 |
| | FIELD CALIBRATION AND SAMPLING DATA | 37 |
| | LABORATORY ANALYSIS RESULTS | 46 |
| | UNCERTAINTY CALCULATIONS | 55 |

PART 1 - EXECUTIVE SUMMARY

1 Monitoring Objectives

Environmental Compliance Ltd (ECL) was commissioned by **NP Aerospace Ltd** to undertake an emission monitoring survey at their **Site 1 and Site 3 Factories, in Coventry**. This report presents the findings of the study.

The monitoring at this installation was carried out in accordance with our quotation reference **PC/P1098/Q001**, for compliance check monitoring of emissions to air. The substances requested for monitoring at each emissions point are listed below:

| Substances to be monitored | Emission Point Identification | |
|----------------------------|-------------------------------|-----------------|
| | SITE 1 | |
| | Spray Booth (A1) | Prep Booth (A2) |
| Particulates | • U | • U |
| Total Organic Carbon (TOC) | • U | |

| Substances to be monitored | Emission Point Identification | |
|----------------------------|-------------------------------|-----------------------|
| | SITE 1 | |
| | LineX Booth (A3) | Wet Backed Booth (A5) |
| Particulates | • U | • U |
| Total Organic Carbon (TOC) | • U | • U |

| Substances to be monitored | Emission Point Identification | |
|----------------------------|-------------------------------|------------------|
| | SITE 3 | |
| | Degreasing Booth (A1) | LineX Booth (A2) |
| Particulates | | • U |
| Total Organic Carbon (TOC) | • U | • U |
| Isocyanates | | • |

•
U

Denotes the substances to be monitored.

Denotes UKAS accreditation is held for monitoring that substance, but does not mean that it has been claimed which will depend on whether the testing could be completed in accordance with the Standard Reference Method.

Special Requirements: "None."

1.1 Monitoring Results

| Emission Point Reference | Substance to be Monitored | Emission Limit Value | Periodic Monitoring Result | Uncertainty % | Units | Reference Conditions 273 K, 101.3 kPa | Date of Sampling | Start and End Times | Monitoring Method Reference | Accreditation for use of Method | Tick if non-conforming test (see Sections 2 & 5) | Operating Status |
|--------------------------|---------------------------|----------------------|----------------------------|---------------|-------------------|---|------------------|---------------------|-----------------------------|---------------------------------|--|------------------|
| Site 1 A1 | Particulates | 50 | 1.90 | 30 | mg/m ³ | STP Wet | 28/11/11 | 11:06 – 11:39 | BS EN 13284-1 | UKAS / MCERTS | ✓ | Spray |
| | | | 0.32 | 100 | | | | 11:46 – 12:19 | | | ✓ | |
| | TOCs as Carbon | 100 | 122.63 | 8 | | | | 11:20 – 11:40 | | | BS EN 13526 | UKAS / MCERTS |
| Site 1 A2 | Particulates | 50 | 0.26 | 100 | mg/m ³ | STP Wet | 28/11/11 | 13:10 – 13:43 | BS EN 13284-1 | UKAS / MCERTS | ✓ | Normal |
| | | | 0.28 | 100 | | | | 14:06 – 14:39 | | | | |
| Site 1 A5 | Particulates | 50 | 0.28 | 100 | mg/m ³ | STP Wet | 13/09/11 | 14:00 – 14:41 | BS EN 13284-1 | UKAS / MCERTS | | Normal |
| | | | 0.43 | 100 | | | | 14:46 – 15:27 | | | | |
| Site 3 A1 | TOCs as Carbon | 75 | 40.5 | 19 | mg/m ³ | STP Wet | 23/08/11 | 10:53 – 12:23 | BS EN 13526 | UKAS / MCERTS | | Normal |
| | | | 1.28 | 37 | | | | 13:00 – 13:33 | | | ✓ | |
| Site 3 A2 | Particulates | 50 | 0.52 | 87 | mg/m ³ | STP Wet | 23/08/11 | 13:45 – 14:18 | BS EN 13284-1 | NU | | Normal |
| | | | 3.5 | 44 | | | | 12:35 – 14:15 | | | UKAS / MCERTS | |
| | Isocyanates | 0.1 | <0.002 | >100 | | | | | MDHS 25 | NA | | |

Notes

Emission Limit Value
 Periodic Monitoring Result
 Uncertainty
 Reference Conditions
 Monitoring Method Reference
 Accreditation for use of Method
 Operating Status

The emission limit value is that stated in the permit and will be expressed as a concentration or a mass emission.
 The result given is expressed in the same terms and units as the emission limit value.
 The uncertainty associated with the quoted result is at the 95% confidence interval. The uncertainty results **DO NOT** take into account the effect of the sample location limitations.
 All results are expressed at 273 K and 101.3kPa. The oxygen and moisture corrections are stated.
 The method stated is in accordance with the Environment Agency Technical Guidance Note M2, or other method approved by the Environment Agency.
The details indicate the accreditation for the use of the complete monitoring method, e.g. MCERTS, UKAS. If use of the method is not accredited "NA" is stated.
 The details indicate the feedstock and the loading rate of the plant during monitoring.
 Chemical Analysis on sample reagents was performed by an External Laboratory as detailed in Section 4
 UKAS Accreditation Held but UKAS Accreditation cannot be claimed for the test as sampling did not comply with the Standard Reference Method (SRM), see section 2 & 5
Method is NOT UKAS Accredited.

1.2 Operating Information

| Emission Point Reference | Process Type | Process Duration | Fuel | Feedstock | Abatement | Load | Comparison of Operator CEMS and Periodic Monitoring Results | | | | |
|--------------------------|--------------|------------------|------|-----------|------------|--------|---|------|------|--------------|-----------------------------|
| | | | | | | | Parameter | Date | Time | CEMS Results | Periodic Monitoring Results |
| Site 1 - A1 | Batch | Various | n/a | n/a | Dry Filter | Normal | ... | ... | NP | ... | ... |
| Site 1 - A2 | Batch | Various | n/a | n/a | Dry Filter | Normal | ... | ... | NP | ... | ... |
| Site 1 - A5 | Batch | Various | n/a | n/a | Wet Filter | Normal | ... | ... | NP | ... | ... |
| Site 3 - A1 | Batch | Various | n/a | n/a | Dry Filter | Normal | ... | ... | NP | ... | ... |
| Site 3 - A2 | Batch | Various | n/a | n/a | Dry Filter | Normal | ... | ... | NP | ... | ... |

Notes:

- Process Type
 - Process Duration
 - Fuel
 - Feedstock
 - Abatement
 - Load
 - CEMS Data
- State whether the process is a continuous or batch process.
 If a batch process, state the duration, frequency and details of the portion of the batch sampled. If continuous state "NA"
 If applicable, state the fuel type if not applicable state "NA"
 State the feedstock type
 State the type and whether operational during monitoring. If not applicable state "NA"
 State the normal load, throughput or rating of the plant
 Enter this data for each CEM installed if it is has been provided by operator otherwise state "NP" (NOT PROVIDED)

2 Monitoring Deviations

The objective of the survey was to measure the concentrations of pollutants from the processes / locations as detailed in Section 1. This survey meets the requirements of the site's **PPC Permit Number: PPC 189 & PPC 190** where UKAS and MCERTS accreditation has and could be claimed for the testing in the monitoring results table.

There were substance deviations from the original and agreed emissions monitoring schedule:-

- **Site 1 – A3:** Plant was not running on scheduled test dates, and has not been run for most of the year, it therefore could not be tested.

Non-conforming tests/ sample locations are as follows:-

- **Site 1 – A1 & A2:** Flow profiles do not conform to the requirements of the SRM. This is because swirl was measured at greater than 15° at a number of points on the sample plane. (Particulate sampling took place on points where swirl was below 15°)
- **Site 1 – A1:** Due to the high duct velocities, a nozzle diameter of less than 6mm had to be used to achieve isokinetic sample rates during particulate samples.
- **Site 3 – A1:** Flow profile does not conform to the requirements of the SRM. This is because swirl was measured at greater than 15° at a number of points on the sample plane.
- **Site 3 – A1 & A2:** Flow profiles do not conform to the requirements of the SRM. This is because the ratio of highest to lowest pitot readings was greater than 9:1.

Homogeneity tests have not been completed for pollutants at any of the sampling locations. Tests are not applicable to these locations and were not requested by client.

PART 2 – SUPPORTING INFORMATION

3 SAMPLING STAFF DETAILS

Site Sampling Team

| Names of Site Team | Dates on Site | MCERTS No. | LEVEL | Technical Endorsements |
|--------------------|----------------------|------------|-------|------------------------|
| Paul Calland | 23/08/11 | MM 03 212 | 2 | TE1, TE2, TE3, TE4 |
| Jonathan Litterick | 23/08/11 13/09/11 | MM 03 236 | 2 | TE1, TE2, TE3, TE4 |
| Robert Jones | 28/11/11 | MM 04 482 | 2 | TE1, TE2, TE3, TE4 |
| Andrew Osborne | 13/09/11 28/11/11 | MM 07 842 | 1 | ... |

Report Reviewer

| Name | MCERTS No. | LEVEL | Technical Endorsements |
|-------------|------------|-------|------------------------|
| Andy Barnes | MM 03 235 | 2 | TE1, TE2, TE3, TE4 |

Technical Endorsement Key:-

- TE1** – Isokinetic Particulates, Temperature & Velocity Profiles, Oxygen.
TE2 – Isokinetic Extractive Pollutants:- Metals, Dioxin & Furans, PAHs, PCBs, HCL, HF.
TE3 – Non-Isokinetic Extractive Pollutants:- Speciated VOCs, HF, HCL, Cyanide.
TE4 – Continuous Analysers (Combustion Gases):- VOCs, CO, NOx, SO2.

4 SAMPLING PROTOCOLS / METHODOLOGIES

TOCs as Carbon

Testing was carried out using a Signal 3030PM FID and heated gas transport system with reference to the manufacturer's operation handbook **BS EN 13526** and in-house technical procedure **ECL/TPD/032**. The analyser was calibrated pre and post the sample period using span gas and nitrogen / zero scrubbed air. Data was corrected by molecular weight to VOCs as total carbon.

Data was recorded as minute averages over each test period. The minute averaged data is presented in the Figures Section and the minute averaged data is detailed in the Tables Section.

Particulates

Testing was carried out using a Manual Stack Sampling system in accordance with **BS EN 13284-1 & MID** and In-house technical procedure **ECL/TPD/027a**.

Isokinetic particulate sampling is achieved when the velocity of gas entering the sampling nozzle is exactly equal to the velocity of the approaching gas stream within the stack.

A measured volume of sample gas is withdrawn from the stack isokinetically through a sampling nozzle and through a pre-weighed filter positioned in an unheated housing inserted into the stack.

Particulate matter is collected on the filter. Following testing the front half of the filter housing and the sample nozzle are rinsed to remove any particulate matter which, may have impacted on the surfaces during testing. The filters and rinses are subsequently analysed to determine the amount of particulate matter captured.

Scientific Analysis Laboratories Ltd (SAL) who are situated in Manchester carried out the analysis of the samples. **SAL** are UKAS accredited for all analysis conducted. In addition to the survey samples, a field blank is submitted as part of the technical procedure.

Isocyanates

Testing was carried out in accordance with **MDHS 25/3**. In this method a measured volume of stack gases is removed from the duct and first passed through a filter, pre treated with 1-2 MP in Toluene, then passed through a series of impingers containing 1-2 MP in Toluene. After sampling the filter is combined with the impinger solution for analysis.

ECL are not UKAS accredited for this sampling method.

Scientific Analysis Laboratories Ltd (SAL) who are situated in **Manchester** carried out the analysis of the samples. **SAL** are UKAS accredited for this analysis.

In addition to the survey samples, a field blank is submitted as part of the procedure.

Pressure, Temperature and Velocity

Testing was carried out using a sampling system in accordance with **BS EN 13284-1 & MID** and In-house technical procedure **ECL/TPD/022**.

Temperature was recorded using a thermocouple and digital temperature reader. Velocity and pressure was recorded using an "L" type pitot and digital manometer, data being recorded in Pascals.

5 SAMPLE POINT DESCRIPTIONS

The sample locations that were monitored are detailed below:-

Site 1 – Spray Booth (A1)

The sampling location does not meet the requirements detailed in *Technical Guidance Note (Monitoring) M1 "Sampling requirements for stack-emission monitoring" Environment Agency*, and BS EN 13284-1 due to the flow profile (Swirl of greater than 15° was measured in areas of the sample plane). The stack dimensions are 0.60m by 0.60m and the sample platform (a temporary scaffold) was 1.5m wide behind the sample ports. Two sample ports are located on one side of the square duct and are located on the same plane. These sample ports are located at a height of approximately 1.0m from the working sample platform. Sampling for Particulates was carried out using an in-stack filter system.

Samples for particulates are non-conforming, due to the fact that the flow profile does not conform to the SRM. Swirl was measured at greater than 15° at a number of points on the sample plane. (Particulate sampling took place at points where swirl was below 15°)

The Uncertainty of the reported concentrations for these pollutant results DOES NOT take into account the effect of these non-conformities or sample location limitations.

Site 1 – Prep Booth (A2)

The sampling location does not meet the requirements detailed in *Technical Guidance Note (Monitoring) M1 "Sampling requirements for stack-emission monitoring" Environment Agency*, and BS EN 13284-1 due to the flow profile (Swirl of greater than 15° was measured in areas of the sample plane). The stack dimensions are 0.60m by 0.60m and the sample platform (a temporary scaffold) was 2.0m wide behind the sample ports. Two sample ports are located on one side of the square duct and are located on the same plane. These sample ports are located at a height of approximately 1.0m from the working sample platform. Sampling for Particulates was carried out using an in-stack filter system.

Samples for particulates are non-conforming, due to the fact that the flow profile does not conform to the SRM. Swirl was measured at greater than 15° at a number of points on the sample plane. (Particulate sampling took place at points where swirl was below 15°)

The Uncertainty of the reported concentrations for these pollutant results DOES NOT take into account the effect of these non-conformities or sample location limitations.

Site 1 – Wet Back Booth (A5)

The stack dimensions are 0.58m by 0.58m and the sample platform (a temporary scaffold) was 1.5m wide behind the sample ports. Two sample ports are located on one side of the square duct and are located on the same plane. These sample ports are located at a height of approximately 1.0m from the working sample platform.

Sampling for Particulates was carried out using an in-stack filter system.

Site 3 – Degreasing Booth (A1)

The sampling location does not meet the requirements detailed in *Technical Guidance Note (Monitoring) M1 "Sampling requirements for stack-emission monitoring"* Environment Agency, and BS EN 13284-1 due to the flow profile (Swirl of greater than 15° was measured in areas of the sample plane and ratio of highest to lowest pitot reading was greater than 9:1).

The stack diameter is 0.8m and the sample platform width back from the sample port is 2.0m. Two sample ports are located on the stack at 90 degrees to each other and are located on the same plane.

The sample location is non-conforming, due to the fact that the flow profile does not conform to the SRM. Swirl was measured at greater than 15° at a number of points on the sample plane, also the ratio of highest to lowest pitot readings exceeded 9:1.

The Uncertainty of the reported concentrations for these pollutant results DOES NOT take into account the effect of these non-conformities or sample location limitations.

Site 3 – LineX Booth (A2)

The sampling location does not meet the requirements detailed in *Technical Guidance Note (Monitoring) M1 "Sampling requirements for stack-emission monitoring"* Environment Agency, and BS EN 13284-1 due to the flow profile (Ratio of highest to lowest pitot reading was greater than 9:1).

The stack diameter is 0.8m and the sample platform width back from the sample port is 2.0m. Two sample ports are located on the stack at 90 degrees to each other and are located on the same plane.

Sampling for Particulates was carried out using an in-stack filter system.

Samples for particulates are non-conforming, due to the fact that the ratio of highest to lowest pitot readings exceeded 9:1. As a consequence of this deviation, UKAS/MCERTS accreditation cannot be claimed for the particulate samples.

The Uncertainty of the reported concentrations for these pollutant results DOES NOT take into account the effect of these non-conformities or sample location limitations.

EQUIPMENT IDs
(Pre site checklist from SSP)

FIGURES

Figure 1

Continuous VOC Emissions Data recorded from Spray Booth (A1) - Site 1 NP Aerospace.
between 11:20 - 11:40, on 28/11/2011. (SPRAYING)
Reference Conditions (273K, 101.3kPa, & Wet Gas)




Figure 2

Continuous VOC Emissions Data recorded from Spray Booth (A1) - Site 1 NP Aerospace.
between 11:20 - 12:20, on 28/11/2011. (Bake Cycle)
Reference Conditions (273K, 101.3kPa, & Wet Gas)




Figure 3

Continuous VOC Emissions Data recorded from Wet Backed Booth (A5) - Site 1 NP Aerospace.
between 14:15 - 15:15, on 13/09/2011.
Reference Conditions (273K, 101.3kPa, & Wet Gas)




Figure 4

Continuous VOC Emissions Data recorded from Degreasing Booth (A1) - Site 3, NP Aerospace.
between 10:53 - 12:23, on 23/08/2011.
Reference Conditions (273K, 101.3kPa, & Wet Gas)





Figure 5

Continuous VOC Emissions Data recorded from LineX booth (A2) - Site 3, NP Aerospace.
between 12:35 - 14:15, on 23/08/2011.
Reference Conditions (273K, 101.3kPa, & Wet Gas)



TABLES

Table 1

Data Recorded from Spray Booth (A1) – Site 1, NP Aerospace
Sample Period: 11:20 – 12:20 on the 28th November 2011.
(Spraying 11:20 to 11:40, Baking 11:40 to 12:20)

Volumetric Flowrate (Reference Conditions) = 4.74 m³/sec *

| | Average | Emission Rate |
|-----------------------------|-------------------|---------------|
| | mg/m ³ | Kg/hr |
| VOCs (as carbon) (Spraying) | 122.63 | 2.09 |
| VOCs (as carbon) (Baking) | 498.13 | 8.50 |

Data expressed at (273K, 101.3 kPa, & Wet Gas)

Table 2

Data Recorded from Wet Backed Booth (A5) – Site 1, NP Aerospace
Sample Period: 14:15 – 15:15 on the 13th September 2011

Volumetric Flowrate (Reference Conditions) = 1.87 m³/sec *

| | Average | Emission Rate |
|------------------|-------------------|---------------|
| | mg/m ³ | Kg/hr |
| VOCs (as carbon) | 24.2 | 0.16 |

Data expressed at (273K, 101.3 kPa, & Wet Gas)

Table 3

Data Recorded from Degreasing Booth (A1) – Site 3, NP Aerospace
Sample Period: 10:53 – 12:23 on the 23rd August 2011

Volumetric Flowrate (Reference Conditions) = 2.76 m³/sec *

| | Average | Emission Rate |
|-------------------------|-------------------------|----------------------|
| | mg/m³ | Kg/hr |
| VOCs (as carbon) | 40.5 | 0.40 |

Data expressed at (273K, 101.3 kPa, & Wet Gas)

Table 4

Data Recorded from LineX Booth (A2) – Site 3, NP Aerospace
Sample Period: 12:35 – 14:15 on the 23rd August 2011

Volumetric Flowrate (Reference Conditions) = 3.08 m³/sec *

| | Average | Emission Rate |
|-------------------------|-------------------------|----------------------|
| | mg/m³ | Kg/hr |
| VOCs (as carbon) | 3.5 | 0.04 |

Data expressed at (273K, 101.3 kPa, & Wet Gas)

Table 5 – Particulates
Data Recorded from Site 1 - Spray Booth (A1)

| Emission Parameter | Units | TPM- 1 | Blank |
|--|----------------------|---------------|-------------|
| Duct Length | metres | 0.60 | ... |
| Duct Width | metres | 0.60 | ... |
| Area of Sample Plane | m ² | 0.360 | ... |
| Moisture Content | % | 0.02 | ... |
| Oxygen Content | % | 20.90 | ... |
| Stack Temperature | °C | 16 | ... |
| Gas Velocity (at Stack Conditions) | m/sec | 14.06 | ... |
| Gas Velocity (Reference Conditions) | m/sec* | 13.16 | ... |
| Volumetric Flowrate (Stack Conditions) | m ³ /sec | 5.06 | ... |
| Volumetric Flowrate (Reference Conditions) | m ³ /sec* | 4.74 | ... |
| Sample Date | ... | 28/11/2011 | ... |
| Sample Period | ... | 11:06 - 11:39 | ... |
| Sample Volume (at Stack) | m ³ | 0.57 | ... |
| Sample Volume (reference Conditions) | m ³ * | 0.54 | 0.54 |
| Isokinetic Sampling Rate | % | 107.2 | ... |
| Sample Reference (ECL ID) | ECL/11/ | 6819 & 6820 | 6823 & 6824 |
| Mass of Particulate Matter Collected | mg | 1.02 | 0.15 |
| Concentration of Particulate Matter | mg/m ³ * | 1.90 | 0.28 |
| Emission Rate of Particulate Matter | g/hr | 32.46 | ... |
| Expanded Uncertainty (%Relative) | % | 30 | ... |
| Emission Limit Value (ELV) | mg/m ³ * | 50 | ... |
| Blank Concentration as Percentage of ELV | % | ... | <1.00% |

*Reference Conditions (273K, 101.3kPa, Wet Gas)

Table 6 – Particulates
Data Recorded from Site 1 - Spray Booth (A1)

| Emission Parameter | Units | TPM- 2 | Blank |
|--|----------------------|---------------|-------------|
| Duct Length | metres | 0.60 | ... |
| Duct Width | metres | 0.60 | ... |
| Area of Sample Plane | m ² | 0.360 | ... |
| Moisture Content | % | 0.02 | ... |
| Oxygen Content | % | 20.90 | ... |
| Stack Temperature | °C | 16 | ... |
| Gas Velocity (at Stack Conditions) | m/sec | 14.06 | ... |
| Gas Velocity (Reference Conditions) | m/sec* | 13.16 | ... |
| Volumetric Flowrate (Stack Conditions) | m ³ /sec | 5.06 | ... |
| Volumetric Flowrate (Reference Conditions) | m ³ /sec* | 4.74 | ... |
| Sample Date | ... | 28/11/2011 | ... |
| Sample Period | ... | 11:46 - 12:19 | ... |
| Sample Volume (at Stack) | m ³ | 0.57 | ... |
| Sample Volume (reference Conditions) | m ³ * | 0.53 | 0.53 |
| Isokinetic Sampling Rate | % | 106.2 | ... |
| Sample Reference (ECL ID) | ECL/11/ | 6821 & 6822 | 6823 & 6824 |
| Mass of Particulate Matter Collected | mg | 0.17 | 0.15 |
| Concentration of Particulate Matter | mg/m ³ * | 0.32 | 0.28 |
| Emission Rate of Particulate Matter | g/hr | 5.46 | ... |
| Expanded Uncertainty (%Relative) | % | 179 | ... |
| Emission Limit Value (ELV) | mg/m ³ * | 50 | ... |
| Blank Concentration as Percentage of ELV | % | ... | <1.00% |

*Reference Conditions (273K, 101.3kPa, Wet Gas)

Table 7 – Particulates
Data Recorded from Site 1 - Prep Booth (A2)

| Emission Parameter | Units | TPM - 1 | Blank |
|--|----------------------|---------------|-------------|
| Duct Length | metres | 0.60 | ... |
| Duct Width | metres | 0.60 | ... |
| Area of Sample Plane | m ² | 0.360 | ... |
| Moisture Content | % | 0.02 | ... |
| Oxygen Content | % | 20.90 | ... |
| Stack Temperature | °C | 12 | ... |
| Gas Velocity (at Stack Conditions) | m/sec | 5.47 | ... |
| Gas Velocity (Reference Conditions) | m/sec* | 5.19 | ... |
| Volumetric Flowrate (Stack Conditions) | m ³ /sec | 1.97 | ... |
| Volumetric Flowrate (Reference Conditions) | m ³ /sec* | 1.87 | ... |
| Sample Date | ... | 28/11/2011 | ... |
| Sample Period | ... | 13:10 - 13:43 | ... |
| Sample Volume (at Stack) | m ³ | 0.60 | ... |
| Sample Volume (reference Conditions) | m ³ * | 0.57 | 0.57 |
| Isokinetic Sampling Rate | % | 108.3 | ... |
| Sample Reference (ECL ID) | ECL/11/ | 6825 & 6826 | 6829 & 6830 |
| Mass of Particulate Matter Collected | mg | 0.15 | 0.15 |
| Concentration of Particulate Matter | mg/m ³ * | 0.26 | 0.26 |
| Emission Rate of Particulate Matter | g/hr | 1.77 | ... |
| Expanded Uncertainty (% Relative) | % | >100% | ... |
| Emission Limit Value (ELV) | mg/m ³ * | 50 | ... |
| Blank Concentration as Percentage of ELV | % | ... | <1.00% |

*Reference Conditions (273K, 101.3kPa, Wet Gas)

Table 8 – Particulates
Data Recorded from Site 1 - Prep Booth (A2)

| Emission Parameter | Units | TPM - 2 | Blank |
|--|----------------------|---------------|-------------|
| Duct Length | metres | 0.60 | ... |
| Duct Width | metres | 0.60 | ... |
| Area of Sample Plane | m ² | 0.360 | ... |
| Moisture Content | % | 0.02 | ... |
| Oxygen Content | % | 20.90 | ... |
| Stack Temperature | °C | 16 | ... |
| Gas Velocity (at Stack Conditions) | m/sec | 5.51 | ... |
| Gas Velocity (Reference Conditions) | m/sec* | 5.16 | ... |
| Volumetric Flowrate (Stack Conditions) | m ³ /sec | 1.98 | ... |
| Volumetric Flowrate (Reference Conditions) | m ³ /sec* | 1.86 | ... |
| Sample Date | ... | 28/11/2011 | ... |
| Sample Period | ... | 14:06 - 14:39 | ... |
| Sample Volume (at Stack) | m ³ | 0.58 | ... |
| Sample Volume (reference Conditions) | m ³ * | 0.54 | 0.54 |
| Isokinetic Sampling Rate | % | 103.4 | ... |
| Sample Reference (ECL ID) | ECL/11/ | 6827 & 6828 | 6829 & 6830 |
| Mass of Particulate Matter Collected | mg | 0.15 | 0.15 |
| Concentration of Particulate Matter | mg/m ³ * | 0.28 | 0.28 |
| Emission Rate of Particulate Matter | g/hr | 1.86 | ... |
| Expanded Uncertainty (% Relative) | % | >100% | ... |
| Emission Limit Value (ELV) | mg/m ³ * | 50 | ... |
| Blank Concentration as Percentage of ELV | % | ... | <1.00% |

*Reference Conditions (273K, 101.3kPa, Wet Gas)

Table 9 – Particulates
Data Recorded from Site 1 - Wet Back Booth (A5)

| Emission Parameter | Units | TPM - 1 | Blank |
|--|----------------------|---------------|-------------|
| Duct Length | metres | 0.58 | ... |
| Duct Width | metres | 0.58 | ... |
| Area of Sample Plane | m ² | 0.336 | ... |
| Moisture Content | % | 0.02 | ... |
| Oxygen Content | % | 20.90 | ... |
| Stack Temperature | °C | 16 | ... |
| Gas Velocity (at Stack Conditions) | m/sec | 10.16 | ... |
| Gas Velocity (Reference Conditions) | m/sec* | 9.46 | ... |
| Volumetric Flowrate (Stack Conditions) | m ³ /sec | 3.42 | ... |
| Volumetric Flowrate (Reference Conditions) | m ³ /sec* | 3.18 | ... |
| Sample Date | ... | 13/09/2011 | ... |
| Sample Period | ... | 14:00 - 14:41 | ... |
| Sample Volume (at Stack) | m ³ | 0.78 | ... |
| Sample Volume (reference Conditions) | m ³ * | 0.73 | 0.73 |
| Isokinetic Sampling Rate | % | 110.6 | ... |
| Sample Reference (ECL ID) | ECL/11/ | 4829 & 4830 | 4833 & 4834 |
| Mass of Particulate Matter Collected | mg | 0.20 | 0.15 |
| Concentration of Particulate Matter | mg/m ³ * | 0.28 | 0.21 |
| Emission Rate of Particulate Matter | g/hr | 3.16 | ... |
| Expanded Uncertainty (% Relative) | % | 152 | ... |
| Emission Limit Value (ELV) | mg/m ³ * | 50 | ... |
| Blank Concentration as Percentage of ELV | % | ... | <1.00% |

*Reference Conditions (273K, 101.3kPa, Wet Gas)

Table 10 – Particulates
 Data Recorded from Site 1 - Wet Back Booth (A5)

| Emission Parameter | Units | TPM - 2 | Blank |
|--|----------------------|---------------|-------------|
| Duct Length | metres | 0.58 | ... |
| Duct Width | metres | 0.58 | ... |
| Area of Sample Plane | m ² | 0.336 | ... |
| Moisture Content | % | 0.02 | ... |
| Oxygen Content | % | 20.90 | ... |
| Stack Temperature | °C | 16 | ... |
| Gas Velocity (at Stack Conditions) | m/sec | 10.16 | ... |
| Gas Velocity (Reference Conditions) | m/sec* | 9.46 | ... |
| Volumetric Flowrate (Stack Conditions) | m ³ /sec | 3.42 | ... |
| Volumetric Flowrate (Reference Conditions) | m ³ /sec* | 3.18 | ... |
| Sample Date | ... | 13/09/2011 | ... |
| Sample Period | ... | 14:46 - 15:27 | ... |
| Sample Volume (at Stack) | m ³ | 0.73 | ... |
| Sample Volume (reference Conditions) | m ³ * | 0.68 | 0.68 |
| Isokinetic Sampling Rate | % | 103.7 | ... |
| Sample Reference (ECL ID) | ECL/11/ | 4831 & 4832 | 4833 & 4834 |
| Mass of Particulate Matter Collected | mg | 0.29 | 0.15 |
| Concentration of Particulate Matter | mg/m ³ * | 0.43 | 0.22 |
| Emission Rate of Particulate Matter | g/hr | 4.89 | ... |
| Expanded Uncertainty (% Relative) | % | 105 | ... |
| Emission Limit Value (ELV) | mg/m ³ * | 50 | ... |
| Blank Concentration as Percentage of ELV | % | ... | <1.00% |

*Reference Conditions (273K, 101.3kPa, Wet Gas)

Table 11 – Particulates
Data Recorded from Site 3 - LineX Booth (A2)

| Emission Parameter | Units | TPM- 1 | Blank |
|--|----------------------|---------------|-------------|
| Stack Diameter | metres | 0.70 | ... |
| | | | ... |
| Area of Sample Plane | m ² | 0.385 | ... |
| Moisture Content | % | 0.00 | ... |
| Oxygen Content | % | 20.90 | ... |
| Stack Temperature | °C | 21 | ... |
| Gas Velocity (at Stack Conditions) | m/sec | 8.71 | ... |
| Gas Velocity (Reference Conditions) | m/sec* | 8.00 | ... |
| Volumetric Flowrate (Stack Conditions) | m ³ /sec | 3.35 | ... |
| Volumetric Flowrate (Reference Conditions) | m ³ /sec* | 3.08 | ... |
| Sample Date | ... | 23/08/2011 | ... |
| Sample Period | ... | 13:00 - 13:33 | ... |
| Sample Volume (at Stack) | m ³ | 0.72 | ... |
| Sample Volume (reference Conditions) | m ³ * | 0.66 | 0.66 |
| Isokinetic Sampling Rate | % | 109.3 | ... |
| Sample Reference (ECL ID) | ECL/11/ | 4349 & 4350 | 4353 & 4354 |
| Mass of Particulate Matter Collected | mg | 0.85 | 0.30 |
| Concentration of Particulate Matter | mg/m ³ * | 1.28 | 0.45 |
| Emission Rate of Particulate Matter | g/hr | 14.17 | ... |
| Expanded Uncertainty (%Relative) | % | 37 | ... |
| Emission Limit Value (ELV) | mg/m ³ * | 50 | ... |
| Blank Concentration as Percentage of ELV | % | ... | <1.00% |

*Reference Conditions (273K, 101.3kPa, Wet Gas)

Table 12 – Particulates
Data Recorded from Site 3 - LineX Booth (A2)

| Emission Parameter | Units | TPM- 2 | Blank |
|--|----------------------|---------------|-------------|
| Stack Diameter | metres | 0.70 | ... |
| | | | ... |
| Area of Sample Plane | m ² | 0.385 | ... |
| Moisture Content | % | 0.00 | ... |
| Oxygen Content | % | 20.90 | ... |
| Stack Temperature | °C | 22 | ... |
| Gas Velocity (at Stack Conditions) | m/sec | 8.73 | ... |
| Gas Velocity (Reference Conditions) | m/sec* | 7.98 | ... |
| Volumetric Flowrate (Stack Conditions) | m ³ /sec | 3.36 | ... |
| Volumetric Flowrate (Reference Conditions) | m ³ /sec* | 3.07 | ... |
| Sample Date | ... | 23/08/2011 | ... |
| Sample Period | ... | 13:45 - 14:18 | ... |
| Sample Volume (at Stack) | m ³ | 0.74 | ... |
| Sample Volume (reference Conditions) | m ³ * | 0.67 | 0.67 |
| Isokinetic Sampling Rate | % | 110.9 | ... |
| Sample Reference (ECL ID) | ECL/11/ | 4351 & 4352 | 4353 & 4354 |
| Mass of Particulate Matter Collected | mg | 0.35 | 0.30 |
| Concentration of Particulate Matter | mg/m ³ * | 0.52 | 0.45 |
| Emission Rate of Particulate Matter | g/hr | 5.75 | ... |
| Expanded Uncertainty (%Relative) | % | 87 | ... |
| Emission Limit Value (ELV) | mg/m ³ * | 50 | ... |
| Blank Concentration as Percentage of ELV | % | ... | <1.00% |

*Reference Conditions (273K, 101.3kPa, Wet Gas)

VELOCITY TRAVERSE PROFILES

FIELD CALIBRATION AND SAMPLING DATA

| Environmental Compliance Limited | | PARTICULATE DATA SAMPLING PROFORMA | | | | Date of Measurement | | 28/11/2011 | | | |
|----------------------------------|-----------------|--|------------------------------|----------------------------|--------|-----------------------|-------|-----------------------|-------|-----------------|-----|
| ECL/TPD | | Z/A | | Time taken to change Point | 1 | Start Time | 11:06 | End Time | 11:39 | Duration (mins) | 32 |
| Client | NP Aerospace | Stack Profile | Stack Area (m ²) | Fluctuation | 0.25 | Pitot ID | 489 | Stack Thermocouple ID | 485 | Inlet gases | n/a |
| Site | Coverby | Stack Area (m ²) | 0.25 | Manometer ID | 366 | Stack Temp Probe ID | 320 | SO ₂ | n/a | | |
| Location | Site 1 | Barometric Pressure (mb) | 1002 | Barometer ID | 205 | Meter Thermocouple ID | 366 | Start Weight (g) | 0.00 | | |
| Stack ID | Spray Booth (A) | Std Flws (m ³ /s) (DIN 51751) | 15.3 | DMW | 1.0723 | Meter Temp Probe ID | 320 | End Weight (g) | 0.10 | | |
| Test No. | TRM-1 | Pitot coefficient | 1 | Nozzle ID | 800 | Dry Gas Meter ID | 389A | Total weight (g) | 0.10 | | |
| Job No. | PK86 | Balance ID | ... | Nozzle Size (mm) | 5.02 | Timer ID | 3662 | | | | |
| ECL Site Staff | FFJ/AC | Orifice ID | ... | Filter ID | 758 | Rotameter ID | 366 | | | | |

| | | | | | | | |
|--------------|----------|--------|--------|--------|--------|------------------------|--------------------------|
| Start Volume | Sample | Leak 1 | Leak 2 | Leak 3 | Leak 4 | Total | Volume (litres) @STP Dry |
| Final Volume | 109540.0 | | | | | Expected Sample Volume | 420.89 |
| Total Volume | 657.0 | 0.0 | 0.0 | 0.0 | 0.0 | Actual Sample Volume | 636.70 |
| | | | | | | Isokinetic Percentage | 107.16 |

| | | | | | | | | | |
|--------------------|-------|--------|-------|-------|---|-----------------------------|-------|--------------------------|-------|
| Leak Check | First | Second | Third | Final | Maximum allowed leak rate is 2% of the set rate | Measured O ₂ | 21.00 | Mixture | 0.02 |
| Leak Rate (l/min) | 0 | | | 0 | | Measured O ₂ % | | Ref O ₂ | 21.9 |
| Set Rate (l/min) | 25 | | | 25 | | Measured O ₂ ppm | | Dry Gas Molecular Weight | 28.84 |
| Time of Leak Check | 11:00 | | | 11:00 | | | | | |
| Leak % of set rate | 0.0 | | | 0.0 | | | | | |

| | | | | | | | | | |
|--|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Traverse Point | A1 | A1 | A2 | A2 | B1 | B1 | B2 | B2 | Total |
| Time Interval (mins) | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | |
| Time Point (mins) | 0-4 | 4-8 | 8-12 | 12-16 | 16-20 | 20-24 | 24-28 | 28-32 | |
| AP (Pa) | 100 | 100 | 150 | 150 | 130 | 130 | 100 | 100 | 120.0 |
| Velocity at Stack (m/s) | 12.88 | 12.88 | 15.78 | 15.78 | 14.69 | 14.69 | 12.88 | 12.88 | |
| Sample Rate (m/s) 10/13 mbar, 3m Dry Gas | 15.4 | 15.4 | 19.9 | 19.9 | 17.6 | 17.6 | 15.5 | 15.5 | 18.0 |
| Meter (Tm) | 20 | 20 | 22 | 22 | 24 | 24 | 21 | 21 | 22.3 |
| Stack Temp (Ts) | 16 | 16 | 16 | 16 | 16 | 16 | 16 | 16 | 16.0 |

| | | | | | | | | | |
|--|--|--|--|--|--|--|--|--|-------|
| Traverse Point | | | | | | | | | Total |
| Time Interval (mins) | | | | | | | | | |
| Time Point (mins) | | | | | | | | | |
| AP (Pa) | | | | | | | | | |
| Velocity at Stack (m/s) | | | | | | | | | |
| Sample Rate (m/s) 10/13 mbar, 3m Dry Gas | | | | | | | | | |
| Meter (Tm) | | | | | | | | | |
| Stack Temp (Ts) | | | | | | | | | |

| | | | | | | | | | |
|--|--|--|--|--|--|--|--|--|-------|
| Traverse Point | | | | | | | | | Total |
| Time Interval (mins) | | | | | | | | | |
| Time Point (mins) | | | | | | | | | |
| AP (Pa) | | | | | | | | | |
| Velocity at Stack (m/s) | | | | | | | | | |
| Sample Rate (m/s) 10/13 mbar, 3m Dry Gas | | | | | | | | | |
| Meter (Tm) | | | | | | | | | |
| Stack Temp (Ts) | | | | | | | | | |

If moisture was not measured and gas was dried before entering the gas meter, impinger weights must be included to produce the moisture concentration used in the isokinetic calculations. If the gas was not dried before it entered the gas meter then impinger weights may be included to produce a nominal 0.1% moisture value.

| | |
|---------------|------|
| Auxiliary SOL | 1628 |
| DI Filter SOL | 1695 |

| | |
|----------------------------|-----|
| Original Flowrate Settings | |
| Tm | 40 |
| Ts | 16 |
| Correction | 0.1 |

| Environmental Compliance Limited | | PARTICULATE DATA SAMPLING PROFORMA | | | | Date of Measurement | | 28/11/2011 | | | |
|----------------------------------|-----------------|--|------------------------------|----------------------------|--------|-----------------------|-------|-----------------------|-------|-----------------|-----|
| ECL/TPD | | Z/A | | Time taken to change Point | 1 | Start Time | 11:46 | End Time | 12:19 | Duration (mins) | 32 |
| Client | NP Aerospace | Stack Profile | Stack Area (m ²) | Fluctuation | 0.25 | Pitot ID | 489 | Stack Thermocouple ID | 485 | Inlet gases | n/a |
| Site | Coverby | Stack Area (m ²) | 0.25 | Manometer ID | 366 | Stack Temp Probe ID | 320 | SO ₂ | n/a | | |
| Location | Site 1 | Barometric Pressure (mb) | 1002 | Barometer ID | 205 | Meter Thermocouple ID | 366 | Start Weight (g) | 0.00 | | |
| Stack ID | Spray Booth (A) | Std Flws (m ³ /s) (DIN 51751) | 15.3 | DMW | 1.0723 | Meter Temp Probe ID | 320 | End Weight (g) | 0.10 | | |
| Test No. | TRM-2 | Pitot coefficient | 1 | Nozzle ID | 800 | Dry Gas Meter ID | 389A | Total weight (g) | 0.10 | | |
| Job No. | PK86 | Balance ID | ... | Nozzle Size (mm) | 5.02 | Timer ID | 3662 | | | | |
| ECL Site Staff | FFJ/AC | Orifice ID | ... | Filter ID | 758 | Rotameter ID | 366 | | | | |

| | | | | | | | |
|--------------|----------|--------|--------|--------|--------|------------------------|--------------------------|
| Start Volume | Sample | Leak 1 | Leak 2 | Leak 3 | Leak 4 | Total | Volume (litres) @STP Dry |
| Final Volume | 109942.0 | | | | | Expected Sample Volume | 430.91 |
| Total Volume | 683.0 | 0.0 | 0.0 | 0.0 | 0.0 | Actual Sample Volume | 603.50 |
| | | | | | | Isokinetic Percentage | 102.20 |

| | | | | | | | | | |
|--------------------|-------|--------|-------|-------|---|-----------------------------|-------|--------------------------|-------|
| Leak Check | First | Second | Third | Final | Maximum allowed leak rate is 2% of the set rate | Measured O ₂ | 21.00 | Mixture | 0.02 |
| Leak Rate (l/min) | 0 | | | 0 | | Measured O ₂ % | | Ref O ₂ | 21.9 |
| Set Rate (l/min) | 25 | | | 25 | | Measured O ₂ ppm | | Dry Gas Molecular Weight | 28.84 |
| Time of Leak Check | 11:45 | | | 12:27 | | | | | |
| Leak % of set rate | 0.0 | | | 0.0 | | | | | |

| | | | | | | | | | |
|--|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Traverse Point | A1 | A1 | A2 | A2 | B1 | B1 | B2 | B2 | Total |
| Time Interval (mins) | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | |
| Time Point (mins) | 0-4 | 4-8 | 8-12 | 12-16 | 16-20 | 20-24 | 24-28 | 28-32 | |
| AP (Pa) | 100 | 100 | 150 | 150 | 130 | 130 | 100 | 100 | 120.0 |
| Velocity at Stack (m/s) | 12.88 | 12.88 | 15.78 | 15.78 | 14.69 | 14.69 | 12.88 | 12.88 | |
| Sample Rate (m/s) 10/13 mbar, 3m Dry Gas | 15.4 | 15.4 | 19.9 | 19.9 | 17.6 | 17.6 | 15.5 | 15.5 | 17.2 |
| Meter (Tm) | 20 | 20 | 22 | 22 | 24 | 24 | 21 | 21 | 22.1 |
| Stack Temp (Ts) | 16 | 16 | 16 | 16 | 16 | 16 | 16 | 16 | 16.0 |

| | | | | | | | | | |
|--|--|--|--|--|--|--|--|--|-------|
| Traverse Point | | | | | | | | | Total |
| Time Interval (mins) | | | | | | | | | |
| Time Point (mins) | | | | | | | | | |
| AP (Pa) | | | | | | | | | |
| Velocity at Stack (m/s) | | | | | | | | | |
| Sample Rate (m/s) 10/13 mbar, 3m Dry Gas | | | | | | | | | |
| Meter (Tm) | | | | | | | | | |
| Stack Temp (Ts) | | | | | | | | | |

| | | | | | | | | | |
|--|--|--|--|--|--|--|--|--|-------|
| Traverse Point | | | | | | | | | Total |
| Time Interval (mins) | | | | | | | | | |
| Time Point (mins) | | | | | | | | | |
| AP (Pa) | | | | | | | | | |
| Velocity at Stack (m/s) | | | | | | | | | |
| Sample Rate (m/s) 10/13 mbar, 3m Dry Gas | | | | | | | | | |
| Meter (Tm) | | | | | | | | | |
| Stack Temp (Ts) | | | | | | | | | |

Impingers are not used for UK/REMITHS sampling of particulate in ECL TPD Z/A as method is for dry gases only (i.e. wet gas reporting). In these cases moisture is entered in calculations as 0.1%.

| | |
|---------------|------|
| Auxiliary SOL | 1628 |
| DI Filter SOL | 1695 |

| | |
|----------------------------|-----|
| Original Flowrate Settings | |
| Tm | 40 |
| Ts | 16 |
| Correction | 0.1 |

| Environmental Compliance Limited | | PARTICULATE DATA SAMPLING PROFORMA | | | | Date of Measurement | | 29/11/2011 | | | |
|----------------------------------|-----------------|--|-------------|----------------------------|-------|-----------------------|-------|------------------|-------|-----------------|----|
| ECL/TPD | | 27a | | Time taken to change Run/s | 1 | Start Time | 13:40 | End Time | 13:43 | Duration (mins) | 32 |
| Client | NP Aerospace | Stack Profile | Rectangular | Flue ID | 488 | Stack Thermocouple ID | 488 | Impingers | n/a | | |
| Site | Coverly | Stack Area (m ²) | 0.36 | Manometer ID | 368 | Stack Temp Reader ID | 370 | SCL | n/a | | |
| Location | Site 1 | Barometric Pressure (mbar) | 1002 | Barometer ID | 205 | Water Thermocouple ID | 366 | Start Weight (g) | 0.00 | | |
| Stack ID | Prep Booth (A2) | Stat Pres. (mmHg) (P _{stat}) | 15 | DMW | 1.000 | Water Temp Reader ID | 370 | End Weight (g) | 0.10 | | |
| Test No | TPM-1 | Pitot coefficient | 1 | Nozzle ID | 800 | Dry Gas Meter ID | 368 | Total weight (g) | 0.10 | | |
| Job No | P108 | Balance ID | ... | Nozzle Size (mm) | 8.19 | Timer ID | 368 | | | | |
| ECL Site Staff | FFJ/AD | Orifice ID | 368 | Filter ID | 300 | Reference ID | 368 | | | | |

| | | | | | | | |
|--------------|---------|--------|--------|--------|--------|------------------------|--------------------------|
| Start Volume | Sample | Leak 1 | Leak 2 | Leak 3 | Leak 4 | Total | Volume (litres) @STP Dry |
| Final Volume | 10000.0 | | | | | Expected Sample Volume | 620.0 |
| Total Volume | 600.0 | 0.0 | 0.0 | 0.0 | 0.0 | Actual Sample Volume | 628.76 |
| | | | | | | Leakage Percentage | 100.32 |

| | | | | | | | | | |
|--------------------|-------|--------|-------|-------|---|------------------------------|-------|--------------------------|-------|
| Leak Check | First | Second | Third | Final | Maximum allowed leak rate in 2nd of test rate | Measured O ₂ | 20.90 | Mixture | 0.02 |
| Leak Rate (l/hr) | 0 | | | 0 | | Measured CO ₂ % | | Ref O ₂ | 20.9 |
| Set Rate (l/hr) | 25 | | | 25 | | Measured CO ₂ ppm | | Dry Gas Molecular Weight | 28.84 |
| Time Of Leak Check | 12:30 | | | 13:45 | | | | | |
| Leak % of set rate | 0.0 | | | 0.0 | | | | | |

| | | | | | | | | | |
|---|------|------|------|-------|-------|-------|-------|-------|-------|
| Traverse Point | A1 | A1 | A2 | A2 | B1 | B1 | B2 | B2 | Total |
| Time Interval (mins) | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | |
| Time Point (mins) | 0-4 | 4-8 | 8-12 | 12-16 | 16-20 | 20-24 | 24-28 | 28-32 | |
| AP (Pa) | 20 | 20 | 20 | 20 | 10 | 10 | 16 | 16 | 19.0 |
| Velocity at Stack (m/s) | 5.72 | 5.72 | 7.01 | 7.01 | 4.05 | 4.05 | 5.12 | 5.12 | |
| Sample Rate (m/s) 1013 mbar, 1m Dry Gas | 15.7 | 15.8 | 23.1 | 23.2 | 13.4 | 13.4 | 17.0 | 17.0 | 18.1 |
| Meter (Tm) | 25 | 26 | 27 | 28 | 29 | 29 | 30 | 30 | 27.8 |
| Stack Temp (Ts) | 12 | 12 | 12 | 12 | 12 | 12 | 12 | 12 | 12.0 |

| | | | | | | | | | |
|---|--|--|--|--|--|--|--|--|-------|
| Traverse Point | | | | | | | | | Total |
| Time Interval (mins) | | | | | | | | | |
| Time Point (mins) | | | | | | | | | |
| AP (Pa) | | | | | | | | | |
| Velocity at Stack (m/s) | | | | | | | | | |
| Sample Rate (m/s) 1013 mbar, 1m Dry Gas | | | | | | | | | |
| Meter (Tm) | | | | | | | | | |
| Stack Temp (Ts) | | | | | | | | | |

| | | | | | | | | | |
|---|--|--|--|--|--|--|--|--|-------|
| Traverse Point | | | | | | | | | Total |
| Time Interval (mins) | | | | | | | | | |
| Time Point (mins) | | | | | | | | | |
| AP (Pa) | | | | | | | | | |
| Velocity at Stack (m/s) | | | | | | | | | |
| Sample Rate (m/s) 1013 mbar, 1m Dry Gas | | | | | | | | | |
| Meter (Tm) | | | | | | | | | |
| Stack Temp (Ts) | | | | | | | | | |

Impingers are not used for UKAS/CEERTS sampling of particulate to ECL TPD 27a as method is for dry stacks only (A wet gas reporting). In these cases moisture is entered into calculations as 0.1%

| | |
|---------------|------|
| Ascorbic SOL | 1008 |
| DI Filter SOL | 1016 |

| | |
|----------------------------|-----|
| Original Flowrate Settings | |
| Tm | 40 |
| Ts | 12 |
| Correlation | 0.1 |

| Environmental Compliance Limited | | PARTICULATE DATA SAMPLING PROFORMA | | | | Date of Measurement | | 29/11/2011 | | | |
|----------------------------------|-----------------|--|-------------|----------------------------|-------|-----------------------|-------|------------------|-------|-----------------|----|
| ECL/TPD | | 27a | | Time taken to change Run/s | 1 | Start Time | 14:05 | End Time | 14:39 | Duration (mins) | 32 |
| Client | NP Aerospace | Stack Profile | Rectangular | Flue ID | 488 | Stack Thermocouple ID | 488 | Impingers | n/a | | |
| Site | Coverly | Stack Area (m ²) | 0.36 | Manometer ID | 368 | Stack Temp Reader ID | 370 | SCL | n/a | | |
| Location | Site 1 | Barometric Pressure (mbar) | 1002 | Barometer ID | 205 | Water Thermocouple ID | 366 | Start Weight (g) | 0.00 | | |
| Stack ID | Prep Booth (A2) | Stat Pres. (mmHg) (P _{stat}) | 15 | DMW | 1.000 | Water Temp Reader ID | 370 | End Weight (g) | 0.10 | | |
| Test No | TPM-2 | Pitot coefficient | 1 | Nozzle ID | 800 | Dry Gas Meter ID | 368 | Total weight (g) | 0.10 | | |
| Job No | P108 | Balance ID | ... | Nozzle Size (mm) | 8.19 | Timer ID | 368 | | | | |
| ECL Site Staff | FFJ/AD | Orifice ID | 368 | Filter ID | 300 | Reference ID | 368 | | | | |

| | | | | | | | |
|--------------|---------|--------|--------|--------|--------|------------------------|--------------------------|
| Start Volume | Sample | Leak 1 | Leak 2 | Leak 3 | Leak 4 | Total | Volume (litres) @STP Dry |
| Final Volume | 10000.0 | | | | | Expected Sample Volume | 621.70 |
| Total Volume | 522.0 | 0.0 | 0.0 | 0.0 | 0.0 | Actual Sample Volume | 633.30 |
| | | | | | | Leakage Percentage | 103.37 |

| | | | | | | | | | |
|--------------------|-------|--------|-------|-------|---|------------------------------|-------|--------------------------|-------|
| Leak Check | First | Second | Third | Final | Maximum allowed leak rate in 2nd of test rate | Measured O ₂ | 20.90 | Mixture | 0.02 |
| Leak Rate (l/hr) | 0 | | | 0 | | Measured CO ₂ % | | Ref O ₂ | 20.9 |
| Set Rate (l/hr) | 25 | | | 25 | | Measured CO ₂ ppm | | Dry Gas Molecular Weight | 28.84 |
| Time Of Leak Check | 13:49 | | | 14:42 | | | | | |
| Leak % of set rate | 0.0 | | | 0.0 | | | | | |

| | | | | | | | | | |
|---|------|------|------|-------|-------|-------|-------|-------|-------|
| Traverse Point | A1 | A1 | A2 | A2 | B1 | B1 | B2 | B2 | Total |
| Time Interval (mins) | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | |
| Time Point (mins) | 0-4 | 4-8 | 8-12 | 12-16 | 16-20 | 20-24 | 24-28 | 28-32 | |
| AP (Pa) | 20 | 20 | 20 | 20 | 10 | 10 | 16 | 16 | 19.0 |
| Velocity at Stack (m/s) | 5.76 | 5.76 | 7.03 | 7.03 | 4.07 | 4.07 | 5.15 | 5.15 | |
| Sample Rate (m/s) 1013 mbar, 1m Dry Gas | 15.8 | 15.7 | 22.9 | 23.0 | 13.3 | 13.4 | 15.9 | 15.9 | 18.0 |
| Meter (Tm) | 25 | 26 | 27 | 28 | 29 | 29 | 30 | 30 | 27.9 |
| Stack Temp (Ts) | 12 | 12 | 12 | 12 | 12 | 12 | 12 | 12 | 12.6 |

| | | | | | | | | | |
|---|--|--|--|--|--|--|--|--|-------|
| Traverse Point | | | | | | | | | Total |
| Time Interval (mins) | | | | | | | | | |
| Time Point (mins) | | | | | | | | | |
| AP (Pa) | | | | | | | | | |
| Velocity at Stack (m/s) | | | | | | | | | |
| Sample Rate (m/s) 1013 mbar, 1m Dry Gas | | | | | | | | | |
| Meter (Tm) | | | | | | | | | |
| Stack Temp (Ts) | | | | | | | | | |

| | | | | | | | | | |
|---|--|--|--|--|--|--|--|--|-------|
| Traverse Point | | | | | | | | | Total |
| Time Interval (mins) | | | | | | | | | |
| Time Point (mins) | | | | | | | | | |
| AP (Pa) | | | | | | | | | |
| Velocity at Stack (m/s) | | | | | | | | | |
| Sample Rate (m/s) 1013 mbar, 1m Dry Gas | | | | | | | | | |
| Meter (Tm) | | | | | | | | | |
| Stack Temp (Ts) | | | | | | | | | |

Impingers are not used for UKAS/CEERTS sampling of particulate to ECL TPD 27a as method is for dry stacks only (A wet gas reporting). In these cases moisture is entered into calculations as 0.1%

| | |
|---------------|------|
| Ascorbic SOL | 1008 |
| DI Filter SOL | 1016 |

| | |
|----------------------------|-----|
| Original Flowrate Settings | |
| Tm | 40 |
| Ts | 12 |
| Correlation | 0.1 |

| Environmental Compliance Limited | | PARTICULATE DATA SAMPLING PROFORMA | | | | Date of Measurement | | 13/09/2011 | | | |
|----------------------------------|---------------------|------------------------------------|-------------|----------------------------|--------|-----------------------|-------|------------------|-------|-----------------|----|
| ECL/TPD# | | 27a | | Time taken to change Ports | 1 | Start Time | 14:00 | End Time | 14:41 | Duration (mins) | 40 |
| Client | NP Aerospace | Stack Profile | Rectangular | Pilot ID | 468 | Stack Thermocouple ID | 468 | Impingers | n/a | | |
| Site | Covenry | Stack Area (m ²) | 0.54 | Manometer ID | 357 | Stack Temp Reader ID | 358 | SOL | n/a | | |
| Location | Site 1 | Barometric Pressure (mb) | 998 | Barometer ID | 352 | Water Thermocouple ID | 365c | Start Weight (g) | 0.00 | | |
| Stack ID | Wet Back Booth (A5) | Stat Pres. (mm Hg) (Pa x 0.81) | 714 | DGM Yd | 1.0503 | Water Temp Reader ID | 468 | End Weight (g) | 0.10 | | |
| Test No. | TPM - 1 | Pilot coefficient | 1 | Nozzle ID | 601 | Dry Gas Meter ID | 366a | Total weight (g) | 0.10 | | |
| Job No | P198 | Balance ID | | Nozzle Size (mm) | 6.06 | Timer ID | 366d | | | | |
| ECL Site Staff | JLAD | Console ID | 368 | Filter ID | 406 | Rotameter ID | 366b | | | | |

| Sample | Leak 1 | Leak 2 | Leak 3 | Leak 4 | Total | Volume (litres) @ STP Dry | |
|--------------|----------|--------|--------|--------|-------|---------------------------|--------|
| Start Volume | 588717.0 | | | | | Expected Sample Volume | 656.58 |
| Final Volume | 589486.0 | | | | | Actual Sample Volume | 726.19 |
| Total Volume | 769.0 | 0.0 | 0.0 | 0.0 | 0.0 | Isokinetic Percentage | 110.22 |

| Leak Check | First | Second | Third | Final | Maximum allowed leak rate is 2% of the set rate | Measured O ₂ | 23.90 | Moisture | 0.02 |
|--------------------|-------|--------|-------|-------|---|------------------------------|-------|--------------------------|-------|
| Leak Rate (l/min) | 0 | 0 | | | | Measured CO ₂ % | | Rel O ₂ | 20.9 |
| Set Rate (l/min) | 25 | 25 | | | | Measured CO ₂ ppm | | Dry Gas Molecular Weight | 28.84 |
| Time Of Leak Check | 1350 | 1642 | | | | | | | |
| Leak % of set rate | 0.0 | 0.0 | | | | | | | |

Impingers are not used for UKAS MCFIS sampling of particulate to ECL TPD 27a as method is for dry stacks only (& wet gas reporting). In these cases moisture is entered into calculations as 0.1%.

| | |
|--------------|------|
| Acetone SOL | 1415 |
| DI Rinse SOL | 1482 |

| Traverse Point | A1 | A1 | A2 | A2 | B1 | B1 | B2 | B2 | Total |
|---|------|------|-------|-------|-------|-------|-------|-------|-------|
| Time Interval (mins) | 5 | 5 | 5 | 5 | 5 | 5 | 5 | 5 | |
| Time Point (mins) | 0-5 | 5-10 | 10-15 | 15-20 | 20-25 | 25-30 | 30-35 | 35-40 | |
| AP (Pa) | 50 | 50 | 60 | 60 | 125 | 125 | 50 | 50 | 66.3 |
| Velocity at Stack (m/s) | 7.07 | 7.07 | 10.00 | 10.00 | 14.44 | 14.44 | 6.13 | 6.13 | |
| Sample Rate (l/min) 151.1 mbar, Tm, Dry Gas | 12.4 | 12.4 | 17.6 | 17.6 | 25.8 | 25.7 | 15.3 | 15.4 | 18.0 |
| Meter (Tm) | 23 | 24 | 26 | 26 | 27 | 28 | 30 | 31 | 26.8 |
| Stack Temp (Tst) | 16 | 16 | 16 | 16 | 16 | 16 | 16 | 16 | 16.0 |

| | |
|----------------------------|-----|
| Original Flowrate Settings | |
| Tm | 35 |
| Ts | 15 |
| % moisture | 0.1 |

| Traverse Point | | | | | | | | | Total |
|---|--|--|--|--|--|--|--|--|-------|
| Time Interval (mins) | | | | | | | | | |
| Time Point (mins) | | | | | | | | | |
| AP (Pa) | | | | | | | | | |
| Velocity at Stack (m/s) | | | | | | | | | |
| Sample Rate (l/min) 151.1 mbar, Tm, Dry Gas | | | | | | | | | |
| Meter (Tm) | | | | | | | | | |
| Stack Temp (Tst) | | | | | | | | | |

| Traverse Point | | | | | | | | | Total |
|---|--|--|--|--|--|--|--|--|-------|
| Time Interval (mins) | | | | | | | | | |
| Time Point (mins) | | | | | | | | | |
| AP (Pa) | | | | | | | | | |
| Velocity at Stack (m/s) | | | | | | | | | |
| Sample Rate (l/min) 151.1 mbar, Tm, Dry Gas | | | | | | | | | |
| Meter (Tm) | | | | | | | | | |
| Stack Temp (Tst) | | | | | | | | | |

| Environmental Compliance Limited | | PARTICULATE DATA SAMPLING PROFORMA | | | | Date of Measurement | | 13/09/2011 | | | |
|----------------------------------|---------------------|------------------------------------|-------------|----------------------------|--------|-----------------------|-------|------------------|-------|-----------------|----|
| ECL/TPD# | | 27a | | Time taken to change Ports | 1 | Start Time | 14:45 | End Time | 15:27 | Duration (mins) | 40 |
| Client | NP Aerospace | Stack Profile | Rectangular | Pilot ID | 468 | Stack Thermocouple ID | 468 | Impingers | n/a | | |
| Site | Covenry | Stack Area (m ²) | 0.54 | Manometer ID | 357 | Stack Temp Reader ID | 358 | SOL | n/a | | |
| Location | Site 1 | Barometric Pressure (mb) | 998 | Barometer ID | 352 | Water Thermocouple ID | 365c | Start Weight (g) | 0.00 | | |
| Stack ID | Wet Back Booth (A5) | Stat Pres. (mm Hg) (Pa x 0.81) | 713.5575943 | DGM Yd | 1.0503 | Water Temp Reader ID | 468 | End Weight (g) | 0.10 | | |
| Test No. | TPM - 2 | Pilot coefficient | 1 | Nozzle ID | 601 | Dry Gas Meter ID | 366a | Total weight (g) | 0.10 | | |
| Job No | P198 | Balance ID | | Nozzle Size (mm) | 6.06 | Timer ID | 366d | | | | |
| ECL Site Staff | JLAD | Console ID | 368 | Filter ID | 406 | Rotameter ID | 366b | | | | |

| Sample | Leak 1 | Leak 2 | Leak 3 | Leak 4 | Total | Volume (litres) @ STP Dry | |
|--------------|----------|--------|--------|--------|-------|---------------------------|--------|
| Start Volume | 689029.0 | | | | | Expected Sample Volume | 656.57 |
| Final Volume | 690243.0 | | | | | Actual Sample Volume | 630.25 |
| Total Volume | 740.0 | 0.0 | 0.0 | 0.0 | 0.0 | Isokinetic Percentage | 103.72 |

| Leak Check | First | Second | Third | Final | Maximum allowed leak rate is 2% of the set rate | Measured O ₂ | 23.90 | Moisture | 0.02 |
|--------------------|-------|--------|-------|-------|---|------------------------------|-------|--------------------------|-------|
| Leak Rate (l/min) | 0 | 0 | | | | Measured CO ₂ % | | Rel O ₂ | 20.9 |
| Set Rate (l/min) | 25 | 25 | | | | Measured CO ₂ ppm | | Dry Gas Molecular Weight | 28.84 |
| Time Of Leak Check | 1453 | 1520 | | | | | | | |
| Leak % of set rate | 0.0 | 0.0 | | | | | | | |

Impingers are not used for UKAS MCFIS sampling of particulate to ECL TPD 27a as method is for dry stacks only (& wet gas reporting). In these cases moisture is entered into calculations as 0.1%.

| | |
|--------------|------|
| Acetone SOL | 1415 |
| DI Rinse SOL | 1482 |

| Traverse Point | A1 | A1 | A2 | A2 | B1 | B1 | B2 | B2 | Total |
|---|------|------|-------|-------|-------|-------|-------|-------|-------|
| Time Interval (mins) | 5 | 5 | 5 | 5 | 5 | 5 | 5 | 5 | |
| Time Point (mins) | 0-5 | 5-10 | 10-15 | 15-20 | 20-25 | 25-30 | 30-36 | 35-40 | |
| AP (Pa) | 30 | 30 | 60 | 60 | 125 | 125 | 50 | 50 | 66.3 |
| Velocity at Stack (m/s) | 7.07 | 7.07 | 10.00 | 10.00 | 14.44 | 14.44 | 6.13 | 6.13 | |
| Sample Rate (l/min) 151.1 mbar, Tm, Dry Gas | 12.7 | 12.7 | 18.1 | 18.2 | 26.3 | 26.3 | 16.7 | 16.8 | 18.6 |
| Meter (Tm) | 30 | 31 | 33 | 35 | 36 | 36 | 37 | 38 | 34.5 |
| Stack Temp (Tst) | 16 | 16 | 16 | 16 | 16 | 16 | 16 | 16 | 16.0 |

| | |
|----------------------------|-----|
| Original Flowrate Settings | |
| Tm | 35 |
| Ts | 15 |
| % moisture | 0.1 |

| Traverse Point | | | | | | | | | Total |
|---|--|--|--|--|--|--|--|--|-------|
| Time Interval (mins) | | | | | | | | | |
| Time Point (mins) | | | | | | | | | |
| AP (Pa) | | | | | | | | | |
| Velocity at Stack (m/s) | | | | | | | | | |
| Sample Rate (l/min) 151.1 mbar, Tm, Dry Gas | | | | | | | | | |
| Meter (Tm) | | | | | | | | | |
| Stack Temp (Tst) | | | | | | | | | |

| Traverse Point | | | | | | | | | Total |
|---|--|--|--|--|--|--|--|--|-------|
| Time Interval (mins) | | | | | | | | | |
| Time Point (mins) | | | | | | | | | |
| AP (Pa) | | | | | | | | | |
| Velocity at Stack (m/s) | | | | | | | | | |
| Sample Rate (l/min) 151.1 mbar, Tm, Dry Gas | | | | | | | | | |
| Meter (Tm) | | | | | | | | | |
| Stack Temp (Tst) | | | | | | | | | |

Environmental Compliance Limited

NP Aerospace Ltd
Permit No : PPC 189 & PPC 190

Report Ref : P1098 : R001
Issue Date : 07/02/12

| Environmental Compliance Limited | | PARTICULATE DATA SAMPLING PROFORMA | | | | Date of Measurement | | 23/09/2011 | |
|--|------------------|------------------------------------|--------|------------------|--|----------------------------|--------------------------|--------------------------|-------|
| BO/TPD | Z/a | Time taken to change Parts | 1 | Start Time | 13:00 | End Time | 13:33 | Duration (mins) | 32 |
| Client | NP Aerospace | Stack Profile | Cruder | Flact ID | 497 | Stack Thermocouple ID | 498 | Impingers | n/a |
| Site | Coverley | Stack Area (m ²) | 0.39 | Micrometer ID | 368 | Stack Temp/Fancter ID | 370 | SCU | n/a |
| Location | Site 3 | Barometric Pressure (mb) | 1001 | Barometer ID | 668 | Meter Thermocouple ID | 367c | Start Weight (g) | 0.00 |
| Stack ID | LineX Booth (A2) | Stat Pres. (mmHg) (Pw9.8) | 1.5 | DMW | 10099 | Meter Temp/Fancter ID | 370 | End Weight (g) | 0.00 |
| Test No. | TPM-1 | Pilot coefficient | 1 | Nozzle ID | 601 | Dry Gas Meter ID | 359d | Total weight (g) | 0.00 |
| Job No. | P1098 | Balance ID | ... | Nozzle Size (mm) | 7.10 | Filter ID | 362b | | |
| ECL Site Staff | PC/JL | Coracle ID | 367 | Filter ID | 363 | Filtermeter ID | 362a | | |
| | Sample | Leak 1 | Leak 2 | Leak 3 | Leak 4 | Total | Volume (litres) @STP Dry | | |
| Start Volume | 66998.0 | | | | | Expected Sample Volume | 603.10 | | |
| Final Volume | 66999.0 | | | | | Actual Sample Volume | 664.51 | | |
| Total Volume | 738.0 | 0.0 | 0.0 | 0.0 | 0.0 | Isokinetic Percentage | 109.29 | | |
| Leak Check | First | Second | Third | Final | Medium allowed leak rate to 2% of the set rate | Measured O ₂ | 20.9 | Mixture | 0.00 |
| Leak Rate (l/min) | 0 | | | 0 | | Measured O ₂ % | 20.9 | Ref O ₂ | 20.9 |
| Set Rate (l/min) | 25 | | | 24 | | Measured CO ₂ % | ... | Dry Gas Molecular Weight | 26.94 |
| Time Of Leak Check | 12:00 | | | 13:35 | | | | | |
| Leak % of set rate | 0.0 | | | 0.0 | | | | | |
| Traverse Point | A1 | A1 | A2 | A2 | B1 | B1 | B2 | B2 | Total |
| Time Interval (mins) | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | |
| Time Point (mins) | 0-4 | 4-8 | 8-12 | 12-16 | 16-20 | 20-24 | 24-28 | 28-32 | |
| AP (Pa) | 40 | 40 | 40 | 40 | 50 | 50 | 50 | 50 | 45.0 |
| Velocity at Stack (m/s) | 8.23 | 8.23 | 8.23 | 8.23 | 8.20 | 8.20 | 8.20 | 8.20 | 8.19 |
| Sample Rate (l/min) 101.3 mbar, 1m Dry Gas | 19.4 | 19.4 | 19.5 | 19.6 | 22.0 | 22.0 | 22.0 | 22.2 | 20.8 |
| Meter (l/min) | 22 | 23 | 24 | 25 | 28 | 28 | 27 | 28 | 25.3 |
| Stack Temp (T _s) | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21.0 |
| Traverse Point | | | | | | | | | Total |
| Time Interval (mins) | | | | | | | | | |
| Time Point (mins) | | | | | | | | | |
| AP (Pa) | | | | | | | | | |
| Velocity at Stack (m/s) | | | | | | | | | |
| Sample Rate (l/min) 101.3 mbar, 1m Dry Gas | | | | | | | | | |
| Meter (l/min) | | | | | | | | | |
| Stack Temp (T _s) | | | | | | | | | |

If moisture was not measured and gas was dried before entering the gas meter, impinger weights must be included to produce the moisture concentration used in the isokinetic calculations. If the gas was not dried before it entered the gas meter then impinger weights may be included to produce a nominal 0.1% moisture value.

| | |
|---------------|------|
| Aspire SCU | 1376 |
| DI Filter SCU | 1489 |

| | |
|----------------------------|-----|
| Original Flowrate Settings | |
| l/min | 30 |
| Ts | 21 |
| Humidity | 0.1 |

| Environmental Compliance Limited | | PARTICULATE DATA SAMPLING PROFORMA | | | | Date of Measurement | | 23/09/2011 | |
|--|------------------|------------------------------------|--------|------------------|--|----------------------------|--------------------------|--------------------------|-------|
| BO/TPD | Z/a | Time taken to change Parts | 1 | Start Time | 13:45 | End Time | 14:18 | Duration (mins) | 32 |
| Client | NP Aerospace | Stack Profile | Cruder | Flact ID | 497 | Stack Thermocouple ID | 498 | Impingers | n/a |
| Site | Coverley | Stack Area (m ²) | 0.39 | Micrometer ID | 368 | Stack Temp/Fancter ID | 370 | SCU | n/a |
| Location | Site 3 | Barometric Pressure (mb) | 1001 | Barometer ID | 668 | Meter Thermocouple ID | 367c | Start Weight (g) | 0.00 |
| Stack ID | LineX Booth (A2) | Stat Pres. (mmHg) (Pw9.8) | 1.5 | DMW | 10099 | Meter Temp/Fancter ID | 370 | End Weight (g) | 0.00 |
| Test No. | TPM-2 | Pilot coefficient | 1 | Nozzle ID | 601 | Dry Gas Meter ID | 359d | Total weight (g) | 0.00 |
| Job No. | P1098 | Balance ID | ... | Nozzle Size (mm) | 7.10 | Filter ID | 362b | | |
| ECL Site Staff | PC/JL | Coracle ID | 367 | Filter ID | 363 | Filtermeter ID | 362a | | |
| | Sample | Leak 1 | Leak 2 | Leak 3 | Leak 4 | Total | Volume (litres) @STP Dry | | |
| Start Volume | 66947.0 | | | | | Expected Sample Volume | 607.12 | | |
| Final Volume | 66951.0 | | | | | Actual Sample Volume | 673.15 | | |
| Total Volume | 744.0 | 0.0 | 0.0 | 0.0 | 0.0 | Isokinetic Percentage | 110.89 | | |
| Leak Check | First | Second | Third | Final | Medium allowed leak rate to 2% of the set rate | Measured O ₂ | 20.9 | Mixture | 0.00 |
| Leak Rate (l/min) | 0 | | | 0 | | Measured O ₂ % | 20.9 | Ref O ₂ | 20.9 |
| Set Rate (l/min) | 25 | | | 24 | | Measured CO ₂ % | ... | Dry Gas Molecular Weight | 26.94 |
| Time Of Leak Check | 13:42 | | | 14:23 | | | | | |
| Leak % of set rate | 0.0 | | | 0.0 | | | | | |
| Traverse Point | A1 | A1 | A2 | A2 | B1 | B1 | B2 | B2 | Total |
| Time Interval (mins) | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | |
| Time Point (mins) | 0-4 | 4-8 | 8-12 | 12-16 | 16-20 | 20-24 | 24-28 | 28-32 | |
| AP (Pa) | 40 | 40 | 40 | 40 | 50 | 50 | 50 | 50 | 45.0 |
| Velocity at Stack (m/s) | 8.24 | 8.24 | 8.24 | 8.24 | 8.22 | 8.22 | 8.22 | 8.22 | 8.15 |
| Sample Rate (l/min) 101.3 mbar, 1m Dry Gas | 19.9 | 20.0 | 20.2 | 20.3 | 22.7 | 22.8 | 22.9 | 22.9 | 21.5 |
| Meter (l/min) | 21 | 22 | 22 | 22 | 27 | 27 | 27 | 27 | 25.0 |
| Stack Temp (T _s) | 22 | 22 | 22 | 22 | 22 | 22 | 22 | 22 | 22.0 |
| Traverse Point | | | | | | | | | Total |
| Time Interval (mins) | | | | | | | | | |
| Time Point (mins) | | | | | | | | | |
| AP (Pa) | | | | | | | | | |
| Velocity at Stack (m/s) | | | | | | | | | |
| Sample Rate (l/min) 101.3 mbar, 1m Dry Gas | | | | | | | | | |
| Meter (l/min) | | | | | | | | | |
| Stack Temp (T _s) | | | | | | | | | |

If moisture was not measured and gas was dried before entering the gas meter, impinger weights must be included to produce the moisture concentration used in the isokinetic calculations. If the gas was not dried before it entered the gas meter then impinger weights may be included to produce a nominal 0.1% moisture value.

| | |
|---------------|------|
| Aspire SCU | 1376 |
| DI Filter SCU | 1489 |

| | |
|----------------------------|-----|
| Original Flowrate Settings | |
| l/min | 30 |
| Ts | 21 |
| Humidity | 0.1 |

Site 1- Spray Booth (A1)

| | | TOC ppm | O2 % | |
|--|-------------|-------------|---------|--------------------|
| Analyser Range | | 4000 | 25 | |
| Repeatability at Zero | | 40 | | |
| Span Gas Concentration Applied | | 1000.0 | 16 | |
| Zero Gas Concentration Applied | | 0 | 0 | |
| Direct Cal | Zero | 51.54 | | |
| | Span | 1002.70 | | |
| | Zero | 62.50 | | |
| Difference (Zero) | | 10.95588235 | | |
| <2*Repeatability @ Zero? | | YES | | |
| Pre Test | | | | |
| | Zero | 71.14 | | |
| | Span | 1002.70 | | |
| Difference (Zero) | | 8.639705882 | | |
| <5% (2% for O₂) Relative to Direct Span | | YES | | If Red CONTACT QM |
| Difference (Span) | | 0.051020408 | | |
| <5% (2% for O₂) Relative to Direct Span | | YES | | If Red CONTACT QM |
| Post Test | | | | |
| | Zero | 62.64 | | |
| | Span | 1002.88 | | |
| Difference (Zero) | | 8.503 | | |
| <2% of Analyser Range | | YES | | If Red apply Drift |
| Difference (Span) | | 19.872 | | |
| <2% of Analyser Range | | YES | | If Red apply Drift |
| Drift <5% of Analyser Range? | | YES | | If Red CONTACT QM |

Note* TOC is logged in mA NOT ppm - Zero Offset is likely

Site 1 – Wet Back Booth (A5)

| | | TOC ppm | O2 % | |
|--|------|-------------|---------|--------------------|
| Analyser Range | | 400 | 25 | |
| Repeatability at Zero | | 4 | | |
| Span Gas Concentration Applied | | 49.95 | 18 | |
| Zero Gas Concentration Applied | | 0 | 0 | |
| Direct Cal | Zero | 7.52 | | |
| | Span | 68.77 | | |
| | Zero | 7.50 | | |
| Difference (Zero) | | 0.018382353 | | |
| <2×Repeatability @ Zero? | | YES | | |
| Pre Test | Zero | 7.57 | | |
| | Span | 68.71 | | |
| Difference (Zero) | | 0.073529412 | | |
| <5% (2% for O ₂) Relative to Direct Span | | YES | | If Red CONTACT QM |
| Difference (Span) | | 0.060457516 | | |
| <5% (2% for O ₂) Relative to Direct Span | | YES | | If Red CONTACT QM |
| Post Test | Zero | 8.75 | | |
| | Span | 69.09 | | |
| Difference (Zero) | | 1.176 | | |
| <2% of Analyser Range | | YES | | If Red apply Drift |
| Difference (Span) | | 1.224 | | |
| <2% of Analyser Range | | YES | | If Red apply Drift |
| Drift <5% of Analyser Range? | | YES | | If Red CONTACT QM |

Note* TOC is logged in mA NOT ppm - Zero Offset is likely

Site 3 – Degreasing Booth (A1)

| | | TOC ppm | O2 % | |
|--|-------------|--------------------|-----------|---------------------------|
| Analyser Range | | 100 | 25 | |
| Repeatability at Zero | | 1 | | |
| Span Gas Concentration Applied | | 49.9 | 10 | |
| Zero Gas Concentration Applied | | 0 | 0 | |
| Direct Cal | Zero | 0.88 | | |
| | Span | 68.66 | | |
| | Zero | 1.24 | | |
| Difference (Zero) | | 0.357056909 | | |
| <2xRepeatability @ Zero? | | YES | | |
| Pre Test | Zero | 1.29 | | |
| | Span | 82.32 | | |
| Difference (Zero) | | 0.045955882 | | |
| <5% (2% for O₂) Relative to Direct Span | | YES | | If Red CONTACT QM |
| Difference (Span) | | 1.235294118 | | |
| <5% (2% for O₂) Relative to Direct Span | | YES | | If Red CONTACT QM |
| Post Test | Zero | 0.60 | | |
| | Span | 61.37 | | |
| Difference (Zero) | | 0.684 | | |
| <2% of Analyser Range | | YES | | If Red apply Drift |
| Difference (Span) | | 0.955 | | |
| <2% of Analyser Range | | YES | | If Red apply Drift |
| Drift <5% of Analyser Range? | | YES | | If Red CONTACT QM |

Note* TOC is logged in mA NOT ppm - Zero Offset is likely

Site 3 – LineX Booth (A2)

| | | TOC ppm | O2 % | |
|--|------|-------------|---------|--------------------|
| Analyser Range | | 100 | 25 | |
| Repeatability at Zero | | 1 | | |
| Span Gas Concentration Applied | | 49.9 | 16 | |
| Zero Gas Concentration Applied | | 0 | 0 | |
| Direct Cal | Zero | 0.88 | | |
| | Span | 69.66 | | |
| | Zero | 1.24 | | |
| Difference (Zero) | | 0.357056909 | | |
| <2*Repeatability @ Zero? | | YES | | |
| Pre Test | Zero | 1.29 | | |
| | Span | 62.82 | | |
| Difference (Zero) | | 0.045955882 | | |
| <5% (2% for O ₂) Relative to Direct Span | | YES | | If Red CONTACT QM |
| Difference (Span) | | 1.235294118 | | |
| <5% (2% for O ₂) Relative to Direct Span | | YES | | If Red CONTACT QM |
| Post Test | Zero | 0.60 | | |
| | Span | 61.87 | | |
| Difference (Zero) | | 0.684 | | |
| <2% of Analyser Range | | YES | | If Red apply Drift |
| Difference (Span) | | 0.955 | | |
| <2% of Analyser Range | | YES | | If Red apply Drift |
| Drift <5% of Analyser Range? | | YES | | If Red CONTACT QM |

Note* TOC is logged in mA NOT ppm - Zero Offset is likely

LABORATORY ANALYSIS RESULTS



Scientific Analysis Laboratories is a
limited company registered in England and
Wales (No 2514783) whose address is at
Hadfield House, Hadfield Street, Manchester M16 9FE

Scientific Analysis Laboratories Ltd
Certificate of Analysis

Hadfield House
Hadfield Street
Combrook
Manchester
M16 9FE
Tel : 0161 874 2400
Fax : 0161 874 2404

Report Number: 249753-1

Date of Report: 16-Sep-2011

Customer: Environmental Compliance Ltd
Unit G1
Main Avenue
Treforest Industrial Estate
Pontypridd
CF37 5YL

Customer Contact: Mr John Litterick

Customer Job Reference: P1098

Customer Purchase Order: P8963

Date Job Received at SAL: 07-Sep-2011

Date Analysis Started: 08-Sep-2011

Date Analysis Completed: 13-Sep-2011

The results reported relate to samples received in the laboratory
Opinions and interpretations expressed herein are outside the scope of UKAS accreditation
This report should not be reproduced except in full without the written approval of the laboratory
Tests covered by this certificate were conducted in accordance with SAL SOPs



Report checked
and authorised by :
Kayleigh McCann
Project Manager

Issued by : **Validity unknown**
Digitally signed by Kayleigh
McCann
Date: 2011.09.16 13:24:03 BST
Reason: Issued
Location: SAL

| | | | | | | | | |
|---|--------------|------|-------|---------------------------|------|-------------|-------------|-------------|
| SAL Reference: 249753 Customer Reference: P1098 | | | | | | | | |
| Filter Quartz 37mm Analysed as Filter Quartz 37mm Miscellaneous | | | | | | | | |
| | | | | SAL Reference | | 249753 001 | 249753 003 | 249753 005 |
| | | | | Customer Sample Reference | | ECL/11/4349 | ECL/11/4351 | ECL/11/4353 |
| | | | | Test Sample | | AR | AR | AR |
| Determinand | Method | LOD | Units | Symbol | | | | |
| Particulates (Total) | Grav (5 Dec) | 0.05 | mg | U | 0.75 | 0.25 | 0.20 | |

| | | | | | | | | |
|---|--------|-----|-------|---------------------------|------|-------------|-------------|-------------|
| SAL Reference: 249753 Customer Reference: P1098 | | | | | | | | |
| Wash(Acetone) Analysed as Wash(Acetone) Miscellaneous | | | | | | | | |
| | | | | SAL Reference | | 249753 002 | 249753 004 | 249753 006 |
| | | | | Customer Sample Reference | | ECL/11/4350 | ECL/11/4352 | ECL/11/4354 |
| | | | | Test Sample | | AR | AR | AR |
| Determinand | Method | LOD | Units | Symbol | | | | |
| Particulates (Total) | Grav | 0.1 | mg | U | <0.1 | <0.1 | <0.1 | |

Index to symbols used in 249753-1

| Value | Description |
|-------|-----------------------------|
| AR | As Received |
| U | Analysis is UKAS accredited |



Scientific Analysis Laboratories is a
limited company registered in England and
Wales (No 2514723) whose address is at
Hadfield House, Hadfield Street, Manchester M16 6FE

Scientific Analysis Laboratories Ltd Certificate of Analysis

Hadfield House
Hadfield Street
Combrook
Manchester
M16 6FE
Tel : 0161 874 2400
Fax : 0161 874 2404

Report Number: 250919-1

Date of Report: 04-Oct-2011

Customer: Environmental Compliance Ltd
Unit G1
Main Avenue
Treforest Industrial Estate
Pontypridd
CF37 5YL

Customer Contact: Mr John Litterick

Customer Job Reference: P1098
Customer Purchase Order: P9050
Date Job Received at SAL: 19-Sep-2011
Date Analysis Started: 20-Sep-2011
Date Analysis Completed: 04-Oct-2011

The results reported relate to samples received in the laboratory
Opinions and interpretations expressed herein are outside the scope of UKAS accreditation
This report should not be reproduced except in full without the written approval of the laboratory
Tests covered by this certificate were conducted in accordance with SAL SOPs



Report checked
and authorised by :
Ms Jennifer Hughes
Customer Service Manager
(Air Division)

Issued by : ~~Validity unknown~~
Ms Jennifer Hughes
Customer Service Manager
(Air Division)
04/10/2011 12:12 BST
Location: SAL

| SAL Reference: 250919 | | | | | | | |
|--|--------|-------------|-------------|-------------|------|------|------|
| Customer Reference: P1098 | | | | | | | |
| Wash(Acetone) Analysed as Wash(Acetone) | | | | | | | |
| Miscellaneous | | | | | | | |
| SAL Reference | | 250919 002 | 250919 004 | 250919 006 | | | |
| Customer Sample Reference | | ECL/11/4830 | ECL/11/4832 | ECL/11/4834 | | | |
| Test Sample | | AR | AR | AR | | | |
| Determinand | Method | LOD | Units | Symbol | | | |
| Particulates (Total) | Grav | 0.1 | mg | U | <0.1 | <0.1 | <0.1 |

| SAL Reference: 250919 | | | | | | | |
|--|--------------|-------------|-------------|-------------|------|------|-------|
| Customer Reference: P1098 | | | | | | | |
| Fiber Quartz 37mm Analysed as Fiber Quartz 37mm | | | | | | | |
| Miscellaneous | | | | | | | |
| SAL Reference | | 250919 001 | 250919 003 | 250919 005 | | | |
| Customer Sample Reference | | ECL/11/4828 | ECL/11/4831 | ECL/11/4833 | | | |
| Test Sample | | AR | AR | AR | | | |
| Determinand | Method | LOD | Units | Symbol | | | |
| Particulates (Total) | Grav (5 Dec) | 0.05 | mg | U | 0.10 | 0.10 | <0.05 |

Index to symbols used in 250919-1

| Value | Description |
|-------|-----------------------------|
| AR | As Received |
| U | Analysis is UKAS accredited |



Scientific Analysis Laboratories is a limited company registered in England and Wales (No 2514723) whose address is at Hatfield House, Hatfield Street, Manchester M10 2FE

Scientific Analysis Laboratories Ltd Certificate of Analysis

Hatfield House
Hatfield Street
Combrook
Manchester
M10 2FE
Tel : 0161 874 2400
Fax : 0161 874 2404

Report Number: 260108-1

Date of Report: 12-Dec-2011

Customer: Environmental Compliance Ltd
Unit G1
Main Avenue
Treforest Industrial Estate
Pontypridd
CF37 5YL

Customer Contact: Mr Robert Jones

Customer Job Reference: P1098

Date Job Received at SAL: 05-Dec-2011

Date Analysis Started: 06-Dec-2011

Date Analysis Completed: 12-Dec-2011

The results reported relate to samples received in the laboratory
Opinions and interpretations expressed herein are outside the scope of UKAS accreditation
This report should not be reproduced except in full without the written approval of the laboratory
Tests covered by this certificate were conducted in accordance with SAL SOPs



Report checked
and authorised by :
Ms Jennifer Hughes
Customer Service Manager
(Air Division)

Issued by :
Ms Jennifer Hughes
Customer Service Manager
(Air Division)

Validity unknown
Digitally signed by Ms Jennifer Hughes
DN: cn=Ms Jennifer Hughes, o=Environmental Compliance Limited, ou=Customer Service Manager, email=j.hughes@ecolimited.co.uk, c=GB
Reason: Issued
Location: SAL

| | | | | | | | | | |
|--|--------------|-----------------|-----------------|-----------------|-----------------|-----------------|-------|-------|-------|
| SAL Reference: 260106 | | | | | | | | | |
| Customer Reference: P1098 | | | | | | | | | |
| Filter GFA 37mm Analysed as Filter GFA 37mm | | | | | | | | | |
| Miscellaneous | | | | | | | | | |
| SAL Reference | | 260106 001 | 260106 003 | 260106 005 | 260106 007 | 260106 009 | | | |
| Customer Sample Reference | | ECL/11/6819 789 | ECL/11/6821 798 | ECL/11/6823 914 | ECL/11/6825 930 | ECL/11/6827 928 | | | |
| Test Sample | | AR | AR | AR | AR | AR | | | |
| Determinand | Method | LOD | Units | Symbol | | | | | |
| Particulates (Total) | Grav (5 Dec) | 0.05 | mg | U | 0.12 | 0.07 | <0.05 | <0.05 | <0.05 |

| | | | | | | | | | |
|--|--------------|-----------------|-------|--------|-------|--|--|--|--|
| SAL Reference: 260106 | | | | | | | | | |
| Customer Reference: P1098 | | | | | | | | | |
| Filter GFA 37mm Analysed as Filter GFA 37mm | | | | | | | | | |
| Miscellaneous | | | | | | | | | |
| SAL Reference | | 260106 011 | | | | | | | |
| Customer Sample Reference | | ECL/11/6829 919 | | | | | | | |
| Test Sample | | AR | | | | | | | |
| Determinand | Method | LOD | Units | Symbol | | | | | |
| Particulates (Total) | Grav (5 Dec) | 0.05 | mg | U | <0.05 | | | | |

| | | | | | | | | | |
|--|--------|-------------|-------------|-------------|-------------|-------------|------|------|------|
| SAL Reference: 260106 | | | | | | | | | |
| Customer Reference: P1098 | | | | | | | | | |
| Wash(Acetone) Analysed as Wash(Acetone) | | | | | | | | | |
| Miscellaneous | | | | | | | | | |
| SAL Reference | | 260106 002 | 260106 004 | 260106 006 | 260106 008 | 260106 010 | | | |
| Customer Sample Reference | | ECL/11/6820 | ECL/11/6822 | ECL/11/6824 | ECL/11/6826 | ECL/11/6828 | | | |
| Test Sample | | AR | AR | AR | AR | AR | | | |
| Determinand | Method | LOD | Units | Symbol | | | | | |
| Particulates (Total) | Grav | 0.1 | mg | U | 0.9 | <0.1 | <0.1 | <0.1 | <0.1 |

| | | | | | | | | | |
|--|--------|-------------|-------|--------|-----|--|--|--|--|
| SAL Reference: 260106 | | | | | | | | | |
| Customer Reference: P1098 | | | | | | | | | |
| Wash(Acetone) Analysed as Wash(Acetone) | | | | | | | | | |
| Miscellaneous | | | | | | | | | |
| SAL Reference | | 260106 012 | | | | | | | |
| Customer Sample Reference | | ECL/11/6830 | | | | | | | |
| Test Sample | | AR | | | | | | | |
| Determinand | Method | LOD | Units | Symbol | | | | | |
| Particulates (Total) | Grav | 0.1 | mg | U | 0.1 | | | | |

Index to symbols used in 260106-1

| Value | Description |
|-------|-----------------------------|
| AR | As Received |
| U | Analysis is UKAS accredited |



Scientific Analysis Laboratories is a
limited company registered in England and
Wales (No 2514783) whose address is at
Hasfield House, Hasfield Street, Manchester M16 9FE

Scientific Analysis Laboratories Ltd Certificate of Analysis

Hasfield House
Hasfield Street
Combrook
Manchester
M16 9FE
Tel: 0161 874 2400
Fax: 0161 874 2404

Report Number: 249752-1

Date of Report: 19-Sep-2011

Customer: Environmental Compliance Ltd
Unit G1
Main Avenue
Treforest Industrial Estate
Pontypridd
CF37 5YL

Customer Contact: Mr John Litterick

Customer Job Reference: P1098

Customer Purchase Order: P8963

Date Job Received at SAL: 07-Sep-2011

Date Analysis Started: 14-Sep-2011

Date Analysis Completed: 19-Sep-2011

The results reported relate to samples received in the laboratory
Opinions and interpretations expressed herein are outside the scope of UKAS accreditation
This report should not be reproduced except in full without the written approval of the laboratory
Tests covered by this certificate were conducted in accordance with SAL SOPs



Report checked
and authorised by :
Kayleigh McCann
Project Manager

Issued by : **Validity unknown**
Digitally signed by Kayleigh
McCann
Date: 2011.09.19 17:39:23 BST
Reason: Issued
Location: SAL

| SAL Reference: 249752 | | | | | |
|---------------------------|------------------|----------------------|------------|--------|-----------------------------------|
| Customer Reference: P1063 | | | | | |
| Impinger | | Analysed as Impinger | | | |
| Miscellaneous | | | | | |
| SAL Reference | | 249752 001 | 249752 002 | | |
| Customer Sample Reference | | ECL1114355 | ECL1114358 | | |
| Test Sample | | AR | | AR | |
| Determinand | Method | LOD | Units | Symbol | |
| Methyl-d-isocyanate | HPLC | 0.2 | µg | U | (15) <0.2 (15) <0.2 |
| Total Isocyanate Polymer | Calc (MDHS 25/3) | 0.20 | µg | N | (15,12,13) <0.20 (15,12,13) <0.20 |

Index to symbols used in 249752-1

| Value | Description |
|-------|--|
| AR | As Received |
| 100 | Expressed as NCO |
| 12 | Isocyanate polymers are based on a calculation which is defined in MDHS 25/3 |
| 139 | Excluding Targets |
| U | Analysis is UKAS accredited |
| N | Analysis is not UKAS accredited |

UNCERTAINTY CALCULATIONS

Site: NP Aerospace, Coventry
Location: Site 1, Stack ID: Spray Booth (A1)

$$u_{max} = \sqrt{\sum (u_{filter})^2 + (u_{solution})^2}$$

| Determinand | Filter mg | Solution mg | Recovered Mass mg | LAB Method Uncert (%) K=2 | Solution mg | Standard Uncertainty Filter mg | Solution mg | Combined Uncertainty mg |
|--------------|-----------|-------------|-------------------|---------------------------|-------------|--------------------------------|-------------|-------------------------|
| TPM-1 | | | | | | | | |
| Particulates | 0.12 | 0.90 | 1.02 | 0.14 | 0.27 | 0.0700 | 0.14 | 0.15 |

| TPM-1 | | Standard Uncertainty @95% | |
|--|--------|---------------------------|--|
| Sampled Volume (V _m) | 0.56 | m ³ | uV _m 0.001 m ³ |
| Meter Correction Factor (Y _d) | 1.05 | ... | ... |
| Meter Temperature (T _m) | 285.40 | k | uT _m 1.5 k |
| Static Pressure of Stack P _{static} | 15.30 | mmHg | uP _{static} 0.25 mmHg |
| Absolute Stack Pressure p _s | 751.66 | mmHg | uP _s 0.8 mmHg |
| Barometric Pressure p _b | 751.75 | mmHg | uP _b 3.8 mmHg |
| Average Differential Pressure (ΔH) | 12.24 | mmHg | uΔH 0.25 mmHg |
| Oxygen content (O _{2,m}) | 20.90 | %by volume | uO _{2,m} = σ/√n 0.00 %by volume |
| Moisture Content (H ₂ O) | 0.0231 | %by volume | uH ₂ O 0.28 %by volume |

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by C_iu_i, where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i=V_m, uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (uP_b), measured static pressure uncertainty component (uP_{static}) & measured temperature of dry gas

| | | | | | | | | | |
|--|---------|---------|-------------|------------------|---|---------|---------|-------------|--|
| $f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 0.961$ | | | | | <p>Uncertainty in volume @STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)</p> $V_{std} = V_{measured} \times f_s = 0.5365$ | | | | |
| | Maximum | Minimum | Sensitivity | u _{std} | | Maximum | Minimum | Sensitivity | Standard Uncertainty (m ³) |
| uΔH | 0.50 | 0.50 | 0.0000488 | 0.0000122 | Effect of uP _s | 0.55 | 0.52 | 0.56 | 0.0111 |
| uP _b | 0.50 | 0.50 | 0.0000664 | 0.000249 | Effect of uV _m | 0.54 | 0.53 | 0.96 | 0.000661 |
| uT _m | 0.50 | 0.50 | 0.000879 | 0.00132 | | | | | |
| H ₂ O | 0.50 | 0.50 | 0.00500 | 0.00142 | | | | | |
| $\frac{u f_s}{f_s} = \sqrt{\left(\frac{\sqrt{(u\Delta H)^2 + (uP_s)^2}}{(P_b/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{(100(100-H_2O))}\right)^2} = 0.0199$ | | | | | $\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.00624$ | | | | |

Uncertainty of correction factor to reference oxygen due to measured oxygen uncertainty component (uO₂) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

| | | | | | | | | | |
|--|---------|---------|-------------|----------------------|---|---------|---------|-------------|----------------------|
| $f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.00$ | | | | | <p>Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM), oxygen correction uncertainty component (uO₂) and STP volume uncertainty component (uV_{std})</p> $Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}} = 1.90$ | | | | |
| | Maximum | Minimum | Sensitivity | Standard Uncertainty | | Maximum | Minimum | Sensitivity | u mg/Nm ³ |
| uO ₂ | ... | ... | ... | ... | uM | 2.19 | 1.62 | 1.87 | 0.28 |
| $uL = \frac{Conc \times 2}{\sqrt{3}} = \text{mg/Nm}^3 \text{ } 0.0220$ | | | | | uO ₂ | ... | ... | ... | ... |
| | | | | | uV _{std} | 1.93 | 1.88 | 3.56 | 0.0222 |

Combined Uncertainty

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (u_{O_2})^2 + (u_{V_{std}})^2}$$

| Combined Uncertainty mg/Nm ³ | Expanded Uncertainty mg/Nm ³ | Measured Concentration mg/Nm ³ | Percent of Measured Concentration |
|---|---|---|-----------------------------------|
| 0.29 | 0.57 | 1.90 | 30.0% |

Site: NP Aerospace, Coventry
Location: Site 1, Stack ID: Spray Booth (A1)

$$u_{\text{mass}} = \sqrt{\sum (u_{\text{filter}})^2 + (u_{\text{solution}})^2}$$

| Determinand | Filter mg | Solution mg | Recovered Mass mg | LAB Method Uncert (%) K=2 | Standard Uncertainty Filter mg | Standard Uncertainty Solution mg | Combined Uncertainty mg |
|--------------|-----------|-------------|-------------------|---------------------------|--------------------------------|----------------------------------|-------------------------|
| TPM-2 | | | | | | | |
| Particulates | 0.0700 | 0.10 | 0.17 | 0.14 | 0.27 | 0.0700 | 0.15 |

| TPM-2 | | Standard Uncertainty @95% | |
|--|--------|---------------------------|--|
| Sampled Volume (V _m) | 0.56 | m ³ | uV _m 0.001 m ³ |
| Meter Correction Factor (Y _d) | 1.05 | --- | --- |
| Meter Temperature (T _m) | 301.28 | k | uT _m 1.5 k |
| Static Pressure of Stack P _{static} | 15.00 | mmHg | uP _{static} 0.25 mmHg |
| Absolute Stack Pressure p _s | 751.56 | mmHg | uP _s 0.8 mmHg |
| Barometric Pressure p _b | 751.75 | mmHg | uP _b 3.8 mmHg |
| Average Differential Pressure (ΔP) | 12.24 | mmHg | uΔP 0.25 mmHg |
| Oxygen content (O _{2,m}) | 20.90 | %by volume | uO _{2,m} = σ/√n 0.00 %by volume |
| Moisture Content (H ₂ O) | 0.0234 | %by volume | uH ₂ O 0.29 %by volume |

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by C_iu_i where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i=M_m uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s, wet} = \frac{100}{(100 - H_2O)} = 1.00$$

| Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (uP _b), measured static pressure uncertainty component (uP _{static}) & measured temperature of dry gas | | | | | Uncertainty in volume @STP due to volume correction factor uncertainty component (uV _{std}) & volume uncertainty component (uV _m) | | | | |
|--|---------|---------|-------------|------------------|---|---------|---------|-------------|--|
| $f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 0.943$ | | | | | $V_{std} = V_{measured} \times f_s = 0.5308$ | | | | |
| | Maximum | Minimum | Sensitivity | u _{STP} | | Maximum | Minimum | Sensitivity | Standard Uncertainty (m ³) |
| uΔH | 0.49 | 0.49 | 0.000483 | 0.0000121 | Effect of uP _s | 0.54 | 0.52 | 0.56 | 0.0109 |
| uP _b | 0.50 | 0.49 | 0.000657 | 0.00246 | Effect of uV _m | 0.53 | 0.53 | 0.94 | 0.000943 |
| uT _m | 0.50 | 0.49 | 0.000961 | 0.00129 | | | | | |
| H ₂ O | 0.50 | 0.49 | 0.00495 | 0.00141 | | | | | |
| $\frac{u_{f_s}}{f_s} = \sqrt{\left(\frac{\sqrt{(u\Delta H)^2 + (uP_s)^2}}{(P_m/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100/(100-H_2O)}\right)^2} = 0.0193$ | | | | | $\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.00619$ | | | | |

| Uncertainty of correction factor to reference oxygen due to measured oxygen uncertainty component (uO ₂) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2%/max) in the sample system (uL) | | | | | Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM), oxygen correction uncertainty component (uO ₂) and STP volume uncertainty component (uV _{STP}) | | | | |
|--|---------|---------|-------------|----------------------|--|---------|---------|-------------|----------------------|
| $f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.00$ | | | | | $Conc = \frac{M_{RECOVERED}}{V_m \times f_s \times f_{O_2}} = 0.32$ | | | | |
| | Maximum | Minimum | Sensitivity | Standard Uncertainty | | Maximum | Minimum | Sensitivity | u mg/Nm ³ |
| uO ₂ | ... | ... | ... | ... | uM | 0.61 | 0.0338 | 1.88 | 0.29 |
| $uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}} = \text{mg/Nm}^3 \text{ } 0.00370$ | | | | | uO ₂ | ... | ... | ... | ... |
| | | | | | uV _{STP} | 0.32 | 0.32 | 0.60 | 0.00373 |

Combined Uncertainty

$$u_{\text{combined}} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (u_{O_2})^2 + (u_{V_{STP}})^2}$$

| Combined Uncertainty | Expanded Uncertainty | Measured Concentration | Percent of Measured Concentration |
|----------------------|----------------------|------------------------|-----------------------------------|
| mg/Nm ³ | mg/Nm ³ | mg/Nm ³ | Concentration |
| 0.29 | 0.57 | 0.32 | 178.9% |

Site: NP Aerospace, Coventry
Location: Site 1, Stack ID: Prep Booth (A2)

$$u_{\text{mass}} = \sqrt{\sum(u_{\text{filter}})^2 + (u_{\text{solution}})^2}$$

| Determinand | Filter mg | Solution mg | Recovered Mass mg | LAB Method Filter mg | Uncert (%) K=2 Solution mg | Standard Uncertainty Filter mg | Standard Uncertainty Solution mg | Combined Uncertainty mg |
|--------------|-----------|-------------|-------------------|----------------------|----------------------------|--------------------------------|----------------------------------|-------------------------|
| TPM - 1 | | | | | | | | |
| Particulates | 0.0500 | 0.10 | 0.15 | 0.14 | 0.27 | 0.0700 | 0.14 | 0.15 |

| TPM - 1 | | | Standard Uncertainty @ 95% | | |
|--|--------|--------------------|----------------------------|-------|--------------------|
| Sampled Volume (V _m) | 0.60 | m ³ | uV _m | 0.001 | m ³ |
| Meter Correction Factor (Y _d) | 1.05 | ... | ... | ... | ... |
| Meter Temperature (T _m) | 300.90 | k | uT _m | 1.5 | k |
| Static Pressure of Stack P _{static} | 15.00 | mmHg ₂₀ | uP _{static} | 0.25 | mmHg ₂₀ |
| Absolute Stack Pressure p _s | 751.56 | mmHg | uP _s | 0.8 | mmHg |
| Barometric Pressure p _b | 751.75 | mmHg | uP _b | 3.8 | mmHg |
| Average Differential Pressure (ΔH) | 1.94 | mmHg ₂₀ | uΔH | 0.25 | mmHg ₂₀ |
| Oxygen content (O _{2,m}) | 20.90 | % by volume | uO _{2,m} = σ/√n | 0.00 | % by volume |
| Moisture Content (H ₂ O) | 0.0218 | % by volume | uH ₂ O | 0.27 | % by volume |

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by C_iu_i where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i=uV_m, uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s, wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (uP_b), measured static pressure uncertainty component (uP_{static}) & measured temperature of dry gas

$$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{T_m}}{13.6} \times Y_d = 0.943$$

| | Maximum | Minimum | Sensitivity | u _{stp} |
|------------------|---------|---------|-------------|------------------|
| uΔH | 0.49 | 0.49 | 0.000483 | 0.0000121 |
| uP _b | 0.50 | 0.49 | 0.000658 | 0.00247 |
| uT _m | 0.50 | 0.49 | 0.000861 | 0.00129 |
| H ₂ O | 0.50 | 0.49 | 0.00495 | 0.00132 |

$$u_{f_s} = \sqrt{\left(\frac{u(\Delta H)}{(P_m/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100/(100-H_2O)}\right)^2} = 0.12$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

$$V_{std} = V_{measured} \times f_s = 0.5686$$

| | Maximum m ³ | Minimum m ³ | Sensitivity | Standard Uncertainty (m ³) |
|--------------------------------------|------------------------|------------------------|-------------|--|
| Effect of u _{f_s} | 0.64 | 0.50 | 0.60 | 0.0733 |
| Effect of uV _m | 0.57 | 0.57 | 0.94 | 0.000943 |

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0442$$

Uncertainty of correction factor to reference oxygen due to measured oxygen uncertainty component (uO₂) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.00$$

| | Maximum | Minimum | Sensitivity | Standard Uncertainty |
|--|---------|---------|-------------|----------------------|
| u _{f_{O₂}} | ... | ... | ... | ... |

$$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}} = \text{mg/Nm}^3 \quad 0.00305$$

Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM), oxygen correction uncertainty component (uO₂) and STP volume uncertainty component (uV_{sp})

$$Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}} = 0.26$$

| | Maximum mg/Nm ³ | Minimum mg/Nm ³ | Sensitivity | u mg/Nm ³ |
|------------------|----------------------------|----------------------------|-------------|----------------------|
| uM | 0.53 | -3.639E-03 | 1.76 | 0.27 |
| uO ₂ | ... | ... | ... | ... |
| uV _{sp} | 0.29 | 0.24 | 0.47 | 0.0206 |

Combined Uncertainty

$$u_{combined} = \sqrt{\sum(u_M)^2 + (u_L)^2 + (u_{f_{O_2}})^2 + (u_{V_{sp}})^2}$$

| Combined Uncertainty mg/Nm ³ | Expanded Uncertainty mg/Nm ³ | Measured Concentration mg/Nm ³ | Percent of Measured Concentration |
|---|---|---|-----------------------------------|
| 0.27 | 0.54 | 0.26 | 203.4% |

Site: NP Aerospace, Coventry
Location: Site 1, Stack ID: Prep Booth (A2)

$$u_{\text{mass}} = \sqrt{\sum (u_{\text{filter}})^2 + (u_{\text{solution}})^2}$$

| Determinand | Filter mg | Solution mg | Recovered Mass mg | LAB Method Uncert (%) K=2 | | Standard Uncertainty | | Combined Uncertainty mg |
|----------------|-----------|-------------|-------------------|---------------------------|-------------|----------------------|-------------|-------------------------|
| | | | | Filter mg | Solution mg | Filter mg | Solution mg | |
| TPM - 2 | | | | | | | | |
| Particulates | 0.0500 | 0.10 | 0.15 | 0.14 | 0.27 | 0.0700 | 0.14 | 0.15 |

| TPM - 2 | | | Standard Uncertainty @ 95% | | | |
|--|--------|--------------------|----------------------------|-------|--------------------|--|
| Sampled Volume (V _m) | 0.57 | m ³ | uV _m | 0.001 | m ³ | |
| Meter Correction Factor (Y _d) | 1.05 | ... | ... | ... | ... | |
| Meter Temperature (T _m) | 301.03 | k | uT _m | 1.5 | k | |
| Static Pressure of Stack P _{static} | 15.00 | mmH ₂ O | uP _{static} | 0.25 | mmH ₂ O | |
| Absolute Stack Pressure p _s | 751.56 | mmHg | uP _s | 0.8 | mmHg | |
| Barometric Pressure p _b | 751.75 | mmHg | uP _b | 3.8 | mmHg | |
| Average Differential Pressure (ΔH) | 1.94 | mmH ₂ O | uΔH | 0.25 | mmH ₂ O | |
| Oxygen content (O _{2,m}) | 20.90 | % by volume | uO _{2,m} = σ/√n | 0.00 | % by volume | |
| Moisture Content (H ₂ O) | 0.0230 | % by volume | uH ₂ O | 0.28 | % by volume | |

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by C_iu_i, where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i=uV_m, uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

| Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (uP _b), measured static pressure uncertainty component (uP _{static}) & measured temperature of dry gas | | | | | Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV _{std}) & volume uncertainty component (uV _m) | | | | |
|--|---------|---------|-------------|-----------|--|---------|---------|-------------|--|
| $f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 0.943$ | | | | | $V_{std} = V_{measured} \times f_s = 0.5392$ | | | | |
| | Maximum | Minimum | Sensitivity | ufstp | | Maximum | Minimum | Sensitivity | Standard Uncertainty (m ³) |
| uΔH | 0.49 | 0.49 | 0.0000483 | 0.0000121 | Effect of uP _b | 0.61 | 0.47 | 0.57 | 0.0695 |
| uP _b | 0.50 | 0.49 | 0.000657 | 0.00247 | Effect of uV _m | 0.54 | 0.54 | 0.94 | 0.000943 |
| uT _m | 0.50 | 0.49 | 0.006861 | 0.00129 | | | | | |
| H ₂ O | 0.50 | 0.49 | 0.00494 | 0.00139 | | | | | |
| $\frac{u_{f_s}}{f_s} = \sqrt{\left(\frac{\sqrt{(u\Delta H)^2 + (uP_b)^2}}{(P_m/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{(100/(100-H_2O))}\right)^2} = 0.12$ | | | | | $\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0398$ | | | | |

| Uncertainty of correction factor to reference oxygen due to measured oxygen uncertainty component (uO ₂) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL) | | | | | Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM), oxygen correction uncertainty component (uO ₂) and STP volume uncertainty component (uV _{stp}) | | | | |
|--|---------|---------|-------------|----------------------|--|-----------------|------------|-------------|----------------------|
| $f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.00$ | | | | | $Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}} = 0.28$ | | | | |
| | Maximum | Minimum | Sensitivity | Standard Uncertainty | | Maximum | Minimum | Sensitivity | u mg/Nm ³ |
| uO ₂ | ... | ... | ... | ... | uM | 0.56 | -3.838E-03 | 1.85 | 0.28 |
| $uL = \frac{Conc \times 2}{\sqrt{3}} = \frac{0.28 \times 2}{\sqrt{3}} = 0.00321$ | | | | | | uO ₂ | ... | ... | ... |
| | | | | | uV _{stp} | 0.30 | 0.26 | 0.52 | 0.0206 |

Combined Uncertainty

$$u_{\text{combined}} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (u_{O_2})^2 + (u_{V_{stp}})^2}$$

| Combined Uncertainty mg/Nm ³ | Expanded Uncertainty mg/Nm ³ | Measured Concentration mg/Nm ³ | Percent of Measured Concentration |
|---|---|---|-----------------------------------|
| 0.28 | 0.57 | 0.28 | 203.3% |

Site: NP Aerospace, Coventry
Location: Site 1, Stack ID: Wet Back Booth (A5)

$$u_{mass} = \sqrt{\sum (u_{filter})^2 + (u_{solution})^2}$$

| Determinand | Filter mg | Solution mg | Recovered Mass mg | FPS Method Uncert (%) K-2 Filter mg | Solution mg | Standard Uncertainty Filter mg | Solution mg | Combined Uncertainty mg |
|--------------|-----------|-------------|-------------------|-------------------------------------|-------------|--------------------------------|-------------|-------------------------|
| TPM-1 | | | | | | | | |
| Particulates | 0.10 | 0.10 | 0.20 | 0.14 | 0.27 | 0.0700 | 0.14 | 0.15 |

| | TPM-1 | | Standard Uncertainty @95% |
|--|--------|--------------------|--|
| Sampled Volume (V _m) | 0.77 | m ³ | uV _m 0.001 m ³ |
| Meter Correction Factor (Y _d) | 1.05 | ... | ... |
| Meter Temperature (T _m) | 293.90 | k | uT _m 1.5 k |
| Static Pressure of Stack P _{static} | 7.14 | mmH ₂ O | uP _{static} 0.25 mmH ₂ O |
| Absolute Stack Pressure p _s | 748.56 | mmHg | uP _s 0.8 mmHg |
| Barometric Pressure p _b | 748.75 | mmHg | uP _b 3.8 mmHg |
| Average Differential Pressure (ΔH) | 6.76 | mmH ₂ O | uΔH 0.25 mmH ₂ O |
| Oxygen content (O _{2,m}) | 20.90 | %by volume | uO _{2,m} = σ/√n 0.00 %by volume |
| Moisture Content (H ₂ O) | 0.0171 | %by volume | uH ₂ O 0.21 %by volume |

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{df}{dx_i}$

For each factor, uncertainty is then calculated by C_iu_i, where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i=V_m, uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (uP_b), measured static pressure uncertainty component (uP_{static}) & measured temperature of dry gas

$$f_s = \frac{273}{760} \times \frac{P_b + \Delta H}{T_m} \times Y_d = 0.943$$

| | Maximum | Minimum | Sensitivity | ufsp |
|------------------|---------|---------|-------------|-----------|
| uΔH | 0.49 | 0.49 | 0.0000484 | 0.0000121 |
| uP _b | 0.50 | 0.49 | 0.000669 | 0.00247 |
| uT _m | 0.49 | 0.49 | 0.000961 | 0.00129 |
| H ₂ O | 0.49 | 0.49 | 0.00494 | 0.00103 |

$$u_{f_s} = \sqrt{\left(\frac{u(\Delta H)}{(P_s/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{(100/(100-H_2O))}\right)^2} = 0.0349$$

Uncertainty in volume @STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

$$V_{std} = V_{measured} \times f_s = 0.7250$$

| | Maximum | Minimum | Sensitivity | Standard Uncertainty (m ³) |
|---------------------------|---------|---------|-------------|--|
| Effect of uP _b | 0.75 | 0.70 | 0.77 | 0.0069 |
| Effect of uV _m | 0.73 | 0.72 | 0.94 | 0.000943 |

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0207$$

Uncertainty of correction factor to reference oxygen due to measured oxygen uncertainty component (uO₂) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2%/max) in the sample system (uL)

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.00$$

| | Maximum | Minimum | Sensitivity | Standard Uncertainty |
|-----------------|---------|---------|-------------|----------------------|
| uO ₂ | ... | ... | ... | ... |

$$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}} = \frac{mg/Nm^3}{0.00319}$$

Uncertainty in final measurement @ reference conditions due to mass oxygen uncertainty component (uM), oxygen correction uncertainty component (uO₂) and STP volume uncertainty component (uV_{std})

$$Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}} = 0.28$$

| | Maximum | Minimum | Sensitivity | u |
|-------------------|---------|---------|-------------|---------|
| uM | 0.49 | 0.0661 | 1.38 | 0.21 |
| uO ₂ | ... | ... | ... | ... |
| uV _{std} | 0.28 | 0.27 | 0.38 | 0.00788 |

Combined Uncertainty

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (u_{O_2})^2 + (u_{V_{std}})^2}$$

| Combined Uncertainty | Expanded Uncertainty | Measured Concentration | Percent of Measured Concentration |
|----------------------------|----------------------------|----------------------------|-----------------------------------|
| mg/Nm ³ 0.21 | mg/Nm ³ 0.42 | mg/Nm ³ 0.28 | 152.2% |

Site: NP Aerospace, Coventry
Location: Site 1, Stack ID: Wet Back Booth (A5)

$$u_{\text{mass}} = \sqrt{\sum (u_{\text{filter}})^2 + (u_{\text{solution}})^2}$$

| Determinand | Filter mg | Solution mg | Recovered Mass mg | HPS Method Uncert (%) | K-2 Filter mg | Solution mg | Standard Uncertainty Filter mg | Solution mg | Combined Uncertainty mg |
|--------------|-----------|-------------|-------------------|-----------------------|---------------|-------------|--------------------------------|-------------|-------------------------|
| TPM-2 | | | | | | | | | |
| Particulates | 0.19 | 0.10 | 0.29 | 0.14 | 0.27 | 0.0700 | 0.14 | 0.15 | |

| TPM-2 | | Standard Uncertainty @95% | |
|--|--------|---------------------------|--|
| Sampled Volume (V _m) | 0.74 | m ³ | uV _m 0.001 m ³ |
| Meter Correction Factor (Y _d) | 1.05 | ... | ... |
| Meter Temperature (T _m) | 307.65 | k | uT _m 1.5 k |
| Static Pressure of Stack P _{static} | 7.14 | mmHg | uP _{static} 0.25 mmHg |
| Absolute Stack Pressure p _s | 748.56 | mmHg | uP _s 0.8 mmHg |
| Barometric Pressure p _b | 748.75 | mmHg | uP _b 3.8 mmHg |
| Average Differential Pressure (ΔH) | 6.76 | mmHg | uΔH 0.25 mmHg |
| Oxygen content (O _{2,m}) | 20.90 | %by volume | uO _{2,m} = σ/√N 0.00 %by volume |
| Moisture Content (H ₂ O) | 0.0182 | %by volume | uH ₂ O 0.22 %by volume |

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by C_iu_i where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i=V_m, uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,\text{wet}} = \frac{100}{(100 - H_2O)} = 1.00$$

| Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (uP _b), measured static pressure uncertainty component (uP _{static}) & measured temperature of dry gas | | | | | Uncertainty in volume @STP due to volume correction factor uncertainty component (uV _{std}) & volume uncertainty component (uV _m) | | | | |
|--|---------|---------|-------------|------------------|---|---------|---------|-------------|--|
| $f_s = \frac{273}{760} \times \frac{P_b + \Delta H}{T_m} \times Y_d = 0.919$ | | | | | $V_{\text{std}} = V_{\text{measured}} \times f_s = 0.6800$ | | | | |
| | Maximum | Minimum | Sensitivity | u _{stp} | | Maximum | Minimum | Sensitivity | Standard Uncertainty (m ³) |
| uΔH | 0.49 | 0.49 | 0.0000478 | 0.0000119 | Effect of uP _b | 0.70 | 0.66 | 0.74 | 0.0049 |
| uP _b | 0.49 | 0.48 | 0.000650 | 0.00244 | Effect of uV _m | 0.68 | 0.68 | 0.92 | 0.000919 |
| uT _m | 0.49 | 0.49 | 0.000339 | 0.00126 | | | | | |
| H ₂ O | 0.49 | 0.49 | 0.00487 | 0.00109 | | | | | |
| $\frac{u_{f_s}}{f_s} = \sqrt{\left(\frac{\sqrt{(u\Delta H)^2 + (uP_s)^2}}{(P_m/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100/(100-H_2O)}\right)^2} = 0.0036$ | | | | | $\frac{uV_{\text{std}}}{V_{\text{std}}} = \sqrt{\left(\frac{uV_{\text{std}}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0184$ | | | | |

| Uncertainty of correction factor to reference oxygen due to measured oxygen uncertainty component (uO ₂) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL) | | | | | Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM), oxygen correction uncertainty component (uO ₂) and STP volume uncertainty component (uV _{stp}) | | | | |
|--|---------|---------|-------------|----------------------|--|---------|---------|-------------|--------|
| $f_{O_2} = \frac{20.9\% - O_{2,\text{ref}}}{20.9\% - O_{2,\text{measured}}} = 1.00$ | | | | | $\text{Conc} = \frac{M_{\text{measured}}}{V_m \times f_s \times f_{O_2}} = 0.43$ | | | | |
| | Maximum | Minimum | Sensitivity | Standard Uncertainty | | Maximum | Minimum | Sensitivity | u |
| u _{f_{O₂}} | ... | ... | ... | ... | uM | 0.65 | 0.20 | 1.47 | 0.22 |
| $uL = \frac{\text{Conc} \times \frac{2}{100}}{\sqrt{3}} = \text{mgNm}^3 \quad 0.00492$ | | | | | uO ₂ | ... | ... | ... | ... |
| | | | | | uV _{stp} | 0.44 | 0.42 | 0.63 | 0.0116 |

Combined Uncertainty

$$u_{\text{combined}} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (u_{f_{O_2}})^2 + (uV_{\text{stp}})^2}$$

| Combined Uncertainty | Expanded Uncertainty | Measured Concentration | Percent of Measured Concentration |
|----------------------|----------------------|------------------------|-----------------------------------|
| 0.22 | 0.46 | 0.43 | 105.0% |

Site: NP Aerospace, Coventry
Location: Site 3, Stack ID: LineX Booth (A2)

$$u_{mass} = \sqrt{\sum(u_{filter})^2 + (u_{solution})^2}$$

| Determinand | Filter mg | Solution mg | Recovered Mass mg | LAB Method Uncert (%) K=2 | Standard Uncertainty | Filter mg | Solution mg | Combined Uncertainty mg |
|--------------|-----------|-------------|-------------------|---------------------------|----------------------|-----------|-------------|-------------------------|
| TPM-1 | | | | | | | | |
| Particulates | 0.75 | 0.10 | 0.85 | 0.14 | 0.27 | 0.0700 | 0.14 | 0.15 |

| | TPM-1 | | Standard Uncertainty @95% |
|--|----------|----------------|--|
| Sampled Volume (V _m) | 0.71 | m ³ | uV _m 0.001 m ³ |
| Meter Correction Factor (Y _d) | 1.04 | --- | --- |
| Meter Temperature (T _m) | 293.40 | k | uT _m 1.5 k |
| Static Pressure of Stack P _{static} | 1.50 | mmHg | uP _{static} 0.25 mmHg |
| Absolute Stack Pressure P _s | 750.81 | mmHg | uP _s 0.8 mmHg |
| Barometric Pressure P _b | 751.00 | mmHg | uP _b 3.8 mmHg |
| Average Differential Pressure (ΔP) | 4.59 | mmHg | uΔP 0.25 mmHg |
| Oxygen content (O _{2,m}) | 20.90 | %by volume | uO _{2,m} = σ/√n 0.00 %by volume |
| Moisture Content (H ₂ O) | 0.000187 | %by volume | uH ₂ O 0.23 %by volume |

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{df}{dx_i}$

For each factor, uncertainty is then calculated by C_iu_i where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i=V_m, uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (uP_b), measured static pressure uncertainty component (uP_{static}) & measured temperature of dry gas

$$f_s = \frac{273}{760} \times \frac{P_b + \Delta H}{T_m} \times Y_d = 0.937$$

| | Maximum | Minimum | Sensitivity | u _{fsp} |
|------------------|---------|---------|-------------|------------------|
| uΔH | 0.49 | 0.49 | 0.0000479 | 0.0000120 |
| uP _b | 0.49 | 0.49 | 0.000651 | 0.00244 |
| uT _m | 0.49 | 0.49 | 0.000656 | 0.00123 |
| H ₂ O | 0.49 | 0.49 | 0.00489 | 0.00112 |

$$u_{f_s} = \sqrt{\left(\frac{u(\Delta H)}{(P_b/1013)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{(100/(100-H_2O))}\right)^2} = 0.0605$$

Uncertainty in volume @STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

$$V_{std} = V_{measured} \times f_s = 0.6643$$

| | Maximum | Minimum | Sensitivity | Standard Uncertainty (m ³) |
|---------------------------|---------|---------|-------------|--|
| Effect of uP _s | 0.70 | 0.63 | 0.71 | 0.0358 |
| Effect of uV _m | 0.67 | 0.65 | 0.94 | 0.000937 |

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0254$$

Uncertainty of correction factor to reference oxygen due to measured oxygen uncertainty component (uO₂) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2%max) in the sample system (uL)

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.00$$

| | Maximum | Minimum | Sensitivity | Standard Uncertainty |
|--|---------|---------|-------------|----------------------|
| u _{f_{O₂}} | ... | ... | ... | ... |

$$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}} = \text{mg/Nm}^3 \quad 0.0148$$

Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM), oxygen correction uncertainty component (uO₂) and STP volume uncertainty component (uV_{std})

$$Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}} = 1.28$$

| | Maximum mg/Nm ³ | Minimum mg/Nm ³ | Sensitivity | u mg/Nm ³ |
|-------------------|----------------------------|----------------------------|-------------|----------------------|
| uM | 1.51 | 1.05 | 1.51 | 0.23 |
| uO ₂ | ... | ... | ... | ... |
| uV _{std} | 1.33 | 1.23 | 1.93 | 0.0480 |

Combined Uncertainty

$$u_{combined} = \sqrt{\sum(u_M)^2 + (u_L)^2 + (u_{f_{O_2}})^2 + (u_{V_{std}})^2}$$

| Combined Uncertainty mg/Nm ³ | Expanded Uncertainty mg/Nm ³ | Measured Concentration mg/Nm ³ | Percent of Measured Concentration |
|---|---|---|-----------------------------------|
| 0.23 | 0.47 | 1.28 | 36.7% |

Site: NP Aerospace, Coventry
Location: Site 3, Stack 1D LineX Booth (A2)

$$u_{mass} = \sqrt{\sum(u_{filter})^2 + (u_{solution})^2}$$

| Determinand | Filter mg | Solution mg | Recovered Mass mg | LAB Method Filter mg | LAB Method Solution mg | Standard Uncertainty Filter mg | Standard Uncertainty Solution mg | Combined Uncertainty mg |
|----------------|-----------|-------------|-------------------|----------------------|------------------------|--------------------------------|----------------------------------|-------------------------|
| TPM - 2 | | | | | | | | |
| Particulates | 0.25 | 0.10 | 0.35 | 0.14 | 0.27 | 0.0700 | 0.14 | 0.15 |

| TPM - 2 | | | Standard Uncertainty @95% | | |
|--|----------|--------------------|---------------------------|-------|--------------------|
| Sampled Volume (V _m) | 0.74 | m ³ | uV _m | 0.001 | m ³ |
| Meter Correction Factor (Y _d) | 1.04 | ... | ... | ... | ... |
| Meter Temperature (T _m) | 303.15 | k | uT _m | 1.5 | k |
| Static Pressure of Stack P _{static} | 1.50 | mmH ₂ O | uP _{static} | 0.25 | mmH ₂ O |
| Absolute Stack Pressure p _s | 750.81 | mmHg | uP _s | 0.8 | mmHg |
| Barometric Pressure p _b | 751.00 | mmHg | uP _b | 3.8 | mmHg |
| Average Differential Pressure (ΔH) | 4.59 | mmH ₂ O | uΔH | 0.25 | mmH ₂ O |
| Oxygen content (O _{2,m}) | 20.90 | %by volume | uO _{2,m} = σ/√n | 0.00 | %by volume |
| Moisture Content (H ₂ O) | 0.000184 | %by volume | uH ₂ O | 0.23 | %by volume |

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by C_iu_i where C is the sensitivity coefficient, u_i is the standard uncertainty and i is the index identifying the contributing factor e.g. i=V_m, uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{1,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (uP_b), measured static pressure uncertainty component (uP_{static}) & measured temperature of dry gas

$$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 0.904$$

| | Maximum | Minimum | Sensitivity | uP _{stp} |
|------------------|---------|---------|-------------|-------------------|
| uΔH | 0.48 | 0.48 | 0.0000470 | 0.0000117 |
| uP _b | 0.48 | 0.48 | 0.000639 | 0.00240 |
| uT _m | 0.48 | 0.48 | 0.000925 | 0.00124 |
| H ₂ O | 0.48 | 0.48 | 0.00480 | 0.00108 |

$$u_{f_s} = \sqrt{\left(\frac{u(\Delta H)}{(P_b/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{(100/(100-H_2O))}\right)^2} = 0.0479$$

Uncertainty in volume @STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

$$V_{std} = V_{measured} \times f_s = 0.6728$$

| | Maximum m ³ | Minimum m ³ | Sensitivity | Standard Uncertainty (m ³) |
|---------------------------|------------------------|------------------------|-------------|--|
| Effect of uP _s | 0.71 | 0.64 | 0.74 | 0.0356 |
| Effect of uV _m | 0.67 | 0.67 | 0.90 | 0.000904 |

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0255$$

Uncertainty of correction factor to reference oxygen due to measured oxygen uncertainty component (uO₂) & uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2%/max) in the sample system (uL)

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.00$$

| | Maximum | Minimum | Sensitivity | Standard Uncertainty |
|-----------------|---------|---------|-------------|----------------------|
| uO ₂ | ... | ... | ... | ... |

$$uL = \frac{Conc \times 2}{\sqrt{3}} = \frac{mg/Nm^3}{0.00601}$$

Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM), oxygen correction uncertainty component (uO₂) and STP volume uncertainty component (uV_{stp})

$$Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}} = 0.52$$

| | Maximum mg/Nm ³ | Minimum mg/Nm ³ | Sensitivity | u mg/Nm ³ |
|-------------------|----------------------------|----------------------------|-------------|----------------------|
| uM | 0.75 | 0.29 | 1.49 | 0.23 |
| uO ₂ | ... | ... | ... | ... |
| uV _{stp} | 0.54 | 0.50 | 0.77 | 0.0205 |

Combined Uncertainty

$$u_{combined} = \sqrt{\sum(u_M)^2 + (u_L)^2 + (u_{O_2})^2 + (u_{V_{stp}})^2}$$

| Combined Uncertainty mg/Nm ³ | Expanded Uncertainty mg/Nm ³ | Measured Concentration mg/Nm ³ | Percent of Measured Concentration |
|---|---|---|-----------------------------------|
| 0.23 | 0.45 | 0.52 | 87.3% |