

COVENTRY CITY COUNCIL

ENVIRONMENTAL PROTECTION ACT 1990, SECTIONS 8(8), 12

NOTICE OF REVOCATION

85


To: *Diesel Power Services*
Units 15 & 16
Hales Industrial Park
Rowleys Green Lane
COVENTRY

Coventry City Council ("the Council"), in exercise of the powers conferred on it by section 8(8), 12 of the Environmental Protection Act ("the Act"), hereby gives you notice as follows:

(for section 12(2) notices)

1. The Council has reason to believe that the prescribed process for which authorisation reference **085** is in force has not been carried on (for a period of 12 months).
2. The authorisation reference **085** is hereby revoked with effect from **22nd November 1998**.

Signed on behalf of Coventry City Council


.....
City Environment Officer
The officer appointed for that purpose

22nd October 1998
Date:

epa/dps.revoc

BB

CERTIFICATE OF SERVICE BY HAND

I, Z. Owen..... being employed
as a EHO..... in the Housing and
Environmental Services Directorate of
Coventry City Council hereby certify that the
Notice of which this is a copy was
served/delivered by me to Diesel Power Service
of Coventry,
on 22.10.1991.....
Signed [Signature].....

Your Reference :
Our Reference :
Please ask for :
Direct Dialling No :
Date :



HOUSING AND ENVIRONMENTAL
SERVICES DIRECTORATE

Director Howard T. Farrand
Providing Housing, Environmental and
Client Agency Services

Michael J. Green
City Environment Officer
Broadgate House
Broadgate
Coventry, CV1 1NH

Telephone : 01203 85 1852/54
Telecom Gold Mailbox : 76 : ENDO42
Fax : 01203 85 1831

THE ENVIRONMENTAL PROTECTION ACT 1990

**The Environmental Protection (Prescribed Processes and Substances) Regulations
1991 (as amended),**

**The Environmental Protection (Application, Appeals and Registers) Regulations
1991 (as amended),**

**Authorization No: 085
Application Received: 10th November 1995**

Notice is hereby given that under Section 6 of the Environmental Protection Act 1990,
Coventry City Council (hereinafter called the Authority) gives authorisation to:

**Diesel Power Services Ltd
Units 15, 16
Hales Industrial Park
Rowley Green Lane
Coventry**

to operate a waste oil burner of 0.041MW net rated thermal input manufactured by
Kongsilde and identified as Thermobile AT400 (hereinafter: the appliance) at:

**Units 15, 16 *
Hales Industrial Park
Rowleys Green Lane
Coventry**

subject to the conditions on pages 2-3 of this authorisation and within the process
boundary as indicated on Plan No. 1.

Signed 
City Environment Officer

Dated 12th day of November 1996

Protecting our City

1. Only hydrocarbon-based oils arising from the draining of engines, gearboxes and other lubrication systems at the address marked * on page 1 of this authorisation shall be burned in the appliance. No waste oil from other sources shall be burned in the appliance.

The following shall at no time be burned in the appliance:

- i. any halogenated materials;
 - ii. polycyclic or polyaromatic compounds arising other than by use as a lubricating oil;
 - iii. low-flash-point fuels, oils or solvents (less than 40°C determined by the Pensky-Marten closed cup method);
 - iv. surface-coating materials eg. paint.
2. Where any modification to the appliance is intended, with the exception of the fitting of standard replacement parts, details of the modification shall be notified to the Authority and approval obtained prior to the modification being undertaken.

Process Controls

3. The appliance shall be refuelled only when cold.
4. All staff who are nominated to operate the appliance shall be trained in, and fully conversant with, its operation in accordance with the manufacturer's instructions for that appliance. Special attention shall be given to the correct procedure for lighting the appliance from cold. Only nominated persons shall operate the appliance.
5. Clear instructions shall be prominently displayed at all times on or near the appliance, detailing its correct operation and maintenance.
6. The appliance shall be cleaned and ash shall be removed in accordance with the manufacturer's instructions for that appliance.
7. The appliance, including the fuel feed system and chimney, shall be thoroughly inspected once a week during operational months to ensure that there are no defects which could lead to excessive smoke emission. The weekly examination shall include an assessment of the smoke emission from the appliance during lighting from cold and in normal operation. The results of the inspection shall be noted in a log book, together with the date and the identity of the person undertaking the inspection.
8. The appliance shall be serviced regularly in accordance with the manufacturer's instructions for that appliance. Suitable precautions shall be taken in the handling and disposal of ash, dust or other residues to minimise any emission to atmosphere. The material shall be collected, contained and transported in sealed bags or other dust-tight containers.
9. Where smoke emissions occur, with the exception of the allowance for lighting from cold in Condition 14 below, the appliance shall be switched off and the cause identified and rectified before the appliance is relit.
10. Waste oil shall be stored and handled so as to minimise the emission of odorous vapours to the air. It shall be stored in closed containers in the bunded area marked 'A' on Plan 1. Suitable covered containers shall be used to transfer it to the appliance.

11. A supply of a suitable oil-absorbent material shall be maintained on site, and any liquid spillage shall be cleaned up immediately.

Chimney

12. The appliance shall be permanently ducted to a chimney, marked 'B' on Plan 1, which shall be 7m above ground level.
13. The chimney shall discharge vertically upwards, and shall be free from any cap, plate, or other restricting device which would interfere with the upward flow of flue gases.

Emission Limits and Controls

14. All emissions to air shall be free from visible smoke and in any event shall not exceed the equivalent of Ringlemann Shade 1 as described in British Standard 2742 : 1969. In the case of lighting from cold, emissions of smoke exceeding Ringlemann Shade 1 are permitted for not more than 10 minutes.

Emission Monitoring

15. Where the operator observes smoke emissions which contravene the requirements of Condition 14 above, the operator shall record the date and time that the emission occurred in the log book specified in Condition 7 above. Records of such emissions shall be retained for a minimum of four years.

This is not part of the Authorization

SUPPLEMENTARY NOTES

1. Your attention is drawn to your obligation under Section 7(2)(a) of the Environmental Protection Act 1990 to ensure that in the carrying out of the prescribed process the best available techniques not entailing excessive cost (BATNEEC) will be used:
 - (i) For preventing the release of substances prescribed for any environmental medium into that medium or, where that is not practicable by such means, for reducing the release of such substances to a minimum and for rendering harmless any such substances which are so released.

and

 - (ii) For rendering harmless any other substances which might cause harm if released into any environmental medium.
2. The Authority for contact purposes shall be taken to mean the Head of the Pollution Control Section, telephone 831832 during office hours, 832222 outside office hours.
3. This Authorization allows you to burn your own arisings of waste oil as fuel. Stricter conditions apply if you wish to use additional waste oil from other sources. This is because of the greater risk that such additional oil may have been contaminated.
4. If you wish to modify either the appliance or the activities permitted by this Authorization, you must apply to us and obtain written permission beforehand.

[PLAN 1]



Hales Park Industrial Estate

REPRODUCED FROM THE ORDINANCE
SURVEY MAPS WITH THE PERMISSION
OF THE CONTROLLER OF HER MAJESTY'S
STATISTICAL SERVICE & CROWN COPYRIGHT
1994. UNAUTHORIZED REPRODUCTION INFRINGES
CROWN COPYRIGHT AND MAY LEAD TO
PROSECUTION OR CIVIL PROCEEDINGS.
1/500 SCALE

GLoucester City Council
PLANNING No. 076 155
Published (year) 1994

APPLICATION FOR AUTHORISATION, UNDER SECTION 6
OF THE ENVIRONMENTAL PROTECTION ACT 1990, TO
OPERATE A WASTE OIL BURNER WITH NET RATED THERMAL
INPUT OF LESS THAN 0.4 MW, BURNING THE OPERATOR'S
OWN ARISING OF WASTE OIL ONLY.

00384124
CT.#
SC 100.00
1 ITEMS
TOTAL 100.00
32428
CT.#
REQUE 100.00
100-0000 10/11/95
486 7 PH 4:05

1. Either Name and address of applicant
..... DIESEL POWER SERVICES
..... UNITS 15/16
..... HALES IND. PARK
..... ROWLEYS GREEN LANE
..... COVENTRY. CV6 6AN
..... TEL: 0203-688004

OR Name, number and registered office of applicant
company (if applicable)

..... SUREBET LIMITED
..... AS ABOVE
..... No :- 2316687

2. Name and address of premises where process is or will be
carried on

..... DIESEL POWER SERVICES
..... UNITS 15/16
..... HALES IND. PARK
..... ROWLEYS GREEN LANE
..... COVENTRY: CV6 6AN
..... TEL: 0203 688004

PC 20/11/95

A plan showing the location of the premises where the appliance
will be installed must be attached. included.

3. Make and model name/number of the appliance(s) to be installed

Kingfisher

..... THERMOBILE AT400
.....

4. Is the appliance(s) constructed or adapted so as to comply with
BS4256?

*Yes (but BS does not
apply to other items!)*

Yes/No *Not Known*

5. What is the net rated thermal input of the appliance(s)?

0.041 MW

..... *Not Known*

6. What fuel will be burned on the appliance?

...engine...oil.....
.....

7. What is the source of the fuel?

...own supply...oil.....
.....

8. What is the height and location of the proposed chimney serving the appliance(s)?

7m

...Roof...the...8.10metres...high.....
.....

9. What is the efflux velocity, in normal operation, of the waste gases leaving the chimney to the appliance(s)?

natural draught

...Nat. Draught.....

10. Where will the fuel storage tank vents be situated?


...other side of building.....

Fee enclosed (cheques made payable to the District/Borough Council)

£

I hereby certify that all the information contained in this application is, to the best of my knowledge, correct.

...*[Signature]*... (Signature) 3 November 95. (Date)



DIESEL POWER SCANNERS
UNITS 15/16
HALES IND. PARK
ROWLEYS GREEN LANE
COVENTRY CV5 6AN
TEL: 0203 600004