

MAINTENANCE SUMMARY SHEET FOR WORKSHOP HEATER AT 400 [PERIOD  
JAN2015-JAN 2016]

JAN 16TH 2015 Heater cleaned,not used.Oil feed cleaned out.

JAN 23RD 2015 Heater run smoke checked[OK] no problems found.

JAN 30TH 2015 Ash pan scrapped clean, ash bagged & disposed of.Cabinet panel outside re- fixed. Heater run,Smoke stack & emmissions checked [OK].

FEB 06TH 2015 Advise check security of smoke stack. Stack checked [OK] Heater not used.

FEB 13TH 2015 Smoke checked [OK] AFTER Report slightly discoloured, checked again [OK].Heater left running ,checked again [OK]

FEB 20TH 2015 Heater cleaned internally Smoke checked [ok] Ash bagged.

FEB 27TH 2015 Heater not in use.

NOV 20TH 2015 Heater checked,cleaned,smoke tested & trial run carried out on todays date.Everything [OK]. Run for 5 hours no problems.

NOV 23RD 2015 Heater pan cleaned,ash bagged & smoke checked . All [OK].

DEC 18TH 2015 Heater run , smoke checked [OK] Oil pipe cleaned.

JAN 08TH 2015 Ash tray cleaned,emptied & bagged.Smoke checked [OK].

JAN 15TH 2016 Heater run,oil supply problem sorted out. Heater run again, smoke checked &stack tightened.[OK].

Staff trained to operate & maintain heater are as follows; STEPHEN BENTON,GRAHAM WHITE , BRADLEY PARSONS & NEVILLE BENTON

NO PROBLEMS RECORDED OR MAJOR FAULTS DURING THIS PERIOD.

ENDERMERE GARAGE LTD . UNIT 11 ALBION INDUSTRIAL ESTATE, ENDEMERE RD  
,COVENTRY

