



Exova Catalyst, Unit C6, Emery Court, The Embankment Business Park, Heaton Mersey, Stockport, SK4 3GL  
Your Exova Catalyst Contact: James Eldridge (07826 916 684)  
E: james.eldridge@exova.com

**Stack Emissions Testing Report Commissioned by**  
Meggitt Aircraft Braking Systems

**Installation Name & Address**  
Meggitt Aircraft Braking Systems  
Holbrook Lane  
Coventry  
West Midlands  
CV6 4AA

PPC Permit: PPC/156

**Stack Reference**  
Plating Shop Main Stack

**Dates of the Monitoring Campaign**  
27th February 2019

**Job Reference Number**  
CAT-4759

<b>Report Written by</b>
Alex Powell Team Leader MCERTS Level 2 MM 10 1082 TE1 TE2 TE3 TE4

<b>Report Approved by</b>
Matthew Pendlebury Team Leader MCERTS Level 2 MM 04 535 TE1 TE2 TE3 TE4

<b>Report Date</b>
26th March 2019

<b>Version</b>
Version 1

<b>Signature of Report Approver</b>



## CONTENTS

TITLE PAGE

CONTENTS

EXECUTIVE SUMMARY

Monitoring Objectives	3
Monitoring Results	4
Monitoring Dates & Times	5
Process Details	6
Monitoring & Analytical Methods	7
Summary of Sampling Deviations	7
Sampling Location	8
Plant Photos / Sample Points	9

APPENDIX 1 - Monitoring Personnel & List of Equipment

APPENDIX 2 - Raw Data, Sampling Equations & Charts

*Opinions and interpretations expressed herein are outside the scope of Exova Catalyst's ISO 17025 accreditation.*

*This test report shall not be reproduced, except in full, without the written approval of Exova Catalyst.*



## Executive Summary

(Page 1 of 7)

### MONITORING OBJECTIVES

Meggitt Aircraft Braking Systems, Coventry  
Plating Shop Main Stack  
27th February 2019

#### Overall Aim of the Monitoring Campaign

Exova Catalyst were commissioned by Meggitt Aircraft Braking Systems to carry out stack emissions testing on the Plating Shop Main Stack at Coventry.

The aim of the monitoring campaign was to demonstrate compliance with a set of emission limit values (ELVs) as specified in the Site's Permit.

#### Special Requirements

There were no special requirements.

#### Target Parameters

Hydrogen Fluoride, Total Oxides of Nitrogen

## Executive Summary

(Page 2 of 7)

### MONITORING RESULTS

Meggitt Aircraft Braking Systems, Coventry

Plating Shop Main Stack

27th February 2019

where MU = Measurement Uncertainty associated with the Result

Parameter	Concentration				Mass Emission			
	Units	Result	MU +/-	Limit	Units	Result	MU +/-	Limit
Hydrogen Fluoride	<sup>1</sup> mg/m <sup>3</sup>	< 0.05	0.003	5	g/hr	< 2.49	0.20	-
Total Oxides of Nitrogen	<sup>1</sup> mg/m <sup>3</sup>	< 5.64	1.13	200	g/hr	< 288	59.1	-
Water Vapour	% v/v	3.14	0.16					
Stack Gas Temperature	°C	24.0						
Stack Gas Velocity	m/s	8.75	0.10					
Volumetric Flow Rate (ACTUAL)	m <sup>3</sup> /hr	55676	2594					
Volumetric Flow Rate (REF)	<sup>1</sup> m <sup>3</sup> /hr	51051	2379					

NOTE: VOLUMETRIC FLOW RATE & VELOCITY DATA TAKEN FROM THE PRELIMINARY VELOCITY TRAVERSE.

<sup>1</sup> Reference Conditions (REF) are: 273K, 101.3kPa, without correction for water vapour content.

## Executive Summary

(Page 3 of 7)

### MONITORING DATE(S) & TIMES

Meggitt Aircraft Braking Systems, Coventry  
 Plating Shop Main Stack  
 27th February 2019

Parameter	Units	Concentration	Units	Mass Emission	Sampling Date(s)	Sampling Times	Duration mins
Hydrogen Fluoride	R1 mg/m <sup>3</sup>	< 0.05	g/hr	< 2.49	27/02/2019	11:50 - 12:50	60
Total Oxides of Nitrogen	R1 mg/m <sup>3</sup>	< 5.64	g/hr	< 288	27/02/2019	11:50 - 12:50	60
Velocity Traverse	R1				27/02/2019	13:00 - 13:15	

All results are expressed at the respective reference conditions.

## Executive Summary

(Page 4 of 7)

### PROCESS DETAILS

Meggitt Aircraft Braking Systems, Coventry  
 Plating Shop Main Stack  
 27th February 2019

#### Standard Operating Conditions

Parameter	Value
Process Status	Normal Operation
Capacity (of 100%) and Tonnes / Hour	Standard Operating Capacity
Continuous or Batch Process	Continuous
Feedstock (if applicable)	Metallic Components
Abatement System	Wet Scrubber
Abatement System Running Status	On
Fuel	N/A
Plume Appearance	None Visible

## Executive Summary

(Page 5 of 7)

### MONITORING & ANALYTICAL METHODS

Meggitt Aircraft Braking Systems, Coventry

Plating Shop Main Stack

27th February 2019

Parameter	Monitoring				Analysis				MCERTS Testing	LOD (Average)
	Standard	Technical Procedure	ISO 17025 Testing	Testing Lab	Analytical Procedure	Analytical Technique	ISO 17025 Analysis	Analysis Lab		
Hydrogen Fluoride	ISO 15713	CAT-TP-10	Yes	CAT	CAT-AP-01	IC	Yes	CAT	Yes	0.05 mg/m <sup>3</sup>
Total Oxides of Nitrogen	US EPA M7D	CAT-TP-35	Yes	CAT	C27	IC	Yes	RPS	Yes	5.64 mg/m <sup>3</sup>
Water Vapour	EN 14790	CAT-TP-05	Yes	CAT	CAT-TP-05	Gravimetric	Yes	CAT	Yes	0.10 % v/v
Velocity & Vol. Flow Rate	EN 16911-1 (MID)	CAT-TP-41	Yes	CAT	Pitot Tube and Thermocouple				Yes	1.2 m/s

### ANALYSIS LABORATORIES

(with short name reference as appears in the table above)

Exova Catalyst (CAT)	ISO 17025 Accreditation Number: 4279
----------------------	--------------------------------------

### SUMMARY OF SAMPLING DEVIATIONS

Parameter	Run	Deviation
All Parameters	All Runs	There are no deviations associated with the sampling employed.

## Executive Summary

(Page 6 of 7)

### SUITABILITY OF SAMPLING LOCATION

#### Duct Characteristics

Parameter	Units	Value
Type	-	Circular
Depth	m	1.50
Width	m	-
Area	m <sup>2</sup>	1.77
Port Depth	cm	9
Orientation of Duct	-	Vertical
Number of Ports	-	2
Sample Port Size	-	4" BSP

#### Location of Sampling Platform

General Platform Information	Value
Permanent / Temporary Platform	Permanent
Inside / Outside	Outside

#### Platform Details

EA Technical Guidance Note M1 / EN 15259 Platform Requirements	Value
Sufficient working area to manipulate probe and operate the measuring instruments	Yes
Platform has 2 levels of handrails (approx. 0.5m & 1.0m high)	Yes
Platform has vertical base boards (approx. 0.25m high)	Yes
Platform has chains / self closing gates at top of ladders	Yes
There are no obstructions present which hamper insertion of sampling equipment	Yes
Safe Access Available	Yes
Easy Access Available	Yes

#### Sampling Location / Platform Improvement Recommendations

The sampling location meets all the requirements specified in EA Guidance Note M1 and EN 15259, and therefore there are no improvement recommendations.

#### EN 15259 Homogeneity Test Requirements

There is no requirement to perform a EN 15259 Homogeneity Test on this Stack.

#### Sampling Plane Validation Criteria (from EN 15259)

Criteria in EN 15259	Units	Traverse 1					Required	Compliant
Lowest Differential Pressure	Pa	42.0					> 5 Pa	Yes
Mean Velocity	m/s	8.75					-	-
Lowest Gas Velocity	m/s	7.11					-	-
Highest Gas Velocity	m/s	10.41					-	-
Ratio of Above	: 1	1.46					< 3 : 1	Yes
Maximum Angle of Swirl	°	NM	NM	NM	NM	NM	NM	
No Local Negative Flow	-	Yes					-	Yes

Where NM = Not Measured as no Isokinetic sampling was performed.



# Executive Summary

(Page 7 of 7)

## PLANT PHOTOS

Photo 1



Photo 2




Photo 3



Photo 4



## SAMPLE POINTS



- where**
- = isokinetic point sampled at
  - = isokinetic point not sampled at
  - = combustion gases sample point
  - = non-isokinetic sample point



## APPENDICES

### APPENDIX CONTENTS

APPENDIX 1 - Stack Emissions Monitoring Personnel, List of Equipment & Methods and Technical Procedures Used

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**STACK EMISSIONS MONITORING PERSONNEL**

Position	Name	MCERTS Accreditation	MCERTS Number	Technical Endorsements
Team Leader	Alex Powell	MCERTS Level 2	MM 10 1082	TE1 TE2 TE3 TE4
Team Leader	Matthew Pendlebury	MCERTS Level 2	MM 04 535	TE1 TE2 TE3 TE4

**LIST OF EQUIPMENT**

Extractive Sampling		Instrumental Analysers		Miscellaneous Items	
Equipment Type	Equipment I.D.	Equipment Type	Equipment I.D.	Equipment Type	Equipment I.D.
Control Box DGM (1)	-	Horiba PG-250	-	Digital Manometer (1)	CAT 3.169
Control Box DGM (2)	-	Horiba PG-250 SRM	-	Digital Manometer (2)	CAT 3.169
Box Thermocouples (1)	-	Servomex 5200 MP	-	Digital Temperature Meter	-
Box Thermocouples (2)	-	Eco Physics CLD 822Mh	-	Stopwatch	CAT 14.53
Umbilical (1)	-	ABB AO2020-URAS26	-	Barometer	CAT 13.26
Umbilical (2)	-	Testo 350 XL	-	Stack Thermocouple (1)	CAT 4.1152
Oven Box (1)	CAT 12.48	JCT JCC P1 Cooler	-	Stack Thermocouple (2)	-
Oven Box (2)	-	Gasmet DX4000	-	Stack Thermocouple (3)	-
Heated Probe (1)	CAT 5.55	Gasmet Sampling System	-	1m Heated Line (1)	-
Heated Probe (2)	-	Bernath 3006 FID	-	1m Heated Line (2)	-
Heated Probe (3)	-	M&C PSS	-	1m Heated Line (3)	-
S-Pitot (1)	CAT 215.41	Mass Flow Controller (1)	-	5m Heated Line (1)	-
S-Pitot (2)	-	Mass Flow Controller (2)	-	15m Heated Line (1)	-
L-Pitot	-	Mass View (1)	CAT 25.40	20m Heated Line (1)	-
Site Balance	CAT 17.23	Mass View (2)	CAT 25.41	20m Heated Line (2)	-
500g / 1Kg Check Weights	CAT 17.23	Easylogger EN-EL-12 Bit	-	Dual Channel Heater Controller	-
Last Impinger Arm	CAT 4.400	Hioki 5043 (V)	-	Single Channel Heater Controller	-
Callipers	-	Bioaerosols Temperature Logger	-	Laboratory Balance	-
Tubes Kit Thermocouple	-	Electronic Refrigerator	-	Tape Measure	CAT 16.52

**METHODS & TECHNICAL PROCEDURES USED**

Parameter	Standard	Technical Procedure
Hydrogen Fluoride	ISO 15713	CAT-TP-10
Total Oxides of Nitrogen	US EPA M7D	CAT-TP-35
Water Vapour	EN 14790	CAT-TP-05
Velocity & Vol. Flow Rate	EN 16911-1 (MID)	CAT-TP-41

**PRELIMINARY STACK SURVEY: CALCULATIONS**

**General Stack Details**

Stack Details (from Traverse)	Units	Value
Stack Diameter / Depth, D	m	1.50
Stack Width, W	m	-
Stack Area, A	m <sup>2</sup>	1.77
Average Stack Gas Temperature, T <sub>a</sub>	°C	24.0
Average Stack Gas Pressure	Pa	64.8
Average Stack Static Pressure, P <sub>static</sub>	kPa	0.05
Average Barometric Pressure, P <sub>b</sub>	kPa	101.0
Average Pitot Tube Calibration Coefficient, C <sub>p</sub>	-	0.84

**Stack Gas Composition & Molecular Weights**

Component	Conc ppm	Conc Dry % v/v	Conc Wet % v/v	Volume Fraction r	Molar Mass M	Density kg/m <sup>3</sup> ρ	Conc kg/m <sup>3</sup> p <sub>i</sub>
CO <sub>2</sub> (Estimated)	-	0.06	0.06	0.0006	44.01	1.9635	0.0012
O <sub>2</sub> (Estimated)	-	20.80	20.15	0.2080	32.00	1.4277	0.2970
N <sub>2</sub>	-	79.14	76.66	0.7914	28.01	1.2498	0.9891
Moisture (H <sub>2</sub> O)	-	-	3.14	0.0314	18.02	0.8037	0.0252

Where:  $\rho = M / 22.41$   
 $p_i = r \times \rho$

**Calculation of Stack Gas Densities**

Determinand	Units	Result
Dry Density (STP), P <sub>STD</sub>	kg/m <sup>3</sup>	1.2873
Wet Density (STP), P <sub>STW</sub>	kg/m <sup>3</sup>	1.2721
Dry Density (Actual), P <sub>Actual</sub>	kg/m <sup>3</sup>	1.1803
Average Wet Density (Actual), P <sub>ActualW</sub>	kg/m <sup>3</sup>	1.1664

Where: P<sub>STD</sub> = sum of component concentrations, kg/m<sup>3</sup> (not including water vapour)  
P<sub>STW</sub> = sum of all wet concentrations / 100 x density, kg/m<sup>3</sup> (including water vapour)  
 $P_{Actual} = P_{STD} \times (T_{STP} / (P_{STP})) \times ((P_{static} + P_b) / T_a)$   
 $P_{ActualW} \text{ (at each sampling point)} = P_{STW} \times (T_s / P_s) \times (P_a / T_a)$

**Calculation of Stack Gas Volumetric Flowrate, Q**

Duct gas flow conditions	Units	Actual	REF <sup>1</sup>
Temperature	°C	24.0	0.00
Total Pressure	kPa	101.1	101.3
Moisture	%	3.14	3.14

Gas Volumetric Flowrate (from Traverse)	Units	Result
Gas Volumetric Flowrate (Actual)	m <sup>3</sup> /hr	55676
Gas Volumetric Flowrate (STP, Wet)	m <sup>3</sup> /hr	51051
Gas Volumetric Flowrate (STP, Dry)	m <sup>3</sup> /hr	49448
Gas Volumetric Flowrate REF <sup>1</sup>	m <sup>3</sup> /hr	51051

**PRELIMINARY STACK SURVEY: VELOCITY TRAVERSE TO EN 16911-1 (MID)**

(1 of 1)

Parameter	Units	Value
Date of Survey	-	27/02/2019
Time of Survey	-	13:00 - 13:15
Atmospheric Pressure	kPa	101.0
Average Stack Static Pressure	Pa	50
Result of Pitot Stagnation Test	-	Pass
Are Water Droplets Present?	-	No
Device Used	S-Type Pitot with KIMO MP 200 (500Pa)	

Parameter	Units	Value
Initial Pitot Leak Check	-	Pass
Final Pitot Leak Check	-	Pass
Orientation of Duct	-	Vertical
Pitot Tube, C <sub>p</sub>	-	0.84
Number of Lines Available	-	2
Number of Lines Used	-	2

Traverse Point	Depth m	ΔP Pa	Sampling Line A				Swirl °	Sampling Line B			
			Temp °C	Wet Density kg/m <sup>3</sup>	Velocity m/s	ΔP Pa		Temp °C	Wet Density kg/m <sup>3</sup>	Velocity m/s	Swirl °
<i>STATIC (Units: Pa)</i>		39.0					61.0				
<b>Mean</b>		<b>50.0</b>	<b>23.8</b>	<b>1.167</b>	<b>7.74</b>		<b>79.5</b>	<b>24.3</b>	<b>1.165</b>	<b>9.77</b>	
1	0.10	60.0	23.0	1.170	8.49		90.0	24.0	1.166	10.41	
2	0.38	55.0	24.0	1.166	8.14		90.0	24.0	1.166	10.41	
3	1.13	43.0	24.0	1.166	7.20		75.0	24.0	1.166	9.51	
4	1.40	42.0	24.0	1.166	7.11		63.0	25.0	1.162	8.73	

**PRELIMINARY STACK SURVEY: VELOCITY TRAVERSE TO EN 16911-1 (MID) - MEASUREMENT UNCERTAINTY**

(1 of 1)

Performance characteristics (Uncertainty Components)	Uncertainty	Value	Units
Standard Uncertainty on the coefficient of the Pitot Tube	$u(k)$	0.005	-
Standard Uncertainty associated with the mean local dynamic pressures	$u(\Delta p_i)$	1.254	Pa
- Resolution	$u(res)$	0.00087	
- Calibration	$u(cal)$	0.437	
- Drift	$u(drift)$	0.083	
- Lack of Fit	$u(fit)$	0.053	
- Overall corrections to dynamic measurements	$u(C_f)$	0.573	
Standard uncertainty associated with the molar mass of the gas	$u(M)$	0.00003	-
- $\phi_{O_2,w}$	-	20.147	
- $\phi_{CO_2,w}$	-	0.058	
- Oxygen, dry	$u(\phi_{O_2,d})$	0.637	
- Carbon Dioxide, dry	$u(\phi_{CO_2,d})$	0.002	
- Water Vapour	$u(\phi_{H_2O})$	0.160	
- Oxygen, wet	$u(\phi_{O_2,w})$	0.618	
- Carbon Dioxide, wet	$u(\phi_{CO_2,w})$	0.002	
Standard uncertainty associated with the stack temperature	$u(T_c)$	1.515	K
Standard uncertainty associated with the absolute pressure in the duct	$u(p_c)$	175.694	Pa
- Atmospheric Pressure	$u(p_{atm})$	175.692	
- Static Pressure	$u(p_{stat})$	0.887	
Standard uncertainty associated with the density in the duct	$u(\rho)$	0.00629	-
Standard uncertainty associated with the local velocities	$u(v_i)$	0.096	Pa
Standard uncertainty associated with the mean velocity	$u(\bar{v})$	0.049	m/s
Standard uncertainty associated with the mean velocity (95% Confidence)	$U_c(v)$	0.097	m/s
Standard uncertainty associated with the mean velocity (95% Confidence), relative	$U_{c,rel}(v)$	1.10	%
Standard uncertainty associated with the volume flow rate (95% Confidence)	$U_c(qV,w)$	2594.0	m <sup>3</sup> /hr
- $u^2(a)/a^2$	-	0.00053	
- $u^2(qV,w)/q^2V,w$	-	0.00057	
- $u^2(qV,w)$	-	1751621	
- $u(qV,w)$	-	1323.5	
Standard uncertainty associated with the volume flow rate (95% Confidence), relative	$U_{c,rel}(qV,w)$	4.66	%

## HYDROGEN FLUORIDE: RESULTS SUMMARY

Meggitt Aircraft Braking Systems, Coventry  
Plating Shop Main Stack

### Sample Runs

Parameter	Units	Run 1	Mean
Concentration	mg/m <sup>3</sup>	< 0.049	< 0.049
Uncertainty	±mg/m <sup>3</sup>	0.003	0.003
Mass Emission	g/hr	< 2.49	< 2.49
Uncertainty	±g/hr	0.20	0.20

Parameter	Units	Run 1	Mean
Water Vapour	% v/v	3.14	3.14
Uncertainty	±% v/v	0.16	0.16

NOTE: Where water droplets are present (See the Quality Assurance page), the Water Vapour concentration as found in Annex A of EN 14790 has been reported instead of the calculated value.

### Blank Runs

Parameter	Units	Blank 1	Maximum
Concentration	mg/m <sup>3</sup>	< 0.031	< 0.031

### General Sampling Information

Parameter	Value
Standard	ISO 15713
Technical Procedure	CAT-TP-10
Name of Analytical Laboratory	CAT
Analytical Laboratory's Procedure	CAT-AP-01
ISO 17025 Accredited Analysis?	Yes
Date of Sample Analysis	04/03/2019
Probe Material	Monel
Filter Housing Material	Monel
Impinger Material	Polyethylene
Absorption Solution	0.1 mol/l Sodium Hydroxide
Positioning of Filter	In Stack
Filter Size and Material	47mm Quartz Fibre
Number of Sampling Lines Used	1 / 1
Number of Sampling Points Used	1 / 1
Sample Point I.D.'s	A3

FORMAT: Number Used / Number Required

### Reference Conditions

Reference Conditions are: 273K, 101.3kPa, without correction for water vapour content.

## HYDROGEN FLUORIDE: SAMPLING DETAILS

### Sample Runs

Parameter	Units	Run 1
Sampling Times	-	11:50 - 12:50
Sampling Dates	-	27/02/2019
Sampling Device	-	MFC / MV
Duration	mins	60
Volume Sampled (STP, Dry)	m <sup>3</sup>	0.3347
Volume Sampled (STP, Wet)	m <sup>3</sup>	0.3455
Volume Sampled (REF)	m <sup>3</sup>	0.3455
Sample Flow Rate	l/min	5.58
Laboratory Result for Front Impingers	µg/ml	< 0.05
Laboratory Result for Back Impinger	µg/ml	< 0.05
Volume in Front Impingers	ml	235.9
Volume in Back Impinger	ml	100.5
Mass in Front Impingers	µg	< 11.8
Mass in Back Impinger	µg	< 5.0
Total Mass Collected	µg	< 16.8
Calculated Concentration	mg/m <sup>3</sup>	< 0.05
Liquid Trap Start Mass	g	1260.3
Liquid Trap End Mass	g	1274.6
Silica Trap Start Mass	g	460.7
Silica Trap End Mass	g	464.4
Total Mass Of Water Vapour	g	18.0
Calculated Water Vapour	% v/v	6.28

**Where:** MFC stands for Mass Flow Controller, MV stands for Mass View Flowmeter

### Blank Runs

Parameter	Units	Blank 1
Blank Dates	-	27/02/2019
Average Volume Sampled (REF)	m <sup>3</sup>	0.3455
Laboratory Result for Impingers	µg/ml	< 0.05
Volume in Impingers	ml	217.4
Total Mass Collected	µg	< 10.9
Calculated Concentration	mg/m <sup>3</sup>	< 0.03



## HYDROGEN FLUORIDE: QUALITY ASSURANCE

### Sample Runs

Leak Test Results	Units	Run 1
Mean Sampling Rate	l/min	5.58
Pre-Sampling Leak Rate	l/min	0.04
Post-Sampling Leak Rate	l/min	0.05
Allowable Leak Rate	l/min	0.11
Leak Test Acceptable	-	Yes

Absorption Efficiency	Units	Run 1
Absorption Efficiency	%	100.0
Allowable Absorption Efficiency	%	N/A <sup>2</sup>
Absorption Efficiency Acceptable	-	Yes <sup>2</sup>

<sup>2</sup> The concentration is less than 30% of the ELV, therefore no assessment against an allowable efficiency is required.

Water Droplets	Units	Run 1
Are Water Droplets Present	-	Yes

MU (Concurrent Water Vapour)	Units	Run 1
Measurement Uncertainty (MU)	%	5.0
Allowable MU	%	20.0
MU Acceptable	%	Yes

Silica Gel (Concurrent Water Vapour)	Units	Run 1
Less than 50% Faded	%	Yes

Test Conditions	Units	Run 1
Ambient Temperature Recorded?	-	Yes

### Blank Runs

Leak Test Results	Units	Blank 1
Expected Sampling Rate	l/min	5.00
Pre-Sampling Leak Rate	l/min	0.08
Post-Sampling Leak Rate	l/min	0.08
Allowable Leak Rate	l/min	0.10
Leak Test Acceptable	-	Yes

Validity of Blank vs ELV	Units	Blank 1
Allowable Blank	mg/m <sup>3</sup>	0.50
Blank Acceptable	-	Yes

### Method Deviations

Nature of Deviation	Run Number	
	(x = deviation applies to the associated run, wx = deviation also applies to the concurrent water vapour run)	1
There are no deviations associated with the sampling employed.	wx	

**HYDROGEN FLUORIDE: MEASUREMENT UNCERTAINTY CALCULATIONS**

Measured Quantities	Value		Standard uncertainty		
	Symbol	Run 1	Symbol	Units	Run 1
Sampled Volume (STP)	V <sub>m</sub>	0.33	uV <sub>m</sub>	m <sup>3</sup>	0.01
Leak	L	0.90	uL	%	-
Laboratory Result	L <sub>r</sub>	2.65	uL <sub>r</sub>	%	-

Measured Quantities	Uncertainty as a Percentage		Requirement of Standard
	Units	Run 1	
Sampled Volume (STP)	%	2.00	≤2%
Leak	%	0.90	≤2%
Laboratory Result	%	2.65	No Requirement

Measured Quantities	Uncertainty in Measurement Units			Sensitivity Coefficient
	Symbol	Units	Run 1	
Sampled Volume (STP)	V <sub>m</sub>	m <sup>3</sup>	0.33	0.15
Leak	L	mg/m <sup>3</sup>	0.000	1.00
Laboratory Result	L <sub>r</sub>	mg/m <sup>3</sup>	0.001	1.00

Measured Quantities	Uncertainty in Result	
	Units	Run 1
Sampled Volume (STP)	mg/m <sup>3</sup>	0.001
Leak	mg/m <sup>3</sup>	0.000
Laboratory Result	mg/m <sup>3</sup>	0.001

Measured Quantities	Oxygen Correction Part of MU Budget	
	Units	Run 1
O <sub>2</sub> Correction Factor	-	N/A
Stack Gas O <sub>2</sub> Content	% v/v	N/A
MU for O <sub>2</sub> Correction	-	N/A
Overall MU For O <sub>2</sub> Measurement	%	N/A

Parameter	Units	Run 1
Combined uncertainty	mg/m <sup>3</sup>	0.002
Expanded uncertainty (95% confidence), without Oxygen Correction	mg/m <sup>3</sup>	0.003
Expanded uncertainty (95% confidence), with Oxygen Correction	mg/m <sup>3</sup>	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	mg/m <sup>3</sup>	0.003
Reported Uncertainty	mg/m <sup>3</sup>	0.003
Expanded uncertainty (95% confidence), without Oxygen Correction	%	6.6
Expanded uncertainty (95% confidence), with Oxygen Correction	%	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	%	6.6
Reported Uncertainty	%	6.6

## TOTAL OXIDES OF NITROGEN: RESULTS SUMMARY

Meggitt Aircraft Braking Systems, Coventry  
Plating Shop Main Stack

### Sample Runs

Parameter	Units	Run 1	Mean
Concentration	mg/m <sup>3</sup>	< 5.64	< 5.64
Uncertainty	±mg/m <sup>3</sup>	1.13	1.13
Mass Emission	g/hr	< 288	< 288
Uncertainty	±g/hr	59.1	59.1

Parameter	Units	Run 1	Mean
Water Vapour	% v/v	3.14	3.14
Uncertainty	±% v/v	0.16	0.16

NOTE: Where water droplets are present (See the Quality Assurance page), the Water Vapour concentration as found in Annex A of EN 14790 has been reported instead of the calculated value.

### Blank Runs

Parameter	Units	Blank 1	Maximum
Concentration	mg/m <sup>3</sup>	< 3.50	< 3.50

### General Sampling Information

Parameter	Value
Standard	US EPA M7D
Technical Procedure	CAT-TP-35
Name of Analytical Laboratory	RPS
Analytical Laboratory's Procedure	C27
ISO 17025 Accredited Analysis?	Yes
Date of Sample Analysis	08/03/2019
Probe Material	Stainless Steel
Filter Housing Material	Borosilicate Glass
Impinger Material	Borosilicate Glass
Absorption Solution	Potassium Permanganate Solution
Positioning of Filter	Out Stack
Filter Size and Material	47mm Quartz Fibre
Number of Sampling Lines Used	1 / 1
Number of Sampling Points Used	1 / 1
Sample Point I.D.'s	B3

FORMAT: Number Used / Number Required

### Reference Conditions

Reference Conditions are: 273K, 101.3kPa, without correction for water vapour content.

**TOTAL OXIDES OF NITROGEN: SAMPLING DETAILS**

**Sample Runs**

Parameter	Units	Run 1
Sampling Times	-	11:50 - 12:50
Sampling Dates	-	27/02/2019
Sampling Device	-	MFC / MV
Duration	mins	60
Volume Sampled (STP, Dry)	m <sup>3</sup>	0.0277
Volume Sampled (STP, Wet)	m <sup>3</sup>	0.0286
Volume Sampled (REF)	m <sup>3</sup>	0.0286
Sample Flow Rate	l/min	0.46
Laboratory Result for Front Impingers	µg/ml	< 0.25
Laboratory Result for Back Impinger	µg/ml	< 0.25
Volume in Front Impingers	ml	434.0
Volume in Back Impinger	ml	212.6
Mass in Front Impingers	µg	< 108.5
Mass in Back Impinger	µg	< 53.2
Total Mass Collected	µg	< 161.7
Calculated Concentration	mg/m <sup>3</sup>	< 5.64
Liquid Trap Start Mass	g	2755.1
Liquid Trap End Mass	g	2657.8
Silica Trap Start Mass	g	761.2
Silica Trap End Mass	g	859.9
Total Mass Of Water Vapour	g	1.4
Calculated Water Vapour	% v/v	5.92

**Where:** MFC stands for Mass Flow Controller, MV stands for Mass View Flowmeter

**Blank Runs**

Parameter	Units	Blank 1
Blank Dates	-	27/02/2019
Average Volume Sampled (REF)	m <sup>3</sup>	0.0286
Laboratory Result for Impingers	µg/ml	< 0.25
Volume in Impingers	ml	400.9
Total Mass Collected	µg	< 100.2
Calculated Concentration	mg/m <sup>3</sup>	< 3.50

**TOTAL OXIDES OF NITROGEN: QUALITY ASSURANCE**

**Sample Runs**

Leak Test Results	Units	Run 1
Mean Sampling Rate	l/min	0.46
Pre-Sampling Leak Rate	l/min	0.00
Post-Sampling Leak Rate	l/min	0.00
Allowable Leak Rate	l/min	0.01
Leak Test Acceptable	-	Yes

Absorption Efficiency	Units	Run 1
Absorption Efficiency	%	100.0
Allowable Absorption Efficiency	%	N/A
Absorption Efficiency Acceptable	-	N/A

Water Droplets	Units	Run 1
Are Water Droplets Present	-	Yes

MU (Concurrent Water Vapour)	Units	Run 1
Measurement Uncertainty (MU)	%	5.0
Allowable MU	%	20
MU Acceptable	%	Yes

Silica Gel (Concurrent Water Vapour)	Units	Run 1
Less than 50% Faded	%	Yes

Test Conditions	Units	Run 1
Ambient Temperature Recorded?	-	Yes

**Blank Runs**

Leak Test Results	Units	Blank 1
Expected Sampling Rate	l/min	0.50
Pre-Sampling Leak Rate	l/min	0.00
Post-Sampling Leak Rate	l/min	0.00
Allowable Leak Rate	l/min	0.01
Leak Test Acceptable	-	Yes

Validity of Blank vs ELV	Units	Blank 1
Allowable Blank	mg/m <sup>3</sup>	20.0
Blank Acceptable	-	Yes

**Method Deviations**

Nature of Deviation	Run Number
(x = deviation applies to the associated run, wx = deviation also applies to the concurrent water vapour run)	1
There are no deviations associated with the sampling employed.	wx

**TOTAL OXIDES OF NITROGEN: MEASUREMENT UNCERTAINTY CALCULATIONS**

Measured Quantities	Value		Standard uncertainty		
	Symbol	Run 1	Symbol	Units	Run 1
Sampled Volume (STP)	V <sub>m</sub>	0.03	uV <sub>m</sub>	m <sup>3</sup>	0.001
Leak	L	0.00	uL	%	-
Laboratory Result	L <sub>r</sub>	10.0	uL <sub>r</sub>	%	-

Measured Quantities	Uncertainty as a Percentage		Requirement of Standard
	Units	Run 1	
Sampled Volume (STP)	%	2.00	≤2%
Leak	%	0.00	≤2%
Laboratory Result	%	10.0	No Requirement

Measured Quantities	Uncertainty in Measurement Units			Sensitivity Coefficient
	Symbol	Units	Run 1	
Sampled Volume (STP)	V <sub>m</sub>	m <sup>3</sup>	0.03	203
Leak	L	mg/m <sup>3</sup>	0.00	1.00
Laboratory Result	L <sub>r</sub>	mg/m <sup>3</sup>	0.56	1.00

Measured Quantities	Uncertainty in Result	
	Units	Run 1
Sampled Volume (STP)	mg/m <sup>3</sup>	0.11
Leak	mg/m <sup>3</sup>	0.00
Laboratory Result	mg/m <sup>3</sup>	0.56

Measured Quantities	Oxygen Correction Part of MU Budget	
	Units	Run 1
O <sub>2</sub> Correction Factor	-	N/A
Stack Gas O <sub>2</sub> Content	% v/v	N/A
MU for O <sub>2</sub> Correction	-	N/A
Overall MU For O <sub>2</sub> Measurement	%	N/A

Parameter	Units	Run 1
Combined uncertainty	mg/m <sup>3</sup>	0.58
Expanded uncertainty (95% confidence), without Oxygen Correction	mg/m <sup>3</sup>	1.13
Expanded uncertainty (95% confidence), with Oxygen Correction	mg/m <sup>3</sup>	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	mg/m <sup>3</sup>	1.13
Reported Uncertainty	mg/m <sup>3</sup>	1.13
Expanded uncertainty (95% confidence), without Oxygen Correction	%	20.0
Expanded uncertainty (95% confidence), with Oxygen Correction	%	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	%	20.0
Reported Uncertainty	%	20.0