

Our Ref: P-RED14-001/EB/R1/Rev0
Client Ref:

27th April 2015

Ian Livingston
Terex United Kingdom Limited
Central Boulevard
Prologis Park
Coventry
CV6 4BX

Dear Ian

Re: Emissions Monitoring

Please find enclosed a copy of your report for the monitoring carried out during January 2014.

I trust the enclosed is satisfactory but if you have any questions please contact me on the numbers below or directly on 07971 628431.

Yours sincerely

Elena Berek BSc (Hons), MSc, CSci, CChem MRSC
Director



PROJECT TEAM

Project work carried out by:

Elena Berek – Team Leader


Tony Berek – Env Consultant

Vicki Gavin – Env Consultant

Report prepared by:

Elena Berek - Director

Signature:




Date:

16th February 2014

Report reviewed by:

Philip Butler - Director

Signature:




Date:

16th February 2014

Report authorised by:

Philip Butler

Signature:



Date:

16th February 2014



JANUARY 2014

**EMISSIONS MONITORING
REPORT**

**Ian Livingston
Terex United Kingdom Limited
Central Boulevard
Prologis Park
Coventry CV6 4BX**

Tel: 02476 339634

Prepared By

**Redwing Environmental Ltd
Unit 7, Manor Road Business Park
Manor Road
Atherstone
Warwickshire CV9 1TE**

Tel: 0844 686 7000 – Fax: 0844 686 7070

Report Number P-RED14-001/EB/R1/Rev0

16th February 2014



Contents

Contents

Executive Summary

1.0	Introduction	Page 1
1.0	Monitoring Programme	Pages 1 - 2
1.5	Monitoring Results, comparison to emission limits	Pages 3 – 5
2.0	Supporting Info	Page 6
2.1	General Info	Page 6
2.1.1	MCerts information	Page 6
2.2	Methods	Pages 6 – 7
3.0	Quality Assurance	Page 8
4.0	Disclaimer	Page 8
	<i>Appendix A – Particulate, Isocyanate & Velocity Results</i>	Appendix Pages 1 to 35
	<i>Appendix B – VOC Raw Data</i>	Appendix Pages 36 to 40
	<i>Appendix C – VOC Charts</i>	Appendix Pages 41 to 45
	<i>Calibration Certificates are available upon request</i>	



EXECUTIVE SUMMARY (Page 1 of 1)

The following document details the emissions to air monitoring survey undertaken by Elena Berek, Vicki Gavin and Tony Berek of Redwing Environmental Ltd at Terex United Kingdom Limited on the 22nd and 23rd January 2014.

All results pertain to the dates monitored only.

A summary of results is shown below:-

Emission point reference Stack N°	Total Particulate Matter at reference conditions (mg/m ³)	* Highest 30 minute mean VOC at reference conditions (mg/m ³)	Isocyanate Concentration at reference conditions (mg/m ³)	Velocity corrected to reference conditions (m/s)	Volume flow corrected to reference conditions (m ³ /hr)
Primer Spray Booth 1	0.52 ± 0.14	--	--	7.4	53,883
Primer Spray Booth 2	1.28 ± 0.25	--	--	7.7	55,712
Primer Flash-off	0.54 ± 0.14	--	--	8.2	14,906
Topcoat Spray Booth 1	0.93 ± 0.13	--	<0.02	6.4	46,099
Topcoat Spray Booth 2	1.02 ± 0.13	--	<0.02	7.0	50,748
Topcoat Flash-off	0.19 ± 0.13	--	<0.02	11.7	33,013
Topcoat Curing Oven	0.62 ± 0.13	--	<0.02	12.3	89,113
Preparation Booth 1	0.95 ± 0.24	--	--	12.3	17,073
Preparation Booth 2	0.35 ± 0.14	--	--	12.3	17,007
Spray Bake Booth 1	--	--	<0.02	12.5	22,677
Spray Bake Booth 2	--	--	<0.02	12.2	22,041
Scissor 1 Booth 1	0.59 ± 0.15	30.9 ± 1.6 (26.2)	--	8.6	11,950
Scissor 1 Booth 2	0.52 ± 0.14	16.4 ± 0.7 (12.0)	--	8.9	12,292
Scissor 1 Oven	0.91 ± 0.29	--	--	6.7	755
Scissor 2 Booth 1	1.12 ± 0.27	36.6 ± 1.7 (28.9)	--	7.9	10,891
Scissor 2 Booth 2	0.86 ± 0.13	23.0 ± 1.3 (21.7)	--	7.7	10,699
Scissor 2 Oven	1.10 ± 0.30	--	--	5.5	627

* Figure in brackets represent the average VOC for the duration of the monitoring

NOTE 1: Reference conditions are standard Temperature (273K) and standard pressure (101.3kPa), without correction for water vapour



1.0 INTRODUCTION

1.1 The exhausts listed below were monitored with respect to quotation **Q-RED14-001/EB/v0** for the compliance check monitoring of emissions to air. The substances requested for monitoring at each emission point are listed below:

Monitoring Programme

Stack reference/Proposed method	Total Particulate Matter BS EN 13284	Volatile Organic Compounds BS EN 13526	Isocyanates USEPA CTM36
Main Paint Facility			
Primer spray booth - 1	✓	x	x
Primer spray booth – 2	✓	x	x
Primer Flash off	✓	x	x
Topcoat Spray booth -1	✓	x	✓
Topcoat spray booth – 2	✓	x	✓
Topcoat Flash off	✓	x	✓
Topcoat Curing Oven	✓	x	✓
Preparation Booth 1	✓	x	x
Preparation Booth 2	✓	x	x
Spray Bake Booth 1	x	x	✓
Spray Bake Booth 2	x	x	✓
Scissor 1 Booth 1	✓	✓	x
Scissor 1 Booth 2	✓	✓	x
Scissor 1 Oven	✓	x	x
Scissor 2 Booth 1	✓	✓	x
Scissor 2 Booth 2	✓	✓	x
Scissor 2 Oven	✓	x	x

1.2 Terex United Kingdom Limited operate a metal and plastic coating process at their site in Coventry, the process is governed by the Secretary of States Process Guidance Note PG6/23 – Coating of Metal and Plastic.



1.3 The emission limits are listed below:

Process Guidance Note PG6/23: Coating of Metal and Plastic

EMISSION LIMITS

ANALYTE	TOTAL PARTICULATE	TOTAL VOC	TOTAL ISOCYANATES
Emission Limit	50 mg/m ³	150 mg/m ³	0.1mg/m ³

1.4 The velocity and temperature profile were within the required parameters of 3:1 metres/second and $\pm 1\%$ for temperature profile. This information indicates that the sample ports are in ideal positions to collect the samples under representative conditions.



1.5 Monitoring Results

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Operating Status
Primer Spray Booth 1	Total Particulate Matter	50	0.52 ± 0.14	mg/m ³	273K, 101.3kPa	22/01/14	1140 – 1240	BS EN 13284-1	Normal
Primer Spray Booth 2	Total Particulate Matter	50	1.28 ± 0.25	mg/m ³	273K, 101.3kPa	22/01/14	1245 – 1345	BS EN 13284-1	Normal
Primer Flash-off	Total Particulate Matter	50	0.54 ± 0.14	mg/m ³	273K, 101.3kPa	23/01/14	1255 – 1355	BS EN 13284-1	Normal
Top Coat Spray Booth 1	Total Particulate Matter	50	0.93 ± 0.13	mg/m ³	273K, 101.3kPa	23/01/14	0947 – 1047	BS EN 13284-1	Normal
	Isocyanates	0.1	<0.02	mg/m ³		23/01/14	0845 – 0945	USEPA 36	
Top Coat Spray Booth 2	Total Particulate Matter	50	1.02 ± 0.13	mg/m ³	273K, 101.3kPa	23/01/14	1152 – 1252	BS EN 13284-1	Normal
	Isocyanates	0.1	<0.02	mg/m ³		23/01/14	1050 - 1150	USEPA 36	



Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Operating Status
Topcoat Flash-off	Total Particulate Matter	50	0.19 ± 0.13	mg/m ³	273K, 101.3kPa	22/01/14	0930 -1030	BS EN 13284-1	Normal
	Isocyanates	0.1	<0.02	mg/m ³		22/01/14	1035 – 1135	USEPA 36	
Topcoat Curing Oven	Total Particulate Matter	50	0.62 ± 0.13	mg/m ³	273K, 101.3kPa	22/01/14	1400 – 1500	BS EN 13284-1	Normal
Preparation Booth 1	Total Particulate Matter	50	0.95 ± 0.24	mg/m ³	273K, 101.3kPa	22/01/14	0925 – 1025	BS EN 13284-1	Normal
Preparation Booth 2	Total Particulate Matter	50	0.35 ± 0.14	mg/m ³	273K, 101.3kPa	22/01/14	1135 – 1235	BS EN 13284-1	Normal
Spray Bake Booth 1	Isocyanates	0.1	<0.02	mg/m ³	273K, 101.3kPa	22/01/14	1030 – 1130	USEPA 36	Normal
Spray Bake Booth 2	Isocyanates	0.1	<0.02	mg/m ³	273K, 101.3kPa	22/01/14	1240 – 1340	USEPA 36	Normal
Scissor 1 Booth 1	Total Particulate Matter	50	0.59 ± 0.15	mg/m ³	273K, 101.3kPa	23/01/14	0850 – 0950	BS EN 13284-1	Normal
	Volatile Organic Compounds	150	30.9 ± 1.6	mg/m ³			1000 - 1100	BS EN 12619	
Scissor 1 Booth 2	Total Particulate Matter	50	0.52 ± 0.14	mg/m ³	273K, 101.3kPa	23/01/14	0850 - 0950	BS EN 13284-1	Normal
	Volatile Organic Compounds	150	16.4 ± 0.7	mg/m ³			1102 - 1202	BS EN 12619	



Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Operating Status
Scissor 1 Oven	Total Particulate Matter	50	0.91 ± 0.29	mg/m ³	273K, 101.3kPa	23/01/14	1302 – 1402	BS EN 13284-1	Normal
Scissor 2 Booth 1	Total Particulate Matter	50	1.12 ± 0.27	mg/m ³	273K, 101.3kPa	23/01/14	1055 – 1155	BS EN 13284-1	Normal
	Volatile Organic Compounds	150	36.6 ± 1.7	mg/m ³			1210 – 1310	BS EN 13526	Normal
Scissor 2 Booth 2	Total Particulate Matter	50	0.86 ± 0.13	mg/m ³	273K, 101.3kPa	23/01/14	1200 – 1300	BS EN 13284-1	Normal
	Volatile Organic Compounds	150	23.0 ± 1.3	mg/m ³			1350 – 1450	BS EN 13526	Normal
Scissor 2 Oven	Total Particulate Matter	50	1.10 ± 0.30	mg/m ³	273K, 101.3kPa	23/01/14	1405 - 1505	BS EN 13284-1	Normal



2 Supporting Information (Held by Redwing Environmental Ltd)

2.1 General Information

2.1.1 Redwing Environmental Ltd staff details

Elena Berek
Vicki Gavin
Tony Berek

2.2 Redwing Environmental Ltd method details

2.2.1 Volatile organic compounds (BS EN 12619: 2013)

2.2.2 Monitoring to determine VOC emission concentrations was in accordance with BS EN 12619: 2013.

2.2.3 Volatile organic compound concentrations were measured using a Signal portable heated VOC analyser. The analyser works by burning the gas sample in a hydrogen flame. This ionises any organic compounds present and the current produced across an electric field is proportional to the number of carbon atoms.

2.2.4 The analyser and heated line were zeroed and calibrated with a test gas (80 ppm and or 800ppm propane) prior to each sampling run. VOC sampling was undertaken over a period of at least 60 minutes to cover any process variation.

2.2.5 All data was logged onto a Grant Squirrel data logger set at 5 second logging.

2.2.6 A heated line from the sample point to analyser was used to ensure that condensation did not occur leading to the loss of sample concentration. Volatile organic compounds.

2.3 Stack Velocity, Pressure and Temperature Measurements

2.3.1 The stack velocity, pressure and temperature will be measured by full pitot traverses of the duct using the points provided. Measurements will be taken at the relevant positions based on the particulate standard followed.

2.4 Leak tests for extractive techniques

2.4.1 All extractive-sampling techniques were tested for leaks before sampling proceeded. Any leaks present were eliminated prior to sampling and will be reported.

2.4.2 Leak checks are carried out during the calibrating procedure, as the concentration of the calibration gas is known it is readily indentified if air is entering the sample line and diluting the gas.



2.5 Particulate matter BS EN 13284-1: 2002

- 2.5.1 Total particulate matter was sampled using a Zambelli isokinetic sampling system in accordance with BS EN 13284-1: 2002 – Determination of Low Range Mass Concentration of dust (< 50mg/m³).
- 2.5.2 The Zambelli sampling system monitors temperature, static pressure and velocities within the duct using an S-type pitot tube and K-type thermocouple. The sampling rate was continuously monitored and adjusted relative to the duct velocity to ensure isokinetic-sampling conditions were maintained throughout the monitoring period.
- 2.5.3 Exhaust gases were drawn under isokinetic conditions from the exhaust points using the Zambelli sampling probe, particulate matter was then collected on a pre-weighed glass fibre filter (or most suitable filter for process) contained within the filter cassette holder, and the total particulate matter determined gravimetrically.
- 2.5.4 It is also necessary to wash the probe and nozzle out with water and then acetone between sampling and the weight of the probe washing added to that collected on the sample filter. Analysis of an acetone/water blank will be carried out and the result corrected accordingly.
- 2.5.5 The sample positions were calculated with respect to BS EN 13284-1: 2002 – Stationary source emissions – Determination of Low Range Mass Concentration of dust.
- 2.5.6 Sampling may be carried out internally or externally, the method used will be reported and provided there are no deviations from the method the uncertainty for the monitoring procedure is reported to be within the requirements specified by the Hazardous Waste Directive (HWD) as stated in the Environment Agency Technical Document M2
- Uncertainty: ± 30%
- 2.5.7 ISO 9096: 2003 and BS EN 13284-1: 2002 are very similar methods but BS EN 13284-1: 2002 recommends the use of an 8mm nozzle and nozzles less than 6mm should not be used.

2.6 Isocyanates (USEPA CTM 36a)

- 2.6.1 There are several Isocyanates; these include TDI, MDI, HDI and IPDI. The isocyanate to be monitored is HDI (1,6 – hexamethylene diisocyanate). All Isocyanates follow the same procedure for sampling and analysis.
- 2.6.2 Isocyanates can be sampled non-isokinetically following MDHS 25 or isokinetically following the USEPA CTM 36
- 2.6.3 The method used was isokinetic method. A sample probe was placed inside the stack; the sample probe was heated.



2.6.4 The samples are stored in brown glass bottles and submitted for analysis. The samples will be 'blown down' to dryness using air and made upto 1ml using the most suitable matrix (usually acetonitrile). The sample will then be ready for analysis by HPLC (High Pressure Liquid Chromatography).

3.0 Quality Assurance

3.1 Redwing Environmental Ltd will always endeavour to follow the methods specified in the Environment Agency Technical Guidance M2. Redwing Environmental Ltd is a member of the Source Testing Association (STA) and therefore operates under the STA's code of practice.

3.2 Redwing Environmental Ltd is accredited to ISO 9001:2008, ISO 14001:2004 and ISO 17025:2005.

4.0 Disclaimer

4.1 Redwing Environmental Ltd confirms that in preparing this report all reasonable skill and care has been exercised.

4.1.1 Unless specifically assigned or transferred within the terms of the agreement, Redwing Environmental Ltd asserts and retains all copyright, and other Intellectual Property Rights, in and over the report and its contents.



APPENDIX A

Particulate, Isocyanate & Velocity Results



Client	Terex							
Site Address	Coventry							
Job Number	P-RED14-001							
Date	22nd January 2014							
Operator(s)	Vicki Gavin & Tony Berek							
Stack Reference	primer booth 1			Isokinetic Sample Positions (%) multiply by diameter to obtain sample points		Sampling Plane Diagram		
Number of Stacks	1			1	6.70			
Stack Configuration	Round			2	25.00			
Dimensions (mtrs)	1.60			3	75.00			
Outlet Diameter (if applicable) (metres)				4	93.30			
Number of Sample Ports	1			5	N/A			
Number of Samples per Axis / Port	4			6	N/A			
Nozzle Diameter (mm)	8.0			7	N/A			
Nozzle Area (m²)	0.00005024			8	N/A			
Stack Area (m²)	2.011			Average Isokinetic Flow Rate (ltrs/min)		Axis 1	Axis 2	
Pitot Coefficient	0.84	Pitot Calibration Due Date			March 2014		21.43	23.45
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test	Atmos. Pressure (kPa)
No.	(cms)	(pa)	(C)	Pass (Y/N)	(pa)	(C)	Pass (Y/N)	100.9
1	10.72	56	18.0	4.0	61	18.0	4	Static Pressure (pa)
2	40.00	43	18.0	3.0	44	18.0	4	-17.0
3	120.00	32	18.0	3.0	37	18.0	4	1 Axis
4	149.28	42	18.0	4.0	65	18.0	4	2 Axis
5	N/A							Velocity of flow (m/s)
6	N/A							7.11
7	N/A							7.78
8	N/A							Volume Flow Rate (m³/s)
Averages		43	18.0		52	18.0		14.30
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2 + 273) =$								291.00
Range of gas temperature readings $\pm 5\%$ ($^{\circ}\text{C}$) $= (0.95T_p - 273)$ to $(1.05T_p - 273) =$								3.45 to 32.55
Highest Velocity Reading (m/s)								9.0
Lowest Velocity Reading (m/s)								6.1
Ratio Highest/Lowest (Max permitted = 3:1)								1.47 : 1
On site Checklist								
Range of Gas Temps	OK			Manometer Leak Check			OK	
Initial Leak Check	<0.2	Final leak check	<0.2	Pitot Leak Check			OK	
Acceptable Leak Check < 2% Vol (l/min)	0.43			Overall Isokinetic Ratio (%) (must be 95 to 115%)			Run 1	Run 2
Passed minimum Velocity requirements (>5pa)	YES						102.9	N/A
Negative Local Flow Present, YES or NO (Yes = Fail)	NO			Are there sufficient rails and kick board? (YES, NO or N/A)			YES	
Is the Platform area greater than 5m²? (YES, NO or N/A)	YES			Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)			YES	
Passed Highest to lowest Velocity (3:1)	YES							
Site Equipment Used								
Pitot Reference	RED 0237			Manometer Reference			RED 0400	
Thermometer Reference	RED 0354			Thermocouple Reference			RED 0344	
Balance Reference				Sampling Pump Reference			RED 0385	
Tape Measure Reference	RED 0123			Barometer Reference			RED 0402	



Stack Reference ID		primer booth 1		
	Terex			
	RUN 1			
Filter Reference No	G47-200114-03			
Date	22nd January 2014			
Sample Period	11:40	to	12:40	
Velocity (m/s)	7.44			
Volumetric flowrate of Stack gas (m ³ /hr)	53883			
Average Stack Temp (°C)	18.0			
Temperature Range - ± 5% (°C)	3.45	to	32.55	
Lowest Velocity Reading (m/s)	6.11			
Highest Velocity Reading (m/s)	8.99			
Ratio (less than 3:1)	1.47	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	18.1			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	18.6			
Carbon Dioxide %	1.40			
Moisture (%)	4.16			
Litres sampled	1450			
Corrected volume sampled - STP (m ³)	1.388			
Blank Filter Run weight gain (mg)	0.000	Blank Concentration (mg/m ³)	0.000	
Blank Wash Run weight gain (mg)	0.040		0.029	
Weighing uncertainty of balance (mg)	0.074	This must be <5% of ELV	ELV = 50	2.5
Overall Blank value (mg/m ³)	0.029	This must be <10% of ELV	ELV = 50	5.0
Particulate weight collected on filter (mg)	0.50			
Particulate weight collected in Wash (mg)	0.25			
Total Particulate weight collected (mg)	0.75			
Total Particulate Concentration, *STP, dry gas (mg/m ³)	0.54			
Total Particulate Concentration, *STP, wet gas (mg/m ³)	0.52			
Total Particulate Concentration corrected for Oxygen, *STP, dry gas (mg/m ³)	N/A			
Total Particulate Mass Emission (kg/hour)	0.027			



Client	Terex							
Site Address	Coventry							
Job Number	P-RED14-001							
Date	22nd January 2014							
Operator(s)	Vicki Gavin & Tony Berek							
Stack Reference	primer booth 1			Isokinetic Sample Positions (%) multiply by diameter to obtain sample points		Sampling Plane Diagram		
Number of Stacks	1			1	6.70			
Stack Configuration	Round			2	25.00			
Dimensions (mtrs)	1.60			3	75.00			
Outlet Diameter (if applicable) (metres)				4	93.30			
Number of Sample Ports	1			5	N/A			
Number of Samples per Axis / Port	4			6	N/A			
Nozzle Diameter (mm)	8.0			7	N/A			
Nozzle Area (m²)	0.00005024			8	N/A			
Stack Area (m²)	2.011			Average Isokinetic Flow Rate (ltrs/min)		Axis 1	Axis 2	
Pitot Coefficient	0.84	Pitot Calibration Due Date			March 2014		22.97	23.43
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test	Atmos. Pressure (kPa)
No.	(cms)	(pa)	(C)	Pass (Y/N)	(pa)	(C)	Pass (Y/N)	100.9
1	10.72	65	17.6	4.0	57	17.6	4	Static Pressure (pa)
2	40.00	45	17.6	5.0	62	17.6	5	-22.0
3	120.00	46	17.7	5.0	45	17.6	5	1 Axis
4	149.28	43	17.6	4.0	43	17.6	4	2 Axis
5	N/A							Velocity of flow (m/s)
6	N/A							7.62
7	N/A							7.77
8	N/A							Volume Flow Rate (m³/s)
Averages		50	17.6		52	17.6		15.32
								15.63
								Reduced Exit
								N/A
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2 + 273) =$								290.61
Range of gas temperature readings $\pm 5\%$ ($^{\circ}\text{C}$) $= (0.95T_p - 273)$ to $(1.05T_p - 273) =$						3.08	to	32.14
Highest Velocity Reading (m/s)								9.0
Lowest Velocity Reading (m/s)								7.1
Ratio Highest/Lowest (Max permitted = 3:1)								1.27 : 1
On site Checklist								
Range of Gas Temps	OK			Manometer Leak Check			OK	
Initial Leak Check	<0.2	Final leak check	<0.2	Pitot Leak Check			OK	
Acceptable Leak Check < 2% Vol (l/min)	0.46			Overall Isokinetic Ratio (%) (must be 95 to 115%)			Run 1	Run 2
Passed minimum Velocity requirements (>5pa)	YES						98.7	N/A
Negative Local Flow Present, YES or NO (Yes = Fail)	NO			Are there sufficient rails and kick board? (YES, NO or N/A)			YES	
Is the Platform area greater than 5m²? (YES, NO or N/A)	YES			Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)			YES	
Passed Highest to lowest Velocity (3:1)	YES							
Site Equipment Used								
Pitot Reference	RED 0237			Manometer Reference			RED 0400	
Thermometer Reference	RED 0354			Thermocouple Reference			RED 0344	
Balance Reference				Sampling Pump Reference			RED 0385	
Tape Measure Reference	RED 0123			Barometer Reference			RED 0402	



Stack Reference ID		primer booth 1		
	Terex			
	RUN 1			
Filter Reference No	G47-200114-05			
Date	22nd January 2014			
Sample Period	12:45	to	13:45	
Velocity (m/s)	7.70			
Volumetric flowrate of Stack gas (m ³ /hr)	55712			
Average Stack Temp (°C)	17.6			
Temperature Range - ± 5% (°C)	3.08	to	32.14	
Lowest Velocity Reading (m/s)	7.08			
Highest Velocity Reading (m/s)	8.98			
Ratio (less than 3:1)	1.27	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	18.1			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	18.6			
Carbon Dioxide %	1.40			
Moisture (%)	4.16			
Litres sampled	1397			
Corrected volume sampled - STP (m ³)	1.337			
Blank Filter Run weight gain (mg)	0.010	Blank Concentration (mg/m³)	0.007	
Blank Wash Run weight gain (mg)	0.040		0.030	
Weighing uncertainty of balance (mg)	0.075	This must be <5% of ELV	ELV = 50	2.5
Overall Blank value (mg/m ³)	0.037	This must be <10% of ELV	ELV = 50	5.0
Particulate weight collected on filter (mg)	0.10			
Particulate weight collected in Wash (mg)	1.69			
Total Particulate weight collected (mg)	1.79			
Total Particulate Concentration, *STP, dry gas (mg/m ³)	1.34			
Total Particulate Concentration, *STP, wet gas (mg/m ³)	1.28			
Total Particulate Concentration corrected for Oxygen, *STP, dry gas (mg/m ³)	N/A			
Total Particulate Mass Emission (kg/hour)	0.000			




Client	Terex							
Site Address	Coventry							
Job Number	P-RED14-001							
Date	23rd January 2014							
Operator(s)	Vicki Gavin & Tony Berek							
Stack Reference	Primer Flash Off			Isokinetic Sample Positions (%) multiply by diameter to obtain sample points		Sampling Plane Diagram		
Number of Stacks	1			1	14.60			
Stack Configuration	Round			2	85.40			
Dimensions (mtrs)	0.80			3	N/A			
Outlet Diameter (if applicable) (metres)				4	N/A			
Number of Sample Ports	1			5	N/A			
Number of Samples per Axis / Port	2			6	N/A			
Nozzle Diameter (mm)	8.0			7	N/A			
Nozzle Area (m²)	0.00005024			8	N/A			
Stack Area (m²)	0.503			Average Isokinetic Flow Rate (ltrs/min)		Axis 1	Axis 2	
Pitot Coefficient	0.84	Pitot Calibration Due Date			March 2014		Atmos. Pressure (kPa)	
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test	Atmos. Pressure (kPa)
No.	(cms)	(pa)	(C)	Pass (Y/N)	(pa)	(C)	Pass (Y/N)	Static Pressure (pa)
1	11.68	66	26.0	5.0	48	26.0	5	-11.0
2	68.32	54	26.0	4.0	56	26.0	3	1 Axis
3	#VALUE!							2 Axis
4	#VALUE!							Velocity of flow (m/s)
5	N/A							8.53
6	N/A							7.94
7	N/A							Volume Flow Rate (m³/s)
8	N/A							4.29
								3.99
								Reduced Exit
Averages		60	26.0		52	26.0		N/A
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2 + 273) =$								299.00
Range of gas temperature readings $\pm 5\%$ (°C) $= (0.95T_p - 273)$ to $(1.05T_p - 273) =$						11.05	to	40.95
Highest Velocity Reading (m/s)								9.2
Lowest Velocity Reading (m/s)								7.6
Ratio Highest/Lowest (Max permitted = 3:1)								1.21 : 1
On site Checklist								
Range of Gas Temps		OK		Manometer Leak Check			OK	
Initial Leak Check	<0.2	Final leak check	<0.2	Pitot Leak Check			OK	
Acceptable Leak Check < 2% Vol (l/min)		0.51		Overall Isokinetic Ratio (%) (must be 95 to 115%)			Run 1	Run 2
Passed minimum Velocity requirements (>5pa)		YES					102.7	N/A
Negative Local Flow Present, YES or NO (Yes = Fail)		NO		Are there sufficient rails and kick board? (YES, NO or N/A)			YES	
Is the Platform area greater than 5m²? (YES, NO or N/A)		YES		Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)			YES	
Passed Highest to lowest Velocity (3:1)		YES						
Site Equipment Used								
Pitot Reference	RED 0237			Manometer Reference			RED 0400	
Thermometer Reference	RED 0354			Thermocouple Reference			RED 0344	
Balance Reference				Sampling Pump Reference			RED 0385	
Tape Measure Reference	RED 0123			Barometer Reference			RED 0402	



Stack Reference ID		Primer Flash Off		
		Terex		
		RUN 1		
Filter Reference No	G47-200114-13			
Date	23rd January 2014			
Sample Period	12:55	to	13:55	
Velocity (m/s)	8.24			
Volumetric flowrate of Stack gas (m ³ /hr)	14906			
Average Stack Temp (°C)	26.0			
Temperature Range - ± 5% (°C)	11.05	to	40.95	
Lowest Velocity Reading (m/s)	7.63			
Highest Velocity Reading (m/s)	9.22			
Ratio (less than 3:1)	1.21	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	26.3			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	18.6			
Carbon Dioxide %	1.40			
Moisture (%)	2.95			
Litres sampled	1523			
Corrected volume sampled - STP (m ³)	1.454			
Blank Filter Run weight gain (mg)	0.010	Blank Concentration (mg/m ³)	0.007	
Blank Wash Run weight gain (mg)	0.040		0.028	
Weighing uncertainty of balance (mg)	0.074	This must be <5% of ELV	ELV = 50	2.5
Overall Blank value (mg/m ³)	0.034	This must be <10% of ELV	ELV = 50	5.0
Particulate weight collected on filter (mg)	0.15			
Particulate weight collected in Wash (mg)	0.66			
Total Particulate weight collected (mg)	0.81			
Total Particulate Concentration, *STP, dry gas (mg/m ³)	0.56			
Total Particulate Concentration, *STP, wet gas (mg/m ³)	0.54			
Total Particulate Concentration corrected for Oxygen, *STP, dry gas (mg/m ³)	N/A			
Total Particulate Mass Emission (kg/hour)	0.008			




Client	TEREX									
Site Address	COVENTRY									
Job Number	P-RED14-001									
Date	23rd January 2014									
Operator(s)	V Gavin & T Berek									
Stack Reference	SCISSOR 1 BOOTH 1				Isokinetic Sample Positions (%) multiply by diameter to obtain sample points			Sampling Plane Diagram 		
Number of Stacks	1				1	14.60				
Stack Configuration	Round				2	85.40				
Dimensions (mtrs)	0.70				3	N/A				
Outlet Diameter (if applicable) (metres)					4	N/A				
Number of Sample Ports	2				5	N/A				
Number of Samples per Axis / Port	2				6	N/A				
Nozzle Diameter (mm)	8.0				7	N/A				
Nozzle Area (m²)	0.00005024				8	N/A				
Stack Area (m²)	0.385				Average Isokinetic Flow Rate (ltrs/min)			Axis 1 26.05	Axis 2 25.95	
Pitot Coefficient	0.84		Pitot Calibration Due Date			15/03/14		Atmos. Pressure (kPa)		
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test	99.8		
No.	(cms)	(pa)	(C)	(°)	(pa)	(C)	(°)	Static Pressure (pa)		
1	10.22	60	18.2	2.0	64	18.2	6	-41.0		
2	59.78	66	18.2	5.0	61	18.2	4	1 Axis	2 Axis	
3	N/A							Velocity of flow (m/s)		
4	N/A							8.64	8.61	
5	N/A							Volume Flow Rate (m³/s)		
6	N/A							3.33	3.31	
7	N/A							Reduced Exit		
8	N/A							N/A		
Averages		63	18.2		63	18.2				
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2) + 273$								291.20		
Permitted Range of gas temperature readings (C) = $(0.95T_p - 273)$ to $(1.05T_p - 273)$								3.64	to	32.76
Highest Velocity Reading (m/s)								9.1		
Lowest Velocity Reading (m/s)								8.4		
Ratio Highest/Lowest (Max permitted = 3:1)								1.08 : 1		
On site Checklist										
Initial Leak Check	0	End of first run	0.2		Start of 2 nd run		End of 2 nd run			
Acceptable Leak Check < 2% Vol (l/min)	0.52				Manometer Leak Check			OK		
					Pitot Leak Check			OK		
Range of Gas Temps	OK				Overall Isokinetic Ratio (%) (must be 95 to 115%)			Run 1	Run 2	
Passed minimum Velocity requirements (>5pa)	YES							100.3	N/A	
Negative Local Flow Present, YES or NO (Yes = Fail)	NO				Are there sufficient rails and kick board? (YES, NO or N/A)			NO		
Is the Platform area greater than 5m²? (YES, NO or N/A)	NO				Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)			YES		
Passed Highest to lowest Velocity (3:1)	YES									
Site Equipment Used										
Pitot Reference	RED 0289				Manometer Reference			RED 0404		
Thermometer Reference	RED 0351-RED 0352				Thermocouple Reference			RED 0292		
Balance Reference	N/A				Sampling Pump Reference			RED 0196		
Tape Measure Reference	RED 0121				Barometer Reference			RED 0403		
DGM Thermocouple	RED 0196T				Impinger Outlet Thermocouple			N/A		
Callipers	RED 0300				Condenser Thermocouple			N/A		



Stack Reference ID		SCISSOR 1 BOOTH 1		
	TEREX			
	RUN 1			
Filter Reference No	G47-200114-19			
Date	23rd January 2014			
Sample Period	08:50	to	09:50	
Velocity (m/s)	8.63			
Volume flow rate of Stack gas (m ³ /hr)	11950			
Average Stack Temp (°C)	18.2			
Temp Range ± 5% (°C)	3.64	to	32.76	
Lowest Velocity Reading (m/s)	8.42			
Highest Velocity Reading (m/s)	9.11			
Ratio (less than 3:1)	1.08	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	18.4			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	18.8			
Carbon Dioxide %	0.90			
Moisture (%)	0.00			
Litres sampled	1518			
Corrected volume sampled - STP (m ³)	1.466			
Blank Filter Run weight gain (mg)	0.010	Blank Concentration (mg/m ³)	0.007	
Blank Wash Run weight gain (mg)	0.210		0.143	
Weighing uncertainty of balance (mg)	0.074	This must be <5% of ELV	ELV = 50	2.5
Overall Blank value (mg/m ³)	0.150	This must be <10% of ELV	ELV = 50	5.0
Particulate weight collected on filter (mg)	0.04			
Particulate weight collected in Wash (mg)	0.82			
Total Particulate weight collected (mg)	0.86			
Total Particulate Concentration, dry gas at STP (mg/m ³)	0.59			
Total Particulate Concentration, wet gas at STP (mg/m ³)	0.59			
Total Particulate Concentration corrected for 11% Oxygen, dry gas (mg/m ³)	N/A			
Total Particulate Mass Emission (kg/hour)	0.007			



Client	TEREX						
Site Address	COVENTRY						
Job Number	P-RED14-001						
Date	23rd January 2014						
Operator(s)	V Gavin & T Berek						
Stack Reference	SCISSOR 1 BOOTH 2				Isokinetic Sample Positions (%) multiply by diameter to obtain sample points		
Number of Stacks	1				1	14.60	
Stack Configuration	Round				2	85.40	
Dimensions (mtrs)	0.70				3	N/A	
Outlet Diameter (if applicable) (metres)					4	N/A	
Number of Sample Ports	2				5	N/A	
Number of Samples per Axis / Port	2				6	N/A	
Nozzle Diameter (mm)	8.0				7	N/A	
Nozzle Area (m ²)	0.00005024				8	N/A	
Stack Area (m ²)	0.385				Average Isokinetic Flow Rate (ltrs/min)		
Pitot Coefficient	0.84				Axis 1		Axis 2
Pitot Calibration Due Date				15/03/14			Atmos. Pressure (kPa)
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test
No.	(cms)	(pa)	(C)	(°)	(pa)	(C)	(°)
1	10.22	67	18.4	3.0	68	18.4	3
2	59.78	64	18.4	3.0	66	18.4	3
3	N/A						
4	N/A						
5	N/A						
6	N/A						
7	N/A						
8	N/A						
Averages		66	18.4		67	18.4	
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2) + 273) =$					291.40		
Permitted Range of gas temperature readings (C) = $(0.95T_p - 273)$ to $(1.05T_p - 273) =$					3.83 to 32.97		
Highest Velocity Reading (m/s) =					9.2		
Lowest Velocity Reading (m/s) =					8.7		
Ratio Highest/Lowest (Max permitted = 3:1)					1.06 : 1		
On site Checklist							
Initial Leak Check	0	End of first run	0.2		Start of 2 nd run		End of 2 nd run
Acceptable Leak Check < 2% Vol (l/min)	0.53				Manometer Leak Check		OK
					Pitot Leak Check		OK
Range of Gas Temps	OK				Overall Isokinetic Ratio (%) (must be 95 to 115%)		Run 1 95.8
Passed minimum Velocity requirements (>5pa)	YES						Run 2 N/A
Negative Local Flow Present, YES or NO (Yes = Fail)	NO				Are there sufficient rails and kick board? (YES, NO or N/A)		NO
Is the Platform area greater than 5m ² ? (YES, NO or N/A)	NO				Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)		YES
Passed Highest to lowest Velocity (3:1)	YES						
Site Equipment Used							
Pitot Reference	RED 0289				Manometer Reference		RED 0404
Thermometer Reference	RED 0351-RED 0352				Thermocouple Reference		RED 0292
Balance Reference	N/A				Sampling Pump Reference		RED 0196
Tape Measure Reference	RED 0121				Barometer Reference		RED 0403
DGM Thermocouple	RED 0196T				Impinger Outlet Thermocouple		N/A
Callipers	RED 0300				Condenser Thermocouple		N/A



Stack Reference ID		SCISSOR 1 BOOTH 2		
		TEREX		
		RUN 1		
Filter Reference No	G47-200114-21			
Date	23rd January 2014			
Sample Period	08:50	to	09:50	
Velocity (m/s)	8.87			
Volume flow rate of Stack gas (m ³ /hr)	12292			
Average Stack Temp (°C)	18.4			
Temp Range ± 5% (°C)	3.83	to	32.97	
Lowest Velocity Reading (m/s)	8.70			
Highest Velocity Reading (m/s)	9.25			
Ratio (less than 3:1)	1.06	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	18.5			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	18.9			
Carbon Dioxide %	0.60			
Moisture (%)	0.00			
Litres sampled	1530			
Corrected volume sampled - STP (m ³)	1.467			
Blank Filter Run weight gain (mg)	0.000	Blank Concentration (mg/m ³)	0.000	
Blank Wash Run weight gain (mg)	0.050		0.034	
Weighing uncertainty of balance (mg)	0.074	This must be <5% of ELV	ELV = 50	2.5
Overall Blank value (mg/m ³)	0.034	This must be <10% of ELV	ELV = 50	5.0
Particulate weight collected on filter (mg)	0.06			
Particulate weight collected in Wash (mg)	0.71			
Total Particulate weight collected (mg)	0.77			
Total Particulate Concentration, dry gas at STP (mg/m ³)	0.52			
Total Particulate Concentration, wet gas at STP (mg/m ³)	0.52			
Total Particulate Concentration corrected for 11% Oxygen, dry gas (mg/m ³)	N/A			
Total Particulate Mass Emission (kg/hour)	0.525			



Client	TEREX							
Site Address	COVENTRY							
Job Number	P-RED14-001							
Date	23rd January 2014							
Operator(s)	V Gavin & T Berek							
Stack Reference	SCISSOR 1 OVEN				Isokinetic Sample Positions (%) multiply by diameter to obtain sample points			
					Sampling Plane Diagram			
Number of Stacks	1				1	50.00		
Stack Configuration	Round				2	N/A		
Dimensions (mtrs)	0.20				3	N/A		
Outlet Diameter (if applicable) (metres)					4	N/A		
Number of Sample Ports	1				5	N/A		
Number of Samples per Axis / Port	1				6	N/A		
Nozzle Diameter (mm)	8.0				7	N/A		
Nozzle Area (m²)	0.00005024				8	N/A		
Stack Area (m²)	0.031				n			Axis 1 20.11
Pitot Coefficient	0.84				15/03/14			Axis 2 N/A
	Pitot Calibration Due Date				Atmos. Pressure (kPa)			99.8
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test	Static Pressure (pa)
No.	(cms)	(pa)	(C)	(°)	(pa)	(C)	(°)	3.0
1	10.00	30	91.2	7.0				1 Axis
2	#VALUE!							2 Axis
3	N/A							Velocity of flow (m/s)
4	N/A							6.67
5	N/A							N/A
6	N/A							Volume Flow Rate (m³/s)
7	N/A							0.21
8	N/A							N/A
Averages		30	91.2					Reduced Exit N/A
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2) + 273$					364.20			
Permitted Range of gas temperature readings (C) = $(0.95T_p - 273)$ to $(1.05T_p - 273)$					72.99 to 109.41			
Highest Velocity Reading (m/s)					6.9			
Lowest Velocity Reading (m/s)					6.7			
Ratio Highest/Lowest (Max permitted = 3:1)					1.03 : 1			
On site Checklist								
Initial Leak Check	<0.2	End of first run	<0.2		Start of 2 nd run	N/A	End of 2 nd run	N/A
Acceptable Leak Check < 2% Vol (l/min)	0.40				Manometer Leak Check			OK
					Pitot Leak Check			OK
Range of Gas Temps	OK				Overall Isokinetic Ratio (%) (must be 95 to 115%)			Run 1 99.4
Passed minimum Velocity requirements (>5pa)	YES							Run 2 N/A
Negative Local Flow Present, YES or NO (Yes = Fail)	NO				Are there sufficient rails and kick board? (YES, NO or N/A)			NO
Is the Platform area greater than 5m²? (YES, NO or N/A)	NO				Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)			YES
Passed Highest to lowest Velocity (3:1)	YES							
Site Equipment Used								
Pitot Reference	RED 0289				Manometer Reference			RED 0404
Thermometer Reference	RED 0351-RED 0352				Thermocouple Reference			RED 0292
Balance Reference	N/A				Sampling Pump Reference			RED 0196
Tape Measure Reference	RED 0121				Barometer Reference			RED 0403
DGM Thermocouple	RED 0196T				Impinger Outlet Thermocouple			N/A
Callipers	RED 0300				Condenser Thermocouple			N/A



Stack Reference ID		SCISSOR 1 OVEN		
	TEREX			
	RUN 1			
Filter Reference No	G47-200114-27			
Date	23rd January 2014			
Sample Period	13:02	to	14:02	
Velocity (m/s)	6.67			
Volume flow rate of Stack gas (m ³ /hr)	755			
Average Stack Temp (°C)	91.2			
Temp Range ± 5% (°C)	72.99	to	109.41	
Lowest Velocity Reading (m/s)	6.66			
Highest Velocity Reading (m/s)	6.87			
Ratio (less than 3:1)	1.03	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	91.7			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	19.5			
Carbon Dioxide %	0.60			
Moisture (%)	0.00			
Litres sampled	1010			
Corrected volume sampled - STP (m ³)	0.956			
Blank Filter Run weight gain (mg)	0.010	Blank Concentration (mg/m ³)	0.010	
Blank Wash Run weight gain (mg)	0.050		0.052	
Weighing uncertainty of balance (mg)	0.074	This must be <5% of ELV	ELV = 50	2.5
Overall Blank value (mg/m ³)	0.063	This must be <10% of ELV	ELV = 50	5.0
Particulate weight collected on filter (mg)	0.07			
Particulate weight collected in Wash (mg)	0.80			
Total Particulate weight collected (mg)	0.87			
Total Particulate Concentration, dry gas at STP (mg/m ³)	0.91			
Total Particulate Concentration, wet gas at STP (mg/m ³)	0.91			
Total Particulate Concentration corrected for 11% Oxygen, dry gas (mg/m ³)	N/A			
Total Particulate Mass Emission (kg/hour)	0.910			




Client	TEREX								
Site Address	COVENTRY								
Job Number	P-RED14-001								
Date	23rd January 2014								
Operator(s)	V Gavin & T Berek								
Stack Reference	SCISSOR 2 BOOTH 1				Isokinetic Sample Positions (%) multiply by diameter to obtain sample points				
				1	14.60				
Number of Stacks			1	2	85.40				
Stack Configuration			Round	3	N/A				
Dimensions (mtrs)			0.70	4	N/A				
Outlet Diameter (if applicable) (metres)				5	N/A				
Number of Sample Ports			2	6	N/A				
Number of Samples per Axis / Port			2	7	N/A				
Nozzle Diameter (mm)			8.0	8	N/A				
Nozzle Area (m ²)			0.00005024	Average Isokinetic Flow Rate (ltrs/min)			Axis 1	Axis 2	
Stack Area (m ²)			0.385				24.04	23.36	
Pitot Coefficient	0.84	Pitot Calibration Due Date			15/03/14			Atmos. Pressure (kPa)	
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test	99.8	
No.	(cms)	(pa)	(C)	(°)	(pa)	(C)	(°)	Static Pressure (pa)	
1	10.22	52	18.3	4.0	50	18.3	4	26.0	
2	59.78	55	18.3	4.0	51	18.3	3	1 Axis	2 Axis
3	N/A							Velocity of flow (m/s)	
4	N/A							7.97	7.75
5	N/A							Volume Flow Rate (m ³ /s)	
6	N/A							3.07	2.98
7	N/A							Reduced Exit	
8	N/A							N/A	
Averages		54	18.3		51	18.3			
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2) + 273$ =							291.30		
Permitted Range of gas temperature readings (C) = $(0.95T_p - 273)$ to $(1.05T_p - 273)$ =							3.74	to	32.87
Highest Velocity Reading (m/s) =							8.3		
Lowest Velocity Reading (m/s) =							7.7		
Ratio Highest/Lowest (Max permitted = 3:1)							1.08 : 1		
On site Checklist									
Initial Leak Check	0	End of first run	0.2		Start of 2 nd run	N/A	End of 2 nd run	N/A	
Acceptable Leak Check < 2% Vol (l/min)	0.48				Manometer Leak Check			OK	
					Pitot Leak Check			OK	
Range of Gas Temps	OK				Overall Isokinetic Ratio (%) (must be 95 to 115%)			Run 1	Run 2
Passed minimum Velocity requirements (>5pa)	YES							100.7	N/A
Negative Local Flow Present, YES or NO (Yes = Fail)	NO				Are there sufficient rails and kick board? (YES, NO or N/A)			NO	
Is the Platform area greater than 5m ² ? (YES, NO or N/A)	NO				Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)			YES	
Passed Highest to lowest Velocity (3:1)	YES								
Site Equipment Used									
Pitot Reference	RED 0289				Manometer Reference			RED 0404	
Thermometer Reference	RED 0351-RED 0352				Thermocouple Reference			RED 0292	
Balance Reference	N/A				Sampling Pump Reference			RED 0196	
Tape Measure Reference	RED 0121				Barometer Reference			RED 0403	
DGM Thermocouple	RED 0196T				Impinger Outlet Thermocouple			N/A	
Callipers	RED 0300				Condenser Thermocouple			N/A	



Stack Reference ID		SCISSOR 2 BOOTH 1		
		TEREX		
		RUN 1		
Filter Reference No	G47-200114-23			
Date	23rd January 2014			
Sample Period	10:55	to	11:55	
Velocity (m/s)	7.86			
Volume flow rate of Stack gas (m ³ /hr)	10891			
Average Stack Temp (°C)	18.3			
Temp Range ± 5% (°C)	3.74	to	32.87	
Lowest Velocity Reading (m/s)	7.69			
Highest Velocity Reading (m/s)	8.32			
Ratio (less than 3:1)	1.08	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	18.4			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	19.2			
Carbon Dioxide %	0.40			
Moisture (%)	0.00			
Litres sampled	1448			
Corrected volume sampled - STP (m ³)	1.388			
Blank Filter Run weight gain (mg)	0.000	Blank Concentration (mg/m ³)	0.000	
Blank Wash Run weight gain (mg)	0.010		0.007	
Weighing uncertainty of balance (mg)	0.075	This must be <5% of ELV	ELV = 50	2.5
Overall Blank value (mg/m ³)	0.007	This must be <20% of ELV	ELV = 50	10.0
Particulate weight collected on filter (mg)	0.02			
Particulate weight collected in Wash (mg)	1.53			
Total Particulate weight collected (mg)	1.55			
Total Particulate Concentration, dry gas at STP (mg/m ³)	1.12			
Total Particulate Concentration, wet gas at STP (mg/m ³)	1.12			
Total Particulate Concentration corrected for 11% Oxygen, dry gas (mg/m ³)	N/A			
Total Particulate Mass Emission (kg/hour)	0.012			



Client	TEREX						
Site Address	COVENTRY						
Job Number	P-RED14-001						
Date	23rd January 2014						
Operator(s)	V Gavin & T Berek						
Stack Reference	SCISSOR 2 BOOTH 2				Isokinetic Sample Positions (%) multiply by diameter to obtain sample points		
Number of Stacks	1				1	14.60	
Stack Configuration	Round				2	85.40	
Dimensions (mtrs)	0.70				3	N/A	
Outlet Diameter (if applicable) (metres)					4	N/A	
Number of Sample Ports	2				5	N/A	
Number of Samples per Axis / Port	2				6	N/A	
Nozzle Diameter (mm)	8.0				7	N/A	
Nozzle Area (m ²)	0.00005024				8	N/A	
Stack Area (m ²)	0.385				Average Isokinetic Flow Rate (ltrs/min)		
Pitot Coefficient	0.84				Axis 1		Axis 2
Pitot Calibration Due Date				15/03/14			Atmos. Pressure (kPa)
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test
No.	(cms)	(pa)	(C)	(°)	(pa)	(C)	(°)
1	10.22	51	18.3	5.0	52	18.3	5
2	59.78	51	18.3	6.0	50	18.3	4
3	N/A						
4	N/A						
5	N/A						
6	N/A						
7	N/A						
8	N/A						
Averages		51	18.3		51	18.3	
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2) + 273) =$					291.30		
Permitted Range of gas temperature readings (C) = $(0.95T_p - 273)$ to $(1.05T_p - 273) =$					3.74 to 32.87		
Highest Velocity Reading (m/s) =					8.1		
Lowest Velocity Reading (m/s) =					7.7		
Ratio Highest/Lowest (Max permitted = 3:1)					1.05 : 1		
On site Checklist							
Initial Leak Check	0	End of first run	0.2		Start of 2 nd run		End of 2 nd run
Acceptable Leak Check < 2% Vol (l/min)	0.47				Manometer Leak Check		OK
					Pitot Leak Check		OK
Range of Gas Temps	OK				Overall Isokinetic Ratio (%) (must be 95 to 115%)		Run 1 100.0
Passed minimum Velocity requirements (>5pa)	YES						Run 2 N/A
Negative Local Flow Present, YES or NO (Yes = Fail)	NO				Are there sufficient rails and kick board? (YES, NO or N/A)		NO
Is the Platform area greater than 5m ² ? (YES, NO or N/A)	NO				Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)		YES
Passed Highest to lowest Velocity (3:1)	YES						
Site Equipment Used							
Pitot Reference	RED 0289				Manometer Reference		RED 0404
Thermometer Reference	RED 0351-RED 0352				Thermocouple Reference		RED 0292
Balance Reference	N/A				Sampling Pump Reference		RED 0196
Tape Measure Reference	RED 0121				Barometer Reference		RED 0403
DGM Thermocouple	RED 0196T				Impinger Outlet Thermocouple		N/A
Callipers	RED 0300				Condenser Thermocouple		N/A



Stack Reference ID		SCISSOR 2 BOOTH 2		
		TEREX		
		RUN 1		
Filter Reference No	G47-200114-25			
Date	23rd January 2014			
Sample Period	12:00	to	13:00	
Velocity (m/s)	7.72			
Volume flow rate of Stack gas (m ³ /hr)	10699			
Average Stack Temp (°C)	18.3			
Temp Range ± 5% (°C)	3.74	to	32.87	
Lowest Velocity Reading (m/s)	7.69			
Highest Velocity Reading (m/s)	8.09			
Ratio (less than 3:1)	1.05	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	18.4			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	10.4			
Carbon Dioxide %	5.60			
Moisture (%)	0.00			
Litres sampled	1403			
Corrected volume sampled - STP (m ³)	1.342			
Blank Filter Run weight gain (mg)	0.050	Blank Concentration (mg/m ³)	0.037	
Blank Wash Run weight gain (mg)	0.020		0.015	
Weighing uncertainty of balance (mg)	0.074	This must be <5% of ELV	ELV = 50	2.5
Overall Blank value (mg/m ³)	0.052	This must be <10% of ELV	ELV = 50	5.0
Particulate weight collected on filter (mg)	0.15			
Particulate weight collected in Wash (mg)	1.00			
Total Particulate weight collected (mg)	1.15			
Total Particulate Concentration, dry gas at STP (mg/m ³)	0.86			
Total Particulate Concentration, wet gas at STP (mg/m ³)	0.86			
Total Particulate Concentration corrected for 11% Oxygen, dry gas (mg/m ³)	N/A			
Total Particulate Mass Emission (kg/hour)	0.009			




Client	TEREX							
Site Address	COVENTRY							
Job Number	P-RED14-001							
Date	23rd January 2014							
Operator(s)	V Gavin & T Berek							
Stack Reference	SCISSOR 2 OVEN				Isokinetic Sample Positions (%) multiply by diameter to obtain sample points			
				1	50.00	Sampling Plane Diagram		
Number of Stacks			1	2	N/A			
Stack Configuration		Round	3	N/A				
Dimensions (mtrs)		0.20	4	N/A				
Outlet Diameter (if applicable) (metres)			5	N/A				
Number of Sample Ports		1	6	N/A				
Number of Samples per Axis / Port		1	7	N/A				
Nozzle Diameter (mm)		8.0	8	N/A				
Nozzle Area (m²)		0.00005024	Average Isokinetic Flow Rate (ltrs/min)					Axis 1
Stack Area (m²)		0.031				16.71	N/A	
Pitot Coefficient	0.84	Pitot Calibration Due Date			15/03/14			Atmos. Pressure (kPa)
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test	99.8
No.	(cms)	(pa)	(C)	(°)	(pa)	(C)	(°)	Static Pressure (pa)
1	10.00	21	85.7	4.0				5.0
2	#VALUE!							1 Axis
3	N/A							2 Axis
4	N/A							Velocity of flow (m/s)
5	N/A							5.54
6	N/A							N/A
7	N/A							Volume Flow Rate (m³/s)
8	N/A							0.17
								N/A
Averages		21	85.7					Reduced Exit
								N/A
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2) + 273) =$							358.70	
Permitted Range of gas temperature readings (C) = $(0.95T_p - 273)$ to $(1.05T_p - 273) =$							67.77 to 103.64	
Highest Velocity Reading (m/s) =							5.7	
Lowest Velocity Reading (m/s) =							5.5	
Ratio Highest/Lowest (Max permitted = 3:1)							1.03 : 1	
On site Checklist								
Initial Leak Check	0	End of first run	0		Start of 2 nd run		End of 2 nd run	
Acceptable Leak Check < 2% Vol (l/min)	0.33				Manometer Leak Check		OK	
					Pitot Leak Check		OK	
Range of Gas Temps	OK				Overall Isokinetic Ratio (%) (must be 95 to 115%)		Run 1	Run 2
Passed minimum Velocity requirements (>5pa)	YES						100.3	#DIV/0!
Negative Local Flow Present, YES or NO (Yes = Fail)	NO				Are there sufficient rails and kick board? (YES, NO or N/A)		NO	
Is the Platform area greater than 5m²? (YES, NO or N/A)	NO				Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)		YES	
Passed Highest to lowest Velocity (3:1)	YES							
Site Equipment Used								
Pitot Reference	RED 0289				Manometer Reference		RED 0404	
Thermometer Reference	RED 0351-RED 0352				Thermocouple Reference		RED 0292	
Balance Reference	N/A				Sampling Pump Reference		RED 0196	
Tape Measure Reference	RED 0121				Barometer Reference		RED 0403	
DGM Thermocouple	RED 0196T				Impinger Outlet Thermocouple		N/A	
Callipers	RED 0300				Condenser Thermocouple		N/A	



Stack Reference ID		SCISSOR 2 OVEN		
	TEREX			
	RUN 1			
Filter Reference No	G47-200114-29			
Date	23rd January 2014			
Sample Period	14:05	to	15:05	
Velocity (m/s)	5.54			
Volume flow rate of Stack gas (m ³ /hr)	627			
Average Stack Temp (°C)	85.7			
Temp Range ± 5% (°C)	67.77	to	103.64	
Lowest Velocity Reading (m/s)	5.53			
Highest Velocity Reading (m/s)	5.70			
Ratio (less than 3:1)	1.03	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	86.4			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	19.3			
Carbon Dioxide %	0.40			
Moisture (%)	0.00			
Litres sampled	1012			
Corrected volume sampled - STP (m ³)	0.955			
Blank Filter Run weight gain (mg)	0.010	Blank Concentration (mg/m ³)	0.010	
Blank Wash Run weight gain (mg)	0.030		0.031	
Weighing uncertainty of balance (mg)	0.074	This must be <5% of ELV	ELV = 50	2.5
Overall Blank value (mg/m ³)	0.042	This must be <10% of ELV	ELV = 50	5.0
Particulate weight collected on filter (mg)	0.15			
Particulate weight collected in Wash (mg)	0.87			
Total Particulate weight collected (mg)	1.02			
Total Particulate Concentration, dry gas at STP (mg/m ³)	1.07			
Total Particulate Concentration, wet gas at STP (mg/m ³)	1.07			
Total Particulate Concentration corrected for 11% Oxygen, dry gas (mg/m ³)	N/A			
Total Particulate Mass Emission (kg/hour)	0.001			



Client	TEREX						
Site Address	COVENTRY						
Job Number	P-RED14-001						
Date	22nd January 2014						
Operator(s)	V Gavin & T Berek						
Stack Reference	Spray Bake Booth 1			Isokinetic Sample Positions (%) multiply by diameter to obtain sample points			
Number of Stacks	1			1	14.60		
Stack Configuration	Round			2	85.40		
Dimensions (mtrs)	0.80			3	N/A		
Outlet Diameter (if applicable) (metres)				4	N/A		
Number of Sample Ports	2			5	N/A		
Number of Samples per Axis / Port	2			6	N/A		
Nozzle Diameter (mm)	6.0			7	N/A		
Nozzle Area (m ²)	0.00002826			8	N/A		
Stack Area (m ²)	0.503			Average Isokinetic Flow Rate (ltrs/min)			
Pitot Coefficient	0.84			Axis 1		Axis 2	
Pitot Calibration Due Date				15/03/14			
Atmos. Pressure (kPa)				101.8			
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test
No.	(cms)	(pa)	(C)	(°)	(pa)	(C)	(°)
1	11.68	129	26.8	4.0	133	26.8	4
2	68.32	131	26.9	3.0	131	27.1	5
3	N/A						
4	N/A						
5	N/A						
6	N/A						
7	N/A						
8	N/A						
Averages		130	26.9		132	27.0	
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2) + 273$ =				299.85			
Permitted Range of gas temperature readings (C) = $(0.95T_p - 273)$ to $(1.05T_p - 273)$ =				11.86 to 41.84			
Highest Velocity Reading (m/s) =				13.0			
Lowest Velocity Reading (m/s) =				12.4			
Ratio Highest/Lowest (Max permitted = 3:1)				1.05 : 1			
On site Checklist							
Initial Leak Check	End of first run		Start of 2 nd run		End of 2 nd run		
Acceptable Leak Check < 2% Vol (l/min)	0.42		Manometer Leak Check		OK		
	OK		Pitot Leak Check		OK		
Range of Gas Temps	OK		Overall Isokinetic Ratio (%) (must be 95 to 115%)		Run 1	Run 2	
Passed minimum Velocity requirements (>5pa)	YES				100.0	N/A	
Negative Local Flow Present, YES or NO (Yes = Fail)	NO		Are there sufficient rails and kick board? (YES, NO or N/A)		NO		
Is the Platform area greater than 5m ² ? (YES, NO or N/A)	NO		Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)		YES		
Passed Highest to lowest Velocity (3:1)	YES						
Site Equipment Used							
Pitot Reference	RED 0290			Manometer Reference		RED 0393	
Thermometer Reference	RED 0351-RED 0352			Thermocouple Reference		RED 0362	
Balance Reference	N/A			Sampling Pump Reference		RED 0258	
Tape Measure Reference	RED 0123			Barometer Reference		RED 0094	
DGM Thermocouple	RED 0395			Impinger Outlet Thermocouple		N/A	
Callipers	RED 0300			Condenser Thermocouple		N/A	



Stack Reference ID		Spray Bake Booth 1		
		TEREX		
		RUN 1		
Filter Reference No	ISOCYANATES NCO			
Date	22nd January 2014			
Sample Period	10:30	to	11:30	
Velocity (m/s)	12.53			
Volume flow rate of Stack gas (m ³ /hr)	22677			
Average Stack Temp (°C)	26.9			
Temp Range ± 5% (°C)	11.86	to	41.84	
Lowest Velocity Reading (m/s)	12.40			
Highest Velocity Reading (m/s)	12.99			
Ratio (less than 3:1)	1.05	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	27.8			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	18.8			
Carbon Dioxide %	0.60			
Moisture (%)	0.00			
Litres sampled	1257			
Corrected volume sampled - STP (m ³)	1.225			
Blank Filter Run weight gain (mg)	0.000	Blank Concentration (mg/m ³)	0.000	
Blank Wash Run weight gain (mg)	0.000		0.000	
Weighing uncertainty of balance (mg)	0.074	This must be <5% of ELV	ELV = 0.1	0.01
Overall Blank value (mg/m ³)	0.000	This must be <10% of ELV	ELV = 0.1	0.01
Isocyanate weight collected on filter (mg)	0.02			
Total Isocyanate Concentration, dry gas at STP (mg/m ³)	0.02			
Total Isocyanate Concentration, wet gas at STP (mg/m ³)	0.02			
Total Isocyanate Mass Emission (kg/hour)	0.0004			



Client	TEREX								
Site Address	COVENTRY								
Job Number	P-RED14-001								
Date	22nd January 2014								
Operator(s)	V Gavin & T Berek								
Stack Reference	SPRAYBAKE BOOTH 2 (NCO)				Isokinetic Sample Positions (%) multiply by diameter to obtain sample points				
Number of Stacks	1				1	14.60			
Stack Configuration	Round				2	85.40			
Dimensions (mtrs)	0.80				3	N/A			
Outlet Diameter (if applicable) (metres)					4	N/A			
Number of Sample Ports	2				5	N/A			
Number of Samples per Axis / Port	2				6	N/A			
Nozzle Diameter (mm)	6.0				7	N/A			
Nozzle Area (m ²)	0.00002826				8	N/A			
Stack Area (m ²)	0.503				Average Isokinetic Flow Rate (ltrs/min)			Axis 1 20.65	Axis 2 20.65
Pitot Coefficient	0.84		Pitot Calibration Due Date			15/03/14		Atmos. Pressure (kPa)	
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test	100.9	
No.	(cms)	(pa)	(C)	(°)	(pa)	(C)	(°)	Static Pressure (pa)	
1	11.68	124	26.0	5.0	128	25.9	3	24.0	
2	68.32	126	25.9	4.0	122	26.2	5	1 Axis	2 Axis
3	N/A							Velocity of flow (m/s)	
4	N/A							12.18	12.18
5	N/A							Volume Flow Rate (m ³ /s)	
6	N/A							6.12	6.12
7	N/A							Reduced Exit	
8	N/A							N/A	
Averages		125	26.0		125	26.1		N/A	
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2) + 273$					298.95				
Permitted Range of gas temperature readings (C) = $(0.95T_p - 273)$ to $(1.05T_p - 273)$					11.00		to		40.90
Highest Velocity Reading (m/s)					12.8				
Lowest Velocity Reading (m/s)					12.1				
Ratio Highest/Lowest (Max permitted = 3:1)					1.06 : 1				
On site Checklist									
Initial Leak Check	0.2	End of first run	0.2		Start of 2 nd run		End of 2 nd run		
Acceptable Leak Check < 2% Vol (l/min)	0.41				Manometer Leak Check			OK	
Range of Gas Temps	OK				Pitot Leak Check			OK	
Passed minimum Velocity requirements (>5pa)	YES				Overall Isokinetic Ratio (%) (must be 95 to 115%)			Run 1	Run 2
Negative Local Flow Present, YES or NO (Yes = Fail)	NO				Are there sufficient rails and kick board? (YES, NO or N/A)			102.2	N/A
Is the Platform area greater than 5m ² ? (YES, NO or N/A)	NO				Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)			YES	
Passed Highest to lowest Velocity (3:1)	YES								
Site Equipment Used									
Pitot Reference	RED 0290				Manometer Reference			RED 0393	
Thermometer Reference	RED 0351-RED 0352				Thermocouple Reference			RED 0362	
Balance Reference	N/A				Sampling Pump Reference			RED 0258	
Tape Measure Reference	RED 0123				Barometer Reference			RED 0094	
DGM Thermocouple	RED 0395				Impinger Outlet Thermocouple			N/A	
Callipers	RED 0300				Condenser Thermocouple			N/A	



Stack Reference ID		SPRAYBAKE BOOTH 2 (NCO)		
		TEREX		
		RUN 1		
Filter Reference No	ISOCYANATES NCO			
Date	22nd January 2014			
Sample Period	12:40	to	13:40	
Velocity (m/s)	12.18			
Volume flow rate of Stack gas (m ³ /hr)	22041			
Average Stack Temp (°C)	26.0			
Temp Range ± 5% (°C)	11.00	to	40.90	
Lowest Velocity Reading (m/s)	12.10			
Highest Velocity Reading (m/s)	12.78			
Ratio (less than 3:1)	1.06	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	26.7			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	10.4			
Carbon Dioxide %	5.60			
Moisture (%)	0.00			
Litres sampled	1286			
Corrected volume sampled - STP (m ³)	1.236			
Blank Filter Run weight gain (mg)	0.000	Blank Concentration (mg/m ³)	0.000	
Blank Wash Run weight gain (mg)	0.000		0.000	
Weighing uncertainty of balance (mg)	0.074	This must be <5% of ELV	ELV = 0.1	0.01
Overall Blank value (mg/m ³)	0.000	This must be <10% of ELV	ELV = 0.1	0.01
Isocyanate weight collected on filter (mg)	0.02			
Total Isocyanate weight collected (mg)	0.02			
Total Isocyanate Concentration, dry gas at STP (mg/m ³)	0.02			
Total Isocyanate Concentration, wet gas at STP (mg/m ³)	0.02			
Total Isocyanate Mass Emission (kg/hour)	0.0004			



Client	Terex									
Site Address	Coventry									
Job Number	P-RED14-001									
Date	22nd January 2014									
Operator(s)	Vicki Gavin & Tony Berek									
Stack Reference		Topcoat Flashoff			Isokinetic Sample Positions (%) multiply by diameter to obtain sample points		Sampling Plane Diagram			
Number of Stacks		1			1	14.60				
Stack Configuration		Round			2	85.40				
Dimensions (mtrs)		1.00			3	N/A				
Outlet Diameter (if applicable) (metres)					4	N/A				
Number of Sample Ports		1			5	N/A				
Number of Samples per Axis / Port		2			6	N/A				
Nozzle Diameter (mm)		6.0			7	N/A				
Nozzle Area (m²)		0.00002826			8	N/A				
Stack Area (m²)		0.785			Average Isokinetic Flow Rate (ltrs/min)		Axis 1	Axis 2		
Pitot Coefficient		0.84			Pitot Calibration Due Date		March 2014		Atmos. Pressure (kPa)	
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test		100.9	
No.	(cms)	(pa)	(C)	Pass (Y/N)	(pa)	(C)	Pass (Y/N)		Static Pressure (pa)	
1	14.60	102	55.0	5.0	112	55.0	6		-80.0	
2	85.40	97	55.0	5.0	103	55.0	3		1 Axis	
3	N/A								2 Axis	
4	N/A								Velocity of flow (m/s)	
5	N/A								11.45	
6	N/A								11.90	
7	N/A								Volume Flow Rate (m³/s)	
8	N/A								8.99	
Averages		100			55.0		108		55.0	Reduced Exit
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2 + 273) =$									328.00	
Range of gas temperature readings $\pm 5\%$ ($^{\circ}\text{C}$) $= (0.95T_p - 273)$ to $(1.05T_p - 273) =$									38.60	
Highest Velocity Reading (m/s)									12.5	
Lowest Velocity Reading (m/s)									11.3	
Ratio Highest/Lowest (Max permitted = 3:1)									1.11 : 1	
On site Checklist										
Range of Gas Temps		OK			Manometer Leak Check		OK			
Initial Leak Check	<0.2	Final leak check	<0.2		Pitot Leak Check		OK			
Acceptable Leak Check < 2% Vol (l/min)		0.39			Overall Isokinetic Ratio (%) (must be 95 to 115%)		Run 1	Run 2		
Passed minimum Velocity requirements (>5pa)		YES					106.3	98.2		
Negative Local Flow Present, YES or NO (Yes = Fail)		NO			Are there sufficient rails and kick board? (YES, NO or N/A)		YES			
Is the Platform area greater than 5m²? (YES, NO or N/A)		YES			Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)		YES			
Passed Highest to lowest Velocity (3:1)		YES								
Site Equipment Used										
Pitot Reference	RED 0237			Manometer Reference		RED 0400				
Thermometer Reference	RED 0354			Thermocouple Reference		RED 0344				
Balance Reference				Sampling Pump Reference		RED 0385				
Tape Measure Reference	RED 0123			Barometer Reference		RED 0402				



Stack Reference ID		Topcoat Flashoff					
		Terex					
		RUN 1			RUN 2		
Filter Reference No	G47-200114-01			NCO Run			
Date	22nd January 2014			22nd January 2014			
Sample Period	09:30	to	10:30	10:35	to	11:35	
Velocity (m/s)	11.68						
Volumetric flowrate of Stack gas (m ³ /hr)	33013						
Average Stack Temp (°C)	55.0						
Temperature Range - ± 5% (°C)	38.60	to		71.40			
Lowest Velocity Reading (m/s)	11.30						
Highest Velocity Reading (m/s)	12.52						
Ratio (less than 3:1)	1.11	:		1			
Pre-conditioning temperature of Filter (°C)	180			180			
Instack sampling - Max Filter temperature (°C)	55.0			55.0			
Post-conditioning temperature Filter/Wash (°C)	160			160			
Oxygen %	18.6			18.6			
Carbon Dioxide %	1.40			1.40			
Moisture (%)	4.16						
Litres sampled	1190			1155			
Corrected volume sampled - STP (m ³)	1.153			1.110			
Blank Filter Run weight gain (mg)	0.020	Blank Concentration (mg/m ³)		0.018			
Blank Wash Run weight gain (mg)	0.010			0.009			
Weighing uncertainty of balance (mg)	0.074	This must be <5% of ELV		ELV = 50	2.5		
Overall Blank value (mg/m ³)	0.027	This must be <10% of ELV		ELV = 50	5.0		
Particulate weight collected on filter (mg)	0.08			0.02			
Particulate weight collected in Wash (mg)	0.15			0.00			
Total Particulate weight collected (mg)	0.23			0.02			
Total Particulate Concentration, *STP, dry gas (mg/m ³)	0.20			0.02			
Total Particulate Concentration, *STP, wet gas (mg/m ³)	0.19			0.02			
Total Particulate Concentration corrected for Oxygen, *STP, dry gas (mg/m ³)	N/A			N/A			
Total Particulate Mass Emission (kg/hour)	0.006			0.001			



Client	Terex							
Site Address	Coventry							
Job Number	P-RED14-001							
Date	23rd January 2014							
Operator(s)	Vicki Gavin & Tony Berek							
Stack Reference	Topcoat 1			Isokinetic Sample Positions (%) multiply by diameter to obtain sample points		Sampling Plane Diagram		
Number of Stacks	1			1	14.60			
Stack Configuration	Round			2	85.40			
Dimensions (mtrs)	1.60			3	N/A			
Outlet Diameter (if applicable) (metres)				4	N/A			
Number of Sample Ports	1			5	N/A			
Number of Samples per Axis / Port	4			6	N/A			
Nozzle Diameter (mm)	8.0			7	N/A			
Nozzle Area (m²)	0.00005024			8	N/A			
Stack Area (m²)	2.011			Average Isokinetic Flow Rate (ltrs/min)		Axis 1	Axis 2	
Pitot Coefficient	0.84	Pitot Calibration Due Date			March 2014		19.48	18.92
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test	Atmos. Pressure (kPa)
No.	(cms)	(pa)	(C)	Pass (Y/N)	(pa)	(C)	Pass (Y/N)	99.9
1	23.36	37	16.8	4.0	32	16.9	4	Static Pressure (pa)
2	136.64	34	16.8	4.0	35	16.8	4	-13.0
3	#VALUE!							1 Axis
4	#VALUE!							2 Axis
5	N/A							Velocity of flow (m/s)
6	N/A							6.46
7	N/A							6.28
8	N/A							Volume Flow Rate (m³/s)
Averages		36	16.8		34	16.9		12.99
								12.62
								Reduced Exit
								N/A
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2 + 273) =$								289.83
Range of gas temperature readings $\pm 5\%$ ($^{\circ}\text{C}$) $= (0.95T_p - 273)$ to $(1.05T_p - 273) =$						2.33	to	31.32
Highest Velocity Reading (m/s)								6.8
Lowest Velocity Reading (m/s)								6.1
Ratio Highest/Lowest (Max permitted = 3:1)								1.11 : 1
On site Checklist								
Range of Gas Temps	OK			Manometer Leak Check			OK	
Initial Leak Check	<0.2	Final leak check	<0.2	Pitot Leak Check			OK	
Acceptable Leak Check < 2% Vol (l/min)	0.39			Overall Isokinetic Ratio (%) (must be 95 to 115%)			Run 1	Run 2
Passed minimum Velocity requirements (>5pa)	YES						101.8	104.1
Negative Local Flow Present, YES or NO (Yes = Fail)	NO			Are there sufficient rails and kick board? (YES, NO or N/A)			YES	
Is the Platform area greater than 5m²? (YES, NO or N/A)	YES			Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)			YES	
Passed Highest to lowest Velocity (3:1)	YES							
Site Equipment Used								
Pitot Reference	RED 0237			Manometer Reference			RED 0400	
Thermometer Reference	RED 0354			Thermocouple Reference			RED 0344	
Balance Reference				Sampling Pump Reference			RED 0385	
Tape Measure Reference	RED 0123			Barometer Reference			RED 0402	



Stack Reference ID		Topcoat 1					
	Terex						
	RUN 1			RUN 2			
Filter Reference No	NCO Run			G47-200114-09			
Date	23rd January 2014			23rd January 2014			
Sample Period	08:45	to	09:45	09:47	to	10:47	
Velocity (m/s)	6.37						
Volumetric flowrate of Stack gas (m ³ /hr)	46099						
Average Stack Temp (°C)	16.8						
Temperature Range - ± 5% (°C)	2.33	to		31.32			
Lowest Velocity Reading (m/s)	6.13						
Highest Velocity Reading (m/s)	6.80						
Ratio (less than 3:1)	1.11	:		1			
Pre-conditioning temperature of Filter (°C)	180			180			
Instack sampling - Max Filter temperature (°C)	16.8			16.8			
Post-conditioning temperature Filter/Wash (°C)	160			160			
Oxygen %	18.6			18.6			
Carbon Dioxide %	1.40			1.40			
Moisture (%)	2.95						
Litres sampled	1155			1159			
Corrected volume sampled - STP (m ³)	1.119			1.114			
Blank Filter Run weight gain (mg)	0.010		Blank Concentration (mg/m ³)	0.009			
Blank Wash Run weight gain (mg)	0.050			0.045			
Weighing uncertainty of balance (mg)	0.074	This must be <5% of ELV		ELV = 50	2.5		
Overall Blank value (mg/m ³)	0.054	This must be <10% of ELV		ELV = 50	5.0		
Particulate weight collected on filter (mg)	0.02			0.21			
Particulate weight collected in Wash (mg)	0.00			0.86			
Total Particulate weight collected (mg)	0.02			1.07			
Total Particulate Concentration, *STP, dry gas (mg/m ³)	0.02			0.96			
Total Particulate Concentration, *STP, wet gas (mg/m ³)	0.02			0.93			
Total Particulate Concentration corrected for Oxygen, *STP, dry gas (mg/m ³)	N/A			N/A			
Total Particulate Mass Emission (kg/hour)	0.001			0.044			



Client	Terex							
Site Address	Coventry							
Job Number	P-RED14-001							
Date	23rd January 2014							
Operator(s)	Vicki Gavin & Tony Berek							
Stack Reference	Topcoat 2			Isokinetic Sample Positions (%) multiply by diameter to obtain sample points		Sampling Plane Diagram		
Number of Stacks	1			1	14.60			
Stack Configuration	Round			2	85.40			
Dimensions (mtrs)	1.60			3	N/A			
Outlet Diameter (if applicable) (metres)				4	N/A			
Number of Sample Ports	1			5	N/A			
Number of Samples per Axis / Port	4			6	N/A			
Nozzle Diameter (mm)	8.0			7	N/A			
Nozzle Area (m²)	0.00005024			8	N/A			
Stack Area (m²)	2.011			Average Isokinetic Flow Rate (ltrs/min)		Axis 1	Axis 2	
Pitot Coefficient	0.84			March 2014			21.32	20.94
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test	Atmos. Pressure (kPa)
No.	(cms)	(pa)	(C)	Pass (Y/N)	(pa)	(C)	Pass (Y/N)	99.9
1	23.36	41	17.2	4.0	43	17.2	4	-17.0
2	136.64	44	17.2	4.0	39	17.2	4	1 Axis
3	N/A							2 Axis
4	N/A							Velocity of flow (m/s)
5	N/A							7.07
6	N/A							6.95
7	N/A							Volume Flow Rate (m³/s)
8	N/A							14.22
								13.97
Averages								Reduced Exit
								N/A
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2 + 273) =$					290.20			
Range of gas temperature readings $\pm 5\%$ ($^{\circ}\text{C}$) $= (0.95T_p - 273)$ to $(1.05T_p - 273) =$					2.69		to 31.71	
Highest Velocity Reading (m/s) =					7.4			
Lowest Velocity Reading (m/s) =					6.8			
Ratio Highest/Lowest (Max permitted = 3:1)					1.10 : 1			
On site Checklist								
Range of Gas Temps		OK		Manometer Leak Check		OK		
Initial Leak Check	<0.2	Final leak check	<0.2	Pitot Leak Check		OK		
Acceptable Leak Check < 2% Vol (l/min)		0.43		Overall Isokinetic Ratio (%) (must be 95 to 115%)		Run 1	Run 2	
Passed minimum Velocity requirements (>5pa)		YES				100.3	103.4	
Negative Local Flow Present, YES or NO (Yes = Fail)		NO		Are there sufficient rails and kick board? (YES, NO or N/A)		YES		
Is the Platform area greater than 5m²? (YES, NO or N/A)		YES		Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)		YES		
Passed Highest to lowest Velocity (3:1)		YES						
Site Equipment Used								
Pitot Reference	RED 0237			Manometer Reference	RED 0400			
Thermometer Reference	RED 0354			Thermocouple Reference	RED 0344			
Balance Reference				Sampling Pump Reference	RED 0385			
Tape Measure Reference	RED 0123			Barometer Reference	RED 0402			



Stack Reference ID	Topcoat 2					
	Terex					
	RUN 1			RUN 2		
Filter Reference No	NCO Run			G47-200114-11		
Date	23rd January 2014			23rd January 2014		
Sample Period	10:50	to	11:50	11:52	to	12:52
Velocity (m/s)	7.01					
Volumetric flowrate of Stack gas (m ³ /hr)	50748					
Average Stack Temp (°C)	17.2					
Temperature Range - ± 5% (°C)	2.69	to			to	31.71
Lowest Velocity Reading (m/s)	6.77					
Highest Velocity Reading (m/s)	7.42					
Ratio (less than 3:1)	1.10		:			1
Pre-conditioning temperature of Filter (°C)	180			180		
Instack sampling - Max Filter temperature (°C)	17.2			17.2		
Post-conditioning temperature Filter/Wash (°C)	160			160		
Oxygen %	18.6			18.6		
Carbon Dioxide %	1.40			1.40		
Moisture (%)	2.95					
Litres sampled	1235			1216		
Corrected volume sampled - STP (m ³)	1.182			1.161		
Blank Filter Run weight gain (mg)	0.020		Blank Concentration (mg/m ³)	0.017		
Blank Wash Run weight gain (mg)	0.020			0.017		
Weighing uncertainty of balance (mg)	0.075	This must be <5% of ELV		ELV = 50	2.5	
Overall Blank value (mg/m ³)	0.034	This must be <10% of ELV		ELV = 50	5.0	
Particulate weight collected on filter (mg)	0.02			0.04		
Particulate weight collected in Wash (mg)	0.00			1.18		
Total Particulate weight collected (mg)	0.02			1.22		
Total Particulate Concentration, *STP, dry gas (mg/m ³)	0.02			1.05		
Total Particulate Concentration, *STP, wet gas (mg/m ³)	0.02			1.02		
Total Particulate Concentration corrected for Oxygen, *STP, dry gas (mg/m ³)	N/A			N/A		
Total Particulate Mass Emission (kg/hour)	0.001			0.052		



Client	Terex							
Site Address	Coventry							
Job Number	P-RED14-001							
Date	22nd January 2014							
Operator(s)	Vicki Gavin & Tony Berek							
Stack Reference	Topcoat Curing Oven				Isokinetic Sample Positions (%) multiply by diameter to obtain sample points		Sampling Plane Diagram	
Number of Stacks	1				1	14.60		
Stack Configuration	Round				2	85.40		
Dimensions (mtrs)	1.60				3	N/A		
Outlet Diameter (if applicable) (metres)					4	N/A		
Number of Sample Ports	1				5	N/A		
Number of Samples per Axis / Port	4				6	N/A		
Nozzle Diameter (mm)	6.0				7	N/A		
Nozzle Area (m²)	0.00002826				8	N/A		
Stack Area (m²)	2.011				Average Isokinetic Flow Rate (ltrs/min)		Axis 1	Axis 2
Pitot Coefficient	0.84				March 2014		20.21	21.54
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test	Atmos. Pressure (kPa)
No.	(cms)	(pa)	(C)	Pass (Y/N)	(pa)	(C)	Pass (Y/N)	100.9
1	23.36	104	60.5	3.0	119	60.5	3	Static Pressure (pa)
2	136.64	108	60.5	3.0	122	60.5	3	30.0
3	#VALUE!							1 Axis
4	#VALUE!							2 Axis
5	N/A							Velocity of flow (m/s)
6	N/A							11.92
7	N/A							12.71
8	N/A							Volume Flow Rate (m³/s)
Averages		106	60.5		121	60.5		23.96
								25.55
								Reduced Exit
								N/A
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2 + 273) =$								333.50
Range of gas temperature readings $\pm 5\%$ ($^{\circ}\text{C}$) $= (0.95T_p - 273)$ to $(1.05T_p - 273) =$								43.83 to 77.18
Highest Velocity Reading (m/s) =								13.2
Lowest Velocity Reading (m/s) =								11.8
Ratio Highest/Lowest (Max permitted = 3:1)								1.12 : 1
On site Checklist								
Range of Gas Temps	OK				Manometer Leak Check	OK		
Initial Leak Check	<0.2	Final leak check	<0.2		Pitot Leak Check	OK		
Acceptable Leak Check < 2% Vol (l/min)	0.40				Overall Isokinetic Ratio (%) (must be 95 to 115%)	Run 1	Run 2	
Passed minimum Velocity requirements (>5pa)	YES					96.6	100.8	
Negative Local Flow Present, YES or NO (Yes = Fail)	NO				Are there sufficient rails and kick board? (YES, NO or N/A)		YES	
Is the Platform area greater than 5m²? (YES, NO or N/A)	YES				Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)		YES	
Passed Highest to lowest Velocity (3:1)	YES							
Site Equipment Used								
Pitot Reference	RED 0237				Manometer Reference	RED 0400		
Thermometer Reference	RED 0354				Thermocouple Reference	RED 0344		
Balance Reference					Sampling Pump Reference	RED 0385		
Tape Measure Reference	RED 0123				Barometer Reference	RED 0402		



Stack Reference ID		Topcoat Curing Oven					
	Terex						
	RUN 1			RUN 2			
Filter Reference No	NCO Run			G47-200114-07			
Date	22nd January 2014			22nd January 2014			
Sample Period	13:50	to	14:50	14:00	to	15:00	
Velocity (m/s)	12.31						
Volumetric flowrate of Stack gas (m ³ /hr)	89113						
Average Stack Temp (°C)	60.5						
Temperature Range - ± 5% (°C)	43.83	to		77.18			
Lowest Velocity Reading (m/s)	11.80						
Highest Velocity Reading (m/s)	13.18						
Ratio (less than 3:1)	1.12	:		1			
Pre-conditioning temperature of Filter (°C)	180			180			
Instack sampling - Max Filter temperature (°C)	60.5			60.5			
Post-conditioning temperature Filter/Wash (°C)	160			160			
Oxygen %	18.6			18.6			
Carbon Dioxide %	1.40			1.40			
Moisture (%)	4.16						
Litres sampled	1200			1353			
Corrected volume sampled - STP (m ³)	1.149			1.302			
Blank Filter Run weight gain (mg)	0.010			Blank Concentration (mg/m ³)	0.008		
Blank Wash Run weight gain (mg)	0.010				0.008		
Weighing uncertainty of balance (mg)	0.074	This must be <5% of ELV		ELV = 50	2.5		
Overall Blank value (mg/m ³)	0.016	This must be <10% of ELV		ELV = 50	5.0		
Particulate weight collected on filter (mg)	0.02			0.08			
Particulate weight collected in Wash (mg)	0.00			0.76			
Total Particulate weight collected (mg)	0.02			0.84			
Total Particulate Concentration, *STP, dry gas (mg/m ³)	0.02			0.64			
Total Particulate Concentration, *STP, wet gas (mg/m ³)	0.02			0.62			
Total Particulate Concentration corrected for Oxygen, *STP, dry gas (mg/m ³)	N/A			N/A			
Total Particulate Mass Emission (kg/hour)	0.001			0.053			



Client	TEREX							
Site Address	COVENTRY							
Job Number	P-RED14-001							
Date	22nd January 2014							
Operator(s)	V Gavin & T Berek							
Stack Reference	Preparation Booth 1			Isokinetic Sample Positions (%) multiply by diameter to obtain sample points		Sampling Plane Diagram		
Number of Stacks	1			1	14.60			
Stack Configuration	Round			2	85.40			
Dimensions (mtrs)	0.70			3	N/A			
Outlet Diameter (if applicable) (metres)				4	N/A			
Number of Sample Ports	2			5	N/A			
Number of Samples per Axis / Port	2			6	N/A			
Nozzle Diameter (mm)	6.0			7	N/A			
Nozzle Area (m²)	0.00002826			8	N/A			
Stack Area (m²)	0.385			Average Isokinetic Flow Rate (ltrs/min)		Axis 1	Axis 2	
Pitot Coefficient	0.84	Pitot Calibration Due Date			15/03/14		21.10	20.69
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test	Atmos. Pressure (kPa)
No.	(cms)	(pa)	(C)	(°)	(pa)	(C)	(°)	100.9
1	10.22	127	23.4	4.0	123	23.4	5	Static Pressure (pa)
2	59.78	132	23.4	5.0	126	23.4	5	22.0
3	N/A							1 Axis
4	N/A							2 Axis
5	N/A							Velocity of flow (m/s)
6	N/A							12.44
7	N/A							Volume Flow Rate (m³/s)
8	N/A							4.79
Averages		130	23.4		125	23.4		4.70
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2) + 273$								296.40
Permitted Range of gas temperature readings (C) = $(0.95T_p - 273)$ to $(1.05T_p - 273)$								8.58 to 38.22
Highest Velocity Reading (m/s)								12.9
Lowest Velocity Reading (m/s)								12.1
Ratio Highest/Lowest (Max permitted = 3:1)								1.07 : 1
On site Checklist								
Initial Leak Check	End of first run				Start of 2 nd run	End of 2 nd run		
Acceptable Leak Check < 2% Vol (l/min)	0.42				Manometer Leak Check			OK
Range of Gas Temps	OK				Pitot Leak Check			OK
Passed minimum Velocity requirements (>5pa)	YES				Overall Isokinetic Ratio (%) (must be 95 to 115%)	Run 1	Run 2	
Negative Local Flow Present, YES or NO (Yes = Fail)	NO					100.8	N/A	
Is the Platform area greater than 5m²? (YES, NO or N/A)	N/A				Are there sufficient rails and kick board? (YES, NO or N/A)			N/A
Passed Highest to lowest Velocity (3:1)	YES				Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)			YES
Site Equipment Used								
Pitot Reference	RED 0289				Manometer Reference			RED 0404
Thermometer Reference	RED 0351-RED 0352				Thermocouple Reference			RED 0292
Balance Reference	N/A				Sampling Pump Reference			RED 0196
Tape Measure Reference	RED 0121				Barometer Reference			RED 0403
DGM Thermocouple	RED 0196T				Impinger Outlet Thermocouple			N/A
Callipers	RED 0300				Condenser Thermocouple			N/A



Stack Reference ID		Preparation Booth 1		
		TEREX		
		RUN 1		
Filter Reference No	G47-200114-15			
Date	22nd January 2014			
Sample Period	09:25	to	10:25	
Velocity (m/s)	12.32			
Volume flow rate of Stack gas (m ³ /hr)	17073			
Average Stack Temp (°C)	23.4			
Temp Range ± 5% (°C)	8.58	to	38.22	
Lowest Velocity Reading (m/s)	12.10			
Highest Velocity Reading (m/s)	12.92			
Ratio (less than 3:1)	1.07	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	24.9			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	19.1			
Carbon Dioxide %	0.50			
Moisture (%)	0.00			
Litres sampled	1254			
Corrected volume sampled - STP (m ³)	1.217			
Blank Filter Run weight gain (mg)	0.000	Blank Concentration (mg/m ³)	0.000	
Blank Wash Run weight gain (mg)	0.000		0.000	
Weighing uncertainty of balance (mg)	0.074	This must be <5% of ELV	ELV = 50	2.5
Overall Blank value (mg/m ³)	0.000	This must be <10% of ELV	ELV = 50	5.0
Particulate weight collected on filter (mg)	0.03			
Particulate weight collected in Wash (mg)	1.13			
Total Particulate weight collected (mg)	1.16			
Total Particulate Concentration, dry gas at STP (mg/m ³)	0.95			
Total Particulate Concentration, wet gas at STP (mg/m ³)	0.95			
Total Particulate Concentration corrected for 11% Oxygen, dry gas (mg/m ³)	N/A			
Total Particulate Mass Emission (kg/hour)	0.016			



Client	TEREX							
Site Address	COVENTRY							
Job Number	P-RED14-001							
Date	22nd January 2014							
Operator(s)	V Gavin & T Berek							
Stack Reference	Preparation Booth 2				Isokinetic Sample Positions (%) multiply by diameter to obtain sample points			
					1	14.60		
Number of Stacks	1				2	85.40		
Stack Configuration	Round				3	N/A		
Dimensions (mtrs)	0.70				4	N/A		
Outlet Diameter (if applicable) (metres)					5	N/A		
Number of Sample Ports	2				6	N/A		
Number of Samples per Axis / Port	2				7	N/A		
Nozzle Diameter (mm)	6.0				8	N/A		
Nozzle Area (m ²)	0.00002826				Average Isokinetic Flow Rate (ltrs/min)			
Stack Area (m ²)	0.385				Axis 1		Axis 2	
Pitot Coefficient	0.84	Pitot Calibration Due Date			15/3/14			Atmos. Pressure (kPa)
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test	100.9
No.	(cms)	(pa)	(C)	(°)	(pa)	(C)	(°)	Static Pressure (pa)
1	10.22	124	26.0	5.0	128	26.1	3	30.0
2	59.78	126	26.1	4.0	122	26.2	5	1 Axis
3	N/A							2 Axis
4	N/A							Velocity of flow (m/s)
5	N/A							12.28
6	N/A							12.28
7	N/A							Volume Flow Rate (m ³ /s)
8	N/A							4.72
Averages		125	26.1		125	26.2		4.72
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2 + 273) =$								299.05
Permitted Range of gas temperature readings (C) = $(0.95T_p - 273)$ to $(1.05T_p - 273) =$								11.10 to 41.00
Highest Velocity Reading (m/s) =								12.8
Lowest Velocity Reading (m/s) =								12.1
Ratio Highest/Lowest (Max permitted = 3:1)								1.06 : 1
On site Checklist								
Initial Leak Check	0.2	End of first run	0.2		Start of 2 nd run		End of 2 nd run	
Acceptable Leak Check < 2% Vol (l/min)	0.42				Manometer Leak Check		OK	
					Pitot Leak Check		OK	
Range of Gas Temps	OK				Overall Isokinetic Ratio (%) (must be 95 to 115%)		Run 1	Run 2
Passed minimum Velocity requirements (>5pa)	YES						101.8	#DIV/0!
Negative Local Flow Present, YES or NO (Yes = Fail)	NO				Are there sufficient rails and kick board? (YES, NO or N/A)		NO	
Is the Platform area greater than 5m ² ? (YES, NO or N/A)	NO				Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)		YES	
Passed Highest to lowest Velocity (3:1)	YES							
Site Equipment Used								
Pitot Reference	RED 0290				Manometer Reference		RED 0393	
Thermometer Reference	RED 0351-RED 0352				Thermocouple Reference		RED 0362	
Balance Reference	N/A				Sampling Pump Reference		RED 0258	
Tape Measure Reference	RED 0123				Barometer Reference		RED 0094	
DGM Thermocouple	RED 0395				Impinger Outlet Thermocouple		N/A	
Callipers	RED 0300				Condenser Thermocouple		N/A	



Stack Reference ID		Preparation Booth 2		
	TEREX			
	RUN 1			
Filter Reference No	G47-200114-17			
Date	22nd January 2014			
Sample Period	11:35	to	12:35	
Velocity (m/s)	12.28			
Volume flow rate of Stack gas (m ³ /hr)	17007			
Average Stack Temp (°C)	26.1			
Temp Range ± 5% (°C)	11.10	to	41.00	
Lowest Velocity Reading (m/s)	12.10			
Highest Velocity Reading (m/s)	12.78			
Ratio (less than 3:1)	1.06	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	26.3			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	18.9			
Carbon Dioxide %	0.70			
Moisture (%)	0.00			
Litres sampled	1296			
Corrected volume sampled - STP (m ³)	1.245			
Blank Filter Run weight gain (mg)	0.020		Blank Concentration (mg/m ³)	0.016
Blank Wash Run weight gain (mg)	0.010			0.008
Weighing uncertainty of balance (mg)	0.074	This must be <5% of ELV	ELV = 50	2.5
Overall Blank value (mg/m ³)	0.024	This must be <10% of ELV	ELV = 50	5.0
Particulate weight collected on filter (mg)	0.04			
Particulate weight collected in Wash (mg)	0.40			
Total Particulate weight collected (mg)	0.44			
Total Particulate Concentration, dry gas at STP (mg/m ³)	0.35			
Total Particulate Concentration, wet gas at STP (mg/m ³)	0.35			
Total Particulate Concentration corrected for 11% Oxygen, dry gas (mg/m ³)	N/A			
Total Particulate Mass Emission (kg/hour)	0.006			



APPENDIX B

VOC Raw Data



Scissor 1 Booth 1 - VOC Monitoring					
Date	Time	VOC mg/m ³	Date	Time	VOC mg/m ³
22-Jan-14	10:00:32	24.75	22-Jan-14	10:49:32	75.21
22-Jan-14	10:01:32	24.43	22-Jan-14	10:50:32	72.00
22-Jan-14	10:02:32	23.46	22-Jan-14	10:51:32	8.36
22-Jan-14	10:03:32	22.50	22-Jan-14	10:52:32	0.96
22-Jan-14	10:04:32	21.21	22-Jan-14	10:53:32	0.00
22-Jan-14	10:05:32	19.93	22-Jan-14	10:54:32	0.00
22-Jan-14	10:06:32	20.25	22-Jan-14	10:55:32	0.00
22-Jan-14	10:07:32	18.00	22-Jan-14	10:56:32	0.00
22-Jan-14	10:08:32	17.04	22-Jan-14	10:57:32	0.00
22-Jan-14	10:09:32	16.07	22-Jan-14	10:58:32	0.00
22-Jan-14	10:10:32	15.11	22-Jan-14	10:59:32	4.18
22-Jan-14	10:11:32	38.25	22-Jan-14	11:00:32	27.00
22-Jan-14	10:12:32	14.14			
22-Jan-14	10:13:32	12.54			
22-Jan-14	10:14:32	13.82			
22-Jan-14	10:15:32	11.25			
22-Jan-14	10:16:32	10.29			
22-Jan-14	10:17:32	9.64			
22-Jan-14	10:18:32	10.61			
22-Jan-14	10:19:32	8.68			
22-Jan-14	10:20:32	92.25			
22-Jan-14	10:21:32	90.64			
22-Jan-14	10:22:32	47.57			
22-Jan-14	10:23:32	94.50			
22-Jan-14	10:24:32	19.61			
22-Jan-14	10:25:32	9.32			
22-Jan-14	10:26:32	7.39			
22-Jan-14	10:27:32	82.93			
22-Jan-14	10:28:32	77.46			
22-Jan-14	10:29:32	61.07			
22-Jan-14	10:30:32	25.07			
22-Jan-14	10:31:32	9.00			
22-Jan-14	10:32:32	5.46			
22-Jan-14	10:33:32	4.18			
22-Jan-14	10:34:32	3.21			
22-Jan-14	10:35:32	2.25			
22-Jan-14	10:36:32	2.57			
22-Jan-14	10:37:32	63.00			
22-Jan-14	10:38:32	81.64			
22-Jan-14	10:39:32	83.57			
22-Jan-14	10:40:32	75.21			
22-Jan-14	10:41:32	10.61			
22-Jan-14	10:42:32	3.21			
22-Jan-14	10:43:32	1.29			
22-Jan-14	10:44:32	0.96			
22-Jan-14	10:45:32	0.00			
22-Jan-14	10:46:32	0.00			
22-Jan-14	10:47:32	62.36			
22-Jan-14	10:48:32	89.04			
			Average		26.24
The data represented in this table is expressed at 1 minute intervals but the data used in the chart is produced using 5 second intervals					



Scissor 1 Booth 2 - VOC Monitoring					
Date	Time	VOC mg/m ³	Date	Time	VOC mg/m ³
22-Jan-14	11:02:28	23.14	22-Jan-14	11:51:28	5.46
22-Jan-14	11:03:28	21.21	22-Jan-14	11:52:28	4.82
22-Jan-14	11:04:28	15.27	22-Jan-14	11:53:28	4.82
22-Jan-14	11:05:28	2.89	22-Jan-14	11:54:28	3.86
22-Jan-14	11:06:28	0.00	22-Jan-14	11:55:28	5.79
22-Jan-14	11:07:28	0.00	22-Jan-14	11:56:28	4.18
22-Jan-14	11:08:28	1.29	22-Jan-14	11:57:28	4.50
22-Jan-14	11:09:28	22.18	22-Jan-14	11:58:28	4.50
22-Jan-14	11:10:28	31.18	22-Jan-14	11:59:28	6.43
22-Jan-14	11:11:28	8.68	22-Jan-14	12:00:28	5.14
22-Jan-14	11:12:28	3.86	22-Jan-14	12:01:28	4.50
22-Jan-14	11:13:28	1.61	22-Jan-14	12:02:28	4.18
22-Jan-14	11:14:28	0.96			
22-Jan-14	11:15:28	0.00			
22-Jan-14	11:16:28	0.00			
22-Jan-14	11:17:28	0.00			
22-Jan-14	11:18:28	0.32			
22-Jan-14	11:19:28	41.14			
22-Jan-14	11:20:28	2.89			
22-Jan-14	11:21:28	0.00			
22-Jan-14	11:22:28	0.00			
22-Jan-14	11:23:28	35.68			
22-Jan-14	11:24:28	67.82			
22-Jan-14	11:25:28	42.11			
22-Jan-14	11:26:28	77.14			
22-Jan-14	11:27:28	10.29			
22-Jan-14	11:28:28	1.93			
22-Jan-14	11:29:28	0.00			
22-Jan-14	11:30:28	0.00			
22-Jan-14	11:31:28	73.61			
22-Jan-14	11:32:28	22.50			
22-Jan-14	11:33:28	49.50			
22-Jan-14	11:34:28	0.64			
22-Jan-14	11:35:28	9.64			
22-Jan-14	11:36:28	9.64			
22-Jan-14	11:37:28	1.61			
22-Jan-14	11:38:28	3.54			
22-Jan-14	11:39:28	7.39			
22-Jan-14	11:40:28	6.11			
22-Jan-14	11:41:28	20.25			
22-Jan-14	11:42:28	5.46			
22-Jan-14	11:43:28	7.07			
22-Jan-14	11:44:28	6.43			
22-Jan-14	11:45:28	7.07			
22-Jan-14	11:46:28	8.36			
22-Jan-14	11:47:28	7.71			
22-Jan-14	11:48:28	7.07			
22-Jan-14	11:49:28	6.43			
22-Jan-14	11:50:28	5.79			
			Average		11.97
The data represented in this table is expressed at 1 minute intervals but the data used in the chart is produced using 5 second intervals					



Scissor 2 Booth 1 - VOC Monitoring					
Date	Time	VOC mg/m ³	Date	Time	VOC mg/m ³
22-Jan-14	12:10:03	7.07	22-Jan-14	12:59:03	52.07
22-Jan-14	12:11:03	11.57	22-Jan-14	13:00:03	49.82
22-Jan-14	12:12:03	17.36	22-Jan-14	13:01:03	48.21
22-Jan-14	12:13:03	19.93	22-Jan-14	13:02:03	49.82
22-Jan-14	12:14:03	18.32	22-Jan-14	13:03:03	46.61
22-Jan-14	12:15:03	21.21	22-Jan-14	13:04:03	49.18
22-Jan-14	12:16:03	25.39	22-Jan-14	13:05:03	42.75
22-Jan-14	12:17:03	47.25	22-Jan-14	13:06:03	45.00
22-Jan-14	12:18:03	37.29	22-Jan-14	13:07:03	45.96
22-Jan-14	12:19:03	24.11	22-Jan-14	13:08:03	47.89
22-Jan-14	12:20:03	21.86	22-Jan-14	13:09:03	44.04
22-Jan-14	12:21:03	19.61			
22-Jan-14	12:22:03	22.50			
22-Jan-14	12:23:03	22.50			
22-Jan-14	12:24:03	48.54	Average		28.94
22-Jan-14	12:25:03	27.64			
22-Jan-14	12:26:03	19.61			
22-Jan-14	12:27:03	18.64			
22-Jan-14	12:28:03	17.36			
22-Jan-14	12:29:03	17.68			
22-Jan-14	12:30:03	16.71			
22-Jan-14	12:31:03	17.36			
22-Jan-14	12:32:03	16.71			
22-Jan-14	12:33:03	24.11			
22-Jan-14	12:34:03	16.39			
22-Jan-14	12:35:03	16.39			
22-Jan-14	12:36:03	16.07			
22-Jan-14	12:37:03	16.07			
22-Jan-14	12:38:03	15.75			
22-Jan-14	12:39:03	14.46			
22-Jan-14	12:40:03	13.82			
22-Jan-14	12:41:03	12.86			
22-Jan-14	12:42:03	14.14			
22-Jan-14	12:43:03	13.50			
22-Jan-14	12:44:03	11.25			
22-Jan-14	12:45:03	11.57			
22-Jan-14	12:46:03	10.93			
22-Jan-14	12:47:03	17.36			
22-Jan-14	12:48:03	21.54			
22-Jan-14	12:49:03	25.39			
22-Jan-14	12:50:03	33.43			
22-Jan-14	12:51:03	41.46			
22-Jan-14	12:52:03	39.21			
22-Jan-14	12:53:03	44.36			
22-Jan-14	12:54:03	45.96			
22-Jan-14	12:55:03	54.96			
22-Jan-14	12:56:03	50.79			
22-Jan-14	12:57:03	50.46			
22-Jan-14	12:58:03	51.11			


The data represented in this table is expressed at 1 minute intervals but the data used in the chart is produced using 5 second intervals



APPENDIX C


VOC Charts






Average Run Time			Volatile Organic Compound (ppm)			Volatile Organic Compound (mg/m³)		
			Mean	Max	Min	Mean	Max	Min
10:00	to	10:30	19.22	67.40	4.60	30.89	108.32	7.39
10:30	to	11:00	13.43	60.00	0.00	21.59	96.43	0.00






Average Run Time			Volatile Organic Compound (ppm)			Volatile Organic Compound (mg/m³)		
			Mean	Max	Min	Mean	Max	Min
11:02	to	11:32	10.17	57.80	0.00	16.35	92.89	0.00
11:32	to	12:02	4.74	56.80	0.00	7.62	91.29	0.00





Average Run Time			Volatile Organic Compound (ppm)			Volatile Organic Compound (mg/m³)		
			Mean	Max	Min	Mean	Max	Min
12:10	to	12:40	13.03	39.20	4.40	20.95	63.00	7.07
12:40	to	13:10	22.79	34.20	6.80	36.63	54.96	10.93





Average Run Time			Volatile Organic Compound (ppm)			Volatile Organic Compound (mg/m³)		
			Mean	Max	Min	Mean	Max	Min
13:50	to	14:20	14.31	79.80	0.00	22.99	128.25	0.00
14:20	to	14:50	12.74	24.40	6.00	20.47	39.21	9.64







This document was created with Win2PDF available at <http://www.win2pdf.com>.
The unregistered version of Win2PDF is for evaluation or non-commercial use only.
This page will not be added after purchasing Win2PDF.