



Element Materials Technology, Unit 3, Wednesbury One, Black Country New Road, Wednesbury, WS10 7NZ
Your Element Contact: James Eldridge (07826 916 684)
E: james.eldridge@element.com

Stack Emissions Testing Report Commissioned by
Air Tech Environmental Consultancy Services

Installation Name & Address

Federal-Mogul Coventry Ltd
Holbrook Lane
Holbrook
Coventry
CV6 4BG

PPC Permit: PPC/197

Stack Reference

Main Stack

Dates of the Monitoring Campaign

15th October 2019

Job Reference Number


CAT-5182

Report Written by
David Burns Team Leader MCERTS Level 2 MM 05 579 TE1 TE2 TE3 TE4

Report Approved by
Michelle Edwards Team Leader MCERTS Level 2 MM 05 659 TE1 TE2 TE3 TE4

Report Date
15th November 2019

Version
Version 1



CONTENTS

TITLE PAGE

CONTENTS

EXECUTIVE SUMMARY

Monitoring Objectives	3
Monitoring Results	4
Monitoring Dates & Times	5
Process Details	6
Monitoring & Analytical Methods	7
Summary of Sampling Deviations	7
Sampling Location	8
Plant Photos / Sample Points	9

APPENDIX 1 - Monitoring Personnel & List of Equipment

APPENDIX 2 - Raw Data, Sampling Equations & Charts

Opinions and interpretations expressed herein are outside the scope of Element's ISO 17025 accreditation.

This test report shall not be reproduced, except in full, without the written approval of Element.



Executive Summary

(Page 1 of 7)

MONITORING OBJECTIVES

Federal-Mogul Coventry Ltd, Coventry
Main Stack
15th October 2019

Overall Aim of the Monitoring Campaign

Element, in partnership with Air Tech Environmental Consultancy Services, were commissioned to carry out stack emissions testing on the Main Stack by Federal-Mogul Coventry Ltd at Coventry.

The aim of the monitoring campaign was to demonstrate compliance with a set of emission limit values (ELVs) as specified in the Site's Permit.

Special Requirements

There were no special requirements.

Target Parameters

Total Particulate Matter, Sulphur Dioxide, Heavy Metals, Hydrogen Sulphide, Odour

Executive Summary

(Page 2 of 7)

MONITORING RESULTS

Federal-Mogul Coventry Ltd, Coventry

Main Stack

15th October 2019

where MU = Measurement Uncertainty associated with the Result

Parameter	Concentration				Mass Emission			
	Units	Result	MU +/-	Limit	Units	Result	MU +/-	Limit
Total Particulate Matter ¹	mg/m ³	0.38	0.34	20	g/hr	1.6	1.4	-
Sulphur Dioxide ¹	mg/m ³	3.4	0.31	-	g/hr	13.9	1.5	-
Heavy Metals ¹	mg/m ³	0.022	0.005	0.1	g/hr	0.09	0.02	-
Hydrogen Sulphide ¹	mg/m ³	< 0.34	0.04	5	g/hr	< 1.4	0.19	-
Stack Gas Temperature	°C	28.6						
Stack Gas Velocity	m/s	20.7	0.86					
Volumetric Flow Rate (ACTUAL)	m ³ /hr	4590	282					
Volumetric Flow Rate (REF) ¹	m ³ /hr	4060	249					
Volumetric Flow Rate (REF) ²	m ³ /hr	4357	267					

NOTE: VOLUMETRIC FLOW RATE & VELOCITY DATA TAKEN FROM AN AVERAGE OF ALL OF THE ISOKINETIC RUNS.

¹ Reference Conditions (REF) are: 273K, 101.3kPa, without correction for water vapour content.

RESULTS FROM ODOUR SAMPLES

Parameter	Concentration				Mass Emission			
	Units	Result	LOWER CI	UPPER CI	Units	Result	LO CI	HI CI
Odour - Main Stack ²	ouE/m ³	233	147	368	ouE/s	263	166	415

Where CI stands for Confidence Interval (or Uncertainty associated with the result)

² Reference Conditions (REF) are: 293K, 101.3kPa, without correction for water vapour content

Executive Summary

(Page 3 of 7)

MONITORING DATE(S) & TIMES

Federal-Mogul Coventry Ltd, Coventry
Main Stack
15th October 2019

Parameter	Units	Concentration	Units	Mass Emission	Sampling Date(s)	Sampling Times	Duration mins	
Total Particulate Matter	R1	mg/m ³	0.38	g/hr	1.6	15/10/2019	07:56 - 09:26	90
Sulphur Dioxide	R1	mg/m ³	3.4	g/hr	13.9	15/10/2019	07:56 - 09:26	90
Heavy Metals	R1	mg/m ³	0.02	g/hr	0.09	15/10/2019	10:54 - 12:29	95
Hydrogen Sulphide	R1	mg/m ³	< 0.34	g/hr	< 1.4	15/10/2019	10:54 - 12:29	95
Odour - Main Stack	B1	ouE/m ³	383	ouE/s	432	15/10/2019	09:00 - 09:06	6
Odour - Main Stack	B2	ouE/m ³	181	ouE/s	204	15/10/2019	09:07 - 09:13	6
Odour - Main Stack	B3	ouE/m ³	182	ouE/s	205	15/10/2019	09:15 - 09:21	6
Velocity Traverse	R1					15/10/2019	07:44 - 07:54	

All results are expressed at the respective reference conditions.

Executive Summary

(Page 4 of 7)

PROCESS DETAILS

Federal-Mogul Coventry Ltd, Coventry

Main Stack

15th October 2019

Standard Operating Conditions

Parameter	Value
Process Status	Normal Operation
Capacity (of 100%) and Tonnes / Hour	100% of Capacity
Continuous or Batch Process	Batch
Feedstock (if applicable)	Aluminium Scrap
Abatement System	Bag Filter
Abatement System Running Status	On
Fuel	Natural Gas
Plume Appearance	None Visible

Executive Summary

(Page 5 of 7)

MONITORING & ANALYTICAL METHODS

Federal-Mogul Coventry Ltd, Coventry

Main Stack

15th October 2019

Parameter	Monitoring				Analysis				MCERTS Testing	LOD (Average)
	Standard	Technical Procedure	ISO 17025 Testing	Testing Lab	Analytical Procedure	Analytical Technique	ISO 17025 Analysis	Analysis Lab		
Total Particulate Matter	EN 13284-1	CAT-TP-01	Yes	EET	CAT-TP-03	Gravimetric	Yes	EET	Yes	0.09 mg/m ³
Sulphur Dioxide	EN 14791	CAT-TP-09	Yes	EET	CAT-AP-01	IC	Yes	EET	Yes	0.008 mg/m ³
Heavy Metals	EN 14385	CAT-TP-06	Yes	EET	CAT-AP-07	ICP-MS	Yes	EET	Yes	0.003 mg/m ³
Hydrogen Sulphide	US EPA M11	CAT-TP-15	Yes	EET	M120	Wet Chemistry	Yes	RPS	Yes	0.332 mg/m ³
Odour	BS EN 13725	CAT-TP-30	Yes	EET	QD01	Olfactometry	Yes	ODO	Yes	30 ouE/m ³
Velocity & Vol. Flow Rate	EN 16911-1 (MID)	CAT-TP-41	Yes	EET	Pitot Tube and Thermocouple				Yes	1.2 m/s

ANALYSIS LABORATORIES

(with short name reference as appears in the table above)

Element Stockport (EET)	ISO 17025 Accreditation Number: 4279
RPS Laboratories Ltd (RPS)	ISO 17025 Accreditation Number: 0605
OdourNet UK Ltd (ODO)	ISO 17025 Accreditation Number: 2430

SUMMARY OF SAMPLING DEVIATIONS

Parameter	Run	Deviation
Sulphur Dioxide	All Runs	The absorption efficiency was less than the required 90%. [75 - 90%]
Heavy Metals	All Runs	The absorption efficiency was less than the required 90%. [75 - 90%]
Odour	Run 1	The volume of sample was insufficient to complete a valid analysis accordance of EN 13725. The Estimated odour concentration based on 6 ITE values is 383 OU/m ³

Executive Summary

(Page 6 of 7)

SUITABILITY OF SAMPLING LOCATION

Duct Characteristics

Parameter	Units	Value
Type	-	Circular
Depth	m	0.28
Width	m	-
Area	m ²	0.06
Port Depth	cm	9
Orientation of Duct	-	Vertical
Number of Ports	-	2
Sample Port Size	-	4" BSP

Location of Sampling Platform

General Platform Information	Value
Permanent / Temporary Platform	Permanent
Inside / Outside	Outside

Platform Details

EA Technical Guidance Note M1 / EN 15259 Platform Requirements	Value
Sufficient working area to manipulate probe and operate the measuring instruments	Yes
Platform has 2 levels of handrails (approx. 0.5m & 1.0m high)	Yes
Platform has vertical base boards (approx. 0.25m high)	Yes
Platform has chains / self closing gates at top of ladders	Yes
There are no obstructions present which hamper insertion of sampling equipment	Yes
Safe Access Available	Yes
Easy Access Available	Yes

Sampling Location / Platform Improvement Recommendations

All platforms should be designed in accordance with the requirements in the Environment Agency's Technical Guidance Note M1 and EN 15259.

EN 15259 Homogeneity Test Requirements


There is no requirement to perform a EN 15259 Homogeneity Test on this Stack.

Sampling Plane Validation Criteria (from EN 15259)


Criteria in EN 15259	Units	Traverse 1	Required	Compliant
Lowest Differential Pressure	Pa	345.2	> 5 Pa	Yes
Mean Velocity	m/s	20.51	-	-
Lowest Gas Velocity	m/s	20.51	-	-
Highest Gas Velocity	m/s	20.51	-	-
Ratio of Above	: 1	1.00	< 3 : 1	Yes
Maximum Angle of Swirl	°	0.00	< 15°	Yes
No Local Negative Flow	-	Yes	-	Yes

Executive Summary
 (Page 7 of 7)

PLANT DIAGRAM



SAMPLE POINTS



- where
- = isokinetic point sampled at
 - = isokinetic point not sampled at
 - = combustion gases sample point
 - = non-isokinetic sample point

APPENDICES

APPENDIX CONTENTS

APPENDIX 1 - Stack Emissions Monitoring Personnel, List of Equipment & Methods and Technical Procedures Used

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

STACK EMISSIONS MONITORING PERSONNEL

Position	Name	MCERTS Accreditation	MCERTS Number	Technical Endorsements
Team Leader	David Burns	MCERTS Level 2	MM 05 579	TE1 TE2 TE3 TE4
Technician	Lee Heaton	MCERTS Level 1	MM 18 1433	None

LIST OF EQUIPMENT

Extractive Sampling		Instrumental Analysers		Miscellaneous Items	
Equipment Type	Equipment I.D.	Equipment Type	Equipment I.D.	Equipment Type	Equipment I.D.
Control Box DGM (1)	CAT 7.58	Horiba PG-350E	CAT 39.11	Digital Manometer (1)	CAT 3.143
Control Box DGM (2)	-	Horiba PG-250	-	Digital Manometer (2)	CAT 3.145
Box Thermocouples (1)	CAT 3.148	Servomex 4900	-	Digital Temperature Meter	-
Box Thermocouples (2)	-	Eco Physics CLD 822Mh	-	Stopwatch	CAT 14.86
Umbilical (1)	CAT 3.148	ABB AO2020-URAS26	-	Barometer	CAT 13.41
Umbilical (2)	-	Servomex 5200MP	-	Stack Thermocouple (1)	CAT 4.1113
Oven Box (1)	CAT 12.201	Ankersmid APS 313	CAT 4.848	Stack Thermocouple (2)	CAT 4.1041
Oven Box (2)	-	Gasmet DX4000	-	Stack Thermocouple (3)	CAT 4.0117
Heated Probe (1)	CAT 5.129	Gasmet Sampling System	-	1m Heated Line (1)	-
Heated Probe (2)	CAT 5.130	Bernath 3006 FID	CAT 8.32	1m Heated Line (2)	-
Heated Probe (3)	CAT 5.131	M&C PSS	CAT 12.108	1m Heated Line (3)	-
S-Pitot (1)	CAT 21P.97	Mass Flow Controller (1)	CAT 6.63	5m Heated Line (1)	-
S-Pitot (2)	CAT 21S.56	Mass Flow Controller (2)	CAT 6.64	15m Heated Line (1)	-
L-Pitot	CAT 21L.41	Mass View (1)	CAT 25.61	20m Heated Line (1)	CAT 20.119
Site Balance	CAT 17.38	Mass View (2)	CAT 25.62	20m Heated Line (2)	-
500g / 1Kg Check Weights	CAT 17.38	Hioki 5043 (V)	CAT 11.70	Dual Channel Heater Controller	CAT 3.002
Last Impinger Arm	CAT 4.902/4.903	Easylogger EN-EL-12 Bit	-	Single Channel Heater Controller	CAT 20.119
Callipers	CAT 23.41	Bioaerosols Temperature Logger	-	Laboratory Balance	CAT 1.18, 1.18a, 1.18b
Tubes Kit Thermocouple	-	Electronic Refrigerator	-	Tape Measure	CAT 16.49

METHODS & TECHNICAL PROCEDURES USED

Parameter	Standard	Technical Procedure
Total Particulate Matter	EN 13284-1	CAT-TP-01
Sulphur Dioxide	EN 14791	CAT-TP-09
Heavy Metals	EN 14385	CAT-TP-06
Hydrogen Sulphide	US EPA M11	CAT-TP-15
Odour	BS EN 13725	CAT-TP-30
Velocity & Vol. Flow Rate	EN 16911-1 (MID)	CAT-TP-41

PRELIMINARY STACK SURVEY: CALCULATIONS

General Stack Details

Stack Details (from Traverse)	Units	Value
Stack Diameter / Depth, D	m	0.28
Stack Width, W	m	-
Stack Area, A	m ²	0.06
Average Stack Gas Temperature, T _a	°C	25.0
Average Stack Gas Pressure	Pa	345.2
Average Stack Static Pressure, P _{static}	kPa	0.110
Average Barometric Pressure, P _b	kPa	98.9
Average Pitot Tube Calibration Coefficient, C _p	-	0.84

Stack Gas Composition & Molecular Weights

Component	Conc ppm	Conc Dry % v/v	Conc Wet % v/v	Volume Fraction r	Molar Mass M	Density kg/m ³ ρ	Conc kg/m ³ ρ _i
CO ₂ (Estimated)	-	2.00	1.97	0.0200	44.01	1.9635	0.03927
O ₂ (Estimated)	-	19.00	18.74	0.1900	32.00	1.4277	0.27126
N ₂	-	79.00	77.91	0.7900	28.01	1.2498	0.98738
Moisture (H ₂ O)	-	-	1.38	0.0138	18.02	0.8037	0.01109

Where: $\rho = M / 22.41$
 $\rho_i = r \times \rho$

Calculation of Stack Gas Densities

Determinand	Units	Result
Dry Density (STP), P _{STD}	kg/m ³	1.298
Wet Density (STP), P _{STW}	kg/m ³	1.291
Dry Density (Actual), P _{Actual}	kg/m ³	1.162
Average Wet Density (Actual), P _{ActualW}	kg/m ³	1.156

Where: P_{STD} = sum of component concentrations, kg/m³ (not including water vapour)
P_{STW} = sum of all wet concentrations / 100 x density, kg/m³ (including water vapour)
 $P_{Actual} = P_{STD} \times (T_{STP} / (P_{STP})) \times ((P_{static} + P_b) / T_a)$
 $P_{ActualW} \text{ (at each sampling point)} = P_{STW} \times (T_s / P_s) \times (P_a / T_a)$

Calculation of Stack Gas Volumetric Flowrate, Q

Duct gas flow conditions	Units	Actual	REF ¹	REF ²
Temperature	°C	25.0	0.0	20.0
Total Pressure	kPa	99.0	101.3	101.3
Moisture	%	1.38	1.38	1.38

Gas Volumetric Flowrate (from Traverse)	Units	Result
Gas Volumetric Flowrate (Actual)	m ³ /hr	4547
Gas Volumetric Flowrate (STP, Wet)	m ³ /hr	4072
Gas Volumetric Flowrate (STP, Dry)	m ³ /hr	4015
Gas Volumetric Flowrate REF ¹	m ³ /hr	4072
Gas Volumetric Flowrate REF ²	m ³ /hr	4370

APPENDIX 2

PRELIMINARY STACK SURVEY: VELOCITY TRAVERSE TO EN 16911-1 (MID)

(1 of 1)

Parameter	Units	Value
Date of Survey	-	15/10/2019
Time of Survey	-	07:44 - 07:54
Atmospheric Pressure	kPa	98.9
Average Stack Static Pressure	Pa	110
Result of Pitot Stagnation Test	-	Pass
Are Water Droplets Present?	-	No
Device Used	S-Type Pitot with KIMO MP 210 (500Pa)	

Parameter	Units	Value
Initial Pitot Leak Check	-	Pass
Final Pitot Leak Check	-	Pass
Orientation of Duct	-	Vertical
Pitot Tube, C _p	-	0.84
Number of Lines Available	-	1
Number of Lines Used	-	1

Sampling Line A						
Traverse Point	Depth m	ΔP Pa	Temp °C	Wet Density kg/m ³	Velocity m/s	Swirl °
<i>STATIC (Units: Pa)</i>		110.0				
Mean		345.2	25.0	1.156	20.51	
1	0.14	345.2	25.0	1.156	20.51	0.0

PRELIMINARY STACK SURVEY: VELOCITY TRAVERSE TO EN 16911-1 (MID) - MEASUREMENT UNCERTAINTY

(1 of 1)

Performance characteristics (Uncertainty Components)	Uncertainty	Value	Units
Standard Uncertainty on the coefficient of the Pitot Tube	$u(k)$	0.005	-
Standard Uncertainty associated with the mean local dynamic pressures	$u(\Delta p_i)$	7.170	Pa
- Resolution	$u(res)$	0.00087	
- Calibration	$u(cal)$	12.408	
- Drift	$u(drift)$	0.083	
- Lack of Fit	$u(fit)$	37.922	
- Overall corrections to dynamic measurements	$u(Cf)$	50.414	
Standard uncertainty associated with the molar mass of the gas	$u(M)$	0.00003	-
- $\varphi_{O_2,w}$	-	18.738	
- $\varphi_{CO_2,w}$	-	1.972	
- Oxygen, dry	$u(\phi_{O_2,d})$	0.582	
- Carbon Dioxide, dry	$u(\phi_{CO_2,d})$	0.061	
- Water Vapour	$u(\phi_{H_2O})$	0.070	
- Oxygen, wet	$u(\phi_{O_2,w})$	0.574	
- Carbon Dioxide, wet	$u(\phi_{CO_2,w})$	0.060	
Standard uncertainty associated with the stack temperature	$u(T_c)$	1.520	K
Standard uncertainty associated with the absolute pressure in the duct	$u(p_c)$	175.838	Pa
- Atmospheric Pressure	$u(p_{atm})$	175.692	
- Static Pressure	$u(p_{stat})$	7.170	
Standard uncertainty associated with the density in the duct	$u(\rho)$	0.00625	-
Standard uncertainty associated with the local velocities	$u(v_i)$	0.434	Pa
Standard uncertainty associated with the mean velocity	$u(\underline{v})$	0.434	m/s
Standard uncertainty associated with the mean velocity (95% Confidence)	$U_c(v)$	0.850	m/s
Standard uncertainty associated with the mean velocity (95% Confidence), relative	$U_{c,rel}(v)$	4.14	%
Standard uncertainty associated with the volume flow rate (95% Confidence)	$U_c(qV,w)$	279.1	m ³ /hr
- $u^2(a)/a^2$	-	0.00053	
- $u^2(qV,w)/q^2V,w$	-	0.00098	
- $u^2(qV,w)$	-	20275	
- $u(qV,w)$	-	142.4	
Standard uncertainty associated with the volume flow rate (95% Confidence), relative	$U_{c,rel}(qV,w)$	6.14	%

TOTAL PARTICULATE MATTER: RESULTS SUMMARY

Federal-Mogul Coventry Ltd, Coventry
Main Stack

Sample Runs

Parameter	Units	Run 1	Mean
Concentration	mg/m ³	0.38	0.38
Uncertainty	±mg/m ³	0.34	0.34
Mass Emission	g/hr	1.6	1.6
Uncertainty	±g/hr	1.4	1.4

Parameter	Units	Run 1	Mean
Water Vapour	% v/v	0.86	0.86
Uncertainty	±% v/v	0.05	0.05

Blank Runs

Parameter	Units	Blank 1	Maximum
Concentration	mg/m ³	0.26	0.26

General Sampling Information

Parameter	Value
Standard	EN 13284-1
Technical Procedure	CAT-TP-01
Probe Material	Titanium
Filter Housing Material	Titanium
Positioning of Filter	In Stack
Filter Size and Material	47mm Glass Fibre
Number of Sampling Lines Used	1 / 1
Number of Sampling Points Used	1 / 1
Sample Point I.D.'s	A1

FORMAT: Number Used / Number Required

FORMAT: Number Used / Number Required

Reference Conditions

Reference Conditions are: 273K, 101.3kPa, without correction for water vapour content.

TOTAL PARTICULATE MATTER: ISOKINETIC SAMPLING CALCULATIONS

Test	Units	Run 1	
Absolute pressure of stack gas, P_s			
Barometric pressure, P _b	mmHg	741.8	
Stack static pressure, P _{static}	mmH ₂ O	11.2	
P _s = (P _b + (P _{static} / 13.6))	mmHg	742.6	
Volume of water vapour collected, V_{wstd}			
Total mass collected in impingers (liquid trap)	g	7.0	
Total mass collected in impingers (silica trap)	g	6.5	
Total mass of liquid collected, V _{lc}	g	13.5	
V _{wstd} = (0.001246)(V _{lc})	m ³	0.0168	
Volume of gas metered dry, V_{mstd}			
Volume of gas sample through gas meter, V _m	m ³	2.1490	
Gas meter correction factor, Y _d	-	0.9790	
Average dry gas meter temperature, T _m	°C	18.0	
Average pressure drop across orifice, ΔH	mmH ₂ O	56.4	
V _{mstd} = ((0.3592)(V _m)(P _b + (ΔH/13.6))(Y _d) / (T _m + 273))	m ³	1.9371	
Moisture content, B_{wv} & R_{wv}			
B _{wv} = V _{wstd} / (V _{mstd} + V _{wstd})	m ³	0.0086	
B _{wv} as a percentage	% v/v	0.86	
Reported Water Vapour, checked with Tables in EN 14790, R _{wv}	% v/v	0.86	
Volume of gas metered wet, V_{mstw}			
V _{mstw} = (V _{mstd})(100/(100 - R _{wv}))	m ³	1.9539	
Volume of gas metered at Oxygen Reference Conditions, V_{mstd@X%O₂} & V_{mstw@X%O₂}			
IED & Incinerates Hazardous Material? (Yes = no positive O ₂ correction)	-	No	
% wet oxygen measured in gas stream, ACT%O _{2w}	% v/v	N/A	
% dry oxygen measured in gas stream, ACT%O _{2d}	% v/v	N/A	
% oxygen reference condition, REF%O ₂	% v/v	N/A	
O ₂ Reference Factor wet (O _{2REFw}) = (21 - REF%O ₂) / (21 - ACT%O _{2w})	-	N/A	
O ₂ Reference Factor dry (O _{2REFd}) = (21 - REF%O ₂) / (21 - ACT%O _{2d})	-	N/A	
V _{mstw@X%oxygen} = (V _{mstw}) / (O _{2REFw})	m ³	N/A	
V _{mstd@X%oxygen} = (V _{mstd}) / (O _{2REFd})	m ³	N/A	
Molecular weight of dry gas stream, M_d			
CO ₂ (Estimated)	% v/v	2.00	
O ₂ (Estimated)	% v/v	19.00	
Total	% v/v	21.00	
N ₂	% v/v	79.00	
M _d = 0.44(%CO ₂)+0.32(%O ₂)+0.28(%N ₂)	g/gmol	29.08	
Molecular weight of stack gas (wet), M_s			
M _s = M _d (1 - (R _{wv} /100)) + 18(R _{wv} /100)	g/gmol	28.98	
Velocity of stack gas, V_s			
Pitot tube velocity constant, K _p	-	34.97	
Velocity pressure coefficient, C _p	-	0.86	
Average of velocity heads, ΔP _{avg}	mmH ₂ O	34.00	
Average square root of velocity heads, √ΔP	√mmH ₂ O	5.83	
Average stack gas temperature, T _s	°C	29.5	
V _s = ((K _p)(C _p)(√ΔP)(√T _s + 273)) / (√(M _s)(P _s))	m/s	20.72	
Total flow of stack gas: Actual (Q_a), Wet (Q_{stw}), Dry (Q_{std}), Wet@O_{2REF} (Q_{stwO₂}), Dry@O_{2REF} (Q_{stdO₂})			
Area of stack, A _s	m ²	0.06	
Q _a = (60)(A _s)(V _s)	m ³ /min	76.5	
Conversion factor (K/mm.Hg), C _f	-	0.3592	
Q _{stw} = ((Q _a)(P _s)(C _f) / ((T _s + 273))	m ³ /min	67.5	
Q _{std} = ((Q _a)(P _s)(C _f)(1 - (R _{wv} /100))) / ((T _s + 273))	m ³ /min	66.9	
Q _{stwO₂} = ((Q _a)(P _s)(C _f) / ((T _s + 273)) / (O _{2REFw})	m ³ /min	N/A	
Q _{stdO₂} = ((Q _a)(P _s)(C _f)(1 - (R _{wv} /100))) / ((T _s + 273)) / (O _{2REFd})	m ³ /min	N/A	
Percent isokinetic, %I			
Nozzle diameter, D _n	mm	4.95	
Nozzle area, A _n	mm ²	19.25	
Total sampling time, q	min	90	
%I = (4.6398E ⁶)(T _s +273)(V _{mstd}) / (P _s)(V _s)(A _n)(q)(1 - (R _{wv} /100))	%	102.9	

TOTAL PARTICULATE MATTER: SAMPLING DETAILS

Sample Runs

Parameter	Units	Run 1
Sampling Times	-	07:56 - 09:26
Sampling Dates	-	15/10/2019
Sampling Device	-	ISO
Volume Sampled (REF)	m ³	1.9539
Filter I.D. Number	-	47-60905
Start Filter Mass	g	0.14405
End Filter Mass	g	0.14438
Total Mass on Filter	g	0.00033
Probe Rinse I.D. Number	-	PR-47-60905
Start Probe Rinse Mass	g	2.73022
End Probe Rinse Mass	g	2.73064
Total Mass in Probe Rinse	g	0.00042
Total Mass Collected	mg	0.75
Calculated Concentration	mg/m ³	0.38
Balance Uncertainty / LOD	mg/m ³	0.09

Where: ISO stands for Manual Isokinetic Sampling Train

Blank Runs

Parameter	Units	Blank 1
Blank Dates	-	15/10/2019
Average Volume Sampled (REF)	m ³	1.9539
Filter I.D. Number	-	47-60682
Start Filter Mass	g	0.14286
End Filter Mass	g	0.14314
Total Mass on Filter	g	0.00028
Probe Rinse I.D. Number	-	PR-47-60682
Start Probe Rinse Mass	g	2.73855
End Probe Rinse Mass	g	2.73878
Total Mass in Probe Rinse	g	0.00023
Total Mass Collected	mg	0.51
Calculated Concentration	mg/m ³	0.26
Balance Uncertainty / LOD	mg/m ³	0.09

TOTAL PARTICULATE MATTER: QUALITY ASSURANCE

(PAGE 1 OF 2)

Sample Runs

Leak Test Results	Units	Run 1
Mean Sampling Rate	l/min	23.4
Pre-Sampling Leak Rate	l/min	0.10
Post-Sampling Leak Rate	l/min	0.10
Allowable Leak Rate	l/min	0.47
Leak Test Acceptable	-	Yes

Water Droplets	Units	Run 1
Are Water Droplets Present	-	No

MU (Concurrent Water Vapour)	Units	Run 1
Measurement Uncertainty (MU)	%	5.5
Allowable MU	%	20.0
MU Acceptable	%	Yes

Silica Gel (Concurrent Water Vapour)	Units	Run 1
Less than 50% Faded	%	Yes

Isokinetic Criterion Compliance	Units	Run 1
Isokinetic Variation	%	102.9
Allowable Isokinetic Range	%	95 - 115
Isokineticity Acceptable	-	Yes

Weighing Uncertainty Criteria	Units	Run 1
Overall Weighing Uncertainty	± mg	0.32
Overall Weighing Uncertainty	± mg/m ³	0.16
ELV [Daily ELV for IED]	mg/m ³	20.00
Allowable Weighing Uncertainty	mg/m ³	1.00
Weighing Uncertainty Acceptable	-	Yes

Filter Temperatures	Units	Run 1
Pre-Conditioning Temperature	°C	180
Post-Conditioning Temperature	°C	160
Maximum Filter Temperature	°C	31

Test Conditions	Units	Run 1
Ambient Temperature Recorded?	-	Yes

TOTAL PARTICULATE MATTER: QUALITY ASSURANCE

(PAGE 2 OF 2)

Blank Runs

Leak Test Results	Units	Blank 1
Expected Sampling Rate	l/min	18.0
Pre-Sampling Leak Rate	l/min	0.10
Post-Sampling Leak Rate	l/min	0.10
Allowable Leak Rate	l/min	0.36
Leak Test Acceptable	-	Yes

Validity of Blank vs ELV	Units	Blank 1
Allowable Blank	mg/m ³	2.0
Blank Acceptable	-	Yes

Acetone / Water Rinse Blank	Units	Blank
Acetone / Water Rinse Value	mg/l	2.7
Allowable Blank	mg/l	10
Blank Acceptable	-	Yes

Method Deviations

Nature of Deviation	Run Number
(x = deviation applies to the associated run, wx = deviation also applies to the concurrent water vapour run)	1
There are no deviations associated with the sampling employed.	x

TOTAL PARTICULATE MATTER: MEASUREMENT UNCERTAINTY CALCULATIONS

Measured Quantities	Value		Standard uncertainty		
	Symbol	Run 1	Symbol	Units	Run 1
Sampled Volume (Actual)	V _m	2.1490	uV _m	m ³	0.0430
Sampled Gas Temperature	T _m	291.0	uT _m	K	2.0
Sampled Gas Pressure	p _m	99.0	uρ _m	kPa	0.5
Sampled Gas Humidity	H _m	0.0	uH _m	% v/v	1.0
Leak	L	0.43	uL	%	-
Mass of Particulate	m	0.75	um	mg	0.17
Uncollected Mass	UCM	0.51	uUCM	mg	-

Measured Quantities	Uncertainty as a Percentage		Requirement of Standard
	Units	Run 1	
Sampled Volume (Actual)	%	2.00	≤2%
Sampled Gas Temperature	%	0.69	≤1%
Sampled Gas Pressure	%	0.50	≤1%
Sampled Gas Humidity	%	1.00	≤1%
Leak	%	0.43	≤2%
Mass of Particulate	%	0.44	<5% of ELV
Uncollected Mass	%	-	-

Measured Quantities	Uncertainty in Measurement Units			Sensitivity Coefficient	
	Symbol	Units	Run 1	Run 1	
Sampled Volume (STP)	V _m	m ³	1.9371	0.20	
Leak	L	mg/m ³	0.001	1.00	
Mass of Particulate	L _r	mg	0.750	0.51	
Uncollected Mass	UCM	mg	0.30	0.51	

Measured Quantities	Uncertainty in Result	
	Units	Run 1
Sampled Volume (STP)	mg/m ³	0.010
Leak	mg/m ³	0.0009
Mass of Particulate	mg/m ³	0.0870
Uncollected Mass	mg/m ³	0.1517

Measured Quantities	Oxygen Correction Part of MU Budget	
	Units	Run 1
O ₂ Correction Factor	-	N/A
Stack Gas O ₂ Content	% v/v	N/A
MU for O ₂ Correction	-	N/A
Overall MU For O ₂ Measurement	%	N/A

Parameter	Units	Run 1
Combined uncertainty	mg/m ³	0.18
Expanded uncertainty (95% confidence), without Oxygen Correction	mg/m ³	0.34
Expanded uncertainty (95% confidence), with Oxygen Correction	mg/m ³	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	mg/m ³	0.34
Reported Uncertainty	mg/m ³	0.34
Expanded uncertainty (95% confidence), without Oxygen Correction	%	89.4
Expanded uncertainty (95% confidence), with Oxygen Correction	%	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	%	89.4
Reported Uncertainty	%	89.4

SULPHUR DIOXIDE: RESULTS SUMMARY

Federal-Mogul Coventry Ltd, Coventry
Main Stack

Sample Runs

Parameter	Units	Run 1	Mean
Concentration	mg/m ³	3.4	3.4
Uncertainty	±mg/m ³	0.31	0.31
Mass Emission	g/hr	13.9	13.9
Uncertainty	±g/hr	1.5	1.5

Parameter	Units	Run 1	Mean
Water Vapour	% v/v	0.86	0.86
Uncertainty	±% v/v	0.05	0.05

Blank Runs

Parameter	Units	Blank 1	Maximum
Concentration	mg/m ³	< 0.01	< 0.01

General Sampling Information

Parameter	Value
Standard	EN 14791
Technical Procedure	CAT-TP-09
Name of Analytical Laboratory	EET
Analytical Laboratory's Procedure	CAT-AP-01
ISO 17025 Accredited Analysis?	Yes
Date of Sample Analysis	23/10/2019
Probe Material	Titanium
Filter Housing Material	Titanium
Impinger Material	Polyethylene
Absorption Solution	0.3% Hydrogen Peroxide
Positioning of Filter	In Stack
Filter Size and Material	47mm Glass Fibre
Number of Sampling Lines Used	1 / 1
Number of Sampling Points Used	1 / 1
Sample Point I.D.'s	A1

FORMAT: Number Used / Number Required

FORMAT: Number Used / Number Required

Reference Conditions

Reference Conditions are: 273K, 101.3kPa, without correction for water vapour content.

SULPHUR DIOXIDE: ISOKINETIC SAMPLING CALCULATIONS

Test	Units	Run 1	
Absolute pressure of stack gas, P_s			
Barometric pressure, P _b	mmHg	741.8	
Stack static pressure, P _{static}	mmH ₂ O	11.2	
$P_s = (P_b + (P_{static} / 13.6))$	mmHg	742.6	
Volume of water vapour collected, V_{wstd}			
Total mass collected in impingers (liquid trap)	g	7.0	
Total mass collected in impingers (silica trap)	g	6.5	
Total mass of liquid collected, V _{lc}	g	13.5	
$V_{wstd} = (0.001246)(V_{lc})$	m ³	0.0168	
Volume of gas metered dry, V_{mstd}			
Volume of gas sample through gas meter, V _m	m ³	2.1490	
Gas meter correction factor, Y _d	-	0.9790	
Average dry gas meter temperature, T _m	°C	18.0	
Average pressure drop across orifice, ΔH	mmH ₂ O	56.4	
$V_{mstd} = ((0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d) / (T_m + 273))$	m ³	1.9371	
Moisture content, B_{wo} & R_{wv}			
$B_{wo} = V_{wstd} / (V_{mstd} + V_{wstd})$	m ³	0.0086	
B _{wo} as a percentage	% v/v	0.86	
Reported Water Vapour, checked with Tables in EN 14790, R _{wv}	% v/v	0.86	
Volume of gas metered wet, V_{mstw}			
$V_{mstw} = (V_{mstd})(100/(100 - R_{wv}))$	m ³	1.9539	
Volume of gas metered at Oxygen Reference Conditions, V_{mstd@X%O₂} & V_{mstw@X%O₂}			
IED & Incinerates Hazardous Material? (Yes = no positive O ₂ correction)	-	No	
% wet oxygen measured in gas stream, ACT%O _{2w}	% v/v	N/A	
% dry oxygen measured in gas stream, ACT%O _{2d}	% v/v	N/A	
% oxygen reference condition, REF%O ₂	% v/v	N/A	
O ₂ Reference Factor wet (O _{2REFw}) = (21 - REF%O ₂) / (21 - ACT%O _{2w})	-	N/A	
O ₂ Reference Factor dry (O _{2REFd}) = (21 - REF%O ₂) / (21 - ACT%O _{2d})	-	N/A	
$V_{mstw@X\%oxygen} = (V_{mstw}) / (O_{2REFw})$	m ³	N/A	
$V_{mstd@X\%oxygen} = (V_{mstd}) / (O_{2REFd})$	m ³	N/A	
Molecular weight of dry gas stream, M_d			
CO ₂ (Estimated)	% v/v	2.00	
O ₂ (Estimated)	% v/v	19.00	
Total	% v/v	21.00	
N ₂	% v/v	79.00	
$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$	g/gmol	29.08	
Molecular weight of stack gas (wet), M_s			
$M_s = M_d(1 - (R_{wv}/100)) + 18(R_{wv}/100)$	g/gmol	28.98	
Velocity of stack gas, V_s			
Pitot tube velocity constant, K _p	-	34.97	
Velocity pressure coefficient, C _p	-	0.86	
Average of velocity heads, ΔP _{avg}	mmH ₂ O	34.00	
Average square root of velocity heads, √ΔP	√mmH ₂ O	5.83	
Average stack gas temperature, T _s	°C	29.5	
$V_s = ((K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})) / (\sqrt{M_s}(P_s))$	m/s	20.72	
Total flow of stack gas: Actual (Q_a), Wet (Q_{stw}), Dry (Q_{std}), Wet@O_{2REF} (Q_{stwO₂}), Dry@O_{2REF} (Q_{stdO₂})			
Area of stack, A _s	m ²	0.06	
$Q_a = (60)(A_s)(V_s)$	m ³ /min	76.5	
Conversion factor (K/mm.Hg), C _f	-	0.3592	
$Q_{stw} = ((Q_a)(P_s)(C_f)) / ((T_s) + 273)$	m ³ /min	67.5	
$Q_{std} = ((Q_a)(P_s)(C_f)(1 - (R_{wv}/100))) / ((T_s) + 273)$	m ³ /min	66.9	
$Q_{stwO_2} = ((Q_a)(P_s)(C_f)) / ((T_s) + 273) / (O_{2REFw})$	m ³ /min	N/A	
$Q_{stdO_2} = ((Q_a)(P_s)(C_f)(1 - (R_{wv}/100))) / ((T_s) + 273) / (O_{2REFd})$	m ³ /min	N/A	
Percent isokinetic, %I			
Nozzle diameter, D _n	mm	4.95	
Nozzle area, A _n	mm ²	19.25	
Total sampling time, q	min	90	
$\%I = (4.6398E^6)(T_s+273)(V_{mstd}) / (P_s)(V_s)(A_n)(q)(1 - (R_{wv}/100))$	%	102.9	

SULPHUR DIOXIDE: SAMPLING DETAILS

Sample Runs

Parameter	Units	Run 1
Sampling Times	-	07:56 - 09:26
Sampling Dates	-	15/10/2019
Sampling Device	-	ISO
Volume Sampled (REF)	m ³	1.9539
Laboratory Result for Front Impingers	µg/ml	26.53
Laboratory Result for Back Impinger	µg/ml	10.47
Volume in Front Impingers	ml	211.8
Volume in Back Impinger	ml	101.2
Mass in Front Impingers	µg	5619.1
Mass in Back Impinger	µg	1059.6
Total Mass Collected	µg	6678.6
Calculated Concentration	mg/m ³	3.42

Where: ISO stands for Manual Isokinetic Sampling Train

Blank Runs

Parameter	Units	Blank 1
Blank Dates	-	15/10/2019
Average Volume Sampled (REF)	m ³	1.9539
Laboratory Result for Impingers	µg/ml	< 0.05
Volume in Impingers	ml	308.2
Total Mass Collected	µg	< 15.4
Calculated Concentration	mg/m ³	< 0.01

SULPHUR DIOXIDE: QUALITY ASSURANCE

(PAGE 1 OF 2)

Sample Runs

Leak Test Results	Units	Run 1
Mean Sampling Rate	l/min	23.4
Pre-Sampling Leak Rate	l/min	0.10
Post-Sampling Leak Rate	l/min	0.10
Allowable Leak Rate	l/min	0.47
Leak Test Acceptable	-	Yes

Absorption Efficiency	Units	Run 1
Absorption Efficiency	%	84.1
Allowable Absorption Efficiency	%	95
Absorption Efficiency Acceptable	-	No

Water Droplets	Units	Run 1
Are Water Droplets Present	-	No

MU (Concurrent Water Vapour)	Units	Run 1
Measurement Uncertainty (MU)	%	5.5
Allowable MU	%	20.0
MU Acceptable	%	Yes

Silica Gel (Concurrent Water Vapour)	Units	Run 1
Less than 50% Faded	%	Yes

Isokinetic Criterion Compliance	Units	Run 1
Isokinetic Variation	%	102.9
Allowable Isokinetic Range	%	95 - 115
Isokineticity Acceptable	-	Yes

Filter Temperatures	Units	Run 1
Maximum Filter Temperature	°C	30

Test Conditions	Units	Run 1
Ambient Temperature Recorded?	-	Yes

SULPHUR DIOXIDE: QUALITY ASSURANCE

(PAGE 2 OF 2)

Blank Runs

Leak Test Results	Units	Blank 1
Expected Sampling Rate	l/min	18.0
Pre-Sampling Leak Rate	l/min	0.10
Post-Sampling Leak Rate	l/min	0.10
Allowable Leak Rate	l/min	0.36
Leak Test Acceptable	-	Yes

Validity of Blank vs ELV	Units	Blank 1
Allowable Blank	mg/m ³	N/A
Blank Acceptable	-	N/A

Method Deviations

Nature of Deviation	Run Number
(x = deviation applies to the associated run, wx = deviation also applies to the concurrent water vapour run)	1
The absorption efficiency was less than the required 90%. [75 - 90%]	wx

SULPHUR DIOXIDE: MEASUREMENT UNCERTAINTY CALCULATIONS

Measured Quantities	Value		Standard uncertainty		
	Symbol	Run 1	Symbol	Units	Run 1
Sampled Volume (Actual)	V _m	2.1490	uV _m	m ³	0.0430
Sampled Gas Temperature	T _m	291.0	uT _m	K	2.0
Sampled Gas Pressure	p _m	99.0	uρ _m	kPa	0.5
Sampled Gas Humidity	H _m	0.0	uH _m	% v/v	1.0
Leak	L	0.43	uL	%	-
Laboratory Result	L _r	2.90	uL _r	%	-

Measured Quantities	Uncertainty as a Percentage		Requirement of Standard
	Units	Run 1	
Sampled Volume (Actual)	%	2.00	≤2%
Sampled Gas Temperature	%	0.69	≤1%
Sampled Gas Pressure	%	0.50	≤1%
Sampled Gas Humidity	%	1.00	≤1%
Leak	%	0.43	≤2%
Laboratory Result	%	2.90	No Requirement

Measured Quantities	Uncertainty in Measurement Units			Sensitivity Coefficient	
	Symbol	Units	Run 1	Run 1	
Sampled Volume (STP)	V _m	m ³	1.9371	1.76	
Leak	L	mg/m ³	0.008	1.00	
Laboratory Result	L _r	mg/m ³	0.099	1.00	

Measured Quantities	Uncertainty in Result	
	Units	Run 1
Sampled Volume (STP)	mg/m ³	0.088
Leak	mg/m ³	0.0084
Laboratory Result	mg/m ³	0.0991

Measured Quantities	Oxygen Correction Part of MU Budget	
	Units	Run 1
O ₂ Correction Factor	-	N/A
Stack Gas O ₂ Content	% v/v	N/A
MU for O ₂ Correction	-	N/A
Overall MU For O ₂ Measurement	%	N/A

Parameter	Units	Run 1
Combined uncertainty	mg/m ³	0.13
Expanded uncertainty (95% confidence), without Oxygen Correction	mg/m ³	0.26
Expanded uncertainty (95% confidence), with Oxygen Correction	mg/m ³	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	mg/m ³	0.31
Reported Uncertainty	mg/m ³	0.31
Expanded uncertainty (95% confidence), without Oxygen Correction	%	7.6
Expanded uncertainty (95% confidence), with Oxygen Correction	%	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	%	9.1
Reported Uncertainty	%	9.1

HEAVY METALS: RESULTS SUMMARY

Federal-Mogul Coventry Ltd, Coventry
Main Stack

Sample Runs

Parameter	Units	Run 1	Mean
Concentration	mg/m ³	0.02	0.02
Uncertainty	±mg/m ³	0.005	0.005
Mass Emission	g/hr	0.09	0.09
Uncertainty	±g/hr	0.02	0.02

Parameter	Units	Run 1	Mean
Water Vapour	% v/v	2.3	2.3
Uncertainty	±% v/v	0.14	0.14

Blank Runs

Parameter	Units	Blank 1	Maximum
Concentration	mg/m ³	0.003	0.003

General Sampling Information

Parameter	Value
Standard	EN 14385
Technical Procedure	CAT-TP-06
Name of Analytical Laboratory	EET
Analytical Laboratory's Procedure	CAT-AP-07
ISO 17025 Accredited Analysis?	Yes
Date of Sample Analysis	25/10/2019
Probe Material	Titanium
Filter Housing Material	Titanium
Impinger Material	Borosilicate Glass
Absorption Solution	Nitric Peroxide
Positioning of Filter	Out Stack
Filter Size and Material	47mm Quartz Fibre
Number of Sampling Lines Used	1 / 1
Number of Sampling Points Used	1 / 1
Sample Point I.D.'s	A1

FORMAT: Number Used / Number Required

FORMAT: Number Used / Number Required

Reference Conditions

Reference Conditions are: 273K, 101.3kPa, without correction for water vapour content.

HEAVY METALS: ISOKINETIC SAMPLING CALCULATIONS

Test	Units	Run 1	
Absolute pressure of stack gas, P_s			
Barometric pressure, P _b	mmHg	741.8	
Stack static pressure, P _{static}	mmH ₂ O	11.2	
$P_s = (P_b + (P_{static} / 13.6))$	mmHg	742.6	
Volume of water vapour collected, V_{wstd}			
Total mass collected in impingers (liquid trap)	g	31.5	
Total mass collected in impingers (silica trap)	g	6.5	
Total mass of liquid collected, V _{lc}	g	38.0	
$V_{wstd} = (0.001246)(V_{lc})$	m ³	0.0473	
Volume of gas metered dry, V_{mstd}			
Volume of gas sample through gas meter, V _m	m ³	2.2990	
Gas meter correction factor, Y _d	-	0.9790	
Average dry gas meter temperature, T _m	°C	21.3	
Average pressure drop across orifice, ΔH	mmH ₂ O	57.5	
$V_{mstd} = ((0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)) / (T_m + 273)$	m ³	2.0490	
Moisture content, B_{wo} & R_{wv}			
$B_{wo} = V_{wstd} / (V_{mstd} + V_{wstd})$	m ³	0.0226	
B _{wo} as a percentage	% v/v	2.26	
Reported Water Vapour, checked with Tables in EN 14790, R _{wv}	% v/v	2.26	
Volume of gas metered wet, V_{mstw}			
$V_{mstw} = (V_{mstd})(100/(100 - R_{wv}))$	m ³	2.0964	
Volume of gas metered at Oxygen Reference Conditions, V_{mstd@X%O₂} & V_{mstw@X%O₂}			
IED & Incinerates Hazardous Material? (Yes = no positive O ₂ correction)	-	No	
% wet oxygen measured in gas stream, ACT%O _{2w}	% v/v	N/A	
% dry oxygen measured in gas stream, ACT%O _{2d}	% v/v	N/A	
% oxygen reference condition, REF%O ₂	% v/v	N/A	
O ₂ Reference Factor wet ($O_{2REFw} = (21 - REF\%O_2) / (21 - ACT\%O_{2w})$)	-	N/A	
O ₂ Reference Factor dry ($O_{2REFd} = (21 - REF\%O_2) / (21 - ACT\%O_{2d})$)	-	N/A	
$V_{mstw@X\%oxygen} = (V_{mstw}) / (O_{2REFw})$	m ³	N/A	
$V_{mstd@X\%oxygen} = (V_{mstd}) / (O_{2REFd})$	m ³	N/A	
Molecular weight of dry gas stream, M_d			
CO ₂ (Estimated)	% v/v	2.00	
O ₂ (Estimated)	% v/v	19.00	
Total	% v/v	21.00	
N ₂	% v/v	79.00	
$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$	g/gmol	29.08	
Molecular weight of stack gas (wet), M_s			
$M_s = M_d(1 - (R_{wv}/100)) + 18(R_{wv}/100)$	g/gmol	28.83	
Velocity of stack gas, V_s			
Pitot tube velocity constant, K _p	-	34.97	
Velocity pressure coefficient, C _p	-	0.86	
Average of velocity heads, ΔP _{avg}	mmH ₂ O	34.00	
Average square root of velocity heads, √ΔP	√mmH ₂ O	5.83	
Average stack gas temperature, T _s	°C	26.7	
$V_s = ((K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})) / (\sqrt{M_s}(P_s))$	m/s	20.68	
Total flow of stack gas: Actual (Q_a), Wet (Q_{stw}), Dry (Q_{std}), Wet@O_{2REF} (Q_{stwO₂}), Dry@O_{2REF} (Q_{stdO₂})			
Area of stack, A _s	m ²	0.06	
$Q_a = (60)(A_s)(V_s)$	m ³ /min	76.4	
Conversion factor (K/mm.Hg), C _f	-	0.3592	
$Q_{stw} = ((Q_a)(P_s)(C_f)) / ((T_s) + 273)$	m ³ /min	68.0	
$Q_{std} = ((Q_a)(P_s)(C_f)(1 - (R_{wv}/100))) / ((T_s) + 273)$	m ³ /min	66.5	
$Q_{stwO_2} = ((Q_a)(P_s)(C_f)) / ((T_s) + 273) / (O_{2REFw})$	m ³ /min	N/A	
$Q_{stdO_2} = ((Q_a)(P_s)(C_f)(1 - (R_{wv}/100))) / ((T_s) + 273) / (O_{2REFd})$	m ³ /min	N/A	
Percent isokinetic, %I			
Nozzle diameter, D _n	mm	4.95	
Nozzle area, A _n	mm ²	19.25	
Total sampling time, q	min	95	
$\%I = (4.6398E^6)(T_s+273)(V_{mstd}) / (P_s)(V_s)(A_n)(q)(1 - (R_{wv}/100))$	%	103.8	

HEAVY METALS: SAMPLING DETAILS

(PAGE 1 OF 5)

Sample Runs

Parameter	Units	Run 1
Sampling Times	-	10:54 - 12:29
Sampling Dates	-	15/10/2019
Sampling Device	-	ISO
Volume Sampled (REF)	m ³	2.0964
Arsenic		
Mass on Filter / in Rinse	µg	< 0.50
Mass in Front Impingers	µg	< 0.08
Mass in Back Impinger	µg	0.04
Total Mass Collected	µg	0.63
Calculated Concentration	mg/m ³	0.0003
Reported Concentration	mg/m ³	0.0003
Mass Emission	g/hr	0.00
Cobalt		
Mass on Filter / in Rinse	µg	0.51
Mass in Front Impingers	µg	0.76
Mass in Back Impinger	µg	0.13
Total Mass Collected	µg	1.40
Calculated Concentration	mg/m ³	0.0007
Reported Concentration	mg/m ³	0.0007
Mass Emission	g/hr	0.00
Chromium		
Mass on Filter / in Rinse	µg	0.95
Mass in Front Impingers	µg	0.52
Mass in Back Impinger	µg	0.30
Total Mass Collected	µg	1.77
Calculated Concentration	mg/m ³	0.0008
Reported Concentration	mg/m ³	0.0008
Mass Emission	g/hr	0.00
Copper		
Mass on Filter / in Rinse	µg	11.09
Mass in Front Impingers	µg	0.61
Mass in Back Impinger	µg	0.10
Total Mass Collected	µg	11.80
Calculated Concentration	mg/m ³	0.0056
Reported Concentration	mg/m ³	0.0056
Mass Emission	g/hr	0.02
Manganese		
Mass on Filter / in Rinse	µg	20.52
Mass in Front Impingers	µg	1.32
Mass in Back Impinger	µg	0.21
Total Mass Collected	µg	22.05
Calculated Concentration	mg/m ³	0.0105
Reported Concentration	mg/m ³	0.0105
Mass Emission	g/hr	0.04

HEAVY METALS: SAMPLING DETAILS

(PAGE 2 OF 5)

Sample Runs (continued)

Parameter	Units	Run 1	
Nickel			
Mass on Filter / in Rinse	µg	1.16	
Mass in Front Impingers	µg	0.19	
Mass in Back Impinger	µg	< 0.03	
Total Mass Collected	µg	1.37	
Calculated Concentration	mg/m ³	0.0007	
Reported Concentration	mg/m ³	0.0007	
Mass Emission	g/hr	0.00	
Lead			
Mass on Filter / in Rinse	µg	3.99	
Mass in Front Impingers	µg	1.65	
Mass in Back Impinger	µg	0.46	
Total Mass Collected	µg	6.10	
Calculated Concentration	mg/m ³	0.0029	
Reported Concentration	mg/m ³	0.0029	
Mass Emission	g/hr	0.01	
Antimony			
Mass on Filter / in Rinse	µg	< 0.60	
Mass in Front Impingers	µg	< 0.06	
Mass in Back Impinger	µg	< 0.03	
Total Mass Collected	µg	< 0.69	
Calculated Concentration	mg/m ³	< 0.0003	
Reported Concentration	mg/m ³	< 0.0003	
Mass Emission	g/hr	< 0.00	
Vanadium			
Mass on Filter / in Rinse	µg	< 0.40	
Mass in Front Impingers	µg	< 0.03	
Mass in Back Impinger	µg	< 0.01	
Total Mass Collected	µg	< 0.44	
Calculated Concentration	mg/m ³	< 0.0002	
Reported Concentration	mg/m ³	< 0.0002	
Mass Emission	g/hr	< 0.00	

HEAVY METALS: SAMPLING DETAILS

(PAGE 3 OF 5)

Sample Runs (continued)

Parameter	Units	Run 1
Heavy Metals Combined		
Total Mass Collected	µg	46.25
Calculated Concentration	mg/m ³	0.0221
Reported Concentration	mg/m ³	0.0221

Where: ISO stands for Manual Isokinetic Sampling Train

Blank Runs

Parameter	Units	Blank 1
Blank Dates	-	15/10/2019
Average Volume Sampled (REF)	m ³	2.0964
Arsenic		
Mass on Filter / in Rinse	µg	< 0.50
Mass in Front Impingers	µg	< 0.06
Mass in Back Impinger	µg	< 0.03
Total Mass Collected	µg	< 0.59
Calculated Concentration	mg/m ³	< 0.0003
Reported Concentration	mg/m ³	< 0.0003
Cobalt		
Mass on Filter / in Rinse	µg	< 0.50
Mass in Front Impingers	µg	< 0.04
Mass in Back Impinger	µg	< 0.02
Total Mass Collected	µg	< 0.56
Calculated Concentration	mg/m ³	< 0.0003
Reported Concentration	mg/m ³	< 0.0003

HEAVY METALS: SAMPLING DETAILS

(PAGE 4 OF 5)

Blank Runs (continued)

Parameter	Units	Blank 1	
Chromium			
Mass on Filter / in Rinse	µg	< 0.60	
Mass in Front Impingers	µg	< 0.02	
Mass in Back Impinger	µg	< 0.01	
Total Mass Collected	µg	< 0.63	
Calculated Concentration	mg/m ³	< 0.0003	
Reported Concentration	mg/m ³	< 0.0003	
Copper			
Mass on Filter / in Rinse	µg	< 0.60	
Mass in Front Impingers	µg	< 0.08	
Mass in Back Impinger	µg	< 0.04	
Total Mass Collected	µg	< 0.73	
Calculated Concentration	mg/m ³	< 0.0003	
Reported Concentration	mg/m ³	< 0.0003	
Manganese			
Mass on Filter / in Rinse	µg	< 0.40	
Mass in Front Impingers	µg	< 0.04	
Mass in Back Impinger	µg	0.03	
Total Mass Collected	µg	< 0.48	
Calculated Concentration	mg/m ³	< 0.0002	
Reported Concentration	mg/m ³	< 0.0002	
Nickel			
Mass on Filter / in Rinse	µg	0.75	
Mass in Front Impingers	µg	< 0.04	
Mass in Back Impinger	µg	< 0.02	
Total Mass Collected	µg	0.81	
Calculated Concentration	mg/m ³	0.0004	
Reported Concentration	mg/m ³	0.0004	
Lead			
Mass on Filter / in Rinse	µg	< 0.50	
Mass in Front Impingers	µg	< 0.04	
Mass in Back Impinger	µg	< 0.02	
Total Mass Collected	µg	< 0.56	
Calculated Concentration	mg/m ³	< 0.0003	
Reported Concentration	mg/m ³	< 0.0003	
Antimony			
Mass on Filter / in Rinse	µg	< 0.60	
Mass in Front Impingers	µg	< 0.04	
Mass in Back Impinger	µg	< 0.02	
Total Mass Collected	µg	< 0.66	
Calculated Concentration	mg/m ³	< 0.0003	
Reported Concentration	mg/m ³	< 0.0003	
Vanadium			
Mass on Filter / in Rinse	µg	< 0.40	
Mass in Front Impingers	µg	< 0.02	
Mass in Back Impinger	µg	< 0.01	
Total Mass Collected	µg	< 0.43	
Calculated Concentration	mg/m ³	< 0.0002	
Reported Concentration	mg/m ³	< 0.0002	

APPENDIX 2

HEAVY METALS: SAMPLING DETAILS

(PAGE 5 OF 5)

Blank Runs (continued)

Parameter	Units	Blank 1	
Heavy Metals Combined			
Total Mass Collected	µg	5.46	
Calculated Concentration	mg/m ³	0.0026	
Reported Concentration	mg/m ³	0.0026	

HEAVY METALS: QUALITY ASSURANCE

(PAGE 1 OF 2)

Sample Runs

Leak Test Results	Units	Run 1
Mean Sampling Rate	l/min	23.7
Pre-Sampling Leak Rate	l/min	0.10
Post-Sampling Leak Rate	l/min	0.10
Allowable Leak Rate	l/min	0.47
Leak Test Acceptable	-	Yes

Absorption Efficiency	Units	Run 1
Arsenic	%	93.0
Cobalt	%	91.0
Chromium	%	82.9
Copper	%	99.2
Manganese	%	99.1
Nickel	%	100.0
Lead	%	92.4
Antimony	%	100.0
Vanadium	%	N/A <1% Total
Allowable Absorption Efficiency	%	90
Absorption Efficiency Acceptable	-	No

Detection Limit	Units	Run 1
Arsenic	µg/m ³	0.3
Cobalt	µg/m ³	0.3
Chromium	µg/m ³	0.3
Copper	µg/m ³	0.4
Manganese	µg/m ³	0.2
Nickel	µg/m ³	0.3
Lead	µg/m ³	0.3
Antimony	µg/m ³	0.3
Vanadium	µg/m ³	0.2
Allowable Detection Limit	µg/m ³	5
Detection Limit Acceptable	-	Yes

Water Droplets	Units	Run 1
Are Water Droplets Present	-	No

MU (Concurrent Water Vapour)	Units	Run 1
Measurement Uncertainty (MU)	%	6.3
Allowable MU	%	20.0
MU Acceptable	%	Yes

APPENDIX 2

HEAVY METALS: QUALITY ASSURANCE

(PAGE 2 OF 2)

Silica Gel (Concurrent Water Vapour)	Units	Run 1	
Less than 50% Faded	%	Yes	
Isokinetic Criterion Compliance	Units	Run 1	
Isokinetic Variation	%	103.8	
Allowable Isokinetic Range	%	95 - 115	
Isokineticity Acceptable	-	Yes	
Filter Temperatures	Units	Run 1	
Maximum Filter Temperature	°C	160	
Impingers Exit Temperature	Units	Run 1	
Maximum Temperature Recorded	°C	18	
Maximum Allowable Temperature	°C	30	
Exit Temperature Acceptable	-	Yes	
Test Conditions	Units	Run 1	
Ambient Temperature Recorded?	-	Yes	

Blank Runs

Leak Test Results	Units	Blank 1	
Expected Sampling Rate	l/min	20.0	
Pre-Sampling Leak Rate	l/min	0.10	
Post-Sampling Leak Rate	l/min	0.10	
Allowable Leak Rate	l/min	0.40	
Leak Test Acceptable	-	Yes	
Validity of Blank vs ELV	Units	Blank 1	
Allowable Blank	mg/m ³	0.01	
Blank Acceptable	-	Yes	

Method Deviations

Nature of Deviation	Run Number	
	(x = deviation applies to the associated run, wx = deviation also applies to the concurrent water vapour run)	1
The absorption efficiency was less than the required 90%. [75 - 90%]	wx	

HEAVY METALS: MEASUREMENT UNCERTAINTY CALCULATIONS

Measured Quantities	Value		Standard uncertainty		
	Symbol	Run 1	Symbol	Units	Run 1
Sampled Volume (Actual)	V _m	2.2990	uV _m	m ³	0.0460
Sampled Gas Temperature	T _m	294.3	uT _m	K	2.0
Sampled Gas Pressure	ρ _m	99.0	uρ _m	kPa	0.5
Sampled Gas Humidity	H _m	0.0	uH _m	% v/v	1.0
Leak	L	0.42	uL	%	-
Laboratory Result	L _r	9.60	uL _r	%	-

Measured Quantities	Uncertainty as a Percentage		Requirement of Standard
	Units	Run 1	
Sampled Volume (Actual)	%	2.00	≤2%
Sampled Gas Temperature	%	0.68	≤1%
Sampled Gas Pressure	%	0.50	≤1%
Sampled Gas Humidity	%	1.00	≤1%
Leak	%	0.42	≤2%
Laboratory Result	%	9.60	No Requirement

Measured Quantities	Uncertainty in Measurement Units			Sensitivity Coefficient	
	Symbol	Units	Run 1	Run 1	
Sampled Volume (STP)	V _m	m ³	2.0490	0.01	
Leak	L	mg/m ³	0.000	1.00	
Laboratory Result	L _r	mg/m ³	0.002	1.00	

Measured Quantities	Uncertainty in Result	
	Units	Run 1
Sampled Volume (STP)	mg/m ³	0.001
Leak	mg/m ³	0.0001
Laboratory Result	mg/m ³	0.0021

Measured Quantities	Oxygen Correction Part of MU Budget	
	Units	Run 1
O ₂ Correction Factor	-	N/A
Stack Gas O ₂ Content	% v/v	N/A
MU for O ₂ Correction	-	N/A
Overall MU For O ₂ Measurement	%	N/A

Parameter	Units	Run 1
Combined uncertainty	mg/m ³	0.002
Expanded uncertainty (95% confidence), without Oxygen Correction	mg/m ³	0.004
Expanded uncertainty (95% confidence), with Oxygen Correction	mg/m ³	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	mg/m ³	0.005
Reported Uncertainty	mg/m ³	0.005
Expanded uncertainty (95% confidence), without Oxygen Correction	%	19.5
Expanded uncertainty (95% confidence), with Oxygen Correction	%	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	%	23.4
Reported Uncertainty	%	23.4

HYDROGEN SULPHIDE: RESULTS SUMMARY

Federal-Mogul Coventry Ltd, Coventry
Main Stack

Sample Runs

Parameter	Units	Run 1	Mean
Concentration	mg/m ³	< 0.34	< 0.34
Uncertainty	±mg/m ³	0.04	0.04
Mass Emission	g/hr	< 1.4	< 1.4
Uncertainty	±g/hr	0.19	0.19

NOTE: Where the maximum Blank concentration is higher than the Sample concentration, the Blank concentration has been reported.

Parameter	Units	Run 1	Mean
Water Vapour	% v/v	1.5	1.5
Uncertainty	±% v/v	0.07	0.07

Blank Runs

Parameter	Units	Blank 1	Maximum
Concentration	mg/m ³	< 0.34	< 0.34

General Sampling Information

Parameter	Value
Standard	US EPA M11
Technical Procedure	CAT-TP-15
Name of Analytical Laboratory	RPS
Analytical Laboratory's Procedure	M120
ISO 17025 Accredited Analysis?	Yes
Date of Sample Analysis	13/11/2019
Probe Material	Titanium
Filter Housing Material	Titanium
Impinger Material	Borosilicate Glass
Absorption Solution	Zinc Acetate Solution
Positioning of Filter	In Stack
Filter Size and Material	47mm Quartz Fibre
Number of Sampling Lines Used	1 / 1
Number of Sampling Points Used	1 / 1
Sample Point I.D.'s	B1

FORMAT: Number Used / Number Required

Reference Conditions

Reference Conditions are: 273K, 101.3kPa, without correction for water vapour content.

HYDROGEN SULPHIDE: SAMPLING DETAILS

Sample Runs

Parameter	Units	Run 1
Sampling Times	-	10:54 - 12:29
Sampling Dates	-	15/10/2019
Sampling Device	-	MFC / MV
Duration	mins	95
Volume Sampled (STP, Dry)	m ³	0.9234
Volume Sampled (STP, Wet)	m ³	0.9379
Volume Sampled (REF)	m ³	0.9379
Sample Flow Rate	l/min	9.66
Laboratory Result for Front Impingers	µg/ml	< 1.00
Laboratory Result for Back Impinger	µg/ml	< 1.00
Volume in Front Impingers	ml	206.6
Volume in Back Impinger	ml	104.9
Mass in Front Impingers	µg	< 206.6
Mass in Back Impinger	µg	< 104.9
Total Mass Collected	µg	< 311.5
Calculated Concentration	mg/m ³	< 0.33
Liquid Trap Start Mass	g	3833.9
Liquid Trap End Mass	g	3839.3
Silica Trap Start Mass	g	796.0
Silica Trap End Mass	g	802.2
Total Mass Of Water Vapour	g	11.6
Calculated Water Vapour	% v/v	1.54

Where: MFC stands for Mass Flow Controller, MV stands for Mass View Flowmeter

Blank Runs

Parameter	Units	Blank 1
Blank Dates	-	15/10/2019
Average Volume Sampled (REF)	m ³	0.9379
Laboratory Result for Impingers	µg/ml	< 1.00
Volume in Impingers	ml	321.0
Total Mass Collected	µg	< 321.0
Calculated Concentration	mg/m ³	< 0.34

HYDROGEN SULPHIDE: QUALITY ASSURANCE

Sample Runs

Leak Test Results	Units	Run 1
Mean Sampling Rate	l/min	9.7
Pre-Sampling Leak Rate	l/min	0.01
Post-Sampling Leak Rate	l/min	0.01
Allowable Leak Rate	l/min	0.19
Leak Test Acceptable	-	Yes

Absorption Efficiency	Units	Run 1
Absorption Efficiency	%	100.0
Allowable Absorption Efficiency	%	N/A
Absorption Efficiency Acceptable	-	N/A

Water Droplets	Units	Run 1
Are Water Droplets Present	-	No

MU (Concurrent Water Vapour)	Units	Run 1
Measurement Uncertainty (MU)	%	4.5
Allowable MU	%	20.0
MU Acceptable	%	Yes

Silica Gel (Concurrent Water Vapour)	Units	Run 1
Less than 50% Faded	%	Yes

Test Conditions	Units	Run 1
Ambient Temperature Recorded?	-	Yes

Blank Runs

Leak Test Results	Units	Blank 1
Expected Sampling Rate	l/min	9.0
Pre-Sampling Leak Rate	l/min	0.01
Post-Sampling Leak Rate	l/min	0.01
Allowable Leak Rate	l/min	0.18
Leak Test Acceptable	-	Yes

Validity of Blank vs ELV	Units	Blank 1
Allowable Blank	mg/m ³	0.5
Blank Acceptable	-	Yes

Method Deviations

Nature of Deviation	Run Number
(x = deviation applies to the associated run, wx = deviation also applies to the concurrent water vapour run)	1
There are no deviations associated with the sampling employed.	wx

HYDROGEN SULPHIDE: MEASUREMENT UNCERTAINTY CALCULATIONS

Measured Quantities	Value		Standard uncertainty		
	Symbol	Run 1	Symbol	Units	Run 1
Sampled Volume (STP)	V _m	0.9234	uV _m	m ³	0.0185
Leak	L	0.10	uL	%	-
Laboratory Result	L _r	6.00	uL _r	%	-

Measured Quantities	Uncertainty as a Percentage		Requirement of Standard
	Units	Run 1	
Sampled Volume (STP)	%	2.00	≤2%
Leak	%	0.10	≤2%
Laboratory Result	%	6.00	No Requirement

Measured Quantities	Uncertainty in Measurement Units			Sensitivity Coefficient
	Symbol	Units	Run 1	
Sampled Volume (STP)	V _m	m ³	0.9234	0.37
Leak	L	mg/m ³	0.000	1.00
Laboratory Result	L _r	mg/m ³	0.021	1.00

Measured Quantities	Uncertainty in Result	
	Units	Run 1
Sampled Volume (STP)	mg/m ³	0.007
Leak	mg/m ³	0.0002
Laboratory Result	mg/m ³	0.0205

Measured Quantities	Oxygen Correction Part of MU Budget	
	Units	Run 1
O ₂ Correction Factor	-	N/A
Stack Gas O ₂ Content	% v/v	N/A
MU for O ₂ Correction	-	N/A
Overall MU For O ₂ Measurement	%	N/A

Parameter	Units	Run 1
Combined uncertainty	mg/m ³	0.02
Expanded uncertainty (95% confidence), without Oxygen Correction	mg/m ³	0.04
Expanded uncertainty (95% confidence), with Oxygen Correction	mg/m ³	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	mg/m ³	0.04
Reported Uncertainty	mg/m ³	0.04
Expanded uncertainty (95% confidence), without Oxygen Correction	%	12.4
Expanded uncertainty (95% confidence), with Oxygen Correction	%	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	%	12.4
Reported Uncertainty	%	12.4

APPENDIX 2

ODOUR: RESULTS SUMMARY

Federal-Mogul Coventry Ltd, Coventry
Release Point 1 - Main Stack

Results Summary

Parameter	Units	Bag 1	Bag 2	Bag 3	GEO Mean
Concentration	ouE/m ³	383	181	182	233
Lower CI	ouE/m ³				147
Upper CI	ouE/m ³				368
Mass Emission	ouE/s	432	204	205	263
Lower CI	ouE/s				166
Upper CI	ouE/s				415

General Sampling Information

Parameter	Value
Standard	BS EN 13725
Technical Procedure	CAT-TP-30
Probe Material	PTFE
Odour Presentation Mode	Yes / No
Equipment Used	Odour Barrel
Calibration Status of Olfactometer	0.055
Number of Sampling Lines Used	1 / 1
Number of Sampling Points Used	1 / 1
Sample Point I.D.'s	A1

FORMAT: Number Used / Number Required

Reference Conditions

Reference Conditions are: 293K, 101.3kPa, without correction for water vapour content

Sampling & Result Information

Parameter	Units	Bag 1	Bag 2	Bag 3
Sampling Times	-	09:00 - 09:06	09:07 - 09:13	09:15 - 09:21
Sampling Dates	-	15/10/2019	15/10/2019	15/10/2019
Sample ID	-	EST-5182-Bag 1	EST-5182-Bag 2	EST-5182-Bag 3
Duration	mins	6	6	6
Oxygen Content of the Stack Gas	% v/v	N/A	N/A	N/A
Oxygen Content of the Odour Bag	% v/v	N/A	N/A	N/A
Calculated Dilution Factor	: 1	N/A	N/A	N/A
Special Process Conditions	-	Pouring Process		
Date of Olfactometric Measurement	-	16/10/2019	16/10/2019	16/10/2019
Times of Olfactometric Measurement	-	12:06	12:19	12:28
Temperature of Olfactometric Lab	-	25°C ± 3°C		
ID of Olfactometer	-	EO9008		
Calculated Panel Threshold	ouE/m ³	383	181	182
Reference Odourant Used	-	n-butanol in N ₂		
Accepted Reference Value Used	ppb	40		
Analysis Result from Laboratory	ouE/m ³	383	181	182
Analysis Result including Dilution Factor	ouE/m ³	383	181	182



APPENDIX 2

ODOUR: METHOD DEVIATIONS

Federal-Mogul Coventry Ltd, Coventry
All Release Points

Method Deviations

Nature of Deviation (x = deviation applies to the associated bag/s)	Bag Numbers			
	1	2	3	
There are no deviations associated with the sampling employed.	x	x	x	