



Element, Unit C6, Emery Court, The Embankment Business Park, Heaton Mersey, Stockport, SK4 3GL  
Your Element Contact: Scott Pilkington (07825 991 537)  
E: scott.pilkington@element.com

**Stack Emissions Testing Report Commissioned by**  
Federal-Mogul Coventry Ltd

**Installation Name & Address**  
Federal-Mogul Coventry Ltd  
Holbrook Lane  
Holbrook  
Coventry  
CV6 4BG

PPC Permit: PPC/197

**Stack Reference**  
Main Stack

**Dates of the Monitoring Campaign**  
5th December 2022


**Job Reference Number**  
EMT04909

<b>Report Written by</b>
Luke Williams Team Leader MCERTS Level 2 MM 18 1496 TE1 TE2 TE3 TE4

<b>Report Approved by</b>
Derek Myers Operations Manager MCERTS Level 2 MM 02 115 TE1 TE2 TE3 TE4

<b>Report Date</b>
21st December 2022

<b>Version</b>
Version 1

<b>Signature of Report Approver</b>


TITLE PAGE

CONTENTS

EXECUTIVE SUMMARY

Monitoring Objectives	3
Monitoring Results	4
Monitoring Dates & Times	5
Process Details	6
Monitoring & Analytical Methods	7
Summary of Sampling Deviations	7
Sampling Location	8
Plant Diagrams / Sample Points	9

APPENDIX 1 - Monitoring Personnel & List of Equipment

APPENDIX 2 - Raw Data, Sampling Equations & Charts

*Opinions and interpretations expressed herein are outside the scope of Element's ISO 17025 accreditation.*

*This test report shall not be reproduced, except in full, without the written approval of Element.*

## Executive Summary

(Page 1 of 7)

### MONITORING OBJECTIVES

Federal-Mogul Coventry Ltd, Coventry

Main Stack

5th December 2022

#### Overall Aim of the Monitoring Campaign

Element were commissioned by Federal-Mogul Coventry Ltd to carry out stack emissions testing on the Main Stack at Coventry.

The aim of the monitoring campaign was to demonstrate compliance with a set of emission limit values (ELVs) as specified in the Site's Permit.

#### Special Requirements

There were no special requirements.

#### Target Parameters

Total Particulate Matter, Sulphur Dioxide, Nickel, Cobalt, Chromium

## Executive Summary

(Page 2 of 7)

### MONITORING RESULTS

Federal-Mogul Coventry Ltd, Coventry

Main Stack

5th December 2022

where MU = Measurement Uncertainty associated with the Result

Parameter	Concentration				Mass Emission			
	Units	Result	MU +/-	Limit	Units	Result	MU +/-	Limit
Total Particulate Matter	<sup>1</sup> mg/m <sup>3</sup>	0.23	0.52	20	g/hr	0.74	1.6	-
Sulphur Dioxide	<sup>1</sup> mg/m <sup>3</sup>	0.02	0.002	-	g/hr	0.07	0.01	-
Nickel	<sup>1</sup> mg/m <sup>3</sup>	0.001	0.0001	5.00	g/hr	0.003	0.0004	-
Cobalt	<sup>1</sup> mg/m <sup>3</sup>	0.001	0.0001	5.0	g/hr	0.002	0.0003	-
Chromium	<sup>1</sup> mg/m <sup>3</sup>	0.001	0.0001	5.0	g/hr	0.002	0.0004	-
Water Vapour	% v/v	1.0	0.06					
Stack Gas Temperature	°C	25.0						
Stack Gas Velocity	m/s	15.0	0.60					
Volumetric Flow Rate (ACTUAL)	m <sup>3</sup> /hr	3315	200					
Volumetric Flow Rate (REF)	<sup>1</sup> m <sup>3</sup> /hr	3071	185					

NOTE: VOLUMETRIC FLOW RATE & VELOCITY DATA TAKEN FROM THE PRELIMINARY VELOCITY TRAVERSE.

<sup>1</sup> Reference Conditions (REF) are: 273K, 101.3kPa, without correction for water vapour content.

## Executive Summary

(Page 3 of 7)

### MONITORING DATE(S) & TIMES

Federal-Mogul Coventry Ltd, Coventry  
Main Stack  
5th December 2022

Parameter	Units	Concentration	Units	Mass Emission	Sampling Date(s)	Sampling Times	Duration mins
Total Particulate Matter	R1 mg/m <sup>3</sup>	0.23	g/hr	0.74	05/12/2022	09:18 - 10:18	60
Sulphur Dioxide	R1 mg/m <sup>3</sup>	0.02	g/hr	0.07	05/12/2022	09:18 - 10:18	60
Nickel	R1 mg/m <sup>3</sup>	0.001	g/hr	0.003	05/12/2022	10:20 - 11:20	60
Cobalt	R1 mg/m <sup>3</sup>	0.001	g/hr	0.002	05/12/2022	10:20 - 11:20	60
Chromium	R1 mg/m <sup>3</sup>	0.001	g/hr	0.002	05/12/2022	10:20 - 11:20	60
Velocity Traverse	R1				05/12/2022	09:00 - 09:05	

All results are expressed at the respective reference conditions.

**Executive Summary**  
(Page 4 of 7)

**PROCESS DETAILS**

Federal-Mogul Coventry Ltd, Coventry  
Main Stack  
5th December 2022

**Standard Operating Conditions**

<b>Parameter</b>	<b>Value</b>
Process Status	On
Capacity (of 100%) and Tonnes / Hour	Standard Operating Capacity
Continuous or Batch Process	Batch
Feedstock (if applicable)	Furnace Extraction
Abatement System	Bag Filter
Abatement System Running Status	On
Fuel	N/A
Plume Appearance	None Visible

## Executive Summary

(Page 5 of 7)

### MONITORING & ANALYTICAL METHODS

Federal-Mogul Coventry Ltd, Coventry

Main Stack

5th December 2022

Parameter	Monitoring				Analysis				Overall Status	LOD (Average)
	Standard	Technical Procedure	Sampling Status	Testing Lab	Analytical Procedure	Analytical Technique	Analysis Status	Analysis Lab		
Total Particulate Matter	EN 13284-1	CAT-TP-01	MCERTS	EET	CAT-TP-03	Gravimetric	MCERTS	EET	MCERTS	0.23 mg/m <sup>3</sup>
Sulphur Dioxide	EN 14791	CAT-TP-09	MCERTS	EET	CAT-AP-01	IC	MCERTS	EET	MCERTS	0.016 mg/m <sup>3</sup>
Nickel	EN 14385	CAT-TP-06	MCERTS	EET	CAT-AP-07	ICP-MS	MCERTS	EET	MCERTS	0.001 mg/m <sup>3</sup>
Cobalt	EN 14385	CAT-TP-06	MCERTS	EET	CAT-AP-07	ICP-MS	MCERTS	EET	MCERTS	0.001 mg/m <sup>3</sup>
Chromium	EN 14385	CAT-TP-06	MCERTS	EET	CAT-AP-07	ICP-MS	MCERTS	EET	MCERTS	0.001 mg/m <sup>3</sup>
Water Vapour	EN 14790	CAT-TP-05	MCERTS	EET	CAT-TP-05	Gravimetric	MCERTS	EET	MCERTS	0.10 % v/v
Velocity & Vol. Flow Rate	EN 16911-1 (MID)	CAT-TP-41	MCERTS	EET	Pitot Tube and Thermocouple			MCERTS	1.2 m/s	

### ANALYSIS LABORATORIES

(with short name reference as appears in the table above)

Element (Stockport Lab - EET)	ISO 17025 Accreditation Number: 4279
-------------------------------	--------------------------------------

### SUMMARY OF SAMPLING DEVIATIONS

Parameter	Run	Deviation
Sulphur Dioxide	1	The absorption efficiency was less than the required 95%. [50 - 75%]

**SUITABILITY OF SAMPLING LOCATION**

**Duct Characteristics**

Parameter	Units	Value
Type	-	Circular
Depth	m	0.28
Width	m	-
Area	m <sup>2</sup>	0.06
Port Depth	cm	9
Orientation of Duct	-	Vertical
Number of Ports	-	2
Sample Port Size	-	4" BSP

**Location of Sampling Platform**

General Platform Information	Value
Permanent / Temporary Platform	Permanent
Inside / Outside	Outside

**Platform Details**

EA Technical Guidance Note M1 / EN 15259 Platform Requirements	Value
Sufficient working area to manipulate probe and operate the measuring instruments	Yes
Platform has 2 levels of handrails (approx. 0.5m & 1.0m high)	Yes
Platform has vertical base boards (approx. 0.25m high)	Yes
Platform has chains / self closing gates at top of ladders	Yes
There are no obstructions present which hamper insertion of sampling equipment	Yes
Safe Access Available	Yes
Easy Access Available	Yes

**Sampling Location / Platform Improvement Recommendations**

The sampling location meets all the requirements specified in EA Guidance Note M1 and EN 15259, and therefore there are no improvement recommendations.

**EN 15259 Homogeneity Test Requirements**

There is no requirement to perform a EN 15259 Homogeneity Test on this Stack.


**Sampling Plane Validation Criteria (from EN 15259)**

Criteria in EN 15259	Units	Traverse 1	Required	Compliant
Lowest Differential Pressure	Pa	189.0	> 5 Pa	Yes
Mean Velocity	m/s	14.95	-	-
Lowest Gas Velocity	m/s	14.95	-	-
Highest Gas Velocity	m/s	14.95	-	-
Ratio of Above	: 1	1.00	< 3 : 1	Yes
Maximum Angle of Swirl	°	0.00	< 15°	Yes
No Local Negative Flow	-	Yes	-	Yes




PLANT DIAGRAMS

Diagram 1



SAMPLE POINTS



- where
- = isokinetic point sampled at
  - = isokinetic point not sampled at
  - = combustion gases sample point
  - = non-isokinetic sample point

**APPENDIX CONTENTS**

APPENDIX 1 - Stack Emissions Monitoring Personnel, List of Equipment & Methods and Technical Procedures Used

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**STACK EMISSIONS MONITORING PERSONNEL**

Position	Name	MCERTS Accreditation	MCERTS Number	Technical Endorsements
Team Leader	Luke Williams	MCERTS Level 2	MM 18 1496	TE1 TE2 TE3 TE4
Trainee	Dominik Krawczyk	MCERTS Trainee	MM 22 1731	N/A

**LIST OF EQUIPMENT**

Extractive Sampling		Instrumental Analysers		Miscellaneous Items	
Equipment Type	Equipment I.D.	Equipment Type	Equipment I.D.	Equipment Type	Equipment I.D.
Control Box DGM (1)	CAT 7.122	Horiba PG-350E	CAT 39.5	Digital Manometer (1)	CAT 3.0005
Control Box DGM (2)	-	Horiba PG-250	-	Digital Manometer (2)	CAT 3.0006
Box Thermocouples (1)	CAT 3.312	Servomex 4900	-	Digital Temperature Meter	CAT 3.0005
Box Thermocouples (2)	-	Eco Physics CLD 822Mh	-	Stopwatch	CAT 14.203
Umbilical (1)	CAT 3.312	ABB AO2020-URAS26	-	Barometer	CAT 13.99
Umbilical (2)	-	Testo 350 XL	-	Stack Thermocouple (1)	CAT 4.1738
Oven Box (1)	CAT 12.162	JCT JCC P1 Cooler	CAT 4.1123	Stack Thermocouple (2)	CAT 4.1768
Oven Box (2)	-	Gasmeter DX4000	-	Stack Thermocouple (3)	CAT 4.1782
Heated Probe (1)	CAT 5.301	Gasmeter Sampling System	-	1m Heated Line (1)	-
Heated Probe (2)	CAT 5.302	Sick 3006	CAT 8.25	1m Heated Line (2)	-
Heated Probe (3)	CAT 5.303	M&C PSS	CAT 12.165	1m Heated Line (3)	-
S-Pitot (1)	CAT 21S.0002	Mass Flow Controller (1)	CAT 6.93	5m Heated Line (1)	-
S-Pitot (2)	CAT 21P.137	Mass Flow Controller (2)	CAT 6.94	15m Heated Line (1)	CAT 20.004
L-Pitot	CAT 21L.002	Mass View (1)	CAT 25.99	20m Heated Line (1)	CAT 20.181
Site Balance	CAT 17.97	Mass View (2)	CAT 25.100	20m Heated Line (2)	-
500g / 1Kg Check Weights	CAT 17.97	Hioki 5043 (V)	CAT 11.96	Dual Channel Heater Controller	CAT 3.0008
Last Impinger Arm	CAT 4.00107	Hioki 5031 (mA)	-	Single Channel Heater Controller	-
Callipers	CAT 23.8	Bioaerosols Temperature Logger	-	Laboratory Balance	CAT 1.18, 1.18a, 1.18b
Tubes Kit Thermocouple	-	Electronic Refrigerator	-	Tape Measure	CAT 16.105

**METHODS & TECHNICAL PROCEDURES USED**

Parameter	Standard	Technical Procedure
Total Particulate Matter	EN 13284-1	CAT-TP-01
Sulphur Dioxide	EN 14791	CAT-TP-09
Nickel	EN 14385	CAT-TP-06
Cobalt	EN 14385	CAT-TP-06
Chromium	EN 14385	CAT-TP-06
Water Vapour	EN 14790	CAT-TP-05
Velocity & Vol. Flow Rate	EN 16911-1 (MID)	CAT-TP-41

**PRELIMINARY STACK SURVEY: CALCULATIONS**

**General Stack Details**

Stack Details (from Traverse)	Units	Value
Stack Diameter / Depth, D	m	0.28
Stack Width, W	m	-
Stack Area, A	m <sup>2</sup>	0.06
Average Stack Gas Temperature, T <sub>a</sub>	°C	25.0
Average Stack Gas Pressure	Pa	189.0
Average Stack Static Pressure, P <sub>static</sub>	kPa	0.030
Average Barometric Pressure, P <sub>b</sub>	kPa	102.4
Average Pitot Tube Calibration Coefficient, C <sub>p</sub>	-	0.84

**Stack Gas Composition & Molecular Weights**

Component	Conc ppm	Conc Dry % v/v	Conc Wet % v/v	Volume Fraction r	Molar Mass M	Density kg/m <sup>3</sup> p	Conc kg/m <sup>3</sup> p <sub>i</sub>
CO <sub>2</sub> (Estimated)	-	0.06	0.06	0.0006	44.01	1.9635	0.00118
O <sub>2</sub> (Estimated)	-	20.80	20.59	0.2080	32.00	1.4277	0.29696
N <sub>2</sub>	-	79.14	78.34	0.7914	28.01	1.2498	0.98913
Moisture (H <sub>2</sub> O)	-	-	1.02	0.0102	18.02	0.8037	0.00817

Where:  $p = M / 22.41$   
 $p_i = r \times p$

**Calculation of Stack Gas Densities**

Determinand	Units	Result
Dry Density (STP), P <sub>STD</sub>	kg/m <sup>3</sup>	1.287
Wet Density (STP), P <sub>STW</sub>	kg/m <sup>3</sup>	1.282
Dry Density (Actual), P <sub>Actual</sub>	kg/m <sup>3</sup>	1.192
Average Wet Density (Actual), P <sub>ActualW</sub>	kg/m <sup>3</sup>	1.188

Where: P<sub>STD</sub> = sum of component concentrations, kg/m<sup>3</sup> (not including water vapour)  
P<sub>STW</sub> = sum of all wet concentrations / 100 x density, kg/m<sup>3</sup> (including water vapour)  
 $P_{Actual} = P_{STD} \times (T_{STP} / (P_{STP})) \times ((P_{static} + P_b) / T_a)$   
 $P_{ActualW} \text{ (at each sampling point)} = P_{STW} \times (T_s / P_s) \times (P_a / T_a)$

**Calculation of Stack Gas Volumetric Flowrate, Q**

Duct gas flow conditions	Units	Actual	REF <sup>1</sup>
Temperature	°C	25.0	0.0
Total Pressure	kPa	102.4	101.3
Moisture	%	1.02	1.02

Gas Volumetric Flowrate (from Traverse)	Units	Result
Gas Volumetric Flowrate (Actual)	m <sup>3</sup> /hr	3315
Gas Volumetric Flowrate (STP, Wet)	m <sup>3</sup> /hr	3071
Gas Volumetric Flowrate (STP, Dry)	m <sup>3</sup> /hr	3040
Gas Volumetric Flowrate REF <sup>1</sup>	m <sup>3</sup> /hr	3071

**PRELIMINARY STACK SURVEY: VELOCITY TRAVERSE TO EN 16911-1 (MID)**

(1 of 1)

Parameter	Units	Value
Date of Survey	-	05/12/2022
Time of Survey	-	09:00 - 09:05
Atmospheric Pressure	kPa	102.4
Average Stack Static Pressure	Pa	30
Result of Pitot Stagnation Test	-	Pass
Are Water Droplets Present?	-	No
Device Used	S-Type Pitot with KIMO MP 200 (500Pa)	

Parameter	Units	Value
Initial Pitot Leak Check	-	Pass
Final Pitot Leak Check	-	Pass
Orientation of Duct	-	Vertical
Pitot Tube, C <sub>p</sub>	-	0.84
Number of Lines Available	-	1
Number of Lines Used	-	1

Sampling Line A						
Traverse Point	Depth m	ΔP Pa	Temp °C	Wet Density kg/m <sup>3</sup>	Velocity m/s	Swirl °
<i>STATIC (Units: Pa)</i>		30.0				
<b>Mean</b>		<b>189.0</b>	<b>25.0</b>	<b>1.188</b>	<b>14.95</b>	
1	0.14	189.0	25.0	1.188	14.95	0.0

**PRELIMINARY STACK SURVEY: VELOCITY TRAVERSE TO EN 16911-1 (MID) - MEASUREMENT UNCERTAINTY**

(1 of 1)

Performance characteristics (Uncertainty Components)	Uncertainty	Value	Units
Standard Uncertainty on the coefficient of the Pitot Tube	$u(k)$	0.005	-
Standard Uncertainty associated with the mean local dynamic pressures	$u(\Delta p_i)$	3.231	Pa
- Resolution	$u(res)$	0.00087	
- Calibration	$u(cal)$	3.719	
- Drift	$u(drift)$	0.083	
- Lack of Fit	$u(fit)$	5.633	
- Overall corrections to dynamic measurements	$u(Cf)$	9.436	
Standard uncertainty associated with the molar mass of the gas	$u(M)$	0.00003	-
- $\varphi_{O_2,w}$	-	20.589	
- $\varphi_{CO_2,w}$	-	0.059	
- Oxygen, dry	$u(\phi_{O_2,d})$	0.637	
- Carbon Dioxide, dry	$u(\phi_{CO_2,d})$	0.002	
- Water Vapour	$u(\phi_{H_2O})$	0.052	
- Oxygen, wet	$u(\phi_{O_2,w})$	0.630	
- Carbon Dioxide, wet	$u(\phi_{CO_2,w})$	0.002	
Standard uncertainty associated with the stack temperature	$u(T_c)$	1.520	K
Standard uncertainty associated with the absolute pressure in the duct	$u(p_c)$	175.722	Pa
- Atmospheric Pressure	$u(p_{atm})$	175.692	
- Static Pressure	$u(p_{stat})$	3.231	
Standard uncertainty associated with the density in the duct	$u(\rho)$	0.00639	-
Standard uncertainty associated with the local velocities	$u(v_i)$	0.304	Pa
Standard uncertainty associated with the mean velocity	$u(\bar{v})$	0.304	m/s
Standard uncertainty associated with the mean velocity (95% Confidence)	$U_c(v)$	0.595	m/s
Standard uncertainty associated with the mean velocity (95% Confidence), relative	$U_{c,rel}(v)$	3.98	%
Standard uncertainty associated with the volume flow rate (95% Confidence)	$U_c(qV,w)$	199.8	m <sup>3</sup> /hr
- $u^2(a)/a^2$	-	0.00053	
- $u^2(qV,w)/q^2V,w$	-	0.00095	
- $u^2(qV,w)$	-	10394	
- $u(qV,w)$	-	102.0	
Standard uncertainty associated with the volume flow rate (95% Confidence), relative	$U_{c,rel}(qV,w)$	6.03	%

**TOTAL PARTICULATE MATTER: RESULTS SUMMARY**

Federal-Mogul Coventry Ltd, Coventry  
Main Stack

**Sample Runs**

Parameter	Units	Run 1	Mean
Concentration	mg/m <sup>3</sup>	0.23	0.23
Uncertainty	±mg/m <sup>3</sup>	0.52	0.52
Mass Emission	g/hr	0.74	0.74
Uncertainty	±g/hr	1.6	1.6

NOTE: Where the maximum Blank concentration is higher than the Sample concentration, the maximum Blank concentration has been reported.

Parameter	Units	Run 1	Mean
Water Vapour	% v/v	0.91	0.91
Uncertainty	±% v/v	0.05	0.05

**Blank Runs**

Parameter	Units	Blank 1	Maximum
Concentration	mg/m <sup>3</sup>	0.23	0.23

NOTE: Where the Balance Uncertainty / Limit of Detection is higher than the Blank concentration, the Balance Uncertainty / Limit of Detection concentration has been reported.

**General Sampling Information**

Parameter	Value
Standard	EN 13284-1
Technical Procedure	CAT-TP-01
Probe Material	Titanium
Filter Housing Material	Titanium
Positioning of Filter	In Stack
Filter Size and Material	47mm Quartz Fibre
Number of Sampling Lines Used	1 / 1
Number of Sampling Points Used	1 / 1
Sample Point I.D.'s	A1

FORMAT: Number Used / Number Required

**Reference Conditions**

Reference Conditions are: 273K, 101.3kPa, without correction for water vapour content.

**TOTAL PARTICULATE MATTER: ISOKINETIC SAMPLING CALCULATIONS**

Test	Units	Run 1	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			
Barometric pressure, P <sub>b</sub>	mmHg	768.1	
Stack static pressure, P <sub>static</sub>	mmH <sub>2</sub> O	3.1	
P <sub>s</sub> = (P <sub>b</sub> + (P <sub>static</sub> / 13.6))	mmHg	768.3	
<b>Volume of water vapour collected, V<sub>wstd</sub></b>			
Total mass collected in impingers (liquid trap)	g	5.4	
Total mass collected in impingers (silica trap)	g	1.9	
Total mass of liquid collected, V <sub>lc</sub>	g	7.3	
V <sub>wstd</sub> = (0.001246)(V <sub>lc</sub> )	m <sup>3</sup>	0.0091	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			
Volume of gas sample through gas meter, V <sub>m</sub>	m <sup>3</sup>	1.0250	
Gas meter correction factor, Y <sub>d</sub>	-	0.9900	
Average dry gas meter temperature, T <sub>m</sub>	°C	11.1	
Average pressure drop across orifice, ΔH	mmH <sub>2</sub> O	35.9	
V <sub>mstd</sub> = ((0.3592)(V <sub>m</sub> )(P <sub>b</sub> + (ΔH/13.6))(Y <sub>d</sub> )) / (T <sub>m</sub> + 273)	m <sup>3</sup>	0.9889	
<b>Moisture content, B<sub>wo</sub> &amp; R<sub>wv</sub></b>			
B <sub>wo</sub> = V <sub>wstd</sub> / (V <sub>mstd</sub> + V <sub>wstd</sub> )	m <sup>3</sup>	0.0091	
B <sub>wo</sub> as a percentage	% v/v	0.91	
Reported Water Vapour, checked with Tables in EN 14790, R <sub>wv</sub>	% v/v	0.91	
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			
V <sub>mstw</sub> = (V <sub>mstd</sub> )(100/(100 - R <sub>wv</sub> ))	m <sup>3</sup>	0.9980	
<b>Volume of gas metered at Oxygen Reference Conditions, V<sub>mstd@X%O<sub>2</sub></sub> &amp; V<sub>mstw@X%O<sub>2</sub></sub></b>			
IED & Incinerates Hazardous Material? (Yes = no positive O <sub>2</sub> correction)	-	No	
% wet oxygen measured in gas stream, ACT%O <sub>2w</sub>	% v/v	N/A	
% dry oxygen measured in gas stream, ACT%O <sub>2d</sub>	% v/v	N/A	
% oxygen reference condition, REF%O <sub>2</sub>	% v/v	N/A	
O <sub>2</sub> Reference Factor wet (O <sub>2REFw</sub> ) = (21 - REF%O <sub>2</sub> ) / (21 - ACT%O <sub>2w</sub> )	-	N/A	
O <sub>2</sub> Reference Factor dry (O <sub>2REFd</sub> ) = (21 - REF%O <sub>2</sub> ) / (21 - ACT%O <sub>2d</sub> )	-	N/A	
V <sub>mstw@X%oxygen</sub> = (V <sub>mstw</sub> ) / (O <sub>2REFw</sub> )	m <sup>3</sup>	N/A	
V <sub>mstd@X%oxygen</sub> = (V <sub>mstd</sub> ) / (O <sub>2REFd</sub> )	m <sup>3</sup>	N/A	
<b>Molecular weight of dry gas stream, M<sub>d</sub></b>			
CO <sub>2</sub> (Estimated)	% v/v	0.06	
O <sub>2</sub> (Estimated)	% v/v	20.80	
Total	% v/v	20.86	
N <sub>2</sub>	% v/v	79.14	
M <sub>d</sub> = 0.44(%CO <sub>2</sub> ) + 0.32(%O <sub>2</sub> ) + 0.28(%N <sub>2</sub> )	g/gmol	28.84	
<b>Molecular weight of stack gas (wet), M<sub>s</sub></b>			
M <sub>s</sub> = M <sub>d</sub> (1 - (R <sub>wv</sub> /100)) + 18(R <sub>wv</sub> /100)	g/gmol	28.74	
<b>Velocity of stack gas, V<sub>s</sub></b>			
Pitot tube velocity constant, K <sub>p</sub>	-	34.97	
Velocity pressure coefficient, C <sub>p</sub>	-	0.86	
Average of velocity heads, ΔP <sub>avg</sub>	mmH <sub>2</sub> O	20.00	
Average square root of velocity heads, √ΔP	√mmH <sub>2</sub> O	4.47	
Average stack gas temperature, T <sub>s</sub>	°C	28.9	
V <sub>s</sub> = ((K <sub>p</sub> )(C <sub>p</sub> )(√ΔP)(√T <sub>s</sub> + 273)) / (V(M <sub>s</sub> )(P <sub>s</sub> ))	m/s	15.78	
<b>Total flow of stack gas: Actual (Q<sub>a</sub>), Wet (Q<sub>stw</sub>), Dry (Q<sub>std</sub>), Wet@O<sub>2REF</sub> (Q<sub>stwO<sub>2</sub></sub>), Dry@O<sub>2REF</sub> (Q<sub>stdO<sub>2</sub></sub>)</b>			
Area of stack, A <sub>s</sub>	m <sup>2</sup>	0.06	
Q <sub>a</sub> = (60)(A <sub>s</sub> )(V <sub>s</sub> )	m <sup>3</sup> /min	58.3	
Conversion factor (K/mm.Hg), C <sub>f</sub>	-	0.3592	
Q <sub>stw</sub> = ((Q <sub>a</sub> )(P <sub>s</sub> )(C <sub>f</sub> )) / ((T <sub>s</sub> + 273))	m <sup>3</sup> /min	53.3	
Q <sub>std</sub> = ((Q <sub>a</sub> )(P <sub>s</sub> )(C <sub>f</sub> )(1 - (R <sub>wv</sub> /100))) / ((T <sub>s</sub> + 273))	m <sup>3</sup> /min	52.8	
Q <sub>stwO<sub>2</sub></sub> = ((Q <sub>a</sub> )(P <sub>s</sub> )(C <sub>f</sub> )) / ((T <sub>s</sub> + 273) / (O <sub>2REFw</sub> ))	m <sup>3</sup> /min	N/A	
Q <sub>stdO<sub>2</sub></sub> = ((Q <sub>a</sub> )(P <sub>s</sub> )(C <sub>f</sub> )(1 - (R <sub>wv</sub> /100))) / ((T <sub>s</sub> + 273) / (O <sub>2REFd</sub> ))	m <sup>3</sup> /min	N/A	
<b>Percent isokinetic, %I</b>			
Nozzle diameter, D <sub>n</sub>	mm	5.00	
Nozzle area, A <sub>n</sub>	mm <sup>2</sup>	19.64	
Total sampling time, q	min	60	
%I = (4.6398E <sup>9</sup> )(T <sub>s</sub> +273)(V <sub>mstd</sub> ) / (P <sub>s</sub> )(V <sub>s</sub> )(A <sub>n</sub> )(q)(1 - (R <sub>wv</sub> /100))	%	97.9	



**TOTAL PARTICULATE MATTER: SAMPLING DETAILS**

**Sample Runs**

Parameter	Units	Run 1
Sampling Times	-	09:18 - 10:18
Sampling Dates	-	05/12/2022
Sampling Device	-	ISO
Volume Sampled (REF)	m <sup>3</sup>	0.9980
Filter I.D. Number	-	47-92901
Start Filter Mass	g	0.14918
End Filter Mass	g	0.14920
Total Mass on Filter	g	0.00002
Probe Rinse I.D. Number	-	PR-47-92901
Start Probe Rinse Mass	g	2.81423
End Probe Rinse Mass	g	2.81435
Total Mass in Probe Rinse	g	0.00012
Total Mass Collected	mg	0.14
Calculated Concentration	mg/m <sup>3</sup>	0.14
Balance Uncertainty / LOD	mg/m <sup>3</sup>	0.23

Where: ISO stands for Manual Isokinetic Sampling Train

**Blank Runs**

Parameter	Units	Blank 1
Blank Dates	-	05/12/2022
Average Volume Sampled (REF)	m <sup>3</sup>	0.9980
Filter I.D. Number	-	47-92900
Start Filter Mass	g	0.15022
End Filter Mass	g	0.15009
Total Mass on Filter	g	-0.00013
Probe Rinse I.D. Number	-	PR-47-92900
Start Probe Rinse Mass	g	2.87790
End Probe Rinse Mass	g	2.87781
Total Mass in Probe Rinse	g	-0.00009
Total Mass Collected	mg	-0.22
Calculated Concentration	mg/m <sup>3</sup>	-0.22
Balance Uncertainty / LOD	mg/m <sup>3</sup>	0.23

**TOTAL PARTICULATE MATTER: QUALITY ASSURANCE**

(PAGE 1 OF 2)

**Sample Runs**

<b>Leak Test Results</b>	<b>Units</b>	<b>Run 1</b>
Mean Sampling Rate	l/min	16.9
Pre-Sampling Leak Rate	l/min	0.00
Allowable Leak Rate	l/min	N/A
Leak Test Acceptable	-	Yes

<b>Water Droplets</b>	<b>Units</b>	<b>Run 1</b>
Are Water Droplets Present	-	No

<b>MU (Concurrent Water Vapour)</b>	<b>Units</b>	<b>Run 1</b>
Measurement Uncertainty (MU)	%	5.9
Allowable MU	%	20.0
MU Acceptable	%	Yes

<b>Silica Gel (Concurrent Water Vapour)</b>	<b>Units</b>	<b>Run 1</b>
Less than 50% Faded	%	Yes

<b>Isokinetic Criterion Compliance</b>	<b>Units</b>	<b>Run 1</b>
Isokinetic Variation	%	97.9
Allowable Isokinetic Range	%	95 - 115
Isokineticity Acceptable	-	Yes

<b>Weighing Uncertainty Criteria</b>	<b>Units</b>	<b>Run 1</b>
Overall Weighing Uncertainty	± mg	0.33
Overall Weighing Uncertainty	± mg/m <sup>3</sup>	0.33
ELV [Daily ELV for IED]	mg/m <sup>3</sup>	20.00
Allowable Weighing Uncertainty	mg/m <sup>3</sup>	1.00
Weighing Uncertainty Acceptable	-	Yes

<b>Filter Temperatures</b>	<b>Units</b>	<b>Run 1</b>
Pre-Conditioning Temperature	°C	180
Post-Conditioning Temperature	°C	160
Maximum Filter Temperature	°C	34

<b>Test Conditions</b>	<b>Units</b>	<b>Run 1</b>
Ambient Temperature Recorded?	-	Yes

**TOTAL PARTICULATE MATTER: QUALITY ASSURANCE**

(PAGE 2 OF 2)

**Blank Runs**

Leak Test Results	Units	Blank 1
Expected Sampling Rate	l/min	25.0
Pre-Sampling Leak Rate	l/min	0.00
Allowable Leak Rate	l/min	N/A
Leak Test Acceptable	-	Yes

Validity of Blank vs ELV	Units	Blank 1
Allowable Blank	mg/m <sup>3</sup>	2.0
Blank Acceptable	-	Yes

Acetone / Water Rinse Blank	Units	Blank
Acetone / Water Rinse Value	mg/l	2.7
Allowable Blank	mg/l	10
Blank Acceptable	-	Yes

**Method Deviations**

Nature of Deviation	Run Number
(x = deviation applies to the associated run, wx = deviation also applies to the concurrent water vapour run)	1
There are no deviations associated with the sampling employed.	wx

**TOTAL PARTICULATE MATTER: MEASUREMENT UNCERTAINTY CALCULATIONS**

Measured Quantities	Value		Standard uncertainty		
	Symbol	Run 1	Symbol	Units	Run 1
Sampled Volume (Actual)	V <sub>m</sub>	1.0250	uV <sub>m</sub>	m <sup>3</sup>	0.0205
Sampled Gas Temperature	T <sub>m</sub>	284.1	uT <sub>m</sub>	K	2.00
Sampled Gas Pressure	ρ <sub>m</sub>	102.4	uρ <sub>m</sub>	kPa	0.50
Sampled Gas Humidity	H <sub>m</sub>	0.00	uH <sub>m</sub>	% v/v	1.00
Leak	L	0.00	uL	%	-
Mass of Particulate	m	0.23	um	mg	0.23
Uncollected Mass	UCM	-0.22	uUCM	mg	-

Measured Quantities	Uncertainty as a Percentage		Requirement of Standard
	Units	Run 1	
Sampled Volume (Actual)	%	2.00	≤2%
Sampled Gas Temperature	%	0.70	≤1%
Sampled Gas Pressure	%	0.49	≤1%
Sampled Gas Humidity	%	1.00	≤1%
Leak	%	0.00	≤2%
Mass of Particulate	%	1.15	-
Uncollected Mass	%	-	-

Measured Quantities	Uncertainty in Measurement Units			Sensitivity Coefficient	
	Symbol	Units	Run 1	Run 1	
Sampled Volume (STP)	V <sub>m</sub>	m <sup>3</sup>	0.9889	0.23	
Leak	L	mg/m <sup>3</sup>	0.0000	1.00	
Mass of Particulate	L <sub>r</sub>	mg	0.2300	1.00	
Uncollected Mass	UCM	mg	-0.13	1.00	

Measured Quantities	Uncertainty in Result	
	Units	Run 1
Sampled Volume (STP)	mg/m <sup>3</sup>	0.006
Leak	mg/m <sup>3</sup>	0.0000
Mass of Particulate	mg/m <sup>3</sup>	0.2305
Uncollected Mass	mg/m <sup>3</sup>	-0.1273

Measured Quantities	Oxygen Correction Part of MU Budget	
	Units	Run 1
O <sub>2</sub> Correction Factor	-	N/A
Stack Gas O <sub>2</sub> Content	% v/v	N/A
MU for O <sub>2</sub> Correction	-	N/A
Overall MU For O <sub>2</sub> Measurement	%	N/A

Parameter	Units	Run 1
Combined uncertainty	mg/m <sup>3</sup>	0.26
Expanded uncertainty (95% confidence), without Oxygen Correction	mg/m <sup>3</sup>	0.52
Expanded uncertainty (95% confidence), with Oxygen Correction	mg/m <sup>3</sup>	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	mg/m <sup>3</sup>	0.52
Reported Uncertainty	mg/m <sup>3</sup>	0.52
Expanded uncertainty (95% confidence), without Oxygen Correction	%	224.0
Expanded uncertainty (95% confidence), with Oxygen Correction	%	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	%	224.0
Reported Uncertainty	%	224.0

**SULPHUR DIOXIDE: RESULTS SUMMARY**

Federal-Mogul Coventry Ltd, Coventry  
Main Stack

**Sample Runs**

Parameter	Units	Run 1	Mean
Concentration	mg/m <sup>3</sup>	0.02	0.02
Uncertainty	±mg/m <sup>3</sup>	0.002	0.002
Mass Emission	g/hr	0.07	0.07
Uncertainty	±g/hr	0.01	0.01

NOTE: Where the maximum Blank concentration is higher than the Sample concentration, the Blank concentration has been reported.

Parameter	Units	Run 1	Mean
Water Vapour	% v/v	0.91	0.91
Uncertainty	±% v/v	0.05	0.05

**Blank Runs**

Parameter	Units	Blank 1	Maximum
Concentration	mg/m <sup>3</sup>	0.02	0.02

**General Sampling Information**

Parameter	Value
Standard	EN 14791
Technical Procedure	CAT-TP-09
Name of Analytical Laboratory	EET
Analytical Laboratory's Procedure	CAT-AP-01
ISO 17025 Accredited Analysis?	MCERTS
Date of Sample Analysis	14/12/2022
Probe Material	Titanium
Filter Housing Material	Titanium
Impinger Material	Polyethylene
Absorption Solution	0.3% Hydrogen Peroxide
Positioning of Filter	In Stack
Filter Size and Material	47mm Quartz Fibre
Number of Sampling Lines Used	1 / 1
Number of Sampling Points Used	1 / 1
Sample Point I.D.'s	A1

FORMAT: Number Used / Number Required

**Reference Conditions**

Reference Conditions are: 273K, 101.3kPa, without correction for water vapour content.

**SULPHUR DIOXIDE: ISOKINETIC SAMPLING CALCULATIONS**

Test	Units	Run 1	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			
Barometric pressure, P <sub>b</sub>	mmHg	768.1	
Stack static pressure, P <sub>static</sub>	mmH <sub>2</sub> O	3.1	
P <sub>s</sub> = (P <sub>b</sub> + (P <sub>static</sub> / 13.6))	mmHg	768.3	
<b>Volume of water vapour collected, V<sub>wstd</sub></b>			
Total mass collected in impingers (liquid trap)	g	5.4	
Total mass collected in impingers (silica trap)	g	1.9	
Total mass of liquid collected, V <sub>lc</sub>	g	7.3	
V <sub>wstd</sub> = (0.001246)(V <sub>lc</sub> )	m <sup>3</sup>	0.0091	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			
Volume of gas sample through gas meter, V <sub>m</sub>	m <sup>3</sup>	1.0250	
Gas meter correction factor, Y <sub>d</sub>	-	0.9900	
Average dry gas meter temperature, T <sub>m</sub>	°C	11.1	
Average pressure drop across orifice, ΔH	mmH <sub>2</sub> O	35.9	
V <sub>mstd</sub> = ((0.3592)(V <sub>m</sub> )(P <sub>b</sub> + (ΔH/13.6))(Y <sub>d</sub> ) / (T <sub>m</sub> + 273))	m <sup>3</sup>	0.9889	
<b>Moisture content, B<sub>wo</sub> &amp; R<sub>wv</sub></b>			
B <sub>wo</sub> = V <sub>wstd</sub> / (V <sub>mstd</sub> + V <sub>wstd</sub> )	m <sup>3</sup>	0.0091	
B <sub>wo</sub> as a percentage	% v/v	0.91	
Reported Water Vapour, checked with Tables in EN 14790, R <sub>wv</sub>	% v/v	0.91	
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			
V <sub>mstw</sub> = (V <sub>mstd</sub> )(100/(100 - R <sub>wv</sub> ))	m <sup>3</sup>	0.9980	
<b>Volume of gas metered at Oxygen Reference Conditions, V<sub>mstd@X%O<sub>2</sub></sub> &amp; V<sub>mstw@X%O<sub>2</sub></sub></b>			
IED & Incinerates Hazardous Material? (Yes = no positive O <sub>2</sub> correction)	-	No	
% wet oxygen measured in gas stream, ACT%O <sub>2w</sub>	% v/v	N/A	
% dry oxygen measured in gas stream, ACT%O <sub>2d</sub>	% v/v	N/A	
% oxygen reference condition, REF%O <sub>2</sub>	% v/v	N/A	
O <sub>2</sub> Reference Factor wet (O <sub>2REFw</sub> ) = (21 - REF%O <sub>2</sub> ) / (21 - ACT%O <sub>2w</sub> )	-	N/A	
O <sub>2</sub> Reference Factor dry (O <sub>2REFd</sub> ) = (21 - REF%O <sub>2</sub> ) / (21 - ACT%O <sub>2d</sub> )	-	N/A	
V <sub>mstw@X%oxygen</sub> = (V <sub>mstw</sub> ) / (O <sub>2REFw</sub> )	m <sup>3</sup>	N/A	
V <sub>mstd@X%oxygen</sub> = (V <sub>mstd</sub> ) / (O <sub>2REFd</sub> )	m <sup>3</sup>	N/A	
<b>Molecular weight of dry gas stream, M<sub>d</sub></b>			
CO <sub>2</sub> (Estimated)	% v/v	0.06	
O <sub>2</sub> (Estimated)	% v/v	20.80	
Total	% v/v	20.86	
N <sub>2</sub>	% v/v	79.14	
M <sub>d</sub> = 0.44(%CO <sub>2</sub> ) + 0.32(%O <sub>2</sub> ) + 0.28(%N <sub>2</sub> )	g/gmol	28.84	
<b>Molecular weight of stack gas (wet), M<sub>s</sub></b>			
M <sub>s</sub> = M <sub>d</sub> (1 - (R <sub>wv</sub> /100)) + 18(R <sub>wv</sub> /100)	g/gmol	28.74	
<b>Velocity of stack gas, V<sub>s</sub></b>			
Pitot tube velocity constant, K <sub>p</sub>	-	34.97	
Velocity pressure coefficient, C <sub>p</sub>	-	0.86	
Average of velocity heads, ΔP <sub>avg</sub>	mmH <sub>2</sub> O	20.00	
Average square root of velocity heads, √ΔP	√mmH <sub>2</sub> O	4.47	
Average stack gas temperature, T <sub>s</sub>	°C	28.9	
V <sub>s</sub> = ((K <sub>p</sub> )(C <sub>p</sub> )(√ΔP)(√T <sub>s</sub> + 273)) / (V(M <sub>s</sub> )(P <sub>s</sub> ))	m/s	15.78	
<b>Total flow of stack gas: Actual (Q<sub>a</sub>), Wet (Q<sub>stw</sub>), Dry (Q<sub>std</sub>), Wet@O<sub>2REF</sub> (Q<sub>stwO<sub>2</sub></sub>), Dry@O<sub>2REF</sub> (Q<sub>stdO<sub>2</sub></sub>)</b>			
Area of stack, A <sub>s</sub>	m <sup>2</sup>	0.06	
Q <sub>a</sub> = (60)(A <sub>s</sub> )(V <sub>s</sub> )	m <sup>3</sup> /min	58.3	
Conversion factor (K/mm.Hg), C <sub>f</sub>	-	0.3592	
Q <sub>stw</sub> = ((Q <sub>a</sub> )(P <sub>s</sub> )(C <sub>f</sub> ) / ((T <sub>s</sub> + 273))	m <sup>3</sup> /min	53.3	
Q <sub>std</sub> = ((Q <sub>a</sub> )(P <sub>s</sub> )(C <sub>f</sub> )(1 - (R <sub>wv</sub> /100))) / ((T <sub>s</sub> + 273))	m <sup>3</sup> /min	52.8	
Q <sub>stwO<sub>2</sub></sub> = ((Q <sub>a</sub> )(P <sub>s</sub> )(C <sub>f</sub> ) / ((T <sub>s</sub> + 273)) / (O <sub>2REFw</sub> )	m <sup>3</sup> /min	N/A	
Q <sub>stdO<sub>2</sub></sub> = ((Q <sub>a</sub> )(P <sub>s</sub> )(C <sub>f</sub> )(1 - (R <sub>wv</sub> /100))) / ((T <sub>s</sub> + 273)) / (O <sub>2REFd</sub> )	m <sup>3</sup> /min	N/A	
<b>Percent isokinetic, %I</b>			
Nozzle diameter, D <sub>n</sub>	mm	5.00	
Nozzle area, A <sub>n</sub>	mm <sup>2</sup>	19.64	
Total sampling time, q	min	60	
%I = (4.6398E <sup>9</sup> )(T <sub>s</sub> +273)(V <sub>mstd</sub> ) / (P <sub>s</sub> )(V <sub>s</sub> )(A <sub>n</sub> )(q)(1 - (R <sub>wv</sub> /100))	%	97.9	

**SULPHUR DIOXIDE: SAMPLING DETAILS**

**Sample Runs**

Parameter	Units	Run 1
Sampling Times	-	09:18 - 10:18
Sampling Dates	-	05/12/2022
Sampling Device	-	ISO
Volume Sampled (REF)	m <sup>3</sup>	0.9980
Laboratory Result for Front Impingers	µg/ml	0.05
Laboratory Result for Back Impinger	µg/ml	0.05
Volume in Front Impingers	ml	211.2
Volume in Back Impinger	ml	111.3
Mass in Front Impingers	µg	10.6
Mass in Back Impinger	µg	5.6
Total Mass Collected	µg	16.1
Calculated Concentration	mg/m <sup>3</sup>	0.02

Where: ISO stands for Manual Isokinetic Sampling Train

**Blank Runs**

Parameter	Units	Blank 1
Blank Dates	-	05/12/2022
Average Volume Sampled (REF)	m <sup>3</sup>	0.9980
Laboratory Result for Impingers	µg/ml	0.07
Volume in Impingers	ml	303.7
Total Mass Collected	µg	21.3
Calculated Concentration	mg/m <sup>3</sup>	0.02

**SULPHUR DIOXIDE: QUALITY ASSURANCE**

(PAGE 1 OF 2)

**Sample Runs**

<b>Leak Test Results</b>	<b>Units</b>	<b>Run 1</b>
Mean Sampling Rate	l/min	16.9
Pre-Sampling Leak Rate	l/min	0.00
Post-Sampling Leak Rate	l/min	N/A
Allowable Leak Rate	l/min	0.50
Leak Test Acceptable	-	Yes

<b>Absorption Efficiency</b>	<b>Units</b>	<b>Run 1</b>
Absorption Efficiency	%	65.5
Allowable Absorption Efficiency	%	95
Absorption Efficiency Acceptable	-	No

<b>Water Droplets</b>	<b>Units</b>	<b>Run 1</b>
Are Water Droplets Present	-	No

<b>MU (Concurrent Water Vapour)</b>	<b>Units</b>	<b>Run 1</b>
Measurement Uncertainty (MU)	%	5.9
Allowable MU	%	20.0
MU Acceptable	%	Yes

<b>Silica Gel (Concurrent Water Vapour)</b>	<b>Units</b>	<b>Run 1</b>
Less than 50% Faded	%	Yes

<b>Isokinetic Criterion Compliance</b>	<b>Units</b>	<b>Run 1</b>
Isokinetic Variation	%	97.9
Allowable Isokinetic Range	%	95 - 115
Isokineticity Acceptable	-	Yes

<b>Filter Temperatures</b>	<b>Units</b>	<b>Run 1</b>
Maximum Filter Temperature	°C	34

<b>Test Conditions</b>	<b>Units</b>	<b>Run 1</b>
Ambient Temperature Recorded?	-	Yes



**SULPHUR DIOXIDE: QUALITY ASSURANCE**

(PAGE 2 OF 2)

**Blank Runs**

Leak Test Results	Units	Blank 1	
Expected Sampling Rate	l/min	25.0	
Pre-Sampling Leak Rate	l/min	0.00	
Allowable Leak Rate	l/min	0.50	
Leak Test Acceptable	-	Yes	

Validity of Blank vs ELV	Units	Blank 1	
Allowable Blank	mg/m <sup>3</sup>	N/A	
Blank Acceptable	-	N/A	

**Method Deviations**

Nature of Deviation	Run Number
(x = deviation applies to the associated run, wx = deviation also applies to the concurrent water vapour run)	1
The absorption efficiency was less than the required 95%. [50 - 75%]	x

**SULPHUR DIOXIDE: MEASUREMENT UNCERTAINTY CALCULATIONS**

Measured Quantities	Value		Standard uncertainty		
	Symbol	Run 1	Symbol	Units	Run 1
Sampled Volume (Actual)	V <sub>m</sub>	1.0250	uV <sub>m</sub>	m <sup>3</sup>	0.0205
Sampled Gas Temperature	T <sub>m</sub>	284.1	uT <sub>m</sub>	K	2.00
Sampled Gas Pressure	ρ <sub>m</sub>	102.4	uρ <sub>m</sub>	kPa	0.50
Sampled Gas Humidity	H <sub>m</sub>	0.00	uH <sub>m</sub>	% v/v	1.00
Leak	L	0.00	uL	%	-
Laboratory Result	L <sub>r</sub>	1.00	uL <sub>r</sub>	%	-

Measured Quantities	Uncertainty as a Percentage		Requirement of Standard
	Units	Run 1	
Sampled Volume (Actual)	%	2.00	≤2%
Sampled Gas Temperature	%	0.70	≤1%
Sampled Gas Pressure	%	0.49	≤1%
Sampled Gas Humidity	%	1.00	≤1%
Leak	%	0.00	≤2%
Laboratory Result	%	1.00	No Requirement

Measured Quantities	Uncertainty in Measurement Units			Sensitivity Coefficient	
	Symbol	Units	Run 1	Run 1	
Sampled Volume (STP)	V <sub>m</sub>	m <sup>3</sup>	0.9889	0.02	
Leak	L	mg/m <sup>3</sup>	0.0000	1.00	
Laboratory Result	L <sub>r</sub>	mg/m <sup>3</sup>	0.0002	1.00	

Measured Quantities	Uncertainty in Result	
	Units	Run 1
Sampled Volume (STP)	mg/m <sup>3</sup>	0.001
Leak	mg/m <sup>3</sup>	0.0000
Laboratory Result	mg/m <sup>3</sup>	0.0002

Measured Quantities	Oxygen Correction Part of MU Budget	
	Units	Run 1
O <sub>2</sub> Correction Factor	-	N/A
Stack Gas O <sub>2</sub> Content	% v/v	N/A
MU for O <sub>2</sub> Correction	-	N/A
Overall MU For O <sub>2</sub> Measurement	%	N/A

Parameter	Units	Run 1
Combined uncertainty	mg/m <sup>3</sup>	0.001
Expanded uncertainty (95% confidence), without Oxygen Correction	mg/m <sup>3</sup>	0.001
Expanded uncertainty (95% confidence), with Oxygen Correction	mg/m <sup>3</sup>	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	mg/m <sup>3</sup>	0.002
Reported Uncertainty	mg/m <sup>3</sup>	0.002
Expanded uncertainty (95% confidence), without Oxygen Correction	%	5.2
Expanded uncertainty (95% confidence), with Oxygen Correction	%	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	%	7.3
Reported Uncertainty	%	7.3

**NICKEL: RESULTS SUMMARY**

Federal-Mogul Coventry Ltd, Coventry  
Main Stack

**Sample Runs**

Parameter	Units	Run 1	Mean
Concentration	mg/m <sup>3</sup>	0.001	0.001
Uncertainty	±mg/m <sup>3</sup>	0.0001	0.0001
Mass Emission	g/hr	0.003	0.003
Uncertainty	±g/hr	0.0004	0.0004

Parameter	Units	Run 1	Mean
Water Vapour	% v/v	1.1	1.1
Uncertainty	±% v/v	0.06	0.06

**Blank Runs**

Parameter	Units	Blank 1	Maximum
Concentration	mg/m <sup>3</sup>	< 0.0006	< 0.0006

**General Sampling Information**

Parameter	Value
Standard	EN 14385
Technical Procedure	CAT-TP-06
Name of Analytical Laboratory	EET
Analytical Laboratory's Procedure	CAT-AP-07
ISO 17025 Accredited Analysis?	MCERTS
Date of Sample Analysis	15/12/2022
Probe Material	Titanium
Filter Housing Material	Titanium
Impinger Material	Borosilicate Glass
Absorption Solution	Nitric Peroxide
Positioning of Filter	Out Stack
Filter Size and Material	47mm Quartz Fibre
Number of Sampling Lines Used	1 / 1
Number of Sampling Points Used	1 / 1
Sample Point I.D.'s	A1

FORMAT: Number Used / Number Required

**Reference Conditions**

Reference Conditions are: 273K, 101.3kPa, without correction for water vapour content.

NICKEL: ISOKINETIC SAMPLING CALCULATIONS

Test	Units	Run 1	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			
Barometric pressure, P <sub>b</sub>	mmHg	768.1	
Stack static pressure, P <sub>static</sub>	mmH <sub>2</sub> O	3.1	
$P_s = (P_b + (P_{static} / 13.6))$	mmHg	768.3	
<b>Volume of water vapour collected, V<sub>wstd</sub></b>			
Total mass collected in impingers (liquid trap)	g	3.5	
Total mass collected in impingers (silica trap)	g	6.2	
Total mass of liquid collected, V <sub>lc</sub>	g	9.7	
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	0.0121	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			
Volume of gas sample through gas meter, V <sub>m</sub>	m <sup>3</sup>	1.1560	
Gas meter correction factor, Y <sub>d</sub>	-	0.9900	
Average dry gas meter temperature, T <sub>m</sub>	°C	15.0	
Average pressure drop across orifice, ΔH	mmH <sub>2</sub> O	36.3	
$V_{mstd} = ((0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)) / (T_m + 273)$	m <sup>3</sup>	1.1001	
<b>Moisture content, B<sub>wo</sub> &amp; R<sub>wv</sub></b>			
$B_{wo} = V_{wstd} / (V_{mstd} + V_{wstd})$	m <sup>3</sup>	0.0109	
B <sub>wo</sub> as a percentage	% v/v	1.09	
Reported Water Vapour, checked with Tables in EN 14790, R <sub>wv</sub>	% v/v	1.09	
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			
$V_{mstw} = (V_{mstd})(100/(100 - R_{wv}))$	m <sup>3</sup>	1.1122	
<b>Volume of gas metered at Oxygen Reference Conditions, V<sub>mstd@X%O<sub>2</sub></sub> &amp; V<sub>mstw@X%O<sub>2</sub></sub></b>			
IED & Incinerates Hazardous Material? (Yes = no positive O <sub>2</sub> correction)	-	No	
% wet oxygen measured in gas stream, ACT%O <sub>2w</sub>	% v/v	N/A	
% dry oxygen measured in gas stream, ACT%O <sub>2d</sub>	% v/v	N/A	
% oxygen reference condition, REF%O <sub>2</sub>	% v/v	N/A	
O <sub>2</sub> Reference Factor wet ( $O_{2REFw} = (21 - REF\%O_2) / (21 - ACT\%O_{2w})$ )	-	N/A	
O <sub>2</sub> Reference Factor dry ( $O_{2REFd} = (21 - REF\%O_2) / (21 - ACT\%O_{2d})$ )	-	N/A	
$V_{mstw@X\%oxygen} = (V_{mstw}) / (O_{2REFw})$	m <sup>3</sup>	N/A	
$V_{mstd@X\%oxygen} = (V_{mstd}) / (O_{2REFd})$	m <sup>3</sup>	N/A	
<b>Molecular weight of dry gas stream, M<sub>d</sub></b>			
CO <sub>2</sub> (Estimated)	% v/v	0.06	
O <sub>2</sub> (Estimated)	% v/v	20.80	
Total	% v/v	20.86	
N <sub>2</sub>	% v/v	79.14	
$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$	g/gmol	28.84	
<b>Molecular weight of stack gas (wet), M<sub>s</sub></b>			
$M_s = M_d(1 - (R_{wv}/100)) + 18(R_{wv}/100)$	g/gmol	28.72	
<b>Velocity of stack gas, V<sub>s</sub></b>			
Pitot tube velocity constant, K <sub>p</sub>	-	34.97	
Velocity pressure coefficient, C <sub>p</sub>	-	0.86	
Average of velocity heads, ΔP <sub>avg</sub>	mmH <sub>2</sub> O	20.00	
Average square root of velocity heads, √ΔP	√mmH <sub>2</sub> O	4.47	
Average stack gas temperature, T <sub>s</sub>	°C	30.0	
$V_s = ((K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})) / (\sqrt{M_s}(P_s))$	m/s	15.81	
<b>Total flow of stack gas: Actual (Q<sub>a</sub>), Wet (Q<sub>stw</sub>), Dry (Q<sub>std</sub>), Wet@O<sub>2REF</sub> (Q<sub>stwO<sub>2</sub></sub>), Dry@O<sub>2REF</sub> (Q<sub>stdO<sub>2</sub></sub>)</b>			
Area of stack, A <sub>s</sub>	m <sup>2</sup>	0.06	
$Q_a = (60)(A_s)(V_s)$	m <sup>3</sup> /min	58.4	
Conversion factor (K/mm.Hg), C <sub>f</sub>	-	0.3592	
$Q_{stw} = ((Q_a)(P_s)(C_f)) / ((T_s) + 273)$	m <sup>3</sup> /min	53.2	
$Q_{std} = ((Q_a)(P_s)(C_f)(1 - (R_{wv}/100))) / ((T_s) + 273)$	m <sup>3</sup> /min	52.6	
$Q_{stwO_2} = ((Q_a)(P_s)(C_f)) / ((T_s) + 273) / (O_{2REFw})$	m <sup>3</sup> /min	N/A	
$Q_{stdO_2} = ((Q_a)(P_s)(C_f)(1 - (R_{wv}/100))) / ((T_s) + 273) / (O_{2REFd})$	m <sup>3</sup> /min	N/A	
<b>Percent isokinetic, %I</b>			
Nozzle diameter, D <sub>n</sub>	mm	5.00	
Nozzle area, A <sub>n</sub>	mm <sup>2</sup>	19.64	
Total sampling time, q	min	60	
$\%I = (4.6398E^6)(T_s + 273)(V_{mstd}) / (P_s)(V_s)(A_n)(q)(1 - (R_{wv}/100))$	%	109.2	

**NICKEL: SAMPLING DETAILS**

**Sample Runs**

Parameter	Units	Run 1
Sampling Times	-	10:20 - 11:20
Sampling Dates	-	05/12/2022
Sampling Device	-	ISO
Volume Sampled (REF)	m <sup>3</sup>	1.1122
Mass on Filter / in Rinse	µg	< 0.60
Mass in Front Impingers	µg	0.30
Mass in Back Impinger	µg	0.13
Total Mass Collected	µg	1.03
Calculated Concentration	mg/m <sup>3</sup>	0.0009
Reported Concentration	mg/m <sup>3</sup>	0.0009

**Where:** ISO stands for Manual Isokinetic Sampling Train

**Blank Runs**

Parameter	Units	Blank 1
Blank Dates	-	05/12/2022
Average Volume Sampled (REF)	m <sup>3</sup>	1.1122
Mass on Filter / in Rinse	µg	< 0.60
Mass in Front Impingers	µg	< 0.04
Mass in Back Impinger	µg	< 0.02
Total Mass Collected	µg	< 0.66
Calculated Concentration	mg/m <sup>3</sup>	< 0.0006
Reported Concentration	mg/m <sup>3</sup>	< 0.0006

**NICKEL: QUALITY ASSURANCE**

(PAGE 1 OF 2)

**Sample Runs**

<b>Leak Test Results</b>	<b>Units</b>	<b>Run 1</b>
Mean Sampling Rate	l/min	19.1
Pre-Sampling Leak Rate	l/min	0.05
Post-Sampling Leak Rate	l/min	N/A
Allowable Leak Rate	l/min	0.50
Leak Test Acceptable	-	Yes

<b>Absorption Efficiency</b>	<b>Units</b>	<b>Run 1</b>
Absorption Efficiency	%	87.0
Allowable Absorption Efficiency	%	N/A
Absorption Efficiency Acceptable	-	Yes

Where the emissions are < 30% of the ELV, MID 14385 does not require the absorption efficiency requirement to be applied

<b>Detection Limit</b>	<b>Units</b>	<b>Run 1</b>
Detection Limit	µg/m <sup>3</sup>	0.6
Allowable Detection Limit	µg/m <sup>3</sup>	5
Detection Limit Acceptable	-	Yes

<b>Water Droplets</b>	<b>Units</b>	<b>Run 1</b>
Are Water Droplets Present	-	No

<b>MU (Concurrent Water Vapour)</b>	<b>Units</b>	<b>Run 1</b>
Measurement Uncertainty (MU)	%	5.5
Allowable MU	%	20.0
MU Acceptable	%	Yes

<b>Silica Gel (Concurrent Water Vapour)</b>	<b>Units</b>	<b>Run 1</b>
Less than 50% Faded	%	Yes

<b>Isokinetic Criterion Compliance</b>	<b>Units</b>	<b>Run 1</b>
Isokinetic Variation	%	109.2
Allowable Isokinetic Range	%	95 - 115
Isokineticity Acceptable	-	Yes

<b>Filter Temperatures</b>	<b>Units</b>	<b>Run 1</b>
Maximum Filter Temperature	°C	160

<b>Impingers Exit Temperature</b>	<b>Units</b>	<b>Run 1</b>
Maximum Temperature Recorded	°C	6
Maximum Allowable Temperature	°C	30
Exit Temperature Acceptable	-	Yes

<b>Test Conditions</b>	<b>Units</b>	<b>Run 1</b>
Ambient Temperature Recorded?	-	Yes

**NICKEL: QUALITY ASSURANCE**

(PAGE 2 OF 2)

**Blank Runs**

Leak Test Results	Units	Blank 1
Expected Sampling Rate	l/min	25.0
Pre-Sampling Leak Rate	l/min	0.00
Post-Sampling Leak Rate	l/min	N/A
Allowable Leak Rate	l/min	0.50
Leak Test Acceptable	-	Yes

Validity of Blank vs ELV	Units	Blank 1
Allowable Blank	mg/m <sup>3</sup>	0.500
Blank Acceptable	-	Yes

**Method Deviations**

Nature of Deviation	Run Number
(x = deviation applies to the associated run, wx = deviation also applies to the concurrent water vapour run)	1
There are no deviations associated with the sampling employed.	wx

**NICKEL: MEASUREMENT UNCERTAINTY CALCULATIONS**

Measured Quantities	Value		Standard uncertainty		
	Symbol	Run 1	Symbol	Units	Run 1
Sampled Volume (Actual)	V <sub>m</sub>	1.1560	uV <sub>m</sub>	m <sup>3</sup>	0.0231
Sampled Gas Temperature	T <sub>m</sub>	288.0	uT <sub>m</sub>	K	2.00
Sampled Gas Pressure	ρ <sub>m</sub>	102.4	uρ <sub>m</sub>	kPa	0.50
Sampled Gas Humidity	H <sub>m</sub>	0.0	uH <sub>m</sub>	% v/v	1.00
Leak	L	0.26	uL	%	-
Laboratory Result	L <sub>r</sub>	5.90	uL <sub>r</sub>	%	-

Measured Quantities	Uncertainty as a Percentage		Requirement of Standard
	Units	Run 1	
Sampled Volume (Actual)	%	2.00	≤2%
Sampled Gas Temperature	%	0.69	≤1%
Sampled Gas Pressure	%	0.49	≤1%
Sampled Gas Humidity	%	1.00	≤1%
Leak	%	0.26	≤2%
Laboratory Result	%	5.90	No Requirement

Measured Quantities	Uncertainty in Measurement Units			Sensitivity Coefficient
	Symbol	Units	Run 1	Run 1
Sampled Volume (STP)	V <sub>m</sub>	m <sup>3</sup>	1.1001	0.001
Leak	L	mg/m <sup>3</sup>	0.000001	1.00
Laboratory Result	L <sub>r</sub>	mg/m <sup>3</sup>	0.0001	1.00

Measured Quantities	Uncertainty in Result	
	Units	Run 1
Sampled Volume (STP)	mg/m <sup>3</sup>	0.00002
Leak	mg/m <sup>3</sup>	0.000001
Laboratory Result	mg/m <sup>3</sup>	0.0001

Measured Quantities	Oxygen Correction Part of MU Budget	
	Units	Run 1
O <sub>2</sub> Correction Factor	-	N/A
Stack Gas O <sub>2</sub> Content	% v/v	N/A
MU for O <sub>2</sub> Correction	%	N/A
Overall MU For O <sub>2</sub> Measurement	%	N/A

Parameter	Units	Run 1
Combined uncertainty	mg/m <sup>3</sup>	0.0001
Expanded uncertainty (95% confidence), without Oxygen Correction	mg/m <sup>3</sup>	0.0001
Expanded uncertainty (95% confidence), with Oxygen Correction	mg/m <sup>3</sup>	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	mg/m <sup>3</sup>	0.0001
Reported Uncertainty	mg/m <sup>3</sup>	0.0001
Expanded uncertainty (95% confidence), without Oxygen Correction	%	12.5
Expanded uncertainty (95% confidence), with Oxygen Correction	%	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	%	12.5
Reported Uncertainty	%	12.5



**COBALT: RESULTS SUMMARY**

Federal-Mogul Coventry Ltd, Coventry  
Main Stack

**Sample Runs**

Parameter	Units	Run 1	Mean
Concentration	mg/m <sup>3</sup>	0.001	0.001
Uncertainty	±mg/m <sup>3</sup>	0.0001	0.0001
Mass Emission	g/hr	0.002	0.002
Uncertainty	±g/hr	0.0003	0.0003

Parameter	Units	Run 1	Mean
Water Vapour	% v/v	1.1	1.1
Uncertainty	±% v/v	0.06	0.06

**Blank Runs**

Parameter	Units	Blank 1	Maximum
Concentration	mg/m <sup>3</sup>	< 0.0005	< 0.0005

**General Sampling Information**

Parameter	Value
Standard	EN 14385
Technical Procedure	CAT-TP-06
Name of Analytical Laboratory	EET
Analytical Laboratory's Procedure	CAT-AP-07
ISO 17025 Accredited Analysis?	MCERTS
Date of Sample Analysis	15/12/2022
Probe Material	Titanium
Filter Housing Material	Titanium
Impinger Material	Borosilicate Glass
Absorption Solution	Nitric Peroxide
Positioning of Filter	Out Stack
Filter Size and Material	47mm Quartz Fibre
Number of Sampling Lines Used	1 / 1
Number of Sampling Points Used	1 / 1
Sample Point I.D.'s	A1

FORMAT: Number Used / Number Required

**Reference Conditions**

Reference Conditions are: 273K, 101.3kPa, without correction for water vapour content.

**COBALT: ISOKINETIC SAMPLING CALCULATIONS**

Test	Units	Run 1	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			
Barometric pressure, P <sub>b</sub>	mmHg	768.1	
Stack static pressure, P <sub>static</sub>	mmH <sub>2</sub> O	3.1	
$P_s = (P_b + (P_{static} / 13.6))$	mmHg	768.3	
<b>Volume of water vapour collected, V<sub>wstd</sub></b>			
Total mass collected in impingers (liquid trap)	g	3.5	
Total mass collected in impingers (silica trap)	g	6.2	
Total mass of liquid collected, V <sub>lc</sub>	g	9.7	
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	0.0121	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			
Volume of gas sample through gas meter, V <sub>m</sub>	m <sup>3</sup>	1.1560	
Gas meter correction factor, Y <sub>d</sub>	-	0.9900	
Average dry gas meter temperature, T <sub>m</sub>	°C	15.0	
Average pressure drop across orifice, ΔH	mmH <sub>2</sub> O	36.3	
$V_{mstd} = ((0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)) / (T_m + 273)$	m <sup>3</sup>	1.1001	
<b>Moisture content, B<sub>wo</sub> &amp; R<sub>wv</sub></b>			
$B_{wo} = V_{wstd} / (V_{mstd} + V_{wstd})$	m <sup>3</sup>	0.0109	
B <sub>wo</sub> as a percentage	% v/v	1.09	
Reported Water Vapour, checked with Tables in EN 14790, R <sub>wv</sub>	% v/v	1.09	
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			
$V_{mstw} = (V_{mstd})(100/(100 - R_{wv}))$	m <sup>3</sup>	1.1122	
<b>Volume of gas metered at Oxygen Reference Conditions, V<sub>mstd@X%O<sub>2</sub></sub> &amp; V<sub>mstw@X%O<sub>2</sub></sub></b>			
IED & Incinerates Hazardous Material? (Yes = no positive O <sub>2</sub> correction)	-	No	
% wet oxygen measured in gas stream, ACT%O <sub>2w</sub>	% v/v	N/A	
% dry oxygen measured in gas stream, ACT%O <sub>2d</sub>	% v/v	N/A	
% oxygen reference condition, REF%O <sub>2</sub>	% v/v	N/A	
O <sub>2</sub> Reference Factor wet ( $O_{2REFw} = (21 - REF\%O_2) / (21 - ACT\%O_{2w})$ )	-	N/A	
O <sub>2</sub> Reference Factor dry ( $O_{2REFd} = (21 - REF\%O_2) / (21 - ACT\%O_{2d})$ )	-	N/A	
$V_{mstw@X\%oxygen} = (V_{mstw}) / (O_{2REFw})$	m <sup>3</sup>	N/A	
$V_{mstd@X\%oxygen} = (V_{mstd}) / (O_{2REFd})$	m <sup>3</sup>	N/A	
<b>Molecular weight of dry gas stream, M<sub>d</sub></b>			
CO <sub>2</sub> (Estimated)	% v/v	0.06	
O <sub>2</sub> (Estimated)	% v/v	20.80	
Total	% v/v	20.86	
N <sub>2</sub>	% v/v	79.14	
$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$	g/gmol	28.84	
<b>Molecular weight of stack gas (wet), M<sub>s</sub></b>			
$M_s = M_d(1 - (R_{wv}/100)) + 18(R_{wv}/100)$	g/gmol	28.72	
<b>Velocity of stack gas, V<sub>s</sub></b>			
Pitot tube velocity constant, K <sub>p</sub>	-	34.97	
Velocity pressure coefficient, C <sub>p</sub>	-	0.86	
Average of velocity heads, ΔP <sub>avg</sub>	mmH <sub>2</sub> O	20.00	
Average square root of velocity heads, √ΔP	√mmH <sub>2</sub> O	4.47	
Average stack gas temperature, T <sub>s</sub>	°C	30.0	
$V_s = ((K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})) / (V(M_s)(P_s))$	m/s	15.81	
<b>Total flow of stack gas: Actual (Q<sub>a</sub>), Wet (Q<sub>stw</sub>), Dry (Q<sub>std</sub>), Wet@O<sub>2REF</sub> (Q<sub>stwO<sub>2</sub></sub>), Dry@O<sub>2REF</sub> (Q<sub>stdO<sub>2</sub></sub>)</b>			
Area of stack, A <sub>s</sub>	m <sup>2</sup>	0.06	
$Q_a = (60)(A_s)(V_s)$	m <sup>3</sup> /min	58.4	
Conversion factor (K/mm.Hg), C <sub>f</sub>	-	0.3592	
$Q_{stw} = ((Q_a)(P_s)(C_f)) / ((T_s) + 273)$	m <sup>3</sup> /min	53.2	
$Q_{std} = ((Q_a)(P_s)(C_f)(1 - (R_{wv}/100))) / ((T_s) + 273)$	m <sup>3</sup> /min	52.6	
$Q_{stwO_2} = ((Q_a)(P_s)(C_f)) / ((T_s) + 273) / (O_{2REFw})$	m <sup>3</sup> /min	N/A	
$Q_{stdO_2} = ((Q_a)(P_s)(C_f)(1 - (R_{wv}/100))) / ((T_s) + 273) / (O_{2REFd})$	m <sup>3</sup> /min	N/A	
<b>Percent isokinetic, %I</b>			
Nozzle diameter, D <sub>n</sub>	mm	5.00	
Nozzle area, A <sub>n</sub>	mm <sup>2</sup>	19.64	
Total sampling time, q	min	60	
$\%I = (4.6398E^6)(T_s + 273)(V_{mstd}) / (P_s)(V_s)(A_n)(q)(1 - (R_{wv}/100))$	%	109.2	

**COBALT: SAMPLING DETAILS**

**Sample Runs**

Parameter	Units	Run 1
Sampling Times	-	10:20 - 11:20
Sampling Dates	-	05/12/2022
Sampling Device	-	ISO
Volume Sampled (REF)	m <sup>3</sup>	1.1122
Mass on Filter / in Rinse	µg	< 0.50
Mass in Front Impingers	µg	0.04
Mass in Back Impinger	µg	0.06
Total Mass Collected	µg	0.60
Calculated Concentration	mg/m <sup>3</sup>	0.0005
Reported Concentration	mg/m <sup>3</sup>	0.0005

**Where:** ISO stands for Manual Isokinetic Sampling Train

**Blank Runs**

Parameter	Units	Blank 1
Blank Dates	-	05/12/2022
Average Volume Sampled (REF)	m <sup>3</sup>	1.1122
Mass on Filter / in Rinse	µg	< 0.50
Mass in Front Impingers	µg	< 0.04
Mass in Back Impinger	µg	< 0.02
Total Mass Collected	µg	< 0.56
Calculated Concentration	mg/m <sup>3</sup>	< 0.0005
Reported Concentration	mg/m <sup>3</sup>	< 0.0005

**COBALT: QUALITY ASSURANCE**

(PAGE 1 OF 2)

**Sample Runs**

<b>Leak Test Results</b>	<b>Units</b>	<b>Run 1</b>
Mean Sampling Rate	l/min	19.1
Pre-Sampling Leak Rate	l/min	0.05
Post-Sampling Leak Rate	l/min	N/A
Allowable Leak Rate	l/min	0.50
Leak Test Acceptable	-	Yes

<b>Absorption Efficiency</b>	<b>Units</b>	<b>Run 1</b>
Absorption Efficiency	%	90.2
Allowable Absorption Efficiency	%	N/A
Absorption Efficiency Acceptable	-	Yes

Where the emissions are < 30% of the ELV, MID 14385 does not require the absorption efficiency requirement to be applied

<b>Detection Limit</b>	<b>Units</b>	<b>Run 1</b>
Detection Limit	µg/m <sup>3</sup>	0.5
Allowable Detection Limit	µg/m <sup>3</sup>	5.0
Detection Limit Acceptable	-	Yes

<b>Water Droplets</b>	<b>Units</b>	<b>Run 1</b>
Are Water Droplets Present	-	No

<b>MU (Concurrent Water Vapour)</b>	<b>Units</b>	<b>Run 1</b>
Measurement Uncertainty (MU)	%	5.5
Allowable MU	%	20.0
MU Acceptable	%	Yes

<b>Silica Gel (Concurrent Water Vapour)</b>	<b>Units</b>	<b>Run 1</b>
Less than 50% Faded	%	Yes

<b>Isokinetic Criterion Compliance</b>	<b>Units</b>	<b>Run 1</b>
Isokinetic Variation	%	109.2
Allowable Isokinetic Range	%	95 - 115
Isokineticity Acceptable	-	Yes

<b>Filter Temperatures</b>	<b>Units</b>	<b>Run 1</b>
Maximum Filter Temperature	°C	160

<b>Impingers Exit Temperature</b>	<b>Units</b>	<b>Run 1</b>
Maximum Temperature Recorded	°C	6
Maximum Allowable Temperature	°C	30
Exit Temperature Acceptable	-	Yes

<b>Test Conditions</b>	<b>Units</b>	<b>Run 1</b>
Ambient Temperature Recorded?	-	Yes

**COBALT: QUALITY ASSURANCE**

(PAGE 2 OF 2)

**Blank Runs**

Leak Test Results	Units	Blank 1
Expected Sampling Rate	l/min	25.0
Pre-Sampling Leak Rate	l/min	0.00
Post-Sampling Leak Rate	l/min	N/A
Allowable Leak Rate	l/min	0.50
Leak Test Acceptable	-	Yes

Validity of Blank vs ELV	Units	Blank 1
Allowable Blank	mg/m <sup>3</sup>	0.500
Blank Acceptable	-	Yes

**Method Deviations**

Nature of Deviation	Run Number
(x = deviation applies to the associated run, wx = deviation also applies to the concurrent water vapour run)	1
There are no deviations associated with the sampling employed.	wx

**COBALT: MEASUREMENT UNCERTAINTY CALCULATIONS**

Measured Quantities	Value		Standard uncertainty		
	Symbol	Run 1	Symbol	Units	Run 1
Sampled Volume (Actual)	V <sub>m</sub>	1.1560	uV <sub>m</sub>	m <sup>3</sup>	0.0231
Sampled Gas Temperature	T <sub>m</sub>	288.0	uT <sub>m</sub>	K	2.00
Sampled Gas Pressure	ρ <sub>m</sub>	102.4	uρ <sub>m</sub>	kPa	0.50
Sampled Gas Humidity	H <sub>m</sub>	0.00	uH <sub>m</sub>	% v/v	1.00
Leak	L	0.26	uL	%	-
Laboratory Result	L <sub>r</sub>	7.70	uL <sub>r</sub>	%	-

Measured Quantities	Uncertainty as a Percentage		Requirement of Standard
	Units	Run 1	
Sampled Volume (Actual)	%	2.00	≤2%
Sampled Gas Temperature	%	0.69	≤1%
Sampled Gas Pressure	%	0.49	≤1%
Sampled Gas Humidity	%	1.00	≤1%
Leak	%	0.26	≤2%
Laboratory Result	%	7.70	No Requirement

Measured Quantities	Uncertainty in Measurement Units			Sensitivity Coefficient	
	Symbol	Units	Run 1	Run 1	
Sampled Volume (STP)	V <sub>m</sub>	m <sup>3</sup>	1.1001	0.0005	
Leak	L	mg/m <sup>3</sup>	0.000001	1.00	
Laboratory Result	L <sub>r</sub>	mg/m <sup>3</sup>	0.00004	1.00	

Measured Quantities	Uncertainty in Result	
	Units	Run 1
Sampled Volume (STP)	mg/m <sup>3</sup>	0.00001
Leak	mg/m <sup>3</sup>	0.000001
Laboratory Result	mg/m <sup>3</sup>	0.00004

Measured Quantities	Oxygen Correction Part of MU Budget	
	Units	Run 1
O <sub>2</sub> Correction Factor	-	N/A
Stack Gas O <sub>2</sub> Content	% v/v	N/A
MU for O <sub>2</sub> Correction	%	N/A
Overall MU For O <sub>2</sub> Measurement	%	N/A

Parameter	Units	Run 1
Combined uncertainty	mg/m <sup>3</sup>	0.00004
Expanded uncertainty (95% confidence), without Oxygen Correction	mg/m <sup>3</sup>	0.00009
Expanded uncertainty (95% confidence), with Oxygen Correction	mg/m <sup>3</sup>	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	mg/m <sup>3</sup>	0.00009
Reported Uncertainty	mg/m <sup>3</sup>	0.00009
Expanded uncertainty (95% confidence), without Oxygen Correction	%	15.9
Expanded uncertainty (95% confidence), with Oxygen Correction	%	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	%	15.9
Reported Uncertainty	%	15.9

**CHROMIUM: RESULTS SUMMARY**

Federal-Mogul Coventry Ltd, Coventry  
Main Stack

**Sample Runs**

Parameter	Units	Run 1	Mean
Concentration	mg/m <sup>3</sup>	0.001	0.001
Uncertainty	±mg/m <sup>3</sup>	0.0001	0.0001
Mass Emission	g/hr	0.002	0.002
Uncertainty	±g/hr	0.0004	0.0004

Parameter	Units	Run 1	Mean
Water Vapour	% v/v	1.1	1.1
Uncertainty	±% v/v	0.06	0.06

**Blank Runs**

Parameter	Units	Blank 1	Maximum
Concentration	mg/m <sup>3</sup>	< 0.0006	< 0.0006

**General Sampling Information**

Parameter	Value
Standard	EN 14385
Technical Procedure	CAT-TP-06
Name of Analytical Laboratory	EET
Analytical Laboratory's Procedure	CAT-AP-07
ISO 17025 Accredited Analysis?	MCERTS
Date of Sample Analysis	15/12/2022
Probe Material	Titanium
Filter Housing Material	Titanium
Impinger Material	Borosilicate Glass
Absorption Solution	Nitric Peroxide
Positioning of Filter	Out Stack
Filter Size and Material	47mm Quartz Fibre
Number of Sampling Lines Used	1 / 1
Number of Sampling Points Used	1 / 1
Sample Point I.D.'s	A1

FORMAT: Number Used / Number Required

**Reference Conditions**

Reference Conditions are: 273K, 101.3kPa, without correction for water vapour content.

**CHROMIUM: ISOKINETIC SAMPLING CALCULATIONS**

Test	Units	Run 1	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			
Barometric pressure, P <sub>b</sub>	mmHg	768.1	
Stack static pressure, P <sub>static</sub>	mmH <sub>2</sub> O	3.1	
$P_s = (P_b + (P_{static} / 13.6))$	mmHg	768.3	
<b>Volume of water vapour collected, V<sub>wstd</sub></b>			
Total mass collected in impingers (liquid trap)	g	3.5	
Total mass collected in impingers (silica trap)	g	6.2	
Total mass of liquid collected, V <sub>lc</sub>	g	9.7	
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	0.0121	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			
Volume of gas sample through gas meter, V <sub>m</sub>	m <sup>3</sup>	1.1560	
Gas meter correction factor, Y <sub>d</sub>	-	0.9900	
Average dry gas meter temperature, T <sub>m</sub>	°C	15.0	
Average pressure drop across orifice, ΔH	mmH <sub>2</sub> O	36.3	
$V_{mstd} = ((0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)) / (T_m + 273)$	m <sup>3</sup>	1.1001	
<b>Moisture content, B<sub>wo</sub> &amp; R<sub>ww</sub></b>			
$B_{wo} = V_{wstd} / (V_{mstd} + V_{wstd})$	m <sup>3</sup>	0.0109	
B <sub>wo</sub> as a percentage	% v/v	1.09	
Reported Water Vapour, checked with Tables in EN 14790, R <sub>ww</sub>	% v/v	1.09	
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			
$V_{mstw} = (V_{mstd})(100/(100 - R_{ww}))$	m <sup>3</sup>	1.1122	
<b>Volume of gas metered at Oxygen Reference Conditions, V<sub>mstd@X%O<sub>2</sub></sub> &amp; V<sub>mstw@X%O<sub>2</sub></sub></b>			
IED & Incinerates Hazardous Material? (Yes = no positive O <sub>2</sub> correction)	-	No	
% wet oxygen measured in gas stream, ACT%O <sub>2w</sub>	% v/v	N/A	
% dry oxygen measured in gas stream, ACT%O <sub>2d</sub>	% v/v	N/A	
% oxygen reference condition, REF%O <sub>2</sub>	% v/v	N/A	
O <sub>2</sub> Reference Factor wet ( $O_{2REFw} = (21 - REF\%O_2) / (21 - ACT\%O_{2w})$ )	-	N/A	
O <sub>2</sub> Reference Factor dry ( $O_{2REFd} = (21 - REF\%O_2) / (21 - ACT\%O_{2d})$ )	-	N/A	
$V_{mstw@X\%oxygen} = (V_{mstw}) / (O_{2REFw})$	m <sup>3</sup>	N/A	
$V_{mstd@X\%oxygen} = (V_{mstd}) / (O_{2REFd})$	m <sup>3</sup>	N/A	
<b>Molecular weight of dry gas stream, M<sub>d</sub></b>			
CO <sub>2</sub> (Estimated)	% v/v	0.06	
O <sub>2</sub> (Estimated)	% v/v	20.80	
Total	% v/v	20.86	
N <sub>2</sub>	% v/v	79.14	
$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$	g/gmol	28.84	
<b>Molecular weight of stack gas (wet), M<sub>s</sub></b>			
$M_s = M_d(1 - (R_{ww}/100)) + 18(R_{ww}/100)$	g/gmol	28.72	
<b>Velocity of stack gas, V<sub>s</sub></b>			
Pitot tube velocity constant, K <sub>p</sub>	-	34.97	
Velocity pressure coefficient, C <sub>p</sub>	-	0.86	
Average of velocity heads, ΔP <sub>avg</sub>	mmH <sub>2</sub> O	20.00	
Average square root of velocity heads, √ΔP	√mmH <sub>2</sub> O	4.47	
Average stack gas temperature, T <sub>s</sub>	°C	30.0	
$V_s = ((K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})) / (V(M_s)(P_s))$	m/s	15.81	
<b>Total flow of stack gas: Actual (Q<sub>a</sub>), Wet (Q<sub>stw</sub>), Dry (Q<sub>std</sub>), Wet@O<sub>2REF</sub> (Q<sub>stwO<sub>2</sub></sub>), Dry@O<sub>2REF</sub> (Q<sub>stdO<sub>2</sub></sub>)</b>			
Area of stack, A <sub>s</sub>	m <sup>2</sup>	0.06	
$Q_a = (60)(A_s)(V_s)$	m <sup>3</sup> /min	58.4	
Conversion factor (K/mm.Hg), C <sub>f</sub>	-	0.3592	
$Q_{stw} = ((Q_a)(P_s)(C_f)) / ((T_s) + 273)$	m <sup>3</sup> /min	53.2	
$Q_{std} = ((Q_a)(P_s)(C_f)(1 - (R_{ww}/100))) / ((T_s) + 273)$	m <sup>3</sup> /min	52.6	
$Q_{stwO_2} = ((Q_a)(P_s)(C_f)) / ((T_s) + 273) / (O_{2REFw})$	m <sup>3</sup> /min	N/A	
$Q_{stdO_2} = ((Q_a)(P_s)(C_f)(1 - (R_{ww}/100))) / ((T_s) + 273) / (O_{2REFd})$	m <sup>3</sup> /min	N/A	
<b>Percent isokinetic, %I</b>			
Nozzle diameter, D <sub>n</sub>	mm	5.00	
Nozzle area, A <sub>n</sub>	mm <sup>2</sup>	19.64	
Total sampling time, q	min	60	
$\%I = (4.6398E^6)(T_s + 273)(V_{mstd}) / (P_s)(V_s)(A_n)(q)(1 - (R_{ww}/100))$	%	109.2	



**CHROMIUM: SAMPLING DETAILS**

**Sample Runs**

Parameter	Units	Run 1
Sampling Times	-	10:20 - 11:20
Sampling Dates	-	05/12/2022
Sampling Device	-	ISO
Volume Sampled (REF)	m <sup>3</sup>	1.1122
Mass on Filter / in Rinse	µg	< 0.60
Mass in Front Impingers	µg	0.12
Mass in Back Impinger	µg	0.07
Total Mass Collected	µg	0.80
Calculated Concentration	mg/m <sup>3</sup>	0.0007
Reported Concentration	mg/m <sup>3</sup>	0.0007

**Where:** ISO stands for Manual Isokinetic Sampling Train

**Blank Runs**

Parameter	Units	Blank 1
Blank Dates	-	05/12/2022
Average Volume Sampled (REF)	m <sup>3</sup>	1.1122
Mass on Filter / in Rinse	µg	< 0.60
Mass in Front Impingers	µg	< 0.02
Mass in Back Impinger	µg	< 0.01
Total Mass Collected	µg	< 0.63
Calculated Concentration	mg/m <sup>3</sup>	< 0.0006
Reported Concentration	mg/m <sup>3</sup>	< 0.0006

**CHROMIUM: QUALITY ASSURANCE**

(PAGE 1 OF 2)

**Sample Runs**

<b>Leak Test Results</b>	<b>Units</b>	<b>Run 1</b>
Mean Sampling Rate	l/min	19.1
Pre-Sampling Leak Rate	l/min	0.05
Post-Sampling Leak Rate	l/min	N/A
Allowable Leak Rate	l/min	0.50
Leak Test Acceptable	-	Yes

<b>Absorption Efficiency</b>	<b>Units</b>	<b>Run 1</b>
Absorption Efficiency	%	91.0
Allowable Absorption Efficiency	%	N/A
Absorption Efficiency Acceptable	-	Yes

Where the emissions are < 30% of the ELV, MID 14385 does not require the absorption efficiency requirement to be applied

<b>Detection Limit</b>	<b>Units</b>	<b>Run 1</b>
Detection Limit	µg/m <sup>3</sup>	0.6
Allowable Detection Limit	µg/m <sup>3</sup>	5.0
Detection Limit Acceptable	-	Yes

<b>Water Droplets</b>	<b>Units</b>	<b>Run 1</b>
Are Water Droplets Present	-	No

<b>MU (Concurrent Water Vapour)</b>	<b>Units</b>	<b>Run 1</b>
Measurement Uncertainty (MU)	%	5.5
Allowable MU	%	20.0
MU Acceptable	%	Yes

<b>Silica Gel (Concurrent Water Vapour)</b>	<b>Units</b>	<b>Run 1</b>
Less than 50% Faded	%	Yes

<b>Isokinetic Criterion Compliance</b>	<b>Units</b>	<b>Run 1</b>
Isokinetic Variation	%	109.2
Allowable Isokinetic Range	%	95 - 115
Isokineticity Acceptable	-	Yes

<b>Filter Temperatures</b>	<b>Units</b>	<b>Run 1</b>
Maximum Filter Temperature	°C	160

<b>Impingers Exit Temperature</b>	<b>Units</b>	<b>Run 1</b>
Maximum Temperature Recorded	°C	6
Maximum Allowable Temperature	°C	30
Exit Temperature Acceptable	-	Yes

<b>Test Conditions</b>	<b>Units</b>	<b>Run 1</b>
Ambient Temperature Recorded?	-	Yes

**CHROMIUM: QUALITY ASSURANCE**

(PAGE 2 OF 2)

**Blank Runs**

Leak Test Results	Units	Blank 1
Expected Sampling Rate	l/min	25.0
Pre-Sampling Leak Rate	l/min	0.00
Post-Sampling Leak Rate	l/min	N/A
Allowable Leak Rate	l/min	0.50
Leak Test Acceptable	-	Yes

Validity of Blank vs ELV	Units	Blank 1
Allowable Blank	mg/m <sup>3</sup>	0.500
Blank Acceptable	-	Yes

**Method Deviations**

Nature of Deviation	Run Number
(x = deviation applies to the associated run, wx = deviation also applies to the concurrent water vapour run)	1
There are no deviations associated with the sampling employed.	wx

**CHROMIUM: MEASUREMENT UNCERTAINTY CALCULATIONS**

Measured Quantities	Value		Standard uncertainty		
	Symbol	Run 1	Symbol	Units	Run 1
Sampled Volume (Actual)	V <sub>m</sub>	1.1560	uV <sub>m</sub>	m <sup>3</sup>	0.0231
Sampled Gas Temperature	T <sub>m</sub>	288.0	uT <sub>m</sub>	K	2.00
Sampled Gas Pressure	ρ <sub>m</sub>	102.4	uρ <sub>m</sub>	kPa	0.50
Sampled Gas Humidity	H <sub>m</sub>	0.00	uH <sub>m</sub>	% v/v	1.00
Leak	L	0.26	uL	%	-
Laboratory Result	L <sub>r</sub>	7.70	uL <sub>r</sub>	%	-

Measured Quantities	Uncertainty as a Percentage		Requirement of Standard
	Units	Run 1	
Sampled Volume (Actual)	%	2.00	≤2%
Sampled Gas Temperature	%	0.69	≤1%
Sampled Gas Pressure	%	0.49	≤1%
Sampled Gas Humidity	%	1.00	≤1%
Leak	%	0.26	≤2%
Laboratory Result	%	7.70	No Requirement

Measured Quantities	Uncertainty in Measurement Units			Sensitivity Coefficient
	Symbol	Units	Run 1	Run 1
Sampled Volume (STP)	V <sub>m</sub>	m <sup>3</sup>	1.1001	0.001
Leak	L	mg/m <sup>3</sup>	0.000001	1.00
Laboratory Result	L <sub>r</sub>	mg/m <sup>3</sup>	0.0001	1.00

Measured Quantities	Uncertainty in Result	
	Units	Run 1
Sampled Volume (STP)	mg/m <sup>3</sup>	0.00002
Leak	mg/m <sup>3</sup>	0.000001
Laboratory Result	mg/m <sup>3</sup>	0.0001

Measured Quantities	Oxygen Correction Part of MU Budget	
	Units	Run 1
O <sub>2</sub> Correction Factor	-	N/A
Stack Gas O <sub>2</sub> Content	% v/v	N/A
MU for O <sub>2</sub> Correction	%	N/A
Overall MU For O <sub>2</sub> Measurement	%	N/A

Parameter	Units	Run 1
Combined uncertainty	mg/m <sup>3</sup>	0.0001
Expanded uncertainty (95% confidence), without Oxygen Correction	mg/m <sup>3</sup>	0.0001
Expanded uncertainty (95% confidence), with Oxygen Correction	mg/m <sup>3</sup>	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	mg/m <sup>3</sup>	0.0001
Reported Uncertainty	mg/m <sup>3</sup>	0.0001
Expanded uncertainty (95% confidence), without Oxygen Correction	%	15.9
Expanded uncertainty (95% confidence), with Oxygen Correction	%	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	%	15.9
Reported Uncertainty	%	15.9

### VERSION HISTORY

Version Number	Record of changes made within this version of the document
V1	The original document issued to the client