

**HYTEC CASTINGS
BARLOW ROAD
ALDERMANS GREEN
COVENTRY
CV2 2LD**

Fax

To: Ayeisha Mann. Att:
From: MALCOLM CLARK. Pages: 1/2
Fax: Date: MON July 4th 05.
Re: EMISSIONS TEST RESULTS. CC:
 Urgent For Review Please Comment Please Reply

Greetings Ayeisha,
We have just had the results in this
Mornings Post from R.E.C. on the thermal
Plant. you will find the plant is averaging
at 41mg/m³.


15/7/05

TIC to Mike Smith
at REC.

He confirmed that
methodology to take
results were same as
me methodology we
received in Feb ~~2005~~ 2005

All ok!

REGARDS



M CLARK



Minute - averaged VOC data from Hytec
Castings on 23 June 2005
Data expressed at 273K, 101.3kPa without
correction for oxygen or water vapour

TIME	VOC ppm	VOC mg/m ³
13:15:31	80.8	44
13:16:31	77.4	42
13:17:31	67.4	36
13:18:31	65.3	35
13:19:31	67.2	36
13:20:31	64.5	35
13:21:31	69.4	37
13:22:31	67.4	31
13:23:31	60.3	33
13:24:31	61.3	33
13:25:31	66.4	36
13:26:31	58.6	32
13:27:31	66.4	36
13:28:31	63.4	34
13:29:31	63.4	34
13:30:31	71.3	39
13:31:31	64.3	35
13:32:31	77.3	42
13:33:31	71.3	39
13:34:31	79.3	43
13:35:31	73.9	40
13:36:31	75.2	41
13:37:31	76.1	41
13:38:31	87.2	47
13:39:31	81.3	44
13:40:31	76.2	41
13:41:31	84.0	45
13:42:31	74.2	40
13:43:31	80.1	43
13:44:31	81.2	44
13:45:31	81.4	44
13:46:31	87.2	47
13:47:31	88.3	48
13:48:31	75.2	41
13:49:31	72.2	39
13:50:31	79.2	43
13:51:31	76.2	41
13:52:31	70.2	38
13:53:31	81.2	44
13:54:31	79.1	43
13:55:31	76.7	41
13:56:31	78.2	42
13:57:31	80.2	43
13:58:31	77.1	42
13:59:31	77.1	42
14:00:31	72.1	39
14:01:31	82.1	44
14:02:31	93.2	50
14:03:31	86.7	47
14:04:31	83.2	45
14:05:31	83.2	45
14:06:31	82.5	45
14:07:31	76.2	41
14:08:31	74.1	40
14:09:31	84.1	45
14:10:31	91.2	49
14:11:31	83.2	45
14:12:31	87.1	47
14:13:31	85.2	46
14:14:31	90.8	49
14:15:31	90.2	49
Maximum	93	50
Minimum	57	31
Average	76	41

VOC data presented as methane (CH₄) →