

Report for Periodic Monitoring of Emissions to Atmosphere

Part 1: **Executive Summary**
Permit Number: **N/A**
Operator: **Covpress Ltd**
Installation: **Canley**
Emission Point(s): **Burn off oven, Gas Burner & Wash Steam Vent**
Monitoring Date(s): **9th & 11th November 2011**



Contract Reference: FTBS18427
Operator: Covpress Ltd
Address: Canley
Coventry
CV5 6RT
Monitoring Organisation: RPS Consultants
Address: Grafton Building, Caswell Science &
Technology Park, Caswell,
Towcester, Northamptonshire, NN12 8EQ.
Report Date: 21st December 2011
Report Approved By: Glyn Harrison
Position: Principal Consultant
MCERTS Registration Number: MM 03 228
MCERTS Certification Level: 2
Technical Endorsements: TE1, TE2, TE3, TE4

Signature:



RPS Consultants has produced this report within the term of the contract with the client and taking account of the resources devoted to it by agreement with the client.

We disclaim any responsibility to the client and others in respect of any matters outside the scope of the above. This report is confidential to the client and we accept no responsibility of whatsoever nature to third parties to whom this report, or any part thereof, is made known. Any such party relies on the report at their own risk.

CONTENTS

Part 1: Executive Summary

Section 1 – Monitoring Objectives

Section 2 – Monitoring Results

Section 3 – Operating Information

Section 4 – Monitoring Deviations

Part 2: Supporting Information

Appendix 1 – Staff & Methodology Details

Appendix 2- Burn off oven Sampling, Analysis & Uncertainty Data

Appendix 3- Gas Burner Sampling, Analysis & Uncertainty Data

Appendix 4- Wash Steam Vent Sampling, Analysis & Uncertainty Data

Monitoring Objectives

At the request of Steve Cottom of Covpress Ltd, RPS Consultants conducted stack emission monitoring at the Canley site in November 2011.

The monitoring programme at this installation was carried out to provide data on emissions to atmosphere for information purposes.

The following tables detail the parameters requested for monitoring at each emission point and the actual monitoring conducted.

Table 1.1

Parameters Requested to be Monitored	Emission Point
	Burn off oven
Total Particulate Matter	✓
Volatile Organic Compounds	✓
Carbon Monoxide	✓
Oxides of Nitrogen	✓
Specific Requirements	Normal

Notes:

✓ Represents pollutants sampled

Table 1.2

Parameters Requested to be Monitored	Emission Point
	Gas Burner
Carbon Monoxide	✓
Oxides of Nitrogen	✓
Specific Requirements	Normal

Notes:

✓ Represents pollutants sampled

Table 1.3

Parameters Requested to be Monitored	Emission Point
	Wash Steam Vent
Total Particulate Matter	✓
Specific Requirements	Normal

Notes:

✓ Represents pollutants sampled

Monitoring Results

Table 2.1 Monitoring results for emission point Burn off oven, Carried out on 11/11/2011

Substance Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty (Expressed expanded k=2)	Reference Conditions 273K, 101.3kPa	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Carbon Monoxide	No ELV	219	mg/m ³	+/- 11	273K, 101.3kPa, Dry, 11% Oxygen	11/11/2011	09:19 - 13:26	EN 15058:2006	MCERTS	Normal
Oxides of Nitrogen	No ELV	81	mg/m ³	+/- 4.4	273K, 101.3kPa, Dry, 11% Oxygen	11/11/2011	09:19 - 13:26	BS EN 14792:2005	MCERTS	Normal
Total Particulate Matter	No ELV	14	mg/m ³	+/- 0.61	273K, 101.3kPa, Dry, 11% Oxygen	11/11/2011	09:22 - 13:32	BS EN 13284-1:2002	MCERTS	Normal
Volatile Organic Compounds (as Carbon)	No ELV	7.2	mg/m ³	+/- 1.6	273K, 101.3kPa, Dry, 11% Oxygen	11/11/2011	09:18 - 13:32	BS EN 13526	MCERTS	Normal

Table 2.2 Monitoring results for emission point Gas Burner, Carried out on 09/11/2011

Substance Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty (Expressed expanded k=2)	Reference Conditions 273K, 101.3kPa	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Carbon Monoxide	No ELV	12	mg/m ³	+/- 0.40	273K, 101.3kPa, Dry	09/11/2011	13:52 - 14:52	EN 15058:2006	MCERTS	Normal
Oxides of Nitrogen	No ELV	16	mg/m ³	+/- 0.54	273K, 101.3kPa, Dry	09/11/2011	13:52 - 14:52	BS EN 14792:2005	MCERTS	Normal

Table 2.3 Monitoring results for emission point Wash Steam Vent, Carried out on 09/11/2011

Substance Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty (Expressed expanded k=2)	Reference Conditions 273K, 101.3kPa	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter	No Limit	3.4	mg/m ³	+/- 0.27	273K, 101.3kPa, Wet	09/11/2011	13:46 - 14:46	BS EN 13284-1:2002	MCERTS	Normal

Operating Information

Table 3.1 Operating conditions during the monitoring of emission point Burn off oven carried out on 11/11/2011

Parameter	Result
Sample Date	11/11/2011
Process Type	Batch
Process Duration	4-5 Hour
If 'Batch', was monitoring carried out over the whole batch?	No
Abatement/Operational?	Not Installed

Comparison of Operator CEM and Periodic Monitoring Results		
Substance	CEMs Results (mg/m ³)	Periodic Monitoring Results (mg/m ³)
No CEMS Installed/Data Available		

Table 3.2 Operating conditions during the monitoring of emission point Gas Burner carried out on 09/11/2011

Parameter	Result
Sample Date	09/11/2011
Process Type	Continuous
Process Duration	N/A
If 'Batch', was monitoring carried out over the whole batch?	N/A
Abatement/Operational?	Not Installed

Comparison of Operator CEM and Periodic Monitoring Results		
Substance	CEMs Results (mg/m ³)	Periodic Monitoring Results (mg/m ³)
No CEMS Installed/Data Available		

Table 3.3 Operating conditions during the monitoring of emission point Wash Steam Vent carried out on 09/11/2011

Parameter	Result
Sample Date	09/11/2011
Process Type	Continuous
Process Duration	N/A
If 'Batch', was monitoring carried out over the whole batch?	N/A
Abatement/Operational?	Not Installed

Comparison of Operator CEM and Periodic Monitoring Results		
Substance	CEMs Results (mg/m ³)	Periodic Monitoring Results (mg/m ³)
No CEMS Installed/Data Available		

Monitoring Deviations

Table 4.1 Monitoring Deviations for Emission Point Burn off oven

Pollutant	Substance Deviations	Monitoring Deviations	Other Relevant Issues
Carbon Monoxide, Oxides of Nitrogen, & Volatile Organic Compounds	None	None	None
Total Particulate Matter	None	Monitoring conducted from a single traverse line as only one sample port was cut into the stack. This was due to the health and safety concerns of cutting an additional open hole into a stack with a duct temperature of 750 deg C.	None

Table 4.2 Monitoring Deviations for Emission Point Gas Burner

Pollutant	Substance Deviations	Monitoring Deviations	Other Relevant Issues
Carbon Monoxide & Oxides of Nitrogen	None	Measured oxygen concentrations in the duct were predominantly close to or at ambient levels. Oxygen correction to 3% as stated in the SSP would have a significant effect on the magnitude of the results. Therefore, correction for oxygen content has not been carried out.	None

Table 4.3 Monitoring Deviations for Emission Point Wash Steam Vent

Pollutant	Substance Deviations	Monitoring Deviations	Other Relevant Issues
Total Particulate Matter	None	None	None

Report for Periodic Monitoring of Emissions to Atmosphere

Part 2: **Supporting Information**
Permit Number: **N/A**
Operator: **Covpress Ltd**
Installation: **Canley**
Emission Point(s): **Burn off oven, Gas Burner & Wash Steam Vent**
Monitoring Date(s): **9th & 11th November 2011**



Contract Reference: FTBS18427
Operator: Covpress Ltd
Address: Canley
Coventry
CV5 6RT
Monitoring Organisation: RPS Consultants
Address: Grafton Building, Caswell Science &
Technology Park, Caswell,
Towcester, Northamptonshire, NN12 8EQ.
Report Date: 21st December 2011
Report Approved By: Glyn Harrison
Position: Principal Consultant
MCERTS Registration Number: MM 03 228
MCERTS Certification Level: 2
Technical Endorsements: TE1, TE2, TE3, TE4

Signature:



RPS Consultants has produced this report within the term of the contract with the client and taking account of the resources devoted to it by agreement with the client.

We disclaim any responsibility to the client and others in respect of any matters outside the scope of the above. This report is confidential to the client and we accept no responsibility of whatsoever nature to third parties to whom this report, or any part thereof, is made known. Any such party relies on the report at their own risk.

CONTENTS

Part 1: Executive Summary

Section 1 – Monitoring Objectives

Section 2 – Monitoring Results

Section 3 – Operating Information

Section 4 – Monitoring Deviations

Part 2: Supporting Information

Appendix 1 – Staff & Methodology Details

Appendix 2- Burn off oven Sampling, Analysis & Uncertainty Data

Appendix 3- Gas Burner Sampling, Analysis & Uncertainty Data

Appendix 4- Wash Steam Vent Sampling, Analysis & Uncertainty Data

APPENDIX 1: General Information

Monitoring Organisation Staff Details

Table 5.1 Sampling Personnel

Sampling Personnel	Position	MCERTS Level	Technical Endorsements	MCERTS Registration Number
Carl Redgrove	Senior Consultant	Level 2	TE1, TE2, TE3, TE4	MM 03 173
Richard Carter	Consultant	Level 2	TE1, TE2, TE3, TE4	MM 07 861

Table 5.2 Report Author

Report Author	Position	MCERTS Level	Technical Endorsements	MCERTS Registration Number
Carl Redgrove	Senior Consultant	Level 2	TE1, TE2, TE3, TE4	MM 03 173

Table 5.3 Report Reviewer

Report Reviewer	Position	MCERTS Level	Technical Endorsements	MCERTS Registration Number
Glyn Harrison	Principal Consultant	Level 2	TE1, TE2, TE3, TE4	MM 03 228

Monitoring Organisation Method Details

Table 6.1 Monitoring Methods


Emission Parameter	Standard Method	Monitoring Procedure No.	Monitoring Accreditation	Analysis	Analysis Procedure No.	Analytical Laboratory	Analysis Accreditation
Practical Considerations Prior to Monitoring	N/A	RPSCE/1/1	UKAS	N/A	N/A	N/A	N/A
Gas Flows	BS-EN 13284-1:2001	RPSCE/1/2	MCERTS	N/A	N/A	N/A	N/A
Gas Temperatures	BS-EN 13284-1:2001	RPSCE/1/2	MCERTS	N/A	N/A	N/A	N/A
Carbon Monoxide	EN 15058:2006	RPSCE/1/21h	MCERTS	NDIR	N/A	N/A	N/A
Oxides of Nitrogen	EN 14792:2005	RPSCE/1/21f	MCERTS	Chemiluminescence	N/A	N/A	N/A
Low Concentration Total Particulate Matter	BS EN 13284-1:2002	RPSCE/1/7c	MCERTS	Gravimetric	D9	RPS Laboratories	UKAS
TOCs at high concentrations	BS EN 13526	RPSCE/1/4c	MCERTS	Flame Ionisation Detector	N/A	N/A	N/A

Table 7.1 – Checklist Used

Equipment Checklist Used	File Location Address
FTBS18427 Checklist	FTBS18427 Electronic & Work File

**APPENDIX 2:
Burn off oven Sampling, Analysis & Uncertainty Data**

Sampling Platform Diagram



Company Name: Covpress Ltd
Site Ref: Coventry
Stack Ref: Burn off oven

Date: 11/11/11
Run: Comb Gases

Static Press, mm H₂O: -1.2
Barometric (mm Hg) Start: 745
Stack Diamter (m): 0.4
Pitot Tube Constant: 0.826

Traverse Point No.	Port A				Port B			
	Δ p, mmH2O	Conversion for pitot coefficient and to Pa	Root Δ p.	Stack Temp °C	Δ p, mmH2O	Conversion for coefficient and t	Root Δ p.	Stack Temp °C
1	0.8	5.5	2.337	750				
2	0.8	5.5	2.337	750				
3								
4								
5								
6								
7								
8								
9								
10								
Minimum	0.8	5.5	2.337	750.0	0.0	0.0	0.000	0.0
Maximum	0.8	5.5	2.337	750.0	0.0	0.0	0.000	0.0
Average	0.8	5.5	2.337	750.0	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!
Sum	1.6	10.9	4.673	1500.0	0.0	0.0	0.000	0.0
Total Sum								
Max. pitot press. =			5.5		Max. Temp. =			750.0
Min. pitot press. =			5.5		Min. Temp. =			750.0
Ratio Max:Min =			1.0 : 1		Mean Temp. =			750.0

Mean Root D p: 2.337

Mean Stack Temperature, °C: 750.00

Traverse Stack Velocity, m/s: 5.805

Stack Area, m²: 0.102

Stack Gas Volume Flow Rate, m³/s (acms): 0.571

Stack Gas Volume Flow Rate, m³/s (scms wet): 0.149

Stack Gas Volume Flow Rate, m³/s (scms DRY) O₂ Corrected: 0.114

Moisture: 1

Stack Pressure, mm Hg: 744.91

Gas Data

Oxygen %: 13.27158465
CO₂ %: 4.83

Oxygen Correction

Required Correction Value (%): 11
Oxygen Factor: 1.298
Enter 0 if correction is not required

Barometric Pressure (mmHg)

Min:
Max:

Ambient Temperature (C)

Min:
Max:

Is the angle of gas flow to duct axis <15° at every sample point?	Y
Is measured flow at every sample point positive?	Y
Is the measured differential pressure at every sample point >5Pa (0.5mm H ₂ O)?	Y
Are the highest to lowest ΔP <9:1	Y

Company Name: Covpress Ltd
Site Ref: Coventry
Stack Ref: Burn off oven

Date: 11/11/11
Run: Comb Gases

	O2 %	CO2 %	CO mg/m ³	CO kg/hr	NOx mg/m ³	NOx kg/hr	SO2 mg/m ³	SO2 kg/hr
Average	13.27	4.83	218.96	0.09	80.95	0.03	0.00	0.00
Max	14.96	17.76	1162.57	0.48	208.08	0.09	0.00	0.00
Min	0.31	3.66	18.18	0.01	0.00	0.00	0.00	0.00
Emission Limit			No ELV		No ELV			
Moisture, %	1.0			Barometric (mmHg) Start		745		
Oxygen Reference, %	11.0			Barometric (mmHg) End		745		

Stack Gas Volume Flow Rate, m3/s (scms DRY) O2 Corrected 0.1137683

Calibrations	O ₂ %	CO ₂ %	CO ppm	NO ppm	SO ₂ ppm
Analyser - Start Zero	0.00	0.06	0.5	0.2	
Analyser - Start Span	14.98	8.04	112.4	35.3	
Analyser - Zero Check	0.00	0.05	0.5	0.3	
System - Zero Check	0.12	0.07	0.6	0.2	
System - Span Check	14.91	7.98	111.6	35.2	
System - End Zero Check	0.20	0.06	0.0	0.5	
System - End Span Check	14.95	7.99	111.5	34.2	
Cylinder Number					
Span Value	14.99	8.01	112.8	35	

Uncertainty calculation for Gaseous Measurement of Carbon Monoxide EN 15058

Measured concentration - CO	219.0	mg/m ³ (O ₂ & H ₂ O uncorrected)	Analyser Make/Model	Horiba PG250
Range (Max Value)	250.0	mg/m ³	ID Number	0928

Performance Characteristics	Value		specification
Response time		seconds	< 200 s
Logger sampling interval	20	seconds	
Measurement period	248	minutes	
Number of readings in measurement	744	Assuming 20 Second Readings over 4.1333333333333333 hour period	
Repeatability at zero	0	% of Range	< 1% Range
Repeatability at span level	0	% of Range	< 2% of Range
Deviation from linearity	0	% of Range	< 2% of Range
Zero drift (during measurement period)	-0.531915	% of Range	< 2% of Range
Span drift (during measurement period)	-0.088652	% of Range	< 2% of Range
volume or pressure flow dependence	0	% of fs / 10l/h	< 1% range
atmospheric pressure dependence	0	% of Range/kPa	< 1.5 % range
ambient temperature dependence	-0.07	% of Range /K	<0.3 % range /K
CO ₂ (% vol)	15	% by volume per	
CH ₄ (mg/m ³)	57	mg/m ³	
N ₂ O (mg/m ³)	42	mg/m ³	
Total	0	% of Range	< 4% of Range (Total)
Dependence on voltage	0.1	% by volume /10V	+ 5% < 2% of Range/10 volt
Losses in the line (leak)	2	% of value	< 2% of value
Uncertainty of calibration gas	2	% of value	

Performance characteristic	Uncertainty	Value of uncertainty quantity	% vol
Standard deviation of repeatability at zero	u ₀	for mean	Only use rep at span
Standard deviation of repeatability at span level	u _{rs}	for mean	0.000
Lack of fit	u _{fit}		0.000
Drift	u _{odr}		-0.880
volume or pressure flow dependence	u _{spres}		0.000
atmospheric pressure dependence	u _{apres}		0.000
ambient temperature dependence	u _{temp}		0.000
CO ₂			0.000
NO			0.000
NO ₂			0.000
dependence on voltage	u _{volt}		0.000
losses in the line (leak)	u _{leak}		2.89
Uncertainty of calibration gas	u _{calib}		2.89

Measurement Concentration	218.96	mg/m³	
Combined uncertainty	4.18	mg/m ³	
Coverage factor k = 2			
Expanded uncertainty (as measured)	8.35	mg/m ³	(expressed with a level of confidence of 95%)
Expanded uncertainty (Corrected to Ref Conditions)	10.84	mg/m³	

Uncertainty calculation for Gaseous Measurement of Oxygen EN14789

Measured concentration	13.27	%vol
Range (Max Value)	25	%vol

Analyser Make/Model	Horiba PG250
ID Number	0928

Performance Characteristics	Value		specification
Response time	12	seconds	< 200 s
Logger sampling interval	20	seconds	
Measurement period	248	minutes	
Number of readings in measurement	744	Assuming 20 Second Readings over 4.1333333333333333 hour period	
Repeatability at zero	0.02	% by volume	stdev <0.2 % range
Repeatability at span level	0.02	% by volume	stdev <0.4 % range
Deviation from linearity	0.14	% vol	+/- <0.3 % volume
Zero drift (during measurement period)	0.5336891	% vol at zero level	+/- <2% of volume / 24hr
Span drift (during measurement period)	0.2668446	% vol at span level	+/- <2% volume/24hr
volume or pressure flow dependence	0	% of fs / 10l/h	+ 5 l/h <1% range
atmospheric pressure dependence	0	% of fs/kPa	+ 2kPa < 1.5 % range
ambient temperature dependence	-0.07	% by volume /10K	+ 15K <0.3% volume 10 K
CO ₂ (% vol)	10	0.1	% by volume per 10
NO (mg/m3)	300	0	% by volume per 300
NO ₂ (mg/m3)	30	0	% by volume per 30
Combined interference		% range	<2% range
Dependence on voltage	0.1	% by volume /10V	+ 5% < 0.1%vol /10 volt
Losses in the line (leak)	2	% of value	< 2% of value
Uncertainty of calibration gas	2	% of value	

Performance characteristic	Uncertainty	Value of uncertainty quantity	% vol
Standard deviation of repeatability at zero	U ₀	for mean	Only use rep at span
Standard deviation of repeatability at span level	U _{rs}	for mean	0.001
Lack of fit	U _{rl}		0.081
Drift	U _{dr}		0.445
volume or pressure flow dependence	U _{spres}		0.000
atmospheric pressure dependence	U _{apres}		0.000
ambient temperature dependence	U _{temp}		0.000
CO ₂			0.115
NO			0.000
NO ₂			0.000
dependence on voltage	U _{volt}		0.000
losses in the line (leak)	U _{leak}		0.15
Uncertainty of calibration gas	U _{calib}		0.15

Measurement Concentration	13.27	%vol
Combined uncertainty	0.51	%vol
% of value	3.87	%
Coverage factor k =	2	
Expanded uncertainty	7.75	% of value
Expanded uncertainty	1.03	% vol (expressed with a level of confidence of 95%)

Uncertainty calculation for Gaseous Measurement of Oxides of Nitrogen BS EN 14792

Measured concentration - NO_x	80.9	mg/m³ (O₂ & H₂O uncorrected)	Analyser Make/Model	Horiba PG250
Range (Max Value)	513.4	mg/m³	ID Number	0928

Performance Characteristics	Value		specification
Response time	13	seconds	< 180 s
Logger sampling interval	20	seconds	
Measurement period	248	minutes	
Number of readings in measurement	744	Assuming 20 Second Readings over 4.1333333333333333 hour period	
Repeatability at zero	0.02	% full range	0.2
Repeatability at span level	0.02	% full range	2.0
Deviation from linearity	0.14	% of Value	2
Zero drift (during measurement period)	0.7714266	% full range	2
Span drift (during measurement period)	-2.857143	% full range	2
volume or pressure flow dependence	0	% of fs / kPa	0.033
atmospheric pressure dependence	0	% of fs/kPa	0.75
ambient temperature dependence	-0.07	% by volume /10K	0.3
CO ₂ (% vol)	15	% by volume per	
CH ₄ (mg/m ³)	57	mg/m ³	
NH ₃ (mg/m ³)	20	mg/m ³	
Converter Efficiency	98.76	%	95%
Dependence on voltage	0.1	% by volume /10V	2% Full Scale /10 volt
Losses in the line (leak)	2	% of value	2% of value
Uncertainty of calibration gas	2	% of value	2% of value

Performance characteristic	Uncertainty	Value of uncertainty quantity	% vol
Standard deviation of repeatability at zero	U ₀	for mean	Only use rep at span
Standard deviation of repeatability at span level	U _{rs}	for mean	0.001
Lack of fit	U _{fit}		0.415
Drift	U _{odr}		-0.975
volume or pressure flow dependence	U _{spres}		0.000
atmospheric pressure dependence	U _{apres}		0.000
ambient temperature dependence	U _{temp}		0.000
CO ₂			0.000
NO			0.000
NO ₂			0.000
Converter Efficiency	U _{ceff}		0.01
dependence on voltage	U _{volt}		0.000
losses in the line (leak)	U _{leak}		0.93
Uncertainty of calibration gas	U _{calib}		0.93

Measurement Concentration (as measured)	80.95	mg/m³	
Combined uncertainty	1.69	mg/m ³	
Coverage factor k = 2			
Expanded uncertainty (as measured)	3.39	mg/m ³	
Expanded uncertainty (Corrected to Ref Conditions)	4.40	mg/m³	(expressed with a level of confidence of 95%)


Uncertainty calculation for Gaseous Measurement of Carbon Dioxide ISO12039

Measured concentration	4.83	%vol
Range (Max Value)	20	%vol

Analyser Make/Model	Horiba PG250
ID Number	0928

Performance Characteristics	Value		specification
Response time	15	seconds	< 200 s
Logger sampling interval	20	seconds	
Measurement period	248	minutes	
Number of readings in measurement	744	Assuming 20 Second Readings over 4.1333333333333333 hour period	
Repeatability at zero	0.02	% by volume	stdev <0.2 % range
Repeatability at span level	0.02	% by volume	stdev <0.4 % range
Deviation from linearity	0.14	% vol	+/- <0.3 % volume
Zero drift (during measurement period)	0	% vol at zero level	+/- <2% of volume / 24hr
Span drift (during measurement period)	-0.62422	% vol at span level	+/- <2% volume/24hr
volume or pressure flow dependence	0	% of fs / 10l/h	+ 5 l/h <1% range
atmospheric pressure dependence	0	% of fs/kPa	+ 2kPa < 1.5 % range
ambient temperature dependence	-0.07	% by volume /10K	+ 15K <0.3% volume 10 K
NO (ppm)	100	0.1	% by volume per 100
SO2 (ppm)	100	0	% by volume per 100
CO (ppm)	100	0	% by volume per 100
Combined interference		% range	<2% range
Dependence on voltage	0.1	% by volume /10V	+ 5% < 0.1%vol /10 volt
Losses in the line (leak)	2	% of value	< 2% of value
Uncertainty of calibration gas	2	% of value	

Performance characteristic	Uncertainty	Value of uncertainty quantity	% vol
Standard deviation of repeatability at zero	U_{r0}	for mean	Only use rep at span
Standard deviation of repeatability at span level	U_{rs}	for mean	0.001
Lack of fit	U_{rl}		0.081
Drift	U_{dr}		-0.116
volume or pressure flow dependence	U_{spres}		0.000
atmospheric pressure dependence	U_{spres}		0.000
ambient temperature dependence	U_{temp}		0.000
CO ₂			0.011
NO			0.000
NO ₂			0.000
dependence on voltage	U_{vlt}		0.000
losses in the line (leak)	U_{leak}		0.06
Uncertainty of calibration gas	U_{calib}		0.06
Measurement Concentration	4.83	%vol	
Combined uncertainty	0.16	%vol	
% of value	3.36	%	
Coverage factor k =	2		
Expanded uncertainty	0.32	% vol	(expressed with a level of confidence of 95%)
Expanded uncertainty	0.02	% of value	



Company Name: Covpress Ltd
Site Ref: Coventry
Sampling Point Ref: Burn off oven
Date: 11/11/11
Run: TPM
Project Ref: FTBS18427

In-stack Filter? Bar. Press mm Hg
Outstack Filter? yes Cp
Operators Bws%
Meter Correction Yd

K Factor
Dn used
Nozzle No.

Ambient Temp.
Start Time
Stop Time

Leak Rate (fin / %)
Leak Rate (start / %)
Box/Probe setting

Sample Filter Weights			
	Reference	Laboratory	Increase, mg
Filter	78462	RPS	12.3
Probe Washings	T122728	RPS	9.9

Sample Filter Blank Weighings			
	Reference	Laboratory	Increase, mg
Filter	77939	RPS	0.6
Probe Wash	T122727	RPS	1.5

Impinger Weights			
Weights	Initial	Final	Increase, g
Impinger 1	816.4	959.5	143.1
Impinger 2	627	644.1	17.1
Impinger 3	890.4	913.7	23.3
Impinger 4			0.0
Impinger 5			0.0
Silica Gel			0.0
Total			183.5

Sample Point	Clock Time min	Pitot Δ p, mm H ₂ O	Stack Temp, °C	Orifice Δ H, mm H ₂ O		Gas Meter Reading m ³	Temp at Gas Meter Outlet °C	Condenser Temp, °C	Filter Box Temp °C	Probe Temp °C	Pump Vacuum Inches Hg	Impinger Stem Temp. °C	Root Δ p.
				Desired	Actual								
	0	1.0	480	8.3	8.3	1701880	12		120		0	10	1.000
	15	1.0	571	8.3	8.3		13		120		0	10	1.000
	30	1.0	606	8.3	8.3		14		120		0	11	1.000
	45	1.0	630	8.3	8.3		16		120		0	11	1.000
	60	1.0	667	8.3	8.3		17		120		0	11	1.000
	75	1.0	660	8.3	8.3		17		120		0	12	1.000
	90	1.0	686	8.3	8.3		17		120		0	12	1.000
	105	1.0	664	8.3	8.3		18		120		0	12	1.000
	120	1.0	659	8.3	8.3		18		120		0	13	1.000
	135	1.0	657	8.3	8.3		18		120		0	13	1.000
	150	1.0	655	8.3	8.3		18		120		0	13	1.000
	165	1.0	660	8.3	8.3		18		120		0	12	1.000
	180	1.0	682	8.3	8.3		18		120		0	11	1.000
	195	1.0	680	8.3	8.3		18		120		0	11	1.000
	210	1.0	670	8.3	8.3		19		120		0	12	1.000
	225	1.0	675	8.3	8.3		19		120		0	12	1.000
Endpoint	240					1704171							
	240.00	1.0	643.9	8.3	8.3	2.291	16.9	#DIV/0!	120.0	#DIV/0!	0.0	11.6	1.0

Company Name: Covpress Ltd
Site Ref: Coventry
Project Ref: FTBS18427

Date: 11/11/11

Sampling Point Ref: Burn off oven	Run: TPM
Meter Volume Sampled, acm	2.291
Sample Run Start Time	9:22
Sample Run End Time	13:32
Total Actual Sampling Time, min	240.0
Barometric Pressure, mm Hg	745.00
Stack Pressure, mm Hg	744.91
Average Stack Temp, °C	643.9
Meter Volume at STP, scm	2.067
Stack Moisture Content, %	10.0
Average Stack Velocity, m/sec	6.035
Stack Flow Rate, scms dry,STP	0.124
Nozzle Diameter, mm	10.80
% Isokinetic Variation	98.6
Total Mass of Particulate, mg	22.2
Percentage of Total Particulate Collected on Filter	55.4
Stack Particulate Concentration, mg/m³	13.9
Particulate Mass rate, kg/hour	0.0062
Emission Limit value	No ELV

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m ³	1.2
Total Weight Gain, mg (Sample Train Blank)	2.1
Blank Result Less than 10% of Limit Value	N/A

Uncertainty Calculation for Total Particulate Matter to BS EN 13284-1

Determined Concentration	13.9	mg/m ³ (at Reference Cond)
--------------------------	------	---------------------------------------

Measured Values

Sampled Volume	2.291	m ³
Sampled gas Temperature	289.875	K
Sampled gas Pressure	99.32	kPa
Sampled gas Humidity	0	% by volume
Oxygen content	13.27	% by volume
Mass	22.2	mg

Leak	0.40	%
Uncollected Mass	0	mg

Standard Uncertainties for Measured Values

Sampled Volume	0.001	m ³
Sampled gas Temperature	2	K
Sampled gas Pressure	1	kPa
Sampled gas Humidity	1	% by volume
Oxygen content	0.1	% by volume
Mass	0.14152385	mg

Uncertainty Calculation for Volume Correction				Uncertainty Calculation for Oxygen Correction			
Volume Correction Factor	0.923			Oxygen Correction Factor	1.2975		
	Sensitivity Coefficient		Uncertainty, U_v		Sensitivity Coefficient		Uncertainty, U_o
Sampled gas Temperature	0.0032		0.0064	Oxygen Measurement	0.1687		0.0169
Sampled gas Pressure	0.0093		0.0093				
Sampled gas Humidity	0.0092		0.0092				
		Sqrt (U_v)²	0.0146				
		Total U_v	0.033			Total U_o	0.0169

Uncertainty Contributions (Itemised)					
	Value		Sensitivity coefficient	Uncertainty Contribution	
				Concentration	%
Volume Correction	2.067	m ³	6.74	0.23 mg.m ⁻³	1.62 %
Mass (weighing)	22.20	mg	0.63	0.09 mg.m ⁻³	0.64 %
Oxygen Correction	1.2975		10.74	0.18 mg.m ⁻³	1.30 %
System Leak	0.03	mg.m ⁻³	1.00	0.03 mg.m ⁻³	0.23 %
Uncollected Mass	0.00	mg	0.63	0.00 mg.m ⁻³	0.00 %
			Total Uncertainty	0.30 mg.m⁻³	

Uncertainty Result	
(Uncertainty has been expanded with a coverage factor of 2 (K=2))	
Expanded Uncertainty =	0.61 mg.m⁻³
=>	4.36 % of Result
=>	#VALUE! % of ELV

Company Name: Covpress
Site Ref: Coventry
Stack Ref: Burn off oven

Date: 11/11/11
Run: VOC

	VOC (as Carbon) ppm	VOC (as Carbon) mg/m3	VOC (as Carbon) kg/h	VOC (as Toluene) mg/m3	VOC (as Toluene) kg/h	Oxygen %
Average	8.56	7.21	0.00	7.90	0.00	#DIV/0!
Max	493.73	417.63	0.16	457.40	0.17	0.00
Min	0.00	0.00	0.00	0.00	0.00	0.00
Emission Limit						
Moisture, %	10.0					
Oxygen Reference, %	11.0					

Stack Gas Volume Flow Rate, m3/s (scms Dry) O2 Corrected	0.103447209
--	-------------

ISO 14956 Calculation Sheet - TOC (BS EN 13526)

Studied Concentration (mg/m ³ as C)	7.209290242
Range of Instrument (mg/m ³ as C)	160.7142857

Sampling Parameters to be met	Requirement Met?
Response Time < 60s	Yes
Operating temperature (5 - 45°C)	Yes
Atmospheric pressure (700 - 1240 mbar)	Yes
Relative Humidity (10 - 90%, non condensing)	Yes
Altitude (< 2000 m)	Yes
Zero Drift 2% of FS	Yes
Span Drift 4% of FS	Yes


Selected Performance Characteristic	Value of Performance Characteristic			Operating Conditions compared to calibration condition		
	%	Numerical	Units	Required	Variable due to sampling conditions	Units
Deviation from Linearity	1	0.01	% FS	0.01	1	% FS
Repeatability Standard Deviation	1	0.01	% FS	0.01	1	% FS
8 Hour Drift	2	0.02	%	0.02	1	%
Atmospheric Pressure Dependence	0.1	0.001	% kPa	0.001	1	% kPa
Temperature Dependence	0.2	0.002	%K	0.002	1	%K
Sum Interference	2	0.02	%	0.02	2	%
Voltage Supply	0.1	0.001	%V	0.001	1	%V
Uncertainty of Calibration Gas	2	0.02	%	0.02	1	%
Moisture Effect	1	0.01	%Vol H2O Error	0.01	2	%Vol H2O Error
Loss in sample line (Leaks)	2	0.02	%	0.02	2	%

Measurement Performance related to stationary conditions							
Performance Characteristic	Uncertainty Quantity	Value of Uncertainty Quantity					
		At Calibration Conditions			At Sampling Conditions		
		Units	U	U ²	Units	U	U ²
Deviation from Linearity	U _{FL}	% FS	1.60714286	2.583	% FS	1.6071429	2.583
Repeatability Standard Deviation	U _R	% FS	0.042	0.002	% FS	0.042	0.002
8 Hour Drift	U _{drift}	%	0.0832	0.007	%	0.083	0.007
Atmospheric Pressure Dependence	U _{atmos}	% / kPa	0.004	0.000	% / kPa	0.004	0.000
Temperature Dependence	U _{temp}	% / K	0.008	0.000	% / K	0.008	0.000
Sum Interference	U _{interference}	%	0.083	0.007	%	0.004	0.000
Voltage Supply	U _{voltage}	% / V	0.004	0.000	% / V	0.004	0.000
Uncertainty of Calibration Gas	U _{calibration gas}	%	0.083	0.007	%	0.083	0.007
Loss in sample line (Leaks)	U _{losses, leak}	%	0.083	0.007	%	0.166	0.028
		Sum	1.998	2.612	Sum	2.003	2.626

Measurement Uncertainty at	7.209290242	mg/m ³ C			
U _{tot}	1.621	mg/m ³ C			
U _{tot} [%]	22.479	%	U _{limit}	30	%
Pass	Yes				


TOC Emissions Profile from the Burn off Oven on 11/11/11 at Covpress Ltd.

reference conditions expressed as 273K, 101.3 kPa, 11% O₂ and dry gas



APPENDIX 3:
Gas Burner Sampling, Analysis & Uncertainty Data

Sampling Platform Diagram



Company Name: Covpress Ltd
Site Ref: Coventry
Stack Ref: Gas Burner

Date: 09/11/11
Run: Comb Gases

Static Press, mm H₂O: -1
Barometric (mm Hg) Start: 744
Stack Diameter (m): 0.6
Pitot Tube Constant: 0.826

Traverse Point No.	Port A				Port B			
	Δ p, Pa	Conversion for pitot coefficient	Root Δ p,	Stack Temp °C	Δ p, Pa	Conversion for pitot coefficient	Root Δ p,	Stack Temp °C
1	1.0	0.7	1.000	85	1.0	0.7	0.834	81
2	1.2	0.8	1.200	86	1.2	0.8	0.914	80
3								
4								
5								
6								
7								
8								
9								
10								
Minimum	1.0	0.7	1.000	85.0	1.0	0.7	0.834	80.0
Maximum	1.2	0.8	1.200	86.0	1.2	0.8	0.914	81.0
Average	1.1	0.8	1.100	85.5	1.1	0.8	0.874	80.5
Sum	2.2	1.5	2.200	171.0	2.2	1.5	1.748	161.0
Total Sum								
Max. pitot press. =			0.8					86.0
Min. pitot press. =			0.7					80.0
Ratio Max:Min =			1.2 : 1					83.0

Mean Root D p	0.987
Mean Stack Temperature, °C	83.00
Traverse Stack Velocity, m/s	1.397
Stack Area, m ²	0.292
Stack Gas Volume Flow Rate, m ³ /s (acms)	0.408
Stack Gas Volume Flow Rate, m ³ /s (scms wet)	0.306
Stack Gas Volume Flow Rate, m ³ /s (scms DRY) O ₂ Corrected	0.303
Moisture	1
Stack Pressure, mm Hg	743.93

Gas Data

Oxygen %	19.67590231
CO ₂ %	0.85

Oxygen Correction

Required Correction Value (%)	0
Oxygen Factor	1.000
Enter 0 if correction is not required	

Barometric Pressure (mmHg)

Min	
Max	

Ambient Temperature (C)

Min	
Max	

Is the angle of gas flow to duct axis <15° at every sample point?	Y
Is measured flow at every sample point positive?	Y
Is the measured differential pressure at every sample point >5Pa (0.5mm H ₂ O)?	Y
Are the highest to lowest ΔP <9:1	Y

Company Name: Covpress Ltd
Site Ref: Coventry
Stack Ref: Gas Burner

Date: 09/11/11
Run: Comb Gases

	O2 %	CO2 %	CO mg/m ³	CO kg/hr	NOx mg/m ³	NOx kg/hr	SO2 mg/m ³	SO2 kg/hr
Average	19.68	0.85	12.28	0.01	16.42	0.02	0.00	0.00
Max	21.04	2.17	46.74	0.05	37.44	0.04	0.00	0.00
Min	17.45	0.08	1.57	0.00	3.87	0.00	0.00	0.00
Emission Limit			No ELV		No ELV			
Moisture, %	1.0		Barometric (mmHg) Start			744		
Oxygen Reference, %	0.0		Barometric (mmHg) End			744		

Stack Gas Volume Flow Rate, m3/s (scms DRY) O2 Corrected	0.3031781
--	-----------

Calibrations	O ₂ %	CO ₂ %	CO ppm	NO ppm	SO ₂ ppm
Analyser - Start Zero	0.00	0.00	0.0	0.0	
Analyser - Start Span	14.99	8.10	112.9	401.4	
Analyser - Zero Check	0.08	0.06	0.7	0.2	
System - Zero Check	0.18	0.03	0.6	0.2	
System - Span Check	15.02	7.89	111.0	398.4	
System - End Zero Check	0.10	0.07	0.2	0.1	
System - End Span Check	15.03	8.04	113.0	401.7	
Cylinder Number					
Span Value	14.989	8.009	112.8	401.4	
Analyser Range (0 - X)	25	20	200	500	

Uncertainty calculation for Gaseous Measurement of Oxygen EN14789

Measured concentration	19.68	%vol
Range (Max Value)	25	%vol

Analyser Make/Model	Horiba PG250
ID Number	0928

Performance Characteristics	Value			specification
Response time	12	seconds		< 200 s
Logger sampling interval	20	seconds		
Measurement period	60	minutes		
Number of readings in measurement	180	Assuming 20 Second Readings over 1 hour period		
Repeatability at zero	0.02	% by volume	stdev	<0.2 % range
Repeatability at span level	0.02	% by volume	stdev	<0.4 % range
Deviation from linearity	0.14	% vol	+/-	<0.3 % volume
Zero drift (during measurement period)	-0.533725	% vol at zero level	+/-	<2% of volume / 24hr
Span drift (during measurement period)	0.0667156	% vol at span level	+/-	<2% volume/24hr
volume or pressure flow dependence	0	% of fs / 10l/h	+ 5 l/h	<1% range
atmospheric pressure dependence	0	% of fs/kPa	+ 2kPa	< 1.5 % range
ambient temperature dependence	-0.07	% by volume /10K	+ 15K	<0.3% volume 10 K
CO ₂ (% vol)	10	0.1	% by volume per	10
NO (mg/m3)	300	0	% by volume per	300
NO ₂ (mg/m3)	30	0	% by volume per	30
Combined interference			% range	<2% range
Dependence on voltage	0.1	% by volume /10V	+ 5%	< 0.1%vol /10 volt
Losses in the line (leak)	2	% of value		< 2% of value
Uncertainty of calibration gas	2	% of value		

Performance characteristic	Uncertainty	Value of uncertainty quantity	% vol
Standard deviation of repeatability at zero	U _{rd}	for mean	Only use rep at span
Standard deviation of repeatability at span level	U _{rs}	for mean	0.001
Lack of fit	U _{fit}		0.081
Drift	U _{odr}		-0.258
volume or pressure flow dependence	U _{spres}		0.000
atmospheric pressure dependence	U _{apres}		0.000
ambient temperature dependence	U _{temp}		0.000
CO ₂			0.013
NO			0.000
NO ₂			0.000
dependence on voltage	U _{volt}		0.000
losses in the line (leak)	U _{leak}		0.23
Uncertainty of calibration gas	U _{calib}		0.23

Measurement Concentration	19.68	%vol	
Combined uncertainty	0.42	%vol	
% of value	2.13	%	
Coverage factor k =	2		
Expanded uncertainty	4.27	% of value	(expressed with a level of confidence of 95%)
Expanded uncertainty	0.84	% vol	

Uncertainty calculation for Gaseous Measurement of Carbon Monoxide EN 15058

Measured concentration - CO	12.3	mg/m ³ (O ₂ & H ₂ O uncorrected)	Analyser Make/Model	Horiba PG250
Range (Max Value)	250.0	mg/m ³	ID Number	0928

Performance Characteristics	Value		specification
Response time		seconds	< 200 s
Logger sampling interval	20	seconds	
Measurement period	60	minutes	
Number of readings in measurement	180	Assuming 20 Second Readings over 1 hour period	
Repeatability at zero	0	% of Range	< 1% Range
Repeatability at span level	0	% of Range	< 2% of Range
Deviation from linearity	0	% of Range	< 2% of Range
Zero drift (during measurement period)	-0.35461	% of Range	< 2% of Range
Span drift (during measurement period)	1.7730496	% of Range	< 2% of Range
volume or pressure flow dependence	0	% of fs / 10l/h	< 1% range
atmospheric pressure dependence	0	% of Range/kPa	< 1.5 % range
ambient temperature dependence	-0.07	% of Range /K	<0.3 % range /K
CO ₂ (% vol)	15	% by volume per	
CH ₄ (mg/m ³)	57	mg/m ³	
N ₂ O (mg/m ³)	42	mg/m ³	
Total	0	% of Range	< 4% of Range (Total)
Dependence on voltage	0.1	% by volume /10V	+ 5% < 2% of Range/10 volt
Losses in the line (leak)	2	% of value	< 2% of value
Uncertainty of calibration gas	2	% of value	

Performance characteristic	Uncertainty	Value of uncertainty quantity	% vol
Standard deviation of repeatability at zero	u ₀	for mean	Only use rep at span
Standard deviation of repeatability at span level	u _{rs}	for mean	0.000
Lack of fit	u _{fit}		0.000
Drift	u _{dr}		0.000
volume or pressure flow dependence	u _{spres}		0.000
atmospheric pressure dependence	u _{apres}		0.000
ambient temperature dependence	u _{temp}		0.000
CO ₂			0.000
NO			0.000
NO ₂			0.000
dependence on voltage	u _{volt}		0.000
losses in the line (leak)	u _{leak}		0.14
Uncertainty of calibration gas	u _{calib}		0.14

Measurement Concentration	12.28	mg/m ³	
Combined uncertainty	0.20	mg/m ³	
Coverage factor k = 2			
Expanded uncertainty (as measured)	0.40	mg/m ³	(expressed with a level of confidence of 95%)
Expanded uncertainty (Corrected to Ref Conditions)	0.40	mg/m³	

Uncertainty calculation for Gaseous Measurement of Oxides of Nitrogen BS EN 14792


Measured concentration - NO _x	16.4	mg/m ³ (O ₂ & H ₂ O uncorrected)	Analyser Make/Model	Horiba PG250
Range (Max Value)	1026.8	mg/m ³	ID Number	0928

Performance Characteristics	Value		specification
Response time	14	seconds	< 180 s
Logger sampling interval	20	seconds	
Measurement period	60	minutes	
Number of readings in measurement	180	Assuming 20 Second Readings over 1 hour period	
Repeatability at zero	0.02	% full range	0.2
Repeatability at span level	0.02	% full range	2.0
Deviation from linearity	0.14	% of Value	2
Zero drift (during measurement period)	-0.024913	% full range	2
Span drift (during measurement period)	0.8221226	% full range	2
volume or pressure flow dependence	0	% of fs / kPa	0.033
atmospheric pressure dependence	0	% of fs/kPa	0.75
ambient temperature dependence	-0.07	% by volume /10K	0.3
CO ₂ (% vol)	15	% by volume per	
CH ₄ (mg/m ³)	57	mg/m ³	
NH ₃ (mg/m ³)	20	mg/m ³	
Converter Efficiency	98.76	%	95%
Dependence on voltage	0.1	% by volume /10V	2% Full Scale /10 volt
Losses in the line (leak)	2	% of value	2% of value
Uncertainty of calibration gas	2	% of value	2% of value

Performance characteristic	Uncertainty	Value of uncertainty quantity	% vol
Standard deviation of repeatability at zero	u ₀	for mean	Only use rep at span
Standard deviation of repeatability at span level	u _{rs}	for mean	0.001
Lack of fit	u _{fit}		0.000
Drift	u _{odr}		0.000
volume or pressure flow dependence	u _{spres}		0.000
atmospheric pressure dependence	u _{apres}		0.000
ambient temperature dependence	u _{temp}		0.000
CO ₂			0.000
NO			0.000
NO ₂			0.000
Converter Efficiency	u _{cent}		0.00
dependence on voltage	u _{volt}		0.000
losses in the line (leak)	u _{leak}		0.19
Uncertainty of calibration gas	u _{calib}		0.19


Measurement Concentration (as measured)	16.42	mg/m³	
Combined uncertainty	0.27	mg/m ³	
Coverage factor k = 2			
Expanded uncertainty (as measured)	0.54	mg/m ³	
Expanded uncertainty (Corrected to Ref Conditions)	0.54	mg/m³	(expressed with a level of confidence of 95%)

**Combustion Gas Emissions from the Gas Burner at Covpress on 9/11/11
reference conditions expressed as 273K, 101.3 kPa, without correction for oxygen**



APPENDIX 4:
Wash Steam Vent Sampling, Analysis & Uncertainty Data

Sampling Platform Diagram



Company Name: Covpress Ltd
Site Ref: Coventry
Sampling Point Ref: Wash Steam Vent
Project Ref: FTBS18427

Date: 09/11/11
Run: TPM

Stack Static press.mm H ₂ O:	0.8	Stack Diameter (m)	0.56			
		Stack Area (m ²)	0.246			
Traverse Point No.	Port A			Port B		
	Δ p, mm H ₂ O	Root Δ p	Stack Temp °C	Δ p, mm H ₂ O	Root Δ p	Stack Temp °C
1	1.8	1.342	30	2.2	1.483	33
2	1.8	1.342	32	2.2	1.483	34
3						
4						
5						
6						
7						
8						
9						
10						
Minimum	1.8	1.342	30	2.2	1.483	33
Maximum	1.8	1.342	32	2.2	1.483	34
Mean	1.8	1.342	31.0	2.2	1.483	33.5
Sum	3.6	2.683	62	4.4	2.966	67
Total Sum						

Max. pitot press. =	2.2
Min. pitot press. =	1.8
Ratio MaxMin =	1.2 :1

Gas Data	
Oxygen %	21.0
CO ₂ %	0.04
CO %	

Oxygen Correction	
Required Correction Value	0
Actual Oxygen Factor	1
Enter 0 if correction is not required	

Is the angle of gas flow to duct axis <15° at every sample point?	Y
Is measured flow at every sample point positive?	Y
Is the measured differential pressure at every sample point >5Pa (0.5mm H ₂ O)?	Y
Are the highest to lowest ΔP <9:1	Y

Company Name: Covpress Ltd In-stack Filter? Bar. Press mm Hg K Factor Ambient Temp.
 Site Ref: Coventry Outstack Filter? Cp Dn used Start Time Leak Rate (fin / %)
 Sampling Point Ref: Wash Steam Vent Date: 09/11/11 Operators Bws% Nozzle No. Stop Time Leak Rate (start / %)
 Run: TPM Meter Correction Yd Box/Probe setting
 Project Ref: FTBS18427

Sample Filter Weights

	Reference	Laboratory	Increase, mg
Filter	78463	RPS	0.1
Probe Washings	T122726	RPS	3.8

Sample Filter Blank Weighings

	Reference	Laboratory	Increase, mg
Filter	78461	RPS	0.1
Probe Wash	T122725	RPS	0.5

Impinger Weights

Weights	Initial	Final	Increase, g
Impinger 1	819	816.4	-2.6
Impinger 2	618.3	627	8.7
Impinger 3	866.4	890.4	24.0
Impinger 4			0.0
Impinger 5			0.0
Silica Gel			0.0
Total			30.1

Sample Point	Clock Time min	Pitot Δ p, mm H ₂ O	Stack Temp, °C	Orifice Δ H, mm H ₂ O		Gas Meter Reading m ³	Temp at Gas Meter Outlet °C	Condenser Temp, °C	Filter Box Temp °C	Probe Temp °C	Pump Vacuum Inches Hg	Impinger Stern Temp. °C	Root Δ p.
				Desired	Actual								
	0	1.8	27	44.7	44.7	758537.9	22		120	120	-2	18	1.342
	5	1.8	28	44.7	44.7		24		120	120	-2	18	1.342
	10	1.8	28	44.7	44.7		24		120	120	-2	17	1.342
	15	1.8	29	44.7	44.7		26		120	121	-2	16	1.342
	20	1.8	30	44.7	44.7		25		120	120	-2	16	1.342
	25	1.8	31	44.7	44.7		26		119	120	-2	17	1.342
Endpoint	30												0.000
	0	1.8	32	44.7	44.7		27		120	121	-2	17	1.342
	5	1.8	34	44.7	44.7		27		120	119	-2	18	1.342
	10	2.0	37	49.7	44.7		27		121	120	-2	18	1.414
	15	2.0	37	49.7	49.7		27		119	120	-2	18	1.414
	20	2.0	38	49.7	49.7		28		119	120	-2	18	1.414
	25	2.0	38	49.7	49.7		29		119	120	-2	17	1.414
Endpoint	30					759780.9							0.000
	60.00	1.9	32.4	46.4	46.0	1.243	26.0	#DIV/0!	119.8	120.1	-2.0	17.3	1.2

Company Name: Covpress Ltd
Site Ref: Coventry
Project Ref: FTBS18427

Date: 09/11/11

Sampling Point Ref: Wash Steam Vent	Run: TPM
Meter Volume Sampled, acm	1.243
Sample Run Start Time	13:46
Sample Run End Time	14:46
Total Actual Sampling Time, min	60.0
Barometric Pressure, mm Hg	744.00
Stack Pressure, mm Hg	744.06
Average Stack Temp, °C	32.4
Meter Volume at Wet STP, scm	1.150
Stack Moisture Content, %	3.3
Average Stack Velocity, m/sec	4.058
Stack Flow Rate, scms wet, STP	0.874
Nozzle Diameter, mm	10.80
% Isokinetic Variation	98.0
Total Mass of Particulate, mg	3.9
Percentage of Total Particulate Collected on Filter	2.6
Stack Particulate Concentration, mg/m³	3.4
Particulate Mass rate, kg/hour	0.011
Emission Limit value	No Limit

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m ³	0.5
Total Weight Gain, mg (Sample Train Blank)	0.6
Blank Result Less than 10% of Limit Value	N/A

Uncertainty Calculation for Total Particulate Matter to BS EN 13284-1

Determined Concentration	3.4	mg/m ³ (at Reference Cond)
--------------------------	-----	---------------------------------------

Measured Values

Sampled Volume	1.243	m ³
Sampled gas Temperature	299	K
Sampled gas Pressure	99.21	kPa
Sampled gas Humidity	0	% by volume
Oxygen content	21	% by volume
Mass	3.9	mg

Leak	0.68	%
Uncollected Mass	0	mg

Standard Uncertainties for Measured Values

Sampled Volume	0.001	m ³
Sampled gas Temperature	2	K
Sampled gas Pressure	1	kPa
Sampled gas Humidity	1	% by volume
Oxygen content	0.1	% by volume
Mass	0.14152385	mg

Uncertainty Calculation for Volume Correction				Uncertainty Calculation for Oxygen Correction			
Volume Correction Factor	0.894			Oxygen Correction Factor	1.0000		
	Sensitivity Coefficient		Uncertainty, U_v		Sensitivity Coefficient		Uncertainty, U_o
Sampled gas Temperature	0.0030		0.0060	Oxygen Measurement	N/A		N/A
Sampled gas Pressure	0.0090		0.0090				
Sampled gas Humidity	0.0089		0.0089				
		Sqrt (U_v)²	0.0140				
		Total U_v	0.017			Total U_o	N/A

Uncertainty Contributions (Itemised)	Value		Sensitivity coefficient	Uncertainty Contribution	
				Concentration	
				Concentration	%
Volume Correction	1.112	m ³	3.05	0.05	1.57 %
Mass (weighing)	3.90	mg	0.87	0.12	3.63 %
Oxygen Correction	N/A		0.00	0.00	0.00 %
System Leak	0.01	mg.m ⁻³	1.00	0.01	0.39 %
Uncollected Mass	0.00	mg	0.87	0.00	0.00 %
			Total Uncertainty	0.13	mg.m⁻³

Uncertainty Result	(Uncertainty has been expanded with a coverage factor of 2 (K=2))
Expanded Uncertainty =	0.27 mg.m⁻³
=>	7.95 % of Result
=>	#VALUE! % of ELV



Test Certificate

Date 26/11/2011

Client RPS Towcester
Grafton Building
Caswell Science & Technology Park
Caswell, Towcester
Northants
NN12 8EQ

Order No. FTBS 18427
Certificate No. WK11-7008
Issue No. 1

Contact Richard Carter
Date Received 16/11/2011

Description 8x samples for TPM
Technique Gravimetric

Parameter	Analysis Method	Accreditation	Method LOD	Uncertainty
Total particulate matter	D9	UKAS	0.1 mg	-
Total particulate matter	D9	UKAS	0.5 mg	-

Sample No.	672666	077939	Method
Total particulate matter	0.6 mg		D9(U)
Sample No.	672666	T122727	Method
Total particulate matter	1.5 mg		D9(U)
Sample No.	672667	078462	Method
Total particulate matter	12.3 mg		D9(U)
Sample No.	672668	T122728	Method
Total particulate matter	9.9 mg		D9(U)
Sample No.	672669	078461	Method
Total particulate matter	<0.1 mg		D9(U)
Sample No.	672670	T122726	Method
Total particulate matter	<0.5 mg		D9(U)
Sample No.	672671	078463	Method
Total particulate matter	<0.1 mg		D9(U)
"Damaged Filter"			

Page 1 of 2

RPS Laboratories Ltd. Unit 12, Waters Edge Business Park, Modwen Road, Salford, M6 3EZ
Tel: (0161) 872 2443 Fax: (0161) 877 3969




Test Certificate

Date 25/11/2011

Client	RPS Towcester		Certificate No.	WK11-7008
			Issue No.	1
Sample No.	672672	T122726	Method	
Total particulate matter		3.8 mg		DS(U)

Tested By John McKeown Date 24/11/2011

Approved By  Date 25/11/2011

Operations Manager

For and on authority of RPS Laboratories Ltd.
RPS Laboratories terms and conditions apply - a copy is available on request.

Method Symbols (U) Analysis is UKAS Accredited
(N) Analysis is not UKAS Accredited

Concentration values (mg/m3 and ppm) are provided to assist with interpretation only, they are not covered by the scope of UKAS accreditation

Analysis carried out on samples 'as received'

This document may not be reproduced other than in full, except with the written approval of the issuing laboratory.