

Report for Periodic Monitoring of Emissions to Atmosphere

Part 1: **Executive Summary**

Permit Number: **N/A**

Operator: **Covpress Ltd**

Installation: **Coventry**

Emission Point: **Burn Off Oven Exhaust**

Monitoring Date: **26th September 2012**



Contract Reference: FTBS 22507

Operator: Covpress Ltd

Address: Burnsall Road
Canley
Coventry
CV5 6RT

Monitoring Organisation: RPS Consultants

Address: Noble House, Capital Drive, Linford Wood,
Milton Keynes, MK14 6QP

Report Date: 26th October 2012

Report Approved By: Carl Redgrove

Position: Senior Consultant

MCERTS Registration Number: MM 03 173

MCERTS Certification Level: 2

Technical Endorsements: TE1, TE2, TE3, TE4

Signature:



RPS Consultants has produced this report within the term of the contract with the client and taking account of the resources devoted to it by agreement with the client.

We disclaim any responsibility to the client and others in respect of any matters outside the scope of the above. This report is confidential to the client and we accept no responsibility of whatsoever nature to third parties to whom this report, or any part thereof, is made known. Any such party relies on the report at their own risk.

CONTENTS

Part 1: Executive Summary

Section 1 – Monitoring Objectives

Section 2 – Monitoring Results

Section 3 – Operating Information

Section 4 – Monitoring Deviations

Part 2: Supporting Information

Appendix 1 – Staff & Methodology Details

Appendix 2- Burn Off Oven Exhaust Sampling, Analysis & Uncertainty Data

Monitoring Objectives

At the request of Steve Cottom of Covpress Ltd, RPS Consultants conducted stack emission monitoring at the Coventry site in September 2012.

The monitoring programme at this installation was carried out to provide data on emissions to atmosphere for comparison with the limits specified in the air emission criteria for this site.

The following tables detail the parameters requested for monitoring at each emission point and the actual monitoring conducted.

Table 1.1

Parameters Requested to be Monitored	Emission Point
	Burn Off Oven Exhaust
Total Particulate Matter	✓
Volatile Organic Compounds	✓
Oxides of Nitrogen	✓
Carbon Monoxide	✓
Specific Requirements	Normal

Notes:

✓ Represents pollutants sampled

Monitoring Results

Table 2.1 Monitoring results for the Burn Off Oven Exhaust, Carried out on 26/09/2012

Substance Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty (Expressed expanded k=2)	Reference Conditions 273K, 101.3kPa	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Carbon Monoxide	N/A	85	mg/m ³	+/- 4.2	273K, 101.3kPa, Dry, 11% Oxygen	26/09/2012	09:45 - 11:50	EN 15058:2006	MCERTS	Normal
	Mass Emission Rate	0.024	kg/hr	-						
Oxides of Nitrogen	N/A	90	mg/m ³	+/- 3.2	273K, 101.3kPa, Dry, 11% Oxygen	26/09/2012	09:45 - 11:50	EN 14792:2005	MCERTS	Normal
	Mass Emission Rate	0.025	kg/hr	-						
Total Particulate Matter	N/A	< 0.66	mg/m ³	+/- 0.31	273K, 101.3kPa, Dry, 11% Oxygen	26/09/2012	09:30 - 11:50	BS EN 13284-1:2002	MCERTS	Normal
	Mass Emission Rate	< 0.00038	kg/hr	-						
Volatile Organic Compounds (as Carbon)	N/A	6.8	mg/m ³	+/- 1.9	273K, 101.3kPa, Dry, 11% Oxygen	26/09/2012	09:45 - 11:50	BS EN 13526	MCERTS	Normal
	Mass Emission Rate	0.047	kg/hr	-						

Operating Information

Table 3.1 Operating conditions during the monitoring of the Burn Off Oven Exhaust emission point, carried out on 26/09/2012

Parameter	Result
Sample Date	26/09/2012
Process Type	Batch
Process Duration	150 Minutes
If 'Batch', was monitoring carried out over the whole batch?	No
Abatement/Operational?	Not Installed
Load	Oven half loaded with small "sky" bars.

Comparison of Operator CEM and Periodic Monitoring Results		
Substance	CEMs Results (mg/m ³)	Periodic Monitoring Results (mg/m ³)
No CEMS Installed/Data Available		

Monitoring Deviations

Table 4.1 Monitoring Deviations for Burn Off Oven Exhaust Emission Point

Pollutant	Substance Deviations	Monitoring Deviations	Other Relevant Issues
Carbon Monoxide, Oxides of Nitrogen & Volatile Organic Compounds	None	None	None
Total Particulate Matter	None	Monitoring conducted from a single traverse line as only one sample port was cut into the stack. This was due to the health and safety concerns of cutting an additional open hole into a stack with a duct temperature of 750 deg C.	None

Report for Periodic Monitoring of Emissions to Atmosphere

Part 2: Supporting Information

Permit Number: N/A
Operator: Covpress Ltd
Installation: Coventry
Emission Point: Burn Off Oven Exhaust
Monitoring Date: 26th September 2012



Contract Reference: FTBS 22507
Operator: Covpress Ltd
**Address: Burnsall Road
Canley
Coventry
CV5 6RT**
Monitoring Organisation: RPS Consultants
**Address: Noble House, Capital Drive, Linford Wood,
Milton Keynes, MK14 6QP**
Report Date: 26th October 2012
Report Approved By: Carl Redgrove
Position: Senior Consultant
MCERTS Registration Number: MM 03 228
MCERTS Certification Level: 2
Technical Endorsements: TE1, TE2, TE3, TE4

Signature:



RPS Consultants has produced this report within the term of the contract with the client and taking account of the resources devoted to it by agreement with the client.

We disclaim any responsibility to the client and others in respect of any matters outside the scope of the above. This report is confidential to the client and we accept no responsibility of whatsoever nature to third parties to whom this report, or any part thereof, is made known. Any such party relies on the report at their own risk.

CONTENTS

Part 1: Executive Summary

Section 1 – Monitoring Objectives

Section 2 – Monitoring Results

Section 3 – Operating Information

Section 4 – Monitoring Deviations

Part 2: Supporting Information

Appendix 1 – Staff & Methodology Details

Appendix 2- Burn Off Oven Exhaust Sampling, Analysis & Uncertainty Data

APPENDIX 1: General Information

Monitoring Organisation Staff Details

Table 5.1 Sampling Personnel

Sampling Personnel	Position	MCERTS Level	Technical Endorsements	MCERTS Registration Number
Luke Sparrow	Trainee Technician	Trainee	None	MM12 189
Richard Carter	Consultant	Level 2	TE1, TE2, TE3, TE4	MM 07 861

Table 5.2 Report Author

Report Author	Position	MCERTS Level	Technical Endorsements	MCERTS Registration Number
Richard Carter	Consultant	Level 2	TE1, TE2, TE3, TE4	MM 07 861

Table 5.3 Report Reviewer

Report Reviewer	Position	MCERTS Level	Technical Endorsements	MCERTS Registration Number
Glyn Harrison	Operations Manager (Stack Emissions)	Level 2	TE1, TE2, TE3, TE4	MM 03 228

Monitoring Organisation Method Details

Table 6.1 Monitoring Methods


Emission Parameter	Standard Method	Monitoring Procedure No.	Monitoring Accreditation	Analysis	Analysis Procedure No.	Analytical Laboratory	Analysis Accreditation
Practical Considerations Prior to Monitoring	N/A	RPSCE/1/1	UKAS	N/A	N/A	N/A	N/A
Gas Flows	BS-EN 13284-1:2001	RPSCE/1/2	MCERTS	N/A	N/A	N/A	N/A
Gas Temperatures	BS-EN 13284-1:2001	RPSCE/1/2	MCERTS	N/A	N/A	N/A	N/A
Carbon Monoxide	EN 15058:2006	RPSCE/1/21h	MCERTS	NDIR	N/A	N/A	N/A
Oxides of Nitrogen	EN 14792:2005	RPSCE/1/21f	MCERTS	Chemiluminescence	N/A	N/A	N/A
Low Concentration Total Particulate Matter	BS EN 13284-1:2002	RPSCE/1/7c	MCERTS	Gravimetric	D9	RPS Laboratories	UKAS
TOCs at high concentrations	BS EN 13526	RPSCE/1/4c	MCERTS	Flame Ionisation Detector	N/A	N/A	N/A

Table 7.1 – Checklist Used

Equipment Checklist Used	File Location Address
FTBS22507 Checklist	FTBS22507 Electronic & Work File

**APPENDIX 2:
Burn Off Oven Exhaust Sampling, Analysis & Uncertainty Data**

Burn Off Oven Exhaust – Stack Diagram



Company Name: Covpress Ltd
Site Ref: Coventry
Stack Ref: Burn Off Oven Exhaust

Date: 26/09/12
Run: Comb Gases

Static Press, mm H₂O: 1.2
Barometric (mm Hg) Start: 760
Stack Diamter (m): 0.4
Pitot Tube Constant: 0.829

Traverse Point No.	Port A				Port B			
	Δ p, mmH ₂ O	Conversion for pitot coefficient and to Pa	Root Δ p.	Stack Temp °C	Δ p, mmH ₂ O	Conversion for coefficient and	Root Δ p.	Stack Temp °C
1	0.8	5.5	2.345	700		0.0	0.000	
2	0.8	5.5	2.345	700		0.0	0.000	
3	0.8	5.5	2.345	700		0.0	0.000	
4	0.8	5.5	2.345	700		0.0	0.000	
5						0.0	0.000	
6						0.0	0.000	
7						0.0	0.000	
8						0.0	0.000	
9						0.0	0.000	
10						0.0	0.000	
Minimum	0.8	5.5	2.345	700.0	0.0	0.0	0.000	0.0
Maximum	0.8	5.5	2.345	700.0	0.0	0.0	0.000	0.0
Average	0.8	5.5	2.345	700.0	#DIV/0!	0.0	0.000	#DIV/0!
Sum	3.2	22.0	9.380	2800.0	0.0	0.0	0.000	0.0
Total Sum								
Max. pitot press. =			5.5		Max. Temp. =			700.0
Min. pitot press. =			5.5		Min. Temp. =			700.0
Ratio Max:Min =			0.0 :1		Mean Temp. =			700.0

Mean Root D p	1.173
Mean Stack Temperature, °C	700.00
Traverse Stack Velocity, m/s	2.743
Stack Area, m ²	0.126
Stack Gas Volume Flow Rate, m ³ /s (acms)	0.345
Stack Gas Volume Flow Rate, m ³ /s (scms wet)	0.097
Stack Gas Volume Flow Rate, m ³ /s (scms DRY) O ₂ Corrected	0.078
Moisture	7.3
Stack Pressure, mm Hg	760.09

Gas Data

Oxygen %	12.30849365
CO ₂ %	#DIV/0!

Oxygen Correction

Required Correction Value (%)	11
Oxygen Factor	1.152
Enter 0 if correction is not required	

Barometric Pressure (mmHg)	
Min	760
Max	760

Ambient Temperature (C)	
Min	18
Max	18

Company Name: Covpress Ltd
Site Ref: Coventry
Stack Ref: Burn Off Oven Exhaust

Date: 26/09/12
Run: Comb Gases

	O2 %	CO2 %	CO mg/m ³	CO kg/hr	NOx mg/m ³	NOx kg/hr
Average	12.31	#DIV/0!	84.67	0.02	90.09	0.03
Max	14.57	0.00	249.64	0.07	361.59	0.10
Min	9.02	0.00	0.00	0.00	45.14	0.01
Emission Limit	N/A	N/A	N/A		N/A	
Moisture, %	0.0			Barometric (mmHg) Start		760
Oxygen Reference, %	11.0			Barometric (mmHg) End		765

Stack Gas Volume Flow Rate, m3/s (scms DRY) O2 Corrected	0.077768
--	----------

Calibrations	O ₂ %	CO ₂ %	CO ppm	NO ppm
Analyser - Start Zero	0.28		0.4	0.2
Analyser - Start Span	15.00		105.0	210.0
Analyser - Zero Check	0.30		0.3	0.1
System - Zero Check	0.28		0.1	0.0
System - Span Check	15.02		105.2	209.8
System - End Zero Check	0.11		0.6	0.0
System - End Span Check	15.21		104.3	208.6
Cylinder Number				
Span Value	15		105	210
Analyser Range (0 - X)	25		500	100

Uncertainty calculation for Gaseous Measurement of Oxygen EN14789

Measured concentration	12.31	%vol
Range (Max Value)	25	%vol

Analyser Make/Model	Horba PG250
ID Number	0955

Performance Characteristics	Value		specification
Response time		seconds	< 200 s
Logger sampling interval	30	seconds	
Measurement period	125	minutes	
Number of readings in measurement	250	Assuming 30 Second Readings over 2.0833333333333333 hour period	
Repeatability at zero	0.02	% by volume	stdev <0.2 % range
Repeatability at span level	0.02	% by volume	stdev <0.4 % range
Deviation from linearity	0.14	% vol	+/- <0.3 % volume
Zero drift (during measurement period)	-1	% vol at zero level	+/- <2% of volume / 24hr
Span drift (during measurement period)	1.266667	% vol at span level	+/- <2% volume/24hr
volume or pressure flow dependence	0	% of fs / 10/h	+ 5 l/h <1% range
atmospheric pressure dependence	0	% of fs/kPa	+ 2kPa < 1.5 % range
ambient temperature dependence	-0.07	% by volume / 10K	+ - 15K <0.3% volume 10 K
CO ₂ (% vol)	10	% by volume per	10
NO (mg/m ³)	300	% by volume per	300
NO ₂ (mg/m ³)	30	% by volume per	30
Combined interference		% range	<2% range
Dependence on voltage	0.1	% by volume / 10V	+ - 5% < 0.1%vol / 10 volt
Losses in the line (leak)	2	% of value	< 2% of value
Uncertainty of calibration gas	2	% of value	

Performance characteristic	Uncertainty	Value of uncertainty quantity	% vol
Standard deviation of repeatability at zero	U _r	for mean	Only use rep at span
Standard deviation of repeatability at span level	U _s	for mean	0.001
Lack of fit	U _f		0.081
Drift	U _{dr}		0.023
volume or pressure flow dependence	U _{flow}		0.000
atmospheric pressure dependence	U _{pres}		0.000
ambient temperature dependence	U _{temp}		0.000
CO ₂			0.000
NO			0.000
NO ₂			0.000
dependence on voltage	U _{volt}		0.000
losses in the line (leak)	U _{leak}		0.14
Uncertainty of calibration gas	U _{cal}		0.14
Measurement Concentration	12.31	%vol	
Combined uncertainty	0.22	%vol	
% of value	1.77	%	
Coverage factor k =	2		
Expanded uncertainty	3.54	% of value	(expressed with a level of confidence of 95%)
Expanded uncertainty	0.44	% vol	

Uncertainty calculation for Gaseous Measurement of Oxides of Nitrogen BS EN 14792

Measured concentration - NOx	78.2	mg/m ³ (O ₂ & H ₂ O uncorrected)	Analyser Make/Model	Honba PG250
Range (Max Value)	205.4	mg/m ³	ID Number	0955

Performance Characteristics	Value		specification
Response time	14	seconds	< 180 s
Logger sampling interval	30	seconds	
Measurement period	125	minutes	
Number of readings in measurement	250	Assuming 30 Second Readings over 2.0833333333333333 hour period	
Repeatability at zero	0.02	% full range	0.2
Repeatability at span level	0.02	% full range	2.0
Deviation from linearity	0.14	% of Value	2
Zero drift (during measurement period)	0	% full range	2
Span drift (during measurement period)	-0.571429	% full range	2
volume or pressure flow dependence	0	% of fs / kPa	0.033
atmospheric pressure dependence	0	% of fs/kPa	0.75
ambient temperature dependence	-0.07	% by volume /10K	0.3
CO ₂ (% vol)	15	0	% by volume per
CH ₄ (mg/m ³)	57	0.1	mg/m ³
NH ₃ (mg/m ³)	20	0	mg/m ³
Converter Efficiency	0		95%
Dependence on voltage	0.1	% by volume /10V	2% Full Scale /10 volt
Losses in the line (leak)	2	% of value	2% of value
Uncertainty of calibration gas	2	% of value	2% of value

Performance characteristic	Uncertainty	Value of uncertainty quantity	% vol
Standard deviation of repeatability at zero	U ₀	for mean	Only use rep at span
Standard deviation of repeatability at span level	U _{fs}	for mean	0.001
Lack of fit	U _{fit}		0.166
Drift	U _{dr}		-0.258
volume or pressure flow dependence	U _{pres}		0.000
atmospheric pressure dependence	U _{apres}		0.000
ambient temperature dependence	U _{temp}		0.000
CO ₂			0.000
NO			0.391
NO ₂			0.000
Converter Efficiency	U _{eff}		45.14
dependence on voltage	U _{volt}		0.000
losses in the line (leak)	U _{leak}		0.90
Uncertainty of calibration gas	U _{calib}		0.90

Measurement Concentration (as measured)	78.18	mg/m ³	
Combined uncertainty	1.37	mg/m ³	
Coverage factor k = 2			
Expanded uncertainty (as measured)	2.74	mg/m ³	(expressed with a level of confidence of 95%)
Expanded uncertainty (Corrected to Ref Conditions)	3.16	mg/m ³	

Uncertainty calculation for Gaseous Measurement of Carbon Monoxide EN 15058


Measured concentration - CO	73.5	mg/m ³ (O ₂ & H ₂ O uncorrected)	Analyser Make/Model	Horiba PG250
Range (Max Value)	625.0	mg/m ³	ID Number	0955

Performance Characteristics	Value		specification
Response time	12	seconds	< 200 s
Logger sampling interval	30	seconds	
Measurement period	125	minutes	
Number of readings in measurement	250	Assuming 30 Second Readings over 2.0833333333333333 hour period	
Repeatability at zero	-0.0016	% of Range	< 1% Range
Repeatability at span level	0.0032	% of Range	< 2% of Range
Deviation from linearity	0.0064	% of Range	< 2% of Range
Zero drift (during measurement period)	0.4761905	% of Range	< 2% of Range
Span drift (during measurement period)	-0.057143	% of Range	< 2% of Range
volume or pressure flow dependence	0	% of fs / 10l/h	< 1% range
atmospheric pressure dependence	0.0078424	% of Range/kPa	< 1.5 % range
ambient temperature dependence	-0.07	% of Range /K	<0.3 % range /K
CO ₂ (% vol)	15	0.1	% by volume per
CH ₄ (mg/m ³)	57	0	mg/m ³
N ₂ O (mg/m ³)	42	0	mg/m ³
Total	0.016	% of Range	< 4% of Range (Total)
Dependence on voltage	0.1	% by volume /10V	+ 5% < 2% of Range/10 volt
Losses in the line (leak)	2	% of value	< 2% of value
Uncertainty of calibration gas	2	% of value	

Performance characteristic	Uncertainty	Value of uncertainty quantity	% vol
Standard deviation of repeatability at zero	U ₀	for mean	Only use rep at span
Standard deviation of repeatability at span level	U _s	for mean	0.000
Lack of fit	U _{fit}		0.023
Drift	U _{dr}		1.355
volume or pressure flow dependence	U _{spres}		0.000
atmospheric pressure dependence	U _{apres}		0.000
ambient temperature dependence	U _{temp}		0.000
CO ₂			0.000
NO			0.000
NO ₂			0.000
dependence on voltage	U _{volt}		0.000
losses in the line (leak)	U _{leak}		0.65
Uncertainty of calibration gas	U _{calib}		0.65

Measurement Concentration	73.48	mg/m³	
Combined uncertainty	1.81	mg/m ³	
Coverage factor k = 2			
Expanded uncertainty (as measured)	3.62	mg/m ³	(expressed with a level of confidence of 95%)
Expanded uncertainty (Corrected to Ref Conditions)	4.17	mg/m³	

Combustion Gas Emissions from the Burn Off Oven Exhaust at Covpress, Coventry on 26th September 2012
reference conditions expressed as 273K, 101.3 kPa, 3 % O₂ and dry gas



Company Name: Covpress Ltd In-stack Filter? N Bar. Press.mm Hg K Factor Ambient Temp
 Site Ref: Coventry Cp Dn used Start Time Leak Rate (fn / %)
 Sampling Point Ref: Burn Off Oven Exhaust: Outstack Filter? Y Operators Bws/% Nozzle No. Stop Time Leak Rate (start / %)
 Date: 26/09/12 Meter Correction Yd Box/Probe setting
 Run: TPM Project Ref: FTBS22507

Sample Filter Weights			
	Reference	Laboratory	Increase, mg
Filter	89947	RPS	0.1
Probe Washings	30001610	RPS	0.5

Sample Filter Blank Weighings			
	Reference	Laboratory	Increase, mg
Filter	89946	RPS	0.1
Probe Wash	30001609	RPS	0.5

Impinger Weights			
Weights	Initial	Final	Increase, g
Impinger 1	729.8	765.1	35.3
Impinger 2	721.2	738.7	17.5
Impinger 3	607.4	613.3	5.9
Impinger 4	835	843	8.0
Impinger 5			0.0
Silica Gel			0.0
Total			65.7

Sample Point	Clock Time min	Pilot Δ p, mm H ₂ O	Stack Temp, °C	Orifice Δ H, mm H ₂ O		Gas Meter Reading m ³	Temp at Gas Meter Outlet °C	Condenser Temp, °C	Filter Box Temp °C	Probe Temp °C	Pump Vacuum Inches Hg	Impinger Stem Temp, °C	Root Δ p.
				Desired	Actual								
	0	0.8	515	7.3	7.3	2037057.9	8		120	120	0	12	0.894
	15	0.8	597	7.3	7.3		10		120	120	0	9	0.894
	30	0.8	633	7.3	7.3		11		120	120	0	11	0.894
	45	0.8	671	7.3	7.3		12		120	120	0	12	0.894
	60	0.8	710	7.3	7.3		12		120	120	0	13	0.894
	75	0.8	676	7.3	7.3		12		120	120	0	13	0.894
	90	0.8	665	7.3	7.3		12		120	120	0	15	0.894
	105	0.8	693	7.3	7.3		12		120	120	0	15	0.894
	120	0.8	693	7.3	7.3		12		120	120	0	15	0.894
Endpoint						2008181							
	135.00	0.8	650.3	7.3	7.3	1.123	10.8	#DIV/0!	120.0	120.0	0.0	12.0	0.9

Company Name: Covpress Ltd
Site Ref: Coventry
Project Ref: FTBS22507

Date: 26/09/12

Sampling Point Ref: Burn Off Oven Exhaust	Run: TPM
Meter Volume Sampled, acm	1.123
Sample Run Start Time	9:30
Sample Run End Time	11:50
Total Actual Sampling Time, min	135.0
Barometric Pressure, mm Hg	760.00
Stack Pressure, mm Hg	760.09
Average Stack Temp, °C	650.3
Meter Volume at STP, scm	1.062
Stack Moisture Content, %	7.3
Average Stack Velocity, m/sec	5.425
Stack Flow Rate, scms dry,STP	0.162
Nozzle Diameter, mm	10.80
% Isokinetic Variation	96.1
Mass of Particulate Collected on Filter, mg	0.1
Mass of Particulate collected in Probe, mg	0.5
Total Mass of Particulate, mg	0.60000
Percentage of Total Particulate Collected on Filter	16.7
Stack Particulate Concentration, mg/m ³	0.65024791
Particulate Mass rate, kg/hour	0.00038
Emission Limit value	N/A

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m ³	0.6
Total Weight Gain, mg (Sample Train Blank)	0.6
Blank Result Less than 10% of Limit Value	#VALUE!

Uncertainty Calculation for Total Particulate Matter to BS EN 13284-1

Determined Concentration	0.7	mg/m ³ (at Reference Cond)
--------------------------	-----	---------------------------------------

Measured Values

Sampled Volume	1.1231	m ³
Sampled gas Temperature	283.7777778	K
Sampled gas Pressure	101.34	kPa
Sampled gas Humidity	0	% by volume
Oxygen content	12.3	% by volume
Mass	0.6	mg

Leak	0.00	%
Uncollected Mass	0	mg

Standard Uncertainties for Measured Values

Sampled Volume	0.001	m ³
Sampled gas Temperature	2	K
Sampled gas Pressure	1	kPa
Sampled gas Humidity	1	% by volume
Oxygen content	0.1	% by volume
Mass	0.14152385	mg

Uncertainty Calculation for Volume Correction				Uncertainty Calculation for Oxygen Correction			
Volume Correction Factor	Sensitivity Coefficient	Uncertainty, Uv	Oxygen Correction Factor	Sensitivity Coefficient	Uncertainty, Uo		
0.962			1.1512				
Sampled gas Temperature	0.0034	0.0068	Oxygen Measurement	0.1329	0.0133		
Sampled gas Pressure	0.0095	0.0095					
Sampled gas Humidity	0.0095	0.0095					
Sqrt (Uv) ²			Total Uo				
Total Uv			0.017			0.0133	

Uncertainty Contributions (Itemised)	Value	Sensitivity coefficient	Uncertainty Contribution	
			Concentration	%
Volume Correction	1.062 m ³	0.61	0.01 mg m ⁻³	1.60 %
Mass (weighing)	0.60 mg	1.08	0.15 mg m ⁻³	23.59 %
Oxygen Correction	1.1512	0.56	0.01 mg m ⁻³	1.15 %
System Leak	0.00 mg m ⁻³	1.00	0.00 mg m ⁻³	0.00 %
Uncollected Mass	0.00 mg	1.08	0.00 mg m ⁻³	0.00 %
Total Uncertainty			0.15 mg m ⁻³	

Uncertainty Result	(Uncertainty has been expanded with a coverage factor of 2 (K=2))	
	Expanded Uncertainty =	0.31 mg.m⁻³
	=>	47.34 % of Result
	=>	N/A % of ELV

Company Name: Covpress
Site Ref: Coventry
Stack Ref: Burn Off Oven E

Date: 26/00/12
Run: VOC

	VOC (as Carbon) ppm	VOC (as Carbon) mg/m ³	VOC (as Carbon) kg/h	VOC (as Toluene) mg/m ³	VOC (as Toluene) kg/h	Oxygen %
Average	ND/ND!	6.82	0.05	7.47	0.05	12.31
Max	0.00	72.34	0.50	79.22	0.52	14.57
Min	0.00	0.43	0.00	6.47	0.00	9.02
Emission Limit						
Moisture, %	7.3					
Oxygen Reference, %	11.0					

Stack Gas Volume Flow Rate, m³/s (scms Dry) O₂ Corrected	1.905315824
---	--------------------

ISO 14956 Calculation Sheet - TOC (BS EN 13526)

Shaded Concentration (mgm ³ on C)	0.824626065
Range of Instrument (mg m ³ on C)	120

Sampling Parameters to be met	Requirements met?
Response Time 4 COs	Yes
Operating temperature (9 – 45 °C)	Yes
Atmospheric pressure (700 – 1240 mbars)	Yes
Relative Humidity (10 – 90% non condensing)	Yes
Altitude (< 2000 m)	Yes
Zero Drift 2% of F.S.	Yes
Span Error 4% of F.S.	Yes

Selected Performance Characteristics	Value of Performance Characteristic			Operating Conditions compared to calibration condition		
	%	Numerical	Units	Required	Variable due to sampling conditions	Units
Response Time	2	0.02	minutes	0.02	1	minutes
Deviation from Linearity	1	0.01	% FS	0.01	1	% FS
Repeatability Standard Deviation	1	0.01	% FS	0.01	1	% FS
0 Hour Drift	2	0.02	%	0.02	1	%
Atmospheric Pressure Dependence	0.1	0.001	% kPa	0.001	1	% kPa
Temperature Dependence	0.2	0.002	%K	0.002	1	%K
Sum Interference	2	0.02	%	0.02	2	%
Voltage Supply	0.1	0.001	%V	0.001	1	%V
Losses in sample line	2	0.02	%	0.02	2	%
Uncertainty of Calibration Gas	2	0.02	%	0.02	1	%
Calibration Error (Gas Density)	0.5	0.005	%	0.005	1	%
Moisture Effect	1	0.01	%Vol H2O Error	0.01	2	%Vol H2O Error
Loss in sample line (Leak)	2	0.02	%	0.02	2	%

Measurement Performance related to stationary conditions									
		Value of Uncertainty Quantity							
Performance Characteristic	Uncertainty Quantity	At Calibration Conditions			At Sampling Conditions			U _{sum}	U _{sum}
		Units	U	U ²	Units	U	U ²		
Response Time	U _{response}	minutes	1.388	1.920	minutes	1.388	1.920		
Deviation from Linearity	U _{linearity}	% FS	1.2	1.440	% FS	1.2	1.440		
Repeatability Standard Deviation	U _{repeatability}	% FS	0.039	0.002	% FS	0.039	0.002		
0 Hour Drift	U _{0hr drift}	%	0.0768	0.006	%	0.0768	0.006		
Atmospheric Pressure Dependence	U _{atm pres}	% / kPa	0.004	0.000	% / kPa	0.004	0.000		
Temperature Dependence	U _{temp}	% / K	0.008	0.000	% / K	0.008	0.000		
Sum Interference	U _{sum int}	%	0.079	0.006	%	0.004	0.000		
Voltage Supply	U _{voltage}	% / V	0.004	0.000	% / V	0.004	0.000		
Losses in sample line	U _{losses}	%	0.079	0.006	%	0.158	0.025		
Uncertainty of Calibration Gas	U _{cal gas}	%	0.079	0.006	%	0.079	0.006		
Calibration Error (Gas Density)	U _{cal error}	%	0.020	0.000	%	0.020	0.000		
Loss in sample line (Leak)	U _{leak}	%	0.079	0.006	%	0.158	0.025		
		Sum	3.055	3.393	Sum	3.137	3.424		


Measurement Uncertainty at	0.824626065	mg m ⁻³ C		
U ₉₅	1.850	mg m ⁻³ C		
U ₉₅ %	27.114	%	U ₉₅	30 %
Pass	Yes			

BS EN 13526 2001 Performance Requirements

Performance Characteristic	Minimum Performance Requirement
Detection Limit	5% of the emission limit value
Response Time	less than 1 minute
Linearity Deviation	permissible deviation 5% of emission limit
Response Factors	Permissible range
Methane	0.9 to 1.2
Aliphatic Hydrocarbons	0.9 to 1.1
Aromatic Hydrocarbons	0.8 to 1.1
Aliphatic Alcohols	0.7 to 1.0
Esters	0.7 to 1.0
Ketones	0.7 to 1.0
Organic Acids	0.5 to 1.0
Dayton Effect	permissible deviation 5% of emission limit

For more details on the above figures see BS EN 13526 2001

TOC Emissions Profile from the Burn off Oven Exhaust on 26th September 2012 at Covpress, Coventry
reference conditions expressed as 273K, 101.3 kPa, 3 % O₂ and dry gas



Certificate of Analysis



Test Certificate

Date 09/10/2012

Client	RPS Milton Keynes HSED Noble House Capital Drive Linford Wood Milton Keynes MK14 6QP	Order No.	FTBS22507
		Certificate No.	WK12-6280
		Issue No.	1
Contact	Richard Carter	Date Received	02/10/2012
Description	2 filters & 2 solutions for tpm	Technique	Gravimetric
Sample No.	715931	089947	Method
Total particulate matter	<0.1 mg		D9(U)
Sample No.	715932	30001610	Method
Total particulate matter	<0.5 mg		D9(U)
Sample No.	715933	089946	Method
Total particulate matter	<0.1 mg		D9(U)
Sample No.	715934	30001609	Method
Total particulate matter	<0.5 mg		D9(U)



Test Certificate

Date 09/10/2012

Client	RPS Millon Keynes HSED	Certificate No.	WK12-0200
		Issue No.	1

Tested By Kirstie Davenport **Date** 05/10/2012

Approved By [Redacted] **Date** 09/10/2012

Jeanne Dewhurst
Laboratory Manager

For and on authority of RPS Laboratories Ltd.

Method Symbols (V) Analysis is UKAS Accredited
(N) Analysis is not UKAS Accredited

Concentration values (mg/m³ and ppm) are provided to assist with interpretation only, they are not covered by the scope of UKAS accreditation.

Results stated as ml are referring to the sample volume.

RPS Laboratories terms and conditions apply - a copy is available on request

Analysis carried out on samples 'as received'

This document may not be reproduced other than in full, except with the written approval of the issuing laboratory