

Our Ref: P-RED12-135/EB/R1/Rev0
Client Ref:

19th November 2012

Terry Cornwall
Terex United Kingdom Limited
Central Boulevard
Prologis Park
Coventry
CV6 4BX

Dear Terry

Re: Emissions Monitoring

Please find enclosed a copy of your report for the monitoring carried out during the 23rd and the 24th October 2012.

I trust the enclosed is satisfactory but if you have any questions please contact me on the numbers below or directly on 07971 628431.

Yours sincerely

Elena Berek BSc (Hons), MSc, CSci, CChem MRSC
Director



PROJECT TEAM

Project work carried out by:

Elena Berek – Team Leader

Tony Berek – Env Consultant

Vicki Gavin – Env Consultant

Report prepared by:

Elena Berek - Director

Signature:




Date:

19th November 2012

Report reviewed by:

Philip Butler - Director

Signature:




Date:

19th November 2012

Report authorised by:

Philip Butler

Signature:



Date:

19th November 2012

OCTOBER 2012

**EMISSIONS MONITORING
REPORT**

**Terry Cornwall
Terex United Kingdom Limited
Central Boulevard
Prologis Park
Coventry CV6 4BX**

Tel: 02476 339634

Prepared By

**Redwing Environmental Ltd
Unit 7, Manor Road Business Park
Manor Road
Atherstone
Warwickshire CV9 1TE**

Tel: 0844 686 7000 – Fax: 0844 686 7070

Report Number P-RED12-135/EB/R1/Rev0

19th November 2012



Contents

Contents

Executive Summary

1.0	Introduction	Page 1
1.0	Monitoring Programme	Pages 1 - 2
1.5	Monitoring Results, comparison to emission limits	Pages 3 – 5
2.0	Supporting Info	Page 6
2.1	General Info	Page 6
2.1.1	MCerts information	Page 6
2.2	Methods	Pages 6 – 7
3.0	Quality Assurance	Page 8
4.0	Disclaimer	Page 8
	<i>Appendix A – Particulate & Velocity Results</i>	Appendix Pages 1 to 31
	<i>Appendix B – VOC Raw Data</i>	Appendix Pages 32 to 36
	<i>Appendix C – VOC Charts</i>	Appendix Pages 37 to 41
	<i>Appendix D – Isocyanate Results</i>	Appendix Pages 42 to 45
	<i>Calibration Certificates are available upon request</i>	

EXECUTIVE SUMMARY (Page 1 of 1)

The following document details the emissions to air monitoring survey undertaken by Elena Berek, Vicki Gavin and Tony Berek of Redwing Environmental Ltd at Terex United Kingdom Limited on the 23rd and 24th October 2012.

All results pertain to the dates monitored only.

A summary of results is shown below:-

Emission point reference Stack N ^o	Total Particulate Matter at reference conditions (mg/m ³)	* Highest 30 minute mean VOC at reference conditions (mg/m ³)	Isocyanate Concentration at reference conditions (mg/m ³)	Velocity corrected to reference conditions (m/s)	Volume flow corrected to reference conditions (m ³ /hr)
Primer Spray Booth 1	0.12 ± 0.13	--	--	7.0	50,977
Primer Spray Booth 2	0.04 ± 0.12	--	--	7.4	53,478
Primer Flash-off	0.46 ± 0.20	--	--	9.4	17,106
Topcoat Spray Booth 1	0.5 ± 0.2	--	<0.001	7.8	56,656
Topcoat Spray Booth 2	0.12 ± 0.17	--	<0.001	8.2	59,662
Topcoat Flash-off	0.52 ± 0.25	--	<0.001	12.0	27,563
Topcoat Curing Oven	0.19 ± 0.15	--	<0.001	11.3	31,902
Preparation Booth 1	3.3 ± 0.4	--	--	13.3	18,404
Preparation Booth 2	0.21 ± 0.14	--	--	13.1	18,186
Spray Bake Booth 1	--	--	<0.001	14.1	25,586
Spray Bake Booth 2	--	--	<0.001	15.1	27,392
Scissor 1 Booth 1	4.2 ± 0.44	19.9 ± 1.2 (19.6)	--	13.4	13,640
Scissor 1 Booth 2	2.22 ± 0.64	14.2 ± 0.8 (13.4)	--	13.8	13,998
Scissor 1 Oven	0.30 ± 0.18	--	--	6.4	724
Scissor 2 Booth 1	0.53 ± 0.25	21.5 ± 1.2 (21.5)	--	13.5	13,708
Scissor 2 Booth 2	0.07 ± 0.12	13.6 ± 0.7 (13.2)	--	13.1	13,362
Scissor 2 Oven	0.11 ± 0.16	--	--	6.1	693

* Figure in brackets represent the average VOC for the duration of the monitoring

NOTE 1: Reference conditions are standard Temperature (273K) and standard pressure (101.3kPa), without correction for water vapour

1.0 INTRODUCTION

1.1 The exhausts listed below were monitored with respect to quotation **Q-RED12-135/EB/v0** for the compliance check monitoring of emissions to air. The substances requested for monitoring at each emission point are listed below:

Monitoring Programme

Stack reference/Proposed method	Total Particulate Matter BS EN 13284	Volatile Organic Compounds BS EN 13526	Isocyanates USEPA CTM36
Main Paint Facility			
Primer spray booth - 1	✓	x	x
Primer spray booth – 2	✓	x	x
Primer Flash off	✓	x	x
Topcoat Spray booth -1	✓	x	✓
Topcoat spray booth – 2	✓	x	✓
Topcoat Flash off	✓	x	✓
Topcoat Curing Oven	✓	x	✓
Preparation Booth 1	✓	x	x
Preparation Booth 2	✓	x	x
Spray Bake Booth 1	x	x	✓
Spray Bake Booth 2	x	x	✓
Scissor 1 Booth 1	✓	✓	x
Scissor 1 Booth 2	✓	✓	x
Scissor 1 Oven	✓	x	x
Scissor 2 Booth 1	✓	✓	x
Scissor 2 Booth 2	✓	✓	x
Scissor 2 Oven	✓	x	x

1.2 Terex United Kingdom Limited operate a metal and plastic coating process at their site in Coventry, the process is governed by the Secretary of States Process Guidance Note PG6/23(04) – Coating of Metal and Plastic.

1.3 The emission limits are listed below:

Process Guidance Note PG6/23 (04): Coating of Metal and Plastic

EMISSION LIMITS

ANALYTE	TOTAL PARTICULATE	TOTAL VOC	TOTAL ISOCYANATES
Emission Limit	50 mg/m ³	150 mg/m ³	0.1mg/m ³

1.4 The velocity and temperature profile were within the required parameters of 3:1 metres/second and ± 1% for temperature profile. This information indicates that the sample ports are in ideal positions to collect the samples under representative conditions.

1.5 Monitoring Results

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Operating Status
Primer Spray Booth 1	Total Particulate Matter	50	0.12 ± 0.13	mg/m ³	273K, 101.3kPa	23/10/12	1245 – 1345	BS EN 13284-1	Normal
Primer Spray Booth 2	Total Particulate Matter	50	0.04 ± 0.12	mg/m ³	273K, 101.3kPa	23/10/12	1350 – 1450	BS EN 13284-1	Normal
Primer Flash-off	Total Particulate Matter	50	0.46 ± 0.20	mg/m ³	273K, 101.3kPa	23/10/12	1455 – 1555	BS EN 13284-1	Normal
Top Coat Spray Booth 1	Total Particulate Matter	50	0.5 ± 0.2	mg/m ³	273K, 101.3kPa	23/10/12	1240 – 1340	BS EN 13284-1	Normal
	Isocyanates	0.1	<0.001	mg/m ³		24/10/12	1000 – 1100	USEPA 36	
Top Coat Spray Booth 2	Total Particulate Matter	50	0.12 ± 0.17	mg/m ³	273K, 101.3kPa	23/10/12	1345 – 1445	BS EN 13284-1	Normal
	Isocyanates	0.1	<0.001	mg/m ³		24/10/12	1145 - 1245	USEPA 36	

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Operating Status
Topcoat Flash-off	Total Particulate Matter	50	0.52 ± 0.25	mg/m ³	273K, 101.3kPa	23/10/12	1450 – 1550	BS EN 13284-1	Normal
	Isocyanates	0.1	<0.001	mg/m ³		24/10/12	1210 - 1310	USEPA 36	
Topcoat Curing Oven	Total Particulate Matter	50	0.19 ± 0.15	mg/m ³	273K, 101.3kPa	24/10/12	0750 - 0850	BS EN 13284-1	Normal
Preparation Booth 1	Total Particulate Matter	50	3.3 ± 0.4	mg/m ³	273K, 101.3kPa	23/10/12	0700 - 0800	BS EN 13284-1	Normal
Preparation Booth 2	Total Particulate Matter	50	0.21 ± 0.14	mg/m ³	273K, 101.3kPa	23/10/12	0707 - 0807	BS EN 13284-1	Normal
Spray Bake Booth 1	Isocyanates	0.1	<0.001	mg/m ³	273K, 101.3kPa	23/10/12	0810 - 0910	USEPA 36	Normal
Spray Bake Booth 2	Isocyanates	0.1	<0.001	mg/m ³	273K, 101.3kPa	23/10/12	0805 - 0905	USEPA 36	Normal
Scissor 1 Booth 1	Total Particulate Matter	50	4.2 ± 0.44	mg/m ³	273K, 101.3kPa	23/10/12	0915 - 1015	BS EN 13284-1	Normal
	Volatile Organic Compounds	150	19.9 ± 1.2	mg/m ³			0920 – 1020	BS EN 13526	
Scissor 1 Booth 2	Total Particulate Matter	50	2.22 ± 0.64	mg/m ³	273K, 101.3kPa	23/10/12	1020 – 1120	BS EN 13284-1	Normal
	Volatile Organic Compounds	150	14.2 ± 0.8	mg/m ³			1025 - 1125	BS EN 13526	

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Operating Status
Scissor 1 Oven	Total Particulate Matter	50	0.30 ± 0.18	mg/m ³	273K, 101.3kPa	23/10/12	1124 – 1224	BS EN 13284-1	Normal
Scissor 2 Booth 1	Total Particulate Matter	50	0.53 ± 0.25	mg/m ³	273K, 101.3kPa	23/10/12	0918 – 1018	BS EN 13284-1	Normal
	Volatile Organic Compounds	150	21.5 ± 1.2	mg/m ³			0915 - 1015	BS EN 13526	Normal
Scissor 2 Booth 2	Total Particulate Matter	50	0.07 ± 0.12	mg/m ³	273K, 101.3kPa	23/10/12	1025 – 1125	BS EN 13284-1	Normal
	Volatile Organic Compounds	150	13.6 ± 0.7	mg/m ³			1030 – 1130	BS EN 13526	Normal
Scissor 2 Oven	Total Particulate Matter	50	0.11 ± 0.16	mg/m ³	273K, 101.3kPa	23/10/12	1130 - 1230	BS EN 13284-1	Normal

2 Supporting Information (Held by Redwing Environmental Ltd)

2.1 General Information

2.1.1 Redwing Environmental Ltd staff details

Elena Berek
Vicki Gavin
Tony Berek

2.2 Redwing Environmental Ltd method details

2.2.1 Volatile organic compounds (BS EN 13526: 2001)

2.2.2 Monitoring to determine VOC emission concentrations was in accordance with BS EN 13526: 2001.

2.2.3 Volatile organic compound concentrations were measured using a Signal portable heated VOC analyser. The analyser works by burning the gas sample in a hydrogen flame. This ionises any organic compounds present and the current produced across an electric field is proportional to the number of carbon atoms.

2.2.4 The analyser and heated line will be zeroed and calibrated with a test gas (80 ppm and or 800ppm propane) prior to each sampling run. VOC sampling will be undertaken over a period of at least 30 minutes to cover any process variation.

2.2.5 All data was logged onto a Grant Squirrel data logger set at 20 second logging.

2.2.6 A heated line from the sample point to analyser was used to ensure that condensation did not occur leading to the loss of sample concentration. Volatile organic compounds.

2.3 Stack Velocity, Pressure and Temperature Measurements

2.3.1 The stack velocity, pressure and temperature will be measured by full pitot traverses of the duct using the points provided. Measurements will be taken at the relevant positions based on the particulate standard followed.

2.4 Leak tests for extractive techniques

2.4.1 All extractive-sampling techniques were tested for leaks before sampling proceeded. Any leaks present were eliminated prior to sampling and will be reported.

2.4.2 Leak checks are carried out during the calibrating procedure, as the concentration of the calibration gas is known it is readily identified if air is entering the sample line and diluting the gas.

2.5 Particulate matter BS EN 13284-1: 2002

- 2.5.1 Total particulate matter was sampled using a Zambelli isokinetic sampling system in accordance with BS EN 13284-1: 2002 – Determination of Low Range Mass Concentration of dust (< 50mg/m³).
- 2.5.2 The Zambelli sampling system monitors temperature, static pressure and velocities within the duct using an S-type pitot tube and K-type thermocouple. The sampling rate was continuously monitored and adjusted relative to the duct velocity to ensure isokinetic-sampling conditions were maintained throughout the monitoring period.
- 2.5.3 Exhaust gases were drawn under isokinetic conditions from the exhaust points using the Zambelli sampling probe, particulate matter was then collected on a pre-weighed glass fibre filter (or most suitable filter for process) contained within the filter cassette holder, and the total particulate matter determined gravimetrically.
- 2.5.4 It is also necessary to wash the probe and nozzle out with water and then acetone between sampling and the weight of the probe washing added to that collected on the sample filter. Analysis of an acetone/water blank will be carried out and the result corrected accordingly.
- 2.5.5 The sample positions were calculated with respect to BS EN 13284-1: 2002 – Stationary source emissions – Determination of Low Range Mass Concentration of dust.
- 2.5.6 Sampling may be carried out internally or externally, the method used will be reported and provided there are no deviations from the method the uncertainty for the monitoring procedure is reported to be within the requirements specified by the Hazardous Waste Directive (HWD) as stated in the Environment Agency Technical Document M2

Uncertainty: $\pm 30\%$

- 2.5.7 ISO 9096: 2003 and BS EN 13284-1: 2002 are very similar methods but BS EN 13284-1: 2002 recommends the use of an 8mm nozzle and nozzles less than 6mm should not be used.

2.6 Isocyanates (USEPA CTM 36a)

- 2.6.1 There are several Isocyanates; these include TDI, MDI, HDI and IPDI. The isocyanate to be monitored is HDI (1,6 – hexamethylene diisocyanate). All Isocyanates follow the same procedure for sampling and analysis.
- 2.6.2 Isocyanates can be sampled non-isokinetically following MDHS 25 or isokinetically following the USEPA CTM 36
- 2.6.3 The method used was isokinetic method. A sample probe was placed inside the stack; the sample probe was heated.
- 2.6.4 The samples are stored in brown glass bottles and submitted for analysis. The samples will be 'blown down' to dryness using air and made upto 1ml using the most suitable matrix (usually acetonitrile). The sample will then be ready for analysis by HPLC (High Pressure Liquid Chromatography).

3.0 Quality Assurance


- 3.1 Redwing Environmental Ltd will always endeavour to follow the methods specified in the Environment Agency Technical Guidance M2. Redwing Environmental Ltd is a member of the Source Testing Association (STA) and therefore operates under the STA's code of practice.
- 3.2 Redwing Environmental Ltd is accredited to ISO 9001:2008, ISO 14001:2004 and ISO 17025:2005.

4.0 Disclaimer

- 4.1 Redwing Environmental Ltd confirms that in preparing this report all reasonable skill and care has been exercised.
- 4.1.1 Unless specifically assigned or transferred within the terms of the agreement, Redwing Environmental Ltd asserts and retains all copyright, and other Intellectual Property Rights, in and over the report and its contents.

APPENDIX A

Particulate & Velocity Results

Client	Terex United Kingdom Limited								
Site Address	Coventry								
Job Number	P-RED12-135								
Date	23rd October 2012								
Operator(s)	E Berek & T Berek								
Stack Reference	Primer Spray Booth 1				Isokinetic Sample Positions (%) multiply by diameter to obtain sample points				Sampling Plane Diagram 
Number of Stacks	1				1	6.70			
Stack Configuration	Round				2	25.00			
Dimensions (mtrs)	1.60				3	75.00			
Outlet Diameter (if applicable) (metres)					4	93.30			
Number of Sample Ports	2				5	N/A			
Number of Samples per Axis / Port	4				6	N/A			
Nozzle Diameter (mm)	8.0				7	N/A			
Nozzle Area (m²)	0.00005024				8	N/A			
Stack Area (m²)	2.011				Average Isokinetic Flow Rate (ltrs/min)			Axis 1 21.23	Axis 2 22.22
Pitot Coefficient	0.84		Pitot Calibration Due Date			31/03/2013			Atmos. Pressure (kPa)
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test	101.8	
No.	(cms)	(pa)	(C)	(°)	(pa)	(C)	(°)	Static Pressure (pa)	
1	10.72	35	22.2	7.7	46	22.2	7.7	-3.0	
2	40.00	39	22.2	7.7	52	22.2	7.7	1 Axis	
3	N/A	44	22.2	7.7	48	22.2	7.7	2 Axis	
4	N/A	50	22.2	7.7	38	22.2	7.7	Velocity of flow (m/s)	
5	N/A							7.04	
6	N/A							7.37	
7	N/A							Volume Flow Rate (m³/s)	
8	N/A							14.16	
								14.82	
								Reduced Exit	
Averages		42	22.2		46	22.2		N/A	
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2) + 273$								295.20	
Permitted Range of gas temperature readings (C) = $(0.95T_p - 273)$ to $(1.05T_p - 273)$								7.44 to 36.96	
Highest Velocity Reading (m/s)								8.1	
Lowest Velocity Reading (m/s)								6.4	
Ratio Highest/Lowest (Max permitted = 3:1)								1.26 : 1	
On site Checklist									
Initial Leak Check	End of first run				Start of 2 nd run		End of 2 nd run		
Acceptable Leak Check < 2% Vol (l/min)	0.42				Manometer Leak Check			OK	
					Pitot Leak Check			OK	
Range of Gas Temps	OK				Overall Isokinetic Ratio (%) (must be 95 to 115%)			Run 1 98.8	
Passed minimum Velocity requirements (>5pa)	YES							Run 2 #DIV/0!	
Negative Local Flow Present, YES or NO (Yes = Fail)	NO				Are there sufficient rails and kick board? (YES, NO or N/A)			NO	
Is the Platform area greater than 5m²? (YES, NO or N/A)	NO				Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)			YES	
Passed Highest to lowest Velocity (3:1)	YES								
Site Equipment Used									
Pitot Reference	RED 0290				Manometer Reference			RED 0393	
Thermometer Reference	RED 0351-RED 0352				Thermocouple Reference			RED 0362	
Balance Reference	N/A				Sampling Pump Reference			RED 0258	
Tape Measure Reference	RED 0123				Barometer Reference			RED 0094	
DGM Thermocouple	RED 0274				Impinger Outlet Thermocouple			N/A	
Calipers	RED 0300				Condenser Thermocouple			N/A	

Stack Reference ID		Primer Spray Booth 1		
	Terex United Kingdom Limited			
	RUN 1			
Filter Reference No	G47-171012-17			
Date	23rd October 2012			
Sample Period	12:45	to	13:45	
Velocity (m/s)	7.04			
Volume flow rate of Stack gas (m ³ /hr)	50977			
Average Stack Temp (°C)	22.2			
Temp Range ± 5% (°C)	7.44	to	36.96	
Lowest Velocity Reading (m/s)	6.41			
Highest Velocity Reading (m/s)	8.06			
Ratio (less than 3:1)	1.26	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	22.2			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	20			
Carbon Dioxide %	0.20			
Moisture (%)	0.00			
Litres sampled	1273			
Corrected volume sampled - STP (m ³)	1.221			
Blank Filter Run weight gain (mg)	0.020	Blank Concentration (mg/m ³)	0.033	
Blank Wash Run weight gain (mg)	0.010		0.016	
Weighing uncertainty of balance (mg)	0.074	This must be <5% of ELV	ELV = 50	2.5
Overall Blank value (mg/m ³)	0.049	This must be <10% of ELV	ELV = 50	5.0
Particulate weight collected on filter (mg)	0.00			
Particulate weight collected in Wash (mg)	0.15			
Total Particulate weight collected (mg)	0.15			
Total Particulate Concentration, dry gas at STP (mg/m ³)	0.12			
Total Particulate Concentration, wet gas at STP (mg/m³)	0.12			
Total Particulate Concentration corrected for 11% Oxygen, dry gas (mg/m ³)	N/A			
Total Particulate Mass Emission (g/hour)	0.004			

Client	Terex United Kingdom Limited							
Site Address	Coventry							
Job Number	P-RED12-135							
Date	23rd October 2012							
Operator(s)	E Berek & T Berek							
Stack Reference	Primer Spray Booth 2				Isokinetic Sample Positions (%) multiply by diameter to obtain sample points			
					Sampling Plane Diagram			
Number of Stacks	1				1	6.70		
Stack Configuration	Round				2	25.00		
Dimensions (mtrs)	1.60				3	75.00		
Outlet Diameter (if applicable) (metres)					4	93.30		
Number of Sample Ports	2				5	N/A		
Number of Samples per Axis / Port	4				6	N/A		
Nozzle Diameter (mm)	8.0				7	N/A		
Nozzle Area (m²)	0.00005024				Average Isokinetic Flow Rate (ltrs/min)			Axis 1
Stack Area (m²)	2.011							Axis 2
Pitot Coefficient	0.84		Pitot Calibration Due Date		31/03/2013			22.27
								24.00
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test	Atmos. Pressure (kPa)
No.	(cms)	(pa)	(C)	(°)	(pa)	(C)	(°)	101.8
1	10.72	28	16.0	7.7	47	16	7.7	Static Pressure (pa)
2	40.00	43	16.0	7.7	55	16	7.7	4.0
3	N/A	55	16.0	7.7	60	16	7.7	1 Axis
4	N/A	66	16.0	7.7	61	16	7.7	2 Axis
5	N/A							Velocity of flow (m/s)
6	N/A							7.39
7	N/A							7.96
8	N/A							Volume Flow Rate (m³/s)
								14.85
								16.01
								Reduced Exit
Averages		48	16.0		56	16.0		N/A
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2) + 273$								289.00
Permitted Range of gas temperature readings (C) = $(0.95T_p - 273)$ to $(1.05T_p - 273)$								1.55 to 30.45
Highest Velocity Reading (m/s)								9.0
Lowest Velocity Reading (m/s)								5.7
Ratio Highest/Lowest (Max permitted = 3:1)								1.58 : 1
On site Checklist								
Initial Leak Check	<0.2	End of first run	<0.2		Start of 2 nd run		End of 2 nd run	
Acceptable Leak Check < 2% Vol (l/min)	0.45				Manometer Leak Check			OK
					Pitot Leak Check			OK
Range of Gas Temps	OK				Overall Isokinetic Ratio (%) (must be 95 to 115%)			Run 1
Passed minimum Velocity requirements (>5pa)	YES							99.2
Negative Local Flow Present, YES or NO (Yes = Fail)	NO				Are there sufficient rails and kick board? (YES, NO or N/A)			N/A
Is the Platform area greater than 5m²? (YES, NO or N/A)	NO				Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)			YES
Passed Highest to lowest Velocity (3:1)	YES							
Site Equipment Used								
Pitot Reference	RED 0290				Manometer Reference			RED 0393
Thermometer Reference	RED 0351-RED 0352				Thermocouple Reference			RED 0362
Balance Reference	N/A				Sampling Pump Reference			RED 0258
Tape Measure Reference	RED 0123				Barometer Reference			RED 0094
DGM Thermocouple	RED 0274				Impinger Outlet Thermocouple			N/A
Calipers	RED 0300				Condenser Thermocouple			N/A

Stack Reference ID		Primer Spray Booth 2		
		Terex United Kingdom Limited		
		RUN 1		
Filter Reference No	G47-171012-19			
Date	23rd October 2012			
Sample Period	13:50	to	14:50	
Velocity (m/s)	7.39			
Volume flow rate of Stack gas (m ³ /hr)	53478			
Average Stack Temp (°C)	16.0			
Temp Range ± 5% (°C)	1.55	to	30.45	
Lowest Velocity Reading (m/s)	5.67			
Highest Velocity Reading (m/s)	8.98			
Ratio (less than 3:1)	1.58	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	16.0			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	10.4			
Carbon Dioxide %	5.60			
Moisture (%)	0.00			
Litres sampled	1260			
Corrected volume sampled - STP (m ³)	1.207			
Blank Filter Run weight gain (mg)	0.020	Blank Concentration (mg/m ³)	0.033	
Blank Wash Run weight gain (mg)	0.000		0.000	
Weighing uncertainty of balance (mg)	0.074	This must be <5% of ELV	ELV = 50	2.5
Overall Blank value (mg/m ³)	0.033	This must be <10% of ELV	ELV = 50	5.0
Particulate weight collected on filter (mg)	0.00			
Particulate weight collected in Wash (mg)	0.05			
Total Particulate weight collected (mg)	0.05			
Total Particulate Concentration, dry gas at STP (mg/m ³)	0.04			
Total Particulate Concentration, wet gas at STP (mg/m ³)	0.04			
Total Particulate Concentration corrected for 11% Oxygen, dry gas (mg/m ³)	N/A			
Total Particulate Mass Emission (g/hour)	0.002			

Client	Terex United Kingdom Limited							
Site Address	Coventry							
Job Number	P-RED12-135							
Date	23rd October 2012							
Operator(s)	E Berek & T Berek							
Stack Reference	Primer Flash Off			Isokinetic Sample Positions (%) multiply by diameter to obtain sample points		Sampling Plane Diagram		
Number of Stacks	1			1	14.60			
Stack Configuration	Round			2	85.40			
Dimensions (mtrs)	0.80			3	N/A			
Outlet Diameter (if applicable) (metres)				4	N/A			
Number of Sample Ports	2			5	N/A			
Number of Samples per Axis / Port	2			6	N/A			
Nozzle Diameter (mm)	7.0			7	N/A			
Nozzle Area (m ²)	0.00003847			8	N/A			
Stack Area (m ²)	0.503			Average Isokinetic Flow Rate (ltrs/min)		Axis 1	Axis 2	
Pitot Coefficient	0.84	Pitot Calibration Due Date			31/03/2013		21.82	23.11
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test	Atmos. Pressure (kPa)
No.	(cms)	(pa)	(C)	(°)	(pa)	(C)	(°)	101.8
1	11.68	77	31.0	6.8	85	31.1	6.8	Static Pressure (pa)
2	68.32	70	31.1	6.8	80	31.1	6.8	22.0
3	N/A							1 Axis
4	N/A							2 Axis
5	N/A							Velocity of flow (m/s)
6	N/A							9.45
7	N/A							10.02
8	N/A							Volume Flow Rate (m ³ /s)
Averages		74	31.1		83	31.1		4.75
								5.03
								Reduced Exit
								N/A
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2) + 273$								304.05
Permitted Range of gas temperature readings (C) = $(0.95T_p - 273)$ to $(1.05T_p - 273)$								15.85 to 46.25
Highest Velocity Reading (m/s)								10.5
Lowest Velocity Reading (m/s)								9.2
Ratio Highest/Lowest (Max permitted = 3:1)								1.14 : 1
On site Checklist								
Initial Leak Check	<0.2	End of first run	<0.2		Start of 2 nd run		End of 2 nd run	
Acceptable Leak Check < 2% Vol (l/min)	0.44				Manometer Leak Check		OK	
Range of Gas Temps	OK				Pitot Leak Check		OK	
Passed minimum Velocity requirements (>5pa)	YES				Overall Isokinetic Ratio (%) (must be 95 to 115%)		Run 1	Run 2
Negative Local Flow Present, YES or NO (Yes = Fail)	NO				Are there sufficient rails and kick board? (YES, NO or N/A)		99.4	N/A
Is the Platform area greater than 5m ² ? (YES, NO or N/A)	NO				Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)		YES	
Passed Highest to lowest Velocity (3:1)	YES							
Site Equipment Used								
Pitot Reference	RED 0290				Manometer Reference		RED 0393	
Thermometer Reference	RED 0351-RED 0352				Thermocouple Reference		RED 0362	
Balance Reference	N/A				Sampling Pump Reference		RED 0258	
Tape Measure Reference	RED 0123				Barometer Reference		RED 0094	
DGM Thermocouple	RED 0274				Impinger Outlet Thermocouple		N/A	
Calipers	RED 0300				Condenser Thermocouple		N/A	

Stack Reference ID		Primer Flash Off		
		Terex United Kingdom Limited		
		RUN 1		
Filter Reference No	G47-171012-21			
Date	23rd October 2012			
Sample Period	14:55	to	15:55	
Velocity (m/s)	9.45			
Volume flow rate of Stack gas (m ³ /hr)	17106			
Average Stack Temp (°C)	31.1			
Temp Range ± 5% (°C)	15.85	to	46.25	
Lowest Velocity Reading (m/s)	9.20			
Highest Velocity Reading (m/s)	10.46			
Ratio (less than 3:1)	1.14	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	31.1			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	19.9			
Carbon Dioxide %	0.30			
Moisture (%)	0.00			
Litres sampled	1304			
Corrected volume sampled - STP (m ³)	1.249			
Blank Filter Run weight gain (mg)	0.010	Blank Concentration (mg/m ³)	0.016	
Blank Wash Run weight gain (mg)	0.050		0.080	
Weighing uncertainty of balance (mg)	0.074	This must be <5% of ELV	ELV = 50	2.5
Overall Blank value (mg/m ³)	0.096	This must be <10% of ELV	ELV = 50	5.0
Particulate weight collected on filter (mg)	0.02			
Particulate weight collected in Wash (mg)	0.55			
Total Particulate weight collected (mg)	0.57			
Total Particulate Concentration, dry gas at STP (mg/m ³)	0.46			
Total Particulate Concentration, wet gas at STP (mg/m ³)	0.46			
Total Particulate Concentration corrected for 11% Oxygen, dry gas (mg/m ³)	N/A			
Total Particulate Mass Emission (g/hour)	0.01			

Client	Terex United Kingdom Limited							
Site Address	Coventry							
Job Number	P-RED12-135							
Date	23rd October 2012							
Operator(s)	E Berek & T Berek							
Stack Reference	TOPCOAT SPRAY BOOTH 1				Isokinetic Sample Positions (%) multiply by diameter to obtain sample points			
					Sampling Plane Diagram			
Number of Stacks	1				1	6.70		
Stack Configuration	Round				2	25.00		
Dimensions (mtrs)	1.60				3	75.00		
Outlet Diameter (if applicable) (metres)					4	93.30		
Number of Sample Ports	1				5	N/A		
Number of Samples per Axis / Port	4				6	N/A		
Nozzle Diameter (mm)	8.0				7	N/A		
Nozzle Area (m²)	0.00005024				Average Isokinetic Flow Rate (ltrs/min)			
Stack Area (m²)	2.011				Axis 1		Axis 2	
Pitot Coefficient	0.84		Pitot Calibration Due Date		31/03/2013		Atmos. Pressure (kPa)	
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test	101.8
No.	(cms)	(pa)	(C)	(°)	(pa)	(C)	(°)	Static Pressure (pa)
1	10.72	44	22.9	6.3	50	22.9	6.4	-4.0
2	40.00	50	22.9	6.3	39	22.9	6.4	1 Axis
3	N/A	56	22.9	6.3	52	22.9	6.4	2 Axis
4	N/A	57	22.9	6.3	48	22.9	6.4	Velocity of flow (m/s)
5	N/A							7.83
6	N/A							7.48
7	N/A							Volume Flow Rate (m³/s)
8	N/A							15.74
								15.04
								Reduced Exit
Averages		52	22.9		47	22.9		N/A
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2 + 273) =$								295.90
Permitted Range of gas temperature readings (C) = $(0.95T_p - 273)$ to $(1.05T_p - 273) =$								8.10 to 37.70
Highest Velocity Reading (m/s) =								8.4
Lowest Velocity Reading (m/s) =								6.8
Ratio Highest/Lowest (Max permitted = 3:1)								1.25 : 1
On site Checklist								
Initial Leak Check	<0.2	End of first run	<0.2		Start of 2 nd run		End of 2 nd run	
Acceptable Leak Check < 2% Vol (l/min)	0.47				Manometer Leak Check		OK	
					Pitot Leak Check		OK	
Range of Gas Temps	OK				Overall Isokinetic Ratio (%) (must be 95 to 115%)		Run 1	Run 2
Passed minimum Velocity requirements (>5pa)	YES						95.5	N/A
Negative Local Flow Present, YES or NO (Yes = Fail)	NO				Are there sufficient rails and kick board? (YES, NO or N/A)		NO	
Is the Platform area greater than 5m²? (YES, NO or N/A)	NO				Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)		YES	
Passed Highest to lowest Velocity (3:1)	YES							
Site Equipment Used								
Pitot Reference	RED 0290				Manometer Reference		RED 0393	
Thermometer Reference	RED 0351-RED 0352				Thermocouple Reference		RED 0362	
Balance Reference	N/A				Sampling Pump Reference		RED 0385	
Tape Measure Reference	RED 0123				Barometer Reference		RED 0094	
DGM Thermocouple	RED 0395				Impinger Outlet Thermocouple		N/A	
Calipers	RED 0300				Condenser Thermocouple		N/A	

Stack Reference ID		TOPCOAT SPRAY BOOTH 1		
		Terex United Kingdom Limited		
		RUN 1		
Filter Reference No	G47-171012-22			
Date	23rd October 2012			
Sample Period	12:40	to	13:40	
Velocity (m/s)	7.83			
Volume flow rate of Stack gas (m ³ /hr)	56656			
Average Stack Temp (°C)	22.9			
Temp Range ± 5% (°C)	8.10	to	37.70	
Lowest Velocity Reading (m/s)	6.77			
Highest Velocity Reading (m/s)	8.45			
Ratio (less than 3:1)	1.25	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	22.9			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	19.9			
Carbon Dioxide %	0.20			
Moisture (%)	0.00			
Litres sampled	1281			
Corrected volume sampled - STP (m ³)	1.230			
Blank Filter Run weight gain (mg)	0.020	Blank Concentration (mg/m ³)	0.016	
Blank Wash Run weight gain (mg)	0.020		0.016	
Weighing uncertainty of balance (mg)	0.074	This must be <5% of ELV	ELV = 50	2.5
Overall Blank value (mg/m ³)	0.033	This must be <10% of ELV	ELV = 50	5.0
Particulate weight collected on filter (mg)	0.02			
Particulate weight collected in Wash (mg)	0.55			
Total Particulate weight collected (mg)	0.57			
Total Particulate Concentration, dry gas at STP (mg/m ³)	0.46			
Total Particulate Concentration, wet gas at STP (mg/m ³)	0.46			
Total Particulate Concentration corrected for 11% Oxygen, dry gas (mg/m ³)	N/A			
Total Particulate Mass Emission (g/hour)	0.02			

Client	Terex United Kingdom Limited							
Site Address	Coventry							
Job Number	P-RED12-135							
Date	23rd October 2012							
Operator(s)	E Berek & T Berek							
Stack Reference	Topcoat Spray Booth 2			Isokinetic Sample Positions (%) multiply by diameter to obtain sample points				
				1	6.70			
Number of Stacks		1		2	25.00			
Stack Configuration		Round		3	75.00			
Dimensions (mtrs)		1.60		4	93.30			
Outlet Diameter (if applicable) (metres)				5	N/A			
Number of Sample Ports		1		6	N/A			
Number of Samples per Axis / Port		4		7	N/A			
Nozzle Diameter (mm)		7.0		8	N/A			
Nozzle Area (m ²)		0.00003847	Average Isokinetic Flow Rate (ltrs/min)			Axis 1	Axis 2	
Stack Area (m ²)		2.011				18.90	19.15	
Pitot Coefficient	0.84	Pitot Calibration Due Date			31/03/2013			Atmos. Pressure (kPa)
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test	101.8
No.	(cms)	(pa)	(C)	(°)	(pa)	(C)	(°)	Static Pressure (pa)
1	10.72	46	23.5	7.9	52	23.5	7.9	-16.0
2	40.00	60	23.5	7.9	54	23.5	7.9	1 Axis
3	120.00	64	23.5	7.9	61	23.5	7.9	2 Axis
4	149.28	56	23.5	7.9	65	23.5	7.9	Velocity of flow (m/s)
5	N/A							8.19
6	N/A							8.30
7	N/A							Volume Flow Rate (m ³ /s)
8	N/A							16.46
								16.68
								Reduced Exit
Averages		57	23.5		58	23.5		N/A
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2) + 273) =$							296.50	
Permitted Range of gas temperature readings (C) = $(0.95T_p - 273)$ to $(1.05T_p - 273) =$							8.68 to 38.33	
Highest Velocity Reading (m/s) =							9.0	
Lowest Velocity Reading (m/s) =							7.4	
Ratio Highest/Lowest (Max permitted = 3:1)							1.23 : 1	
On site Checklist								
Initial Leak Check	End of first run			Start of 2 nd run	End of 2 nd run			
Acceptable Leak Check < 2% Vol (l/min)	0.38			Manometer Leak Check			OK	
				Pitot Leak Check			OK	
Range of Gas Temps	OK			Overall Isokinetic Ratio (%) (must be 95 to 115%)	Run 1	Run 2		
Passed minimum Velocity requirements (>5pa)	YES				#DIV/0!	#DIV/0!		
Negative Local Flow Present, YES or NO (Yes = Fail)	NO			Are there sufficient rails and kick board? (YES, NO or N/A)			NO	
Is the Platform area greater than 5m ² ? (YES, NO or N/A)	NO			Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)			YES	
Passed Highest to lowest Velocity (3:1)	YES							
Site Equipment Used								
Pitot Reference	RED 0290			Manometer Reference			RED 0393	
Thermometer Reference	RED 0351-RED 0352			Thermocouple Reference			RED 0362	
Balance Reference	N/A			Sampling Pump Reference			RED 0385	
Tape Measure Reference	RED 0123			Barometer Reference			RED 0094	
DGM Thermocouple	RED 0395			Impinger Outlet Thermocouple			N/A	
Calipers	RED 0300			Condenser Thermocouple			N/A	

Stack Reference ID		Topcoat Spray Booth 2		
		Terex United Kingdom Limited		
		RUN 1		
Filter Reference No	G47-171012-23			
Date	23rd October 2012			
Sample Period	13:45	to	14:45	
Velocity (m/s)	8.24			
Volume flow rate of Stack gas (m ³ /hr)	59662			
Average Stack Temp (°C)	23.5			
Temp Range ± 5% (°C)	8.68	to	38.33	
Lowest Velocity Reading (m/s)	7.37			
Highest Velocity Reading (m/s)	9.03			
Ratio (less than 3:1)	1.23	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	23.7			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	20			
Carbon Dioxide %	0.10			
Moisture (%)	0.00			
Litres sampled	947			
Corrected volume sampled - STP (m ³)	0.908			
Blank Filter Run weight gain (mg)	0.020	Blank Concentration (mg/m ³)	0.022	
Blank Wash Run weight gain (mg)	0.006		0.007	
Weighing uncertainty of balance (mg)	0.074	This must be <5% of ELV	ELV = 50	2.5
Overall Blank value (mg/m ³)	0.029	This must be <10% of ELV	ELV = 50	5.0
Particulate weight collected on filter (mg)	0.05			
Particulate weight collected in Wash (mg)	0.06			
Total Particulate weight collected (mg)	0.11			
Total Particulate Concentration, dry gas at STP (mg/m ³)	0.12			
Total Particulate Concentration, wet gas at STP (mg/m³)	0.12			
Total Particulate Concentration corrected for 11% Oxygen, dry gas (mg/m ³)	N/A			
Total Particulate Mass Emission (Kg/hour)	0.01			

Client	Terex United Kingdom Limited							
Site Address	Coventry							
Job Number	P-RED12-135							
Date	23rd October 2012							
Operator(s)	E Berek & T Berek							
Stack Reference	Top Coat Flash Off			Isokinetic Sample Positions (%) multiply by diameter to obtain sample points		Sampling Plane Diagram		
Number of Stacks	1			1	14.60			
Stack Configuration	Round			2	85.40			
Dimensions (mtrs)	0.90			3	N/A			
Outlet Diameter (if applicable) (metres)				4	N/A			
Number of Sample Ports	1			5	N/A			
Number of Samples per Axis / Port	2			6	N/A			
Nozzle Diameter (mm)	6.0			7	N/A			
Nozzle Area (m ²)	0.00002826			8	N/A			
Stack Area (m ²)	0.636			Average Isokinetic Flow Rate (ltrs/min)		Axis 1	Axis 2	
Pitot Coefficient	0.84	Pitot Calibration Due Date			31/03/2013		20.41	21.22
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test	Atmos. Pressure (kPa)
No.	(cms)	(pa)	(C)	(°)	(pa)	(C)	(°)	101.8
1	13.14	88	53.0	8.5	140	53.3	8.6	Static Pressure (pa)
2	76.86	134	53.0	8.5	100	53.2	8.6	36.0
3	N/A							1 Axis
4	N/A							2 Axis
5	N/A							Velocity of flow (m/s)
6	N/A							12.04
7	N/A							12.51
8	N/A							Volume Flow Rate (m ³ /s)
Averages		111	53.0		120	53.3		7.66
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2) + 273$								326.00
Permitted Range of gas temperature readings (C) = $(0.95T_p - 273)$ to $(1.05T_p - 273)$								36.70 to 69.30
Highest Velocity Reading (m/s)								13.9
Lowest Velocity Reading (m/s)								10.7
Ratio Highest/Lowest (Max permitted = 3:1)								1.30 : 1
On site Checklist								
Initial Leak Check	End of first run		Start of 2 nd run		End of 2 nd run			
Acceptable Leak Check < 2% Vol (l/min)	0.41			Manometer Leak Check		OK		
Range of Gas Temps	OK			Pitot Leak Check		OK		
Passed minimum Velocity requirements (>5pa)	YES			Overall Isokinetic Ratio (%) (must be 95 to 115%)		Run 1	Run 2	
Negative Local Flow Present, YES or NO (Yes = Fail)	NO			Are there sufficient rails and kick board? (YES, NO or N/A)		95.8	N/A	
Is the Platform area greater than 5m ² ? (YES, NO or N/A)	NO			Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)		YES		
Passed Highest to lowest Velocity (3:1)	YES							
Site Equipment Used								
Pitot Reference	RED 0290			Manometer Reference		RED 0393		
Thermometer Reference	RED 0351-RED 0352			Thermocouple Reference		RED 0362		
Balance Reference	N/A			Sampling Pump Reference		RED 0385		
Tape Measure Reference	RED 0123			Barometer Reference		RED 0094		
DGM Thermocouple	RED 0395			Impinger Outlet Thermocouple		N/A		
Calipers	RED 0300			Condenser Thermocouple		N/A		

Stack Reference ID		Top Coat Flash Off		
	Terex United Kingdom Limited			
	RUN 1			
Filter Reference No	G47-171012-21			
Date	23rd October 2012			
Sample Period	14:50	to	15:50	
Velocity (m/s)	12.04			
Volume flow rate of Stack gas (m ³ /hr)	27563			
Average Stack Temp (°C)	53.0			
Temp Range ± 5% (°C)	36.70	to	69.30	
Lowest Velocity Reading (m/s)	10.68			
Highest Velocity Reading (m/s)	13.90			
Ratio (less than 3:1)	1.30	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	53.0			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	20			
Carbon Dioxide %	0.10			
Moisture (%)	0.00			
Litres sampled	1144			
Corrected volume sampled - STP (m ³)	1.097			
Blank Filter Run weight gain (mg)	0.010	Blank Concentration (mg/m ³)	0.009	
Blank Wash Run weight gain (mg)	0.050		0.046	
Weighing uncertainty of balance (mg)	0.074	This must be <5% of ELV	ELV = 50	2.5
Overall Blank value (mg/m ³)	0.055	This must be <10% of ELV	ELV = 50	5.0
Particulate weight collected on filter (mg)	0.02			
Particulate weight collected in Wash (mg)	0.55			
Total Particulate weight collected (mg)	0.57			
Total Particulate Concentration, dry gas at STP (mg/m ³)	0.52			
Total Particulate Concentration, wet gas at STP (mg/m ³)	0.52			
Total Particulate Concentration corrected for 11% Oxygen, dry gas (mg/m ³)	N/A			
Total Particulate Mass Emission (g/hour)	0.01			

Client	Terex United Kingdom Limited								
Site Address	Coventry								
Job Number	P-RED12-135								
Date	24th October 2012								
Operator(s)	V Gavin & T Berek								
Stack Reference	Top Coat Curing Oven				Isokinetic Sample Positions (%) multiply by diameter to obtain sample points				
Number of Stacks	1				1	14.60			
Stack Configuration	Round				2	85.40			
Dimensions (mtrs)	1.00				3	N/A			
Outlet Diameter (if applicable) (metres)					4	N/A			
Number of Sample Ports	2				5	N/A			
Number of Samples per Axis / Port	2				6	N/A			
Nozzle Diameter (mm)	6.0				7	N/A			
Nozzle Area (m ²)	0.00002826				8	N/A			
Stack Area (m ²)	0.785				Average Isokinetic Flow Rate (ltrs/min)			Axis 1	Axis 2
Pitot Coefficient	0.84	Pitot Calibration Due Date			31/03/2013			19.13	20.74
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test	Atmos. Pressure (kPa)	
No.	(cms)	(pa)	(C)	(°)	(pa)	(C)	(°)	101.8	
1	14.60	82	37.3	9.1	130	37.3	9.1	Static Pressure (pa)	
2	85.40	123	37.3	9.1	111	37.3	9.1	-67.0	
3	N/A							1 Axis	2 Axis
4	N/A							Velocity of flow (m/s)	
5	N/A							11.28	12.23
6	N/A							Volume Flow Rate (m ³ /s)	
7	N/A							8.86	9.61
8	N/A							Reduced Exit	
Averages		103	37.3		121	37.3		N/A	
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2) + 273) =$								310.30	
Permitted Range of gas temperature readings (C) = $(0.95T_p - 273)$ to $(1.05T_p - 273) =$								21.79	52.82
Highest Velocity Reading (m/s) =								13.1	
Lowest Velocity Reading (m/s) =								10.1	
Ratio Highest/Lowest (Max permitted = 3:1)								1.30 : 1	
On site Checklist									
Initial Leak Check	End of first run				Start of 2 nd run		End of 2 nd run		
Acceptable Leak Check < 2% Vol (l/min)	0.38				Manometer Leak Check			OK	
Range of Gas Temps	OK				Pitot Leak Check			OK	
Passed minimum Velocity requirements (>5pa)	YES				Overall Isokinetic Ratio (%) (must be 95 to 115%)			Run 1	Run 2
Negative Local Flow Present, YES or NO (Yes = Fail)	NO				Are there sufficient rails and kick board? (YES, NO or N/A)			97.8	N/A
Is the Platform area greater than 5m ² ? (YES, NO or N/A)	NO				Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)			YES	
Passed Highest to lowest Velocity (3:1)	YES								
Site Equipment Used									
Pitot Reference	RED 0290				Manometer Reference			RED 0393	
Thermometer Reference	RED 0351-RED 0352				Thermocouple Reference			RED 0362	
Balance Reference	N/A				Sampling Pump Reference			RED 0385	
Tape Measure Reference	RED 0123				Barometer Reference			RED 0094	
DGM Thermocouple	RED 0395				Impinger Outlet Thermocouple			N/A	
Calipers	RED 0300				Condenser Thermocouple			N/A	

Stack Reference ID		Top Coat Curing Oven		
	Terex United Kingdom Limited			
	RUN 1			
Filter Reference No	G47-221012-03			
Date	24th October 2012			
Sample Period	07:50	to	08:50	
Velocity (m/s)	11.28			
Volume flow rate of Stack gas (m ³ /hr)	31902			
Average Stack Temp (°C)	37.3			
Temp Range ± 5% (°C)	21.79	to	52.82	
Lowest Velocity Reading (m/s)	10.06			
Highest Velocity Reading (m/s)	13.06			
Ratio (less than 3:1)	1.30	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	37.3			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	20			
Carbon Dioxide %	0.10			
Moisture (%)	0.00			
Litres sampled	1156			
Corrected volume sampled - STP (m ³)	1.116			
Blank Filter Run weight gain (mg)	0.010	Blank Concentration (mg/m ³)	0.009	
Blank Wash Run weight gain (mg)	0.070		0.063	
Weighing uncertainty of balance (mg)	0.074	This must be <5% of ELV	ELV = 50	2.5
Overall Blank value (mg/m ³)	0.072	This must be <10% of ELV	ELV = 50	5.0
Particulate weight collected on filter (mg)	0.12			
Particulate weight collected in Wash (mg)	0.09			
Total Particulate weight collected (mg)	0.21			
Total Particulate Concentration, dry gas at STP (mg/m ³)	0.19			
Total Particulate Concentration, wet gas at STP (mg/m ³)	0.19			
Total Particulate Concentration corrected for 11% Oxygen, dry gas (mg/m ³)	N/A			
Total Particulate Mass Emission (g/hour)	0.004			

Client	Terex United Kingdom Limited								
Site Address	Coventry								
Job Number	P-RED12-135								
Date	23th October 2012								
Operator(s)	E Berek & T Berek								
Stack Reference	Preparation Booth 1				Isokinetic Sample Positions (%) multiply by diameter to obtain sample points				
Number of Stacks	1				1	14.60			
Stack Configuration	Round				2	85.40			
Dimensions (mtrs)	0.70				3	N/A			
Outlet Diameter (if applicable) (metres)					4	N/A			
Number of Sample Ports	2				5	N/A			
Number of Samples per Axis / Port	2				6	N/A			
Nozzle Diameter (mm)	6.0				7	N/A			
Nozzle Area (m ²)	0.00002826				8	N/A			
Stack Area (m ²)	0.385				Average Isokinetic Flow Rate (ltrs/min)			Axis 1	Axis 2
Pitot Coefficient	0.84				31/03/2013			22.52	22.60
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test	Atmos. Pressure (kPa)	
No.	(cms)	(pa)	(C)	(°)	(pa)	(C)	(°)	101.8	
1	10.22	138	31.1	8.4	145	31.2	8.5	Static Pressure (pa)	
2	59.78	152	31.0	8.4	147	31.2	8.5	25.0	
3	N/A							1 Axis	2 Axis
4	N/A							Velocity of flow (m/s)	
5	N/A							13.28	
6	N/A							Volume Flow Rate (m ³ /s)	
7	N/A							5.11	
8	N/A							5.13	
Averages		145	31.1		146	31.2		Reduced Exit	
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2 + 273) =$								304.05	
Permitted Range of gas temperature readings (C) = $(0.95T_p - 273)$ to $(1.05T_p - 273) =$								15.85	46.25
Highest Velocity Reading (m/s) =								14.0	
Lowest Velocity Reading (m/s) =								12.9	
Ratio Highest/Lowest (Max permitted = 3:1)								1.08 : 1	
On site Checklist									
Initial Leak Check	<0.2	End of first run	<0.2		Start of 2 nd run		End of 2 nd run		
Acceptable Leak Check < 2% Vol (l/min)	0.45				Manometer Leak Check			OK	
Range of Gas Temps	OK				Pitot Leak Check			OK	
Passed minimum Velocity requirements (>5pa)	YES				Overall Isokinetic Ratio (%) (must be 95 to 115%)			Run 1	Run 2
Negative Local Flow Present, YES or NO (Yes = Fail)	NO				Are there sufficient rails and kick board? (YES, NO or N/A)			101.0	N/A
Is the Platform area greater than 5m ² ? (YES, NO or N/A)	NO				Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)			YES	
Passed Highest to lowest Velocity (3:1)	YES								
Site Equipment Used									
Pitot Reference	RED 0290				Manometer Reference				RED 0393
Thermometer Reference	RED 0351-RED 0352				Thermocouple Reference				RED 0362
Balance Reference	N/A				Sampling Pump Reference				RED 0385
Tape Measure Reference	RED 0123				Barometer Reference				RED 0094
DGM Thermocouple	RED 0395				Impinger Outlet Thermocouple				N/A
Calipers	RED 0300				Condenser Thermocouple				N/A

Stack Reference ID		Preparation Booth 1		
	Terex United Kingdom Limited			
	RUN 1			
Filter Reference No	G47-171012-01			
Date	23th October 2012			
Sample Period	07:00	to	08:00	
Velocity (m/s)	13.28			
Volume flow rate of Stack gas (m ³ /hr)	18404			
Average Stack Temp (°C)	31.1			
Temp Range ± 5% (°C)	15.85	to	46.25	
Lowest Velocity Reading (m/s)	12.92			
Highest Velocity Reading (m/s)	13.98			
Ratio (less than 3:1)	1.08	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	31.4			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	20			
Carbon Dioxide %	0.10			
Moisture (%)	0.00			
Litres sampled	1290			
Corrected volume sampled - STP (m ³)	1.249			
Blank Filter Run weight gain (mg)	0.030	Blank Concentration (mg/m ³)	0.048	
Blank Wash Run weight gain (mg)	0.010		0.016	
Weighing uncertainty of balance (mg)	0.079	This must be <5% of ELV	ELV = 50	2.5
Overall Blank value (mg/m ³)	0.064	This must be <10% of ELV	ELV = 50	5.0
Particulate weight collected on filter (mg)	4.09			
Particulate weight collected in Wash (mg)	0.02			
Total Particulate weight collected (mg)	4.11			
Total Particulate Concentration, dry gas at STP (mg/m ³)	3.29			
Total Particulate Concentration, wet gas at STP (mg/m ³)	3.29			
Total Particulate Concentration corrected for 11% Oxygen, dry gas (mg/m ³)	N/A			
Total Particulate Mass Emission (Kg/hour)	0.06			

Client	Terex United Kingdom Limited						
Site Address	Coventry						
Job Number	P-RED12-135						
Date	23rd October 2012						
Operator(s)	E Berek & T Berek						
Stack Reference	Preparation Booth 2		Isokinetic Sample Positions (%) multiply by diameter to obtain sample points		Sampling Plane Diagram		
Number of Stacks	1		1	14.60			
Stack Configuration	Round		2	85.40			
Dimensions (mtrs)	0.70		3	N/A			
Outlet Diameter (if applicable) (metres)			4	N/A			
Number of Sample Ports	2		5	N/A			
Number of Samples per Axis / Port	2		6	N/A			
Nozzle Diameter (mm)	6.0		7	N/A			
Nozzle Area (m ²)	0.00002826		8	N/A			
Stack Area (m ²)	0.385		Average Isokinetic Flow Rate (ltrs/min)		Axis 1	Axis 2	
Pitot Coefficient	0.84	Pitot Calibration Due Date		31/03/2013		22.26	22.49
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test
No.	(cms)	(pa)	(C)	(°)	(pa)	(C)	(°)
1	10.22	129	25.9	8.2	133	26	8.2
2	59.78	159	26.0	8.2	161	26.1	8.2
3	N/A						
4	N/A						
5	N/A						
6	N/A						
7	N/A						
8	N/A						
Averages		144	26.0		147	26.1	
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2) + 273$							298.95
Permitted Range of gas temperature readings (C) = $(0.95T_p - 273)$ to $(1.05T_p - 273)$							11.00 to 40.90
Highest Velocity Reading (m/s)							14.3
Lowest Velocity Reading (m/s)							12.4
Ratio Highest/Lowest (Max permitted = 3:1)							1.15 : 1
On site Checklist							
Initial Leak Check	<0.2	End of first run	<0.2		Start of 2 nd run		End of 2 nd run
Acceptable Leak Check < 2% Vol (l/min)	0.45				Manometer Leak Check		OK
					Pitot Leak Check		OK
Range of Gas Temps	OK				Overall Isokinetic Ratio (%) (must be 95 to 115%)		Run 1 102.3
Passed minimum Velocity requirements (>5pa)	YES						Run 2 N/A
Negative Local Flow Present, YES or NO (Yes = Fail)	NO				Are there sufficient rails and kick board? (YES, NO or N/A)		NO
Is the Platform area greater than 5m ² ? (YES, NO or N/A)	NO				Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)		YES
Passed Highest to lowest Velocity (3:1)	YES						
Site Equipment Used							
Pitot Reference	RED 0290				Manometer Reference		RED 0393
Thermometer Reference	RED 0351-RED 0352				Thermocouple Reference		RED 0362
Balance Reference	N/A				Sampling Pump Reference		RED 0258
Tape Measure Reference	RED 0123				Barometer Reference		RED 0094
DGM Thermocouple	RED 0395				Impinger Outlet Thermocouple		N/A
Calipers	RED 0300				Condenser Thermocouple		N/A

Stack Reference ID		Preparation Booth 2		
		Terex United Kingdom Limited		
		RUN 1		
Filter Reference No	G47-171012-03			
Date	23rd October 2012			
Sample Period	07:07	to	08:07	
Velocity (m/s)	13.13			
Volume flow rate of Stack gas (m ³ /hr)	18186			
Average Stack Temp (°C)	26.0			
Temp Range ± 5% (°C)	11.00	to	40.90	
Lowest Velocity Reading (m/s)	12.38			
Highest Velocity Reading (m/s)	14.27			
Ratio (less than 3:1)	1.15	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	26.0			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	20			
Carbon Dioxide %	0.10			
Moisture (%)	0.00			
Litres sampled	1328			
Corrected volume sampled - STP (m ³)	1.286			
Blank Filter Run weight gain (mg)	0.010	Blank Concentration (mg/m ³)	0.016	
Blank Wash Run weight gain (mg)	0.020		0.031	
Weighing uncertainty of balance (mg)	0.074	This must be <5% of ELV	ELV = 50	2.5
Overall Blank value (mg/m ³)	0.047	This must be <10% of ELV	ELV = 50	5.0
Particulate weight collected on filter (mg)	0.20			
Particulate weight collected in Wash (mg)	0.07			
Total Particulate weight collected (mg)	0.27			
Total Particulate Concentration, dry gas at STP (mg/m ³)	0.21			
Total Particulate Concentration, wet gas at STP (mg/m ³)	0.21			
Total Particulate Concentration corrected for 11% Oxygen, dry gas (mg/m ³)	N/A			
Total Particulate Mass Emission (g/hour)	0.003			

Client	Terex United Kingdom Limited								
Site Address	Coventry								
Job Number	P-RED12-135								
Date	23rd October 2012								
Operator(s)	E Berek & T Berek								
Stack Reference	Scissor 1 Booth 1				Isokinetic Sample Positions (%) multiply by diameter to obtain sample points				
Number of Stacks	1				1	14.60			
Stack Configuration	Round				2	85.40			
Dimensions (mtrs)	0.60				3	N/A			
Outlet Diameter (if applicable) (metres)					4	N/A			
Number of Sample Ports	2				5	N/A			
Number of Samples per Axis / Port	2				6	N/A			
Nozzle Diameter (mm)	6.0				7	N/A			
Nozzle Area (m ²)	0.00002826				8	N/A			
Stack Area (m ²)	0.283				Average Isokinetic Flow Rate (ltrs/min)			Axis 1	Axis 2
Pitot Coefficient	0.84				31/03/2013			22.72	23.94
Pitot Calibration Due Date		31/03/2013		Atmos. Pressure (kPa)				101.8	
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test	Static Pressure (pa)	
No.	(cms)	(pa)	(C)	(°)	(pa)	(C)	(°)	30.0	
1	8.76	119	26.0	9.4	145	26.2	9.4	1 Axis	2 Axis
2	51.24	181	26.2	9.4	188	26.2	9.4	Velocity of flow (m/s)	
3	N/A							13.40	14.12
4	N/A							Volume Flow Rate (m ³ /s)	
5	N/A							3.79	3.99
6	N/A							Reduced Exit	
7	N/A							N/A	
8	N/A								
Averages		150	26.1		167	26.2			
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2) + 273) =$					299.10				
Permitted Range of gas temperature readings (C) = $(0.95T_p - 273)$ to $(1.05T_p - 273) =$					11.15 to 41.06				
Highest Velocity Reading (m/s) =					15.4				
Lowest Velocity Reading (m/s) =					11.9				
Ratio Highest/Lowest (Max permitted = 3:1)					1.30 : 1				
On site Checklist									
Initial Leak Check	<0.2	End of first run	<0.2		Start of 2 nd run		End of 2 nd run		
Acceptable Leak Check < 2% Vol (l/min)	0.45				Manometer Leak Check			OK	
					Pitot Leak Check			OK	
Range of Gas Temps	OK				Overall Isokinetic Ratio (%) (must be 95 to 115%)			Run 1	Run 2
Passed minimum Velocity requirements (>5pa)	YES							101.2	N/A
Negative Local Flow Present, YES or NO (Yes = Fail)	NO				Are there sufficient rails and kick board? (YES, NO or N/A)			NO	
Is the Platform area greater than 5m ² ? (YES, NO or N/A)	NO				Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)			YES	
Passed Highest to lowest Velocity (3:1)	YES								
Site Equipment Used									
Pitot Reference	RED 0290				Manometer Reference			RED 0393	
Thermometer Reference	RED 0351-RED 0352				Thermocouple Reference			RED 0362	
Balance Reference	N/A				Sampling Pump Reference			RED 0385	
Tape Measure Reference	RED 0123				Barometer Reference			RED 0094	
DGM Thermocouple	RED 0395				Impinger Outlet Thermocouple			N/A	
Calipers	RED 0300				Condenser Thermocouple			N/A	

Stack Reference ID		Scissor 1 Booth 1		
		Terex United Kingdom Limited		
		RUN 1		
Filter Reference No	G47-171012-05			
Date	23rd October 2012			
Sample Period	09:15	to	10:15	
Velocity (m/s)	13.40			
Volume flow rate of Stack gas (m ³ /hr)	13640			
Average Stack Temp (°C)	26.1			
Temp Range ± 5% (°C)	11.15	to	41.06	
Lowest Velocity Reading (m/s)	11.90			
Highest Velocity Reading (m/s)	15.42			
Ratio (less than 3:1)	1.30	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	26.1			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	20			
Carbon Dioxide %	0.10			
Moisture (%)	0.00			
Litres sampled	1418			
Corrected volume sampled - STP (m ³)	1.366			
Blank Filter Run weight gain (mg)	0.010	Blank Concentration (mg/m ³)	0.015	
Blank Wash Run weight gain (mg)	0.010		0.015	
Weighing uncertainty of balance (mg)	0.083	This must be <5% of ELV	ELV = 50	2.5
Overall Blank value (mg/m ³)	0.029	This must be <10% of ELV	ELV = 50	5.0
Particulate weight collected on filter (mg)	5.51			
Particulate weight collected in Wash (mg)	0.19			
Total Particulate weight collected (mg)	5.70			
Total Particulate Concentration, dry gas at STP (mg/m ³)	4.17			
Total Particulate Concentration, wet gas at STP (mg/m ³)	4.17			
Total Particulate Concentration corrected for 11% Oxygen, dry gas (mg/m ³)	N/A			
Total Particulate Mass Emission (g/hour)	0.04			

Client	Terex United Kingdom Limited								
Site Address	Coventry								
Job Number	P-RED12-135								
Date	23rd October 2012								
Operator(s)	E Berek & T Berek								
Stack Reference	Scissor 1 Booth 2				Isokinetic Sample Positions (%) multiply by diameter to obtain sample points				
					Sampling Plane Diagram				
Number of Stacks	1				1	14.60			
Stack Configuration	Round				2	85.40			
Dimensions (mtrs)	0.60				3	N/A			
Outlet Diameter (if applicable) (metres)					4	N/A			
Number of Sample Ports	2				5	N/A			
Number of Samples per Axis / Port	2				6	N/A			
Nozzle Diameter (mm)	6.0				7	N/A			
Nozzle Area (m ²)	0.00002826				8	N/A			
Stack Area (m ²)	0.283				Average Isokinetic Flow Rate (ltrs/min)			Axis 1	Axis 2
Pitot Coefficient	0.84							23.32	23.28
	Pitot Calibration Due Date				31/03/2013			Atmos. Pressure (kPa)	
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test	101.8	
No.	(cms)	(pa)	(C)	(°)	(pa)	(C)	(°)	Static Pressure (pa)	
1	8.76	139	27.1	8.9	165	27.2	8.9	23.0	
2	51.24	176	27.2	8.9	149	27.1	8.9	1 Axis	2 Axis
3	N/A							Velocity of flow (m/s)	
4	N/A							13.75	13.73
5	N/A							Volume Flow Rate (m ³ /s)	
6	N/A							3.89	3.88
7	N/A							Reduced Exit	
8	N/A							N/A	
Averages		158	27.2		157	27.2		N/A	
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2) + 273$					300.15				
Permitted Range of gas temperature readings (C) = $(0.95T_p - 273)$ to $(1.05T_p - 273)$					12.14		to		42.16
Highest Velocity Reading (m/s)	=				15.0				
Lowest Velocity Reading (m/s)	=				12.9				
Ratio Highest/Lowest (Max permitted = 3:1)					1.16 : 1				
On site Checklist									
Initial Leak Check	<0.2	End of first run	<0.2		Start of 2 nd run		End of 2 nd run		
Acceptable Leak Check < 2% Vol (l/min)	0.47				Manometer Leak Check			OK	
					Pitot Leak Check			OK	
Range of Gas Temps	OK				Overall Isokinetic Ratio (%) (must be 95 to 115%)			Run 1	Run 2
Passed minimum Velocity requirements (>5pa)	YES							95.5	N/A
Negative Local Flow Present, YES or NO (Yes = Fail)	NO				Are there sufficient rails and kick board? (YES, NO or N/A)			NO	
Is the Platform area greater than 5m ² ? (YES, NO or N/A)	NO				Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)			YES	
Passed Highest to lowest Velocity (3:1)	YES								
Site Equipment Used									
Pitot Reference	RED 0290				Manometer Reference			RED 0393	
Thermometer Reference	RED 0351-RED 0352				Thermocouple Reference			RED 0362	
Balance Reference	N/A				Sampling Pump Reference			RED 0385	
Tape Measure Reference	RED 0123				Barometer Reference			RED 0094	
DGM Thermocouple	RED 0395				Impinger Outlet Thermocouple			N/A	
Calipers	RED 0300				Condenser Thermocouple			N/A	

Stack Reference ID		Scissor 1 Booth 2		
		Terex United Kingdom Limited		
		RUN 1		
Filter Reference No	G47-171012-07			
Date	23rd October 2012			
Sample Period	10:20	to	11:20	
Velocity (m/s)	13.75			
Volume flow rate of Stack gas (m ³ /hr)	13998			
Average Stack Temp (°C)	27.2			
Temp Range ± 5% (°C)	12.14	to	42.16	
Lowest Velocity Reading (m/s)	12.88			
Highest Velocity Reading (m/s)	14.95			
Ratio (less than 3:1)	1.16	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	27.2			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	20			
Carbon Dioxide %	0.20			
Moisture (%)	0.00			
Litres sampled	1321			
Corrected volume sampled - STP (m ³)	1.272			
Blank Filter Run weight gain (mg)	0.530	Blank Concentration (mg/m ³)	0.834	
Blank Wash Run weight gain (mg)	0.000		0.000	
Weighing uncertainty of balance (mg)	0.077	This must be <5% of ELV	ELV = 50	2.5
Overall Blank value (mg/m ³)	0.834	This must be <10% of ELV	ELV = 50	5.0
Particulate weight collected on filter (mg)	2.78			
Particulate weight collected in Wash (mg)	0.04			
Total Particulate weight collected (mg)	2.82			
Total Particulate Concentration, dry gas at STP (mg/m ³)	2.22			
Total Particulate Concentration, wet gas at STP (mg/m ³)	2.22			
Total Particulate Concentration corrected for 11% Oxygen, dry gas (mg/m ³)	N/A			
Total Particulate Mass Emission (g/hour)	0.02			

Client	Terex United Kingdom Limited							
Site Address	Coventry							
Job Number	P-RED12-135							
Date	23rd October 2012							
Operator(s)	E Berek & T Berek							
Stack Reference	Scissor 1 Oven			Isokinetic Sample Positions (%) multiply by diameter to obtain sample points		Sampling Plane Diagram		
Number of Stacks	1			1	50.00			
Stack Configuration	Round			2	N/A			
Dimensions (mtrs)	0.20			3	N/A			
Outlet Diameter (if applicable) (metres)				4	N/A			
Number of Sample Ports	1			5	N/A			
Number of Samples per Axis / Port	1			6	N/A			
Nozzle Diameter (mm)	8.0			7	N/A			
Nozzle Area (m ²)	0.00005024			8	N/A			
Stack Area (m ²)	0.031			Average Isokinetic Flow Rate (ltrs/min)		Axis 1	Axis 2	
Pitot Coefficient	0.84	Pitot Calibration Due Date			31/03/2011		19.29	N/A
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test	Atmos. Pressure (kPa)
No.	(cms)	(pa)	(C)	(°)	(pa)	(C)	(°)	101.8
1	10.00	28	92.3	7.0				Static Pressure (pa)
2	N/A							7.0
3	N/A							1 Axis
4	N/A							2 Axis
5	N/A							Velocity of flow (m/s)
6	N/A							6.40
7	N/A							N/A
8	N/A							Volume Flow Rate (m ³ /s)
								0.20
								N/A
								Reduced Exit
Averages		28	92.3					N/A
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2) + 273$								365.30
Permitted Range of gas temperature readings (C) = $(0.95T_p - 273)$ to $(1.05T_p - 273)$								74.04 to 110.57
Highest Velocity Reading (m/s)								6.6
Lowest Velocity Reading (m/s)								6.4
Ratio Highest/Lowest (Max permitted = 3:1)								1.03 : 1
On site Checklist								
Initial Leak Check	<0.2	End of first run	<0.2		Start of 2 nd run		End of 2 nd run	
Acceptable Leak Check < 2% Vol (l/min)	0.39				Manometer Leak Check		OK	
					Pitot Leak Check		OK	
Range of Gas Temps	OK				Overall Isokinetic Ratio (%) (must be 95 to 115%)		Run 1	Run 2
Passed minimum Velocity requirements (>5pa)	YES						110.0	N/A
Negative Local Flow Present, YES or NO (Yes = Fail)	NO				Are there sufficient rails and kick board? (YES, NO or N/A)		NO	
Is the Platform area greater than 5m ² ? (YES, NO or N/A)	NO				Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)		YES	
Passed Highest to lowest Velocity (3:1)	YES							
Site Equipment Used								
Pitot Reference	RED 0290				Manometer Reference		RED 0393	
Thermometer Reference	RED 0351-RED 0352				Thermocouple Reference		RED 0362	
Balance Reference	N/A				Sampling Pump Reference		RED 0385	
Tape Measure Reference	RED 0123				Barometer Reference		RED 0094	
DGM Thermocouple	RED 0395				Impinger Outlet Thermocouple		N/A	
Calipers	RED 0300				Condenser Thermocouple		N/A	

Stack Reference ID		Scissor 1 Oven		
		Terex United Kingdom Limited		
		RUN 1		
Filter Reference No	G47-171012-09			
Date	23rd October 2012			
Sample Period	11:24	to	12:24	
Velocity (m/s)	6.40			
Volume flow rate of Stack gas (m ³ /hr)	724			
Average Stack Temp (°C)	92.3			
Temp Range ± 5% (°C)	74.04	to	110.57	
Lowest Velocity Reading (m/s)	6.38			
Highest Velocity Reading (m/s)	6.58			
Ratio (less than 3:1)	1.03	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	92.3			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	20			
Carbon Dioxide %	0.10			
Moisture (%)	0.00			
Litres sampled	1184			
Corrected volume sampled - STP (m ³)	1.137			
Blank Filter Run weight gain (mg)	0.010	Blank Concentration (mg/m ³)	0.018	
Blank Wash Run weight gain (mg)	0.030		0.053	
Weighing uncertainty of balance (mg)	0.074	This must be <5% of ELV	ELV = 50	2.5
Overall Blank value (mg/m ³)	0.070	This must be <10% of ELV	ELV = 50	5.0
Particulate weight collected on filter (mg)	0.15			
Particulate weight collected in Wash (mg)	0.19			
Total Particulate weight collected (mg)	0.34			
Total Particulate Concentration, dry gas at STP (mg/m ³)	0.30			
Total Particulate Concentration, wet gas at STP (mg/m ³)	0.30			
Total Particulate Concentration corrected for 11% Oxygen, dry gas (mg/m ³)	N/A			
Total Particulate Mass Emission (g/hour)	0.0002			

Client	Terex United Kingdom Limited						
Site Address	Coventry						
Job Number	P-RED12-135						
Date	23rd October 2012						
Operator(s)	E Berek & T Berek						
Stack Reference	Scisoor 2 Booth 1			Isokinetic Sample Positions (%) multiply by diameter to obtain sample points			
Number of Stacks	1			1	14.60		
Stack Configuration	Round			2	85.40		
Dimensions (mtrs)	0.60			3	N/A		
Outlet Diameter (if applicable) (metres)				4	N/A		
Number of Sample Ports	2			5	N/A		
Number of Samples per Axis / Port	2			6	N/A		
Nozzle Diameter (mm)	6.0			7	N/A		
Nozzle Area (m ²)	0.00002826			8	N/A		
Stack Area (m ²)	0.283			Average Isokinetic Flow Rate (ltrs/min)			
Pitot Coefficient	0.84			31/03/2013			
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test
No.	(cms)	(pa)	(C)	(°)	(pa)	(C)	(°)
1	8.76	133	30.1	6.8	149	30.1	6.7
2	51.24	186	30.1	6.8	170	30.1	6.7
3	N/A						
4	N/A						
5	N/A						
6	N/A						
7	N/A						
8	N/A						
Averages		150	30.1		160	30.1	
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2) + 273$				303.10			
Permitted Range of gas temperature readings (C) = $(0.95T_p - 273)$ to $(1.05T_p - 273)$				14.95 to 45.26			
Highest Velocity Reading (m/s)	=			14.8			
Lowest Velocity Reading (m/s)	=			12.7			
Ratio Highest/Lowest (Max permitted = 3:1)				1.17 : 1			
On site Checklist							
Initial Leak Check	End of first run			Start of 2 nd run		End of 2 nd run	
Acceptable Leak Check < 2% Vol (l/min)	0.46			Manometer Leak Check			
				Pitot Leak Check			
Range of Gas Temps	OK			Overall Isokinetic Ratio (%) (must be 95 to 115%)			
Passed minimum Velocity requirements (>5pa)	YES			Run 1			
Negative Local Flow Present, YES or NO (Yes = Fail)	NO			98.2			
Is the Platform area greater than 5m ² ? (YES, NO or N/A)	NO			#DIV/0!			
Passed Highest to lowest Velocity (3:1)	YES			Are there sufficient rails and kick board? (YES, NO or N/A)			
				Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)			
				YES			
Site Equipment Used							
Pitot Reference	RED 0290			Manometer Reference			
Thermometer Reference	RED 0351-RED 0352			Thermocouple Reference			
Balance Reference	N/A			Sampling Pump Reference			
Tape Measure Reference	RED 0123			Barometer Reference			
DGM Thermocouple	RED 0274			Impinger Outlet Thermocouple			
Calipers	RED 0300			Condenser Thermocouple			

Stack Reference ID		Scissor 2 Booth 1		
		Terex United Kingdom Limited		
		RUN 1		
Filter Reference No	G47-171012-11			
Date	23rd October 2012			
Sample Period	09:18	to	10:18	
Velocity (m/s)	13.47			
Volume flow rate of Stack gas (m ³ /hr)	13708			
Average Stack Temp (°C)	30.1			
Temp Range ± 5% (°C)	14.95	to	45.26	
Lowest Velocity Reading (m/s)	12.66			
Highest Velocity Reading (m/s)	14.77			
Ratio (less than 3:1)	1.17	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	30.1			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	20			
Carbon Dioxide %	0.10			
Moisture (%)	0.00			
Litres sampled	1363			
Corrected volume sampled - STP (m ³)	1.309			
Blank Filter Run weight gain (mg)	0.050	Blank Concentration (mg/m ³)	0.076	
Blank Wash Run weight gain (mg)	0.030		0.046	
Weighing uncertainty of balance (mg)	0.074	This must be <5% of ELV	ELV = 50	2.5
Overall Blank value (mg/m ³)	0.122	This must be <10% of ELV	ELV = 50	5.0
Particulate weight collected on filter (mg)	0.49			
Particulate weight collected in Wash (mg)	0.21			
Total Particulate weight collected (mg)	0.70			
Total Particulate Concentration, dry gas at STP (mg/m ³)	0.53			
Total Particulate Concentration, wet gas at STP (mg/m ³)	0.53			
Total Particulate Concentration corrected for 11% Oxygen, dry gas (mg/m ³)	N/A			
Total Particulate Mass Emission (g/hour)	0.01			

Client	Terex United Kingdom Limited								
Site Address	Coventry								
Job Number	P-RED12-135								
Date	23rd October 2012								
Operator(s)	E Berek & T Berek								
Stack Reference	Scissor 2 Booth 2				Isokinetic Sample Positions (%) multiply by diameter to obtain sample points				
				1	14.60				
Number of Stacks			1	2	85.40				
Stack Configuration			Round	3	N/A				
Dimensions (mtrs)			0.60	4	N/A				
Outlet Diameter (if applicable) (metres)				5	N/A				
Number of Sample Ports			2	6	N/A				
Number of Samples per Axis / Port			2	7	N/A				
Nozzle Diameter (mm)			6.0	8	N/A				
Nozzle Area (m ²)			0.00002826	Average Isokinetic Flow Rate (ltrs/min)			Axis 1	Axis 2	
Stack Area (m ²)			0.283				22.26	23.72	
Pitot Coefficient	0.84	Pitot Calibration Due Date			31/03/2013			Atmos. Pressure (kPa)	
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test	101.8	
No.	(cms)	(pa)	(C)	(°)	(pa)	(C)	(°)	Static Pressure (pa)	
1	8.76	122	31.1	6.8	172	31.1	6.7	44.0	
2	51.24	186	31.1	6.8	155	31.1	6.7	1 Axis	2 Axis
3	N/A							Velocity of flow (m/s)	
4	N/A							13.13	13.99
5	N/A							Volume Flow Rate (m ³ /s)	
6	N/A							3.71	3.95
7	N/A							Reduced Exit	
8	N/A								
Averages		144	31.1		164	31.1		N/A	
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2) + 273$							304.10		
Permitted Range of gas temperature readings (C) = $(0.95T_p - 273)$ to $(1.05T_p - 273)$							15.90	to 46.31	
Highest Velocity Reading (m/s)	=							14.9	
Lowest Velocity Reading (m/s)	=							12.1	
Ratio Highest/Lowest (Max permitted = 3:1)							1.22 : 1		
On site Checklist									
Initial Leak Check	<0.2	End of first run	<0.2		Start of 2 nd run		End of 2 nd run		
Acceptable Leak Check < 2% Vol (l/min)	0.45				Manometer Leak Check			OK	
					Pitot Leak Check			OK	
Range of Gas Temps	OK				Overall Isokinetic Ratio (%) (must be 95 to 115%)			Run 1	Run 2
Passed minimum Velocity requirements (>5pa)	YES							94.7	N/A
Negative Local Flow Present, YES or NO (Yes = Fail)	NO				Are there sufficient rails and kick board? (YES, NO or N/A)			NO	
Is the Platform area greater than 5m ² ? (YES, NO or N/A)	NO				Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)			YES	
Passed Highest to lowest Velocity (3:1)	YES								
Site Equipment Used									
Pitot Reference	RED 0290				Manometer Reference			RED 0393	
Thermometer Reference	RED 0351-RED 0352				Thermocouple Reference			RED 0362	
Balance Reference	N/A				Sampling Pump Reference			RED 0258	
Tape Measure Reference	RED 0123				Barometer Reference			RED 0094	
DGM Thermocouple	RED 0274				Impinger Outlet Thermocouple			N/A	
Calipers	RED 0300				Condenser Thermocouple			N/A	

Stack Reference ID		Scissor 2 Booth 2		
		Terex United Kingdom Limited		
		RUN 1		
Filter Reference No	G47-171012-13			
Date	23rd October 2012			
Sample Period	10:25	to	11:25	
Velocity (m/s)	13.13			
Volume flow rate of Stack gas (m ³ /hr)	13362			
Average Stack Temp (°C)	31.1			
Temp Range ± 5% (°C)	15.90	to	46.31	
Lowest Velocity Reading (m/s)	12.15			
Highest Velocity Reading (m/s)	14.88			
Ratio (less than 3:1)	1.22	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	31.1			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	10.4			
Carbon Dioxide %	5.60			
Moisture (%)	0.00			
Litres sampled	1323			
Corrected volume sampled - STP (m ³)	1.269			
Blank Filter Run weight gain (mg)	0.030	Blank Concentration (mg/m ³)	0.047	
Blank Wash Run weight gain (mg)	0.020		0.032	
Weighing uncertainty of balance (mg)	0.074	This must be <5% of ELV	ELV = 50	2.5
Overall Blank value (mg/m ³)	0.079	This must be <10% of ELV	ELV = 50	5.0
Particulate weight collected on filter (mg)	0.01			
Particulate weight collected in Wash (mg)	0.08			
Total Particulate weight collected (mg)	0.09			
Total Particulate Concentration, dry gas at STP (mg/m ³)	0.07			
Total Particulate Concentration, wet gas at STP (mg/m ³)	0.07			
Total Particulate Concentration corrected for 11% Oxygen, dry gas (mg/m ³)	N/A			
Total Particulate Mass Emission (g/hour)	0.001			

Client	Terex United Kingdom Limited							
Site Address	Coventry							
Job Number	P-RED12-135							
Date	23rd October 2012							
Operator(s)	E Berek & T Berek							
Stack Reference	Scissor 2 Oven			Isokinetic Sample Positions (%) multiply by diameter to obtain sample points		Sampling Plane Diagram		
Number of Stacks	1			1	50.00			
Stack Configuration	Round			2	N/A			
Dimensions (mtrs)	0.20			3	N/A			
Outlet Diameter (if applicable) (metres)				4	N/A			
Number of Sample Ports	2			5	N/A			
Number of Samples per Axis / Port	1			6	N/A			
Nozzle Diameter (mm)	8.0			7	N/A			
Nozzle Area (m ²)	0.00005024			8	N/A			
Stack Area (m ²)	0.031			Average Isokinetic Flow Rate (ltrs/min)		Axis 1	Axis 2	
Pitot Coefficient	0.84	Pitot Calibration Due Date			31/03/2013		18.48	N/A
Position	Distance	Axis 1	Temperature	Swirl Test	Axis 2	Temperature	Swirl Test	Atmos. Pressure (kPa)
No.	(cms)	(pa)	(C)	(°)	(pa)	(C)	(°)	101.8
1	10.00	26	88.0	6.2				Static Pressure (pa)
2	N/A							5.0
3	N/A							1 Axis
4	N/A							2 Axis
5	N/A							Velocity of flow (m/s)
6	N/A							6.13
7	N/A							N/A
8	N/A							Volume Flow Rate (m ³ /s)
								0.19
								N/A
								Reduced Exit
Averages		26	88.0					N/A
Mean Flue Gas Temp (in K) $T_p = ((\text{Mean } T_1 + \text{Mean } T_2)/2) + 273$								361.00
Permitted Range of gas temperature readings (C) = $(0.95T_p - 273)$ to $(1.05T_p - 273)$								69.95 to 106.05
Highest Velocity Reading (m/s)	=							6.3
Lowest Velocity Reading (m/s)	=							6.1
Ratio Highest/Lowest (Max permitted = 3:1)								1.03 : 1
On site Checklist								
Initial Leak Check	<0.2	End of first run	<0.2		Start of 2 nd run		End of 2 nd run	
Acceptable Leak Check < 2% Vol (l/min)	0.37				Manometer Leak Check		OK	
Range of Gas Temps	OK				Pitot Leak Check		OK	
Passed minimum Velocity requirements (>5pa)	YES				Overall Isokinetic Ratio (%) (must be 95 to 115%)		Run 1	Run 2
Negative Local Flow Present, YES or NO (Yes = Fail)	NO				Are there sufficient rails and kick board? (YES, NO or N/A)		95.6	N/A
Is the Platform area greater than 5m ² ? (YES, NO or N/A)	NO				Is the area in front of the sample line the length of the probe + 1 metre? (YES or NO)		YES	
Passed Highest to lowest Velocity (3:1)	YES							
Site Equipment Used								
Pitot Reference	RED 0290				Manometer Reference		RED 0393	
Thermometer Reference	RED 0351-RED 0352				Thermocouple Reference		RED 0362	
Balance Reference	N/A				Sampling Pump Reference		RED 0258	
Tape Measure Reference	RED 0123				Barometer Reference		RED 0094	
DGM Thermocouple	RED 0274				Impinger Outlet Thermocouple		N/A	
Calipers	RED 0300				Condenser Thermocouple		N/A	

Stack Reference ID		Scissor 2 Oven		
		Terex United Kingdom Limited		
		RUN 1		
Filter Reference No	G47-171012-15			
Date	23rd October 2012			
Sample Period	11:30	to	12:30	
Velocity (m/s)	6.13			
Volume flow rate of Stack gas (m ³ /hr)	693			
Average Stack Temp (°C)	88.0			
Temp Range ± 5% (°C)	69.95	to	106.05	
Lowest Velocity Reading (m/s)	6.11			
Highest Velocity Reading (m/s)	6.30			
Ratio (less than 3:1)	1.03	:	1	
Pre-conditioning temperature of Filter (°C)	180			
Instack sampling - Max Filter temperature (°C)	88.0			
Post-conditioning temperature Filter/Wash (°C)	160			
Oxygen %	20			
Carbon Dioxide %	0.10			
Moisture (%)	0.00			
Litres sampled	992			
Corrected volume sampled - STP (m ³)	0.951			
Blank Filter Run weight gain (mg)	0.000	Blank Concentration (mg/m ³)	0.000	
Blank Wash Run weight gain (mg)	0.020		0.021	
Weighing uncertainty of balance (mg)	0.074	This must be <5% of ELV	ELV = 50	2.5
Overall Blank value (mg/m ³)	0.021	This must be <10% of ELV	ELV = 50	5.0
Particulate weight collected on filter (mg)	0.01			
Particulate weight collected in Wash (mg)	0.10			
Total Particulate weight collected (mg)	0.11			
Total Particulate Concentration, dry gas at STP (mg/m ³)	0.11			
Total Particulate Concentration, wet gas at STP (mg/m ³)	0.11			
Total Particulate Concentration corrected for 11% Oxygen, dry gas (mg/m ³)	N/A			
Total Particulate Mass Emission (g/hour)	0.0001			

APPENDIX B

VOC Raw Data

Scissor 1 Booth 1 - VOC Monitoring					
Date	Time	VOC mg/m ³	Date	Time	VOC mg/m ³
23-Oct-12	09:20:00	19.61	23-Oct-12	10:09:00	19.61
23-Oct-12	09:21:00	18.96	23-Oct-12	10:10:00	18.96
23-Oct-12	09:22:00	18.32	23-Oct-12	10:11:00	19.61
23-Oct-12	09:23:00	20.89	23-Oct-12	10:12:00	18.96
23-Oct-12	09:24:00	20.89	23-Oct-12	10:13:00	18.96
23-Oct-12	09:25:00	20.25	23-Oct-12	10:14:00	18.96
23-Oct-12	09:26:00	18.96	23-Oct-12	10:15:00	18.96
23-Oct-12	09:27:00	18.32	23-Oct-12	10:16:00	18.96
23-Oct-12	09:28:00	20.25	23-Oct-12	10:17:00	19.61
23-Oct-12	09:29:00	16.39	23-Oct-12	10:18:00	20.25
23-Oct-12	09:30:00	17.68	23-Oct-12	10:19:00	19.61
23-Oct-12	09:31:00	18.96	23-Oct-12	10:20:00	19.61
23-Oct-12	09:32:00	17.68			
23-Oct-12	09:33:00	20.25			
23-Oct-12	09:34:00	17.68			
23-Oct-12	09:35:00	18.96			
23-Oct-12	09:36:00	18.32			
23-Oct-12	09:37:00	18.96			
23-Oct-12	09:38:00	18.32			
23-Oct-12	09:39:00	18.32			
23-Oct-12	09:40:00	18.96			
23-Oct-12	09:41:00	18.96			
23-Oct-12	09:42:00	20.89			
23-Oct-12	09:43:00	21.54			
23-Oct-12	09:44:00	20.89			
23-Oct-12	09:45:00	20.25			
23-Oct-12	09:46:00	20.25			
23-Oct-12	09:47:00	21.54			
23-Oct-12	09:48:00	20.25			
23-Oct-12	09:49:00	20.25			
23-Oct-12	09:50:00	20.89			
23-Oct-12	09:51:00	18.96			
23-Oct-12	09:52:00	19.61			
23-Oct-12	09:53:00	18.96			
23-Oct-12	09:54:00	19.61			
23-Oct-12	09:55:00	20.25			
23-Oct-12	09:56:00	19.61			
23-Oct-12	09:57:00	19.61			
23-Oct-12	09:58:00	19.61			
23-Oct-12	09:59:00	18.96			
23-Oct-12	10:00:00	18.96			
23-Oct-12	10:01:00	20.25			
23-Oct-12	10:02:00	20.89			
23-Oct-12	10:03:00	20.89			
23-Oct-12	10:04:00	21.54			
23-Oct-12	10:05:00	22.82			
23-Oct-12	10:06:00	21.54			
23-Oct-12	10:07:00	20.25			
23-Oct-12	10:08:00	20.25			
Average					19.59
The data represented in this table is expressed at 1 minute intervals but the data used in the chart is produced using 5 second intervals					


Scissor 1 Booth 2 - VOC Monitoring					
Date	Time	VOC mg/m ³	Date	Time	VOC mg/m ³
23-Oct-12	10:25:15	17.44	23-Oct-12	11:14:15	12.78
23-Oct-12	10:26:15	16.79	23-Oct-12	11:15:15	15.59
23-Oct-12	10:27:15	14.71	23-Oct-12	11:16:15	12.13
23-Oct-12	10:28:15	12.62	23-Oct-12	11:17:15	11.65
23-Oct-12	10:29:15	12.29	23-Oct-12	11:18:15	21.21
23-Oct-12	10:30:15	14.06	23-Oct-12	11:19:15	15.83
23-Oct-12	10:31:15	12.29	23-Oct-12	11:20:15	11.17
23-Oct-12	10:32:15	11.81	23-Oct-12	11:21:15	11.01
23-Oct-12	10:33:15	12.46	23-Oct-12	11:22:15	11.97
23-Oct-12	10:34:15	11.17	23-Oct-12	11:23:15	12.46
23-Oct-12	10:35:15	10.37	23-Oct-12	11:24:15	19.13
23-Oct-12	10:36:15	17.44	23-Oct-12	11:25:15	16.88
23-Oct-12	10:37:15	9.56			
23-Oct-12	10:38:15	9.24			
23-Oct-12	10:39:15	9.40			
23-Oct-12	10:40:15	8.92			
23-Oct-12	10:41:15	12.13			
23-Oct-12	10:42:15	12.94			
23-Oct-12	10:43:15	11.33			
23-Oct-12	10:44:15	11.01			
23-Oct-12	10:45:15	11.33			
23-Oct-12	10:46:15	12.29			
23-Oct-12	10:47:15	12.78			
23-Oct-12	10:48:15	10.85			
23-Oct-12	10:49:15	11.17			
23-Oct-12	10:50:15	16.63			
23-Oct-12	10:51:15	15.19			
23-Oct-12	10:52:15	15.83			
23-Oct-12	10:53:15	13.58			
23-Oct-12	10:54:15	12.62			
23-Oct-12	10:55:15	13.42			
23-Oct-12	10:56:15	16.15			
23-Oct-12	10:57:15	13.26			
23-Oct-12	10:58:15	18.88			
23-Oct-12	10:59:15	14.38			
23-Oct-12	11:00:15	13.02			
23-Oct-12	11:01:15	13.98			
23-Oct-12	11:02:15	22.82			
23-Oct-12	11:03:15	17.20			
23-Oct-12	11:04:15	13.42			
23-Oct-12	11:05:15	12.78			
23-Oct-12	11:06:15	16.39			
23-Oct-12	11:07:15	16.23			
23-Oct-12	11:08:15	13.90			
23-Oct-12	11:09:15	12.29			
23-Oct-12	11:10:15	11.49			
23-Oct-12	11:11:15	10.37			
23-Oct-12	11:12:15	9.80			
23-Oct-12	11:13:15	9.56			
			Average		13.41
The data represented in this table is expressed at 1 minute intervals but the data used in the chart is produced using 5 second intervals					

Scissor 2 Booth 1 - VOC Monitoring					
Date	Time	VOC mg/m ³	Date	Time	VOC mg/m ³
23-Oct-12	09:15:15	21.86	23-Oct-12	10:04:15	21.97
23-Oct-12	09:16:15	21.64	23-Oct-12	10:05:15	22.18
23-Oct-12	09:17:15	21.75	23-Oct-12	10:06:15	21.86
23-Oct-12	09:18:15	21.86	23-Oct-12	10:07:15	21.54
23-Oct-12	09:19:15	21.43	23-Oct-12	10:08:15	21.86
23-Oct-12	09:20:15	21.43	23-Oct-12	10:09:15	21.64
23-Oct-12	09:21:15	21.64	23-Oct-12	10:10:15	21.86
23-Oct-12	09:22:15	21.64	23-Oct-12	10:11:15	21.43
23-Oct-12	09:23:15	21.86	23-Oct-12	10:12:15	21.64
23-Oct-12	09:24:15	21.43	23-Oct-12	10:13:15	21.43
23-Oct-12	09:25:15	21.75	23-Oct-12	10:14:15	21.75
23-Oct-12	09:26:15	21.75			
23-Oct-12	09:27:15	21.64			
23-Oct-12	09:28:15	21.43			
23-Oct-12	09:29:15	21.54			
23-Oct-12	09:30:15	21.32			
23-Oct-12	09:31:15	20.85			
23-Oct-12	09:32:15	16.26			
23-Oct-12	09:33:15	19.06			
23-Oct-12	09:34:15	20.57			
23-Oct-12	09:35:15	21.97			
23-Oct-12	09:36:15	22.29			
23-Oct-12	09:37:15	22.29			
23-Oct-12	09:38:15	22.18			
23-Oct-12	09:39:15	22.29			
23-Oct-12	09:40:15	21.32			
23-Oct-12	09:41:15	21.43			
23-Oct-12	09:42:15	21.43			
23-Oct-12	09:43:15	21.64			
23-Oct-12	09:44:15	21.43			
23-Oct-12	09:45:15	21.32			
23-Oct-12	09:46:15	21.21			
23-Oct-12	09:47:15	21.32			
23-Oct-12	09:48:15	21.21			
23-Oct-12	09:49:15	21.00			
23-Oct-12	09:50:15	21.00			
23-Oct-12	09:51:15	20.78			
23-Oct-12	09:52:15	22.07			
23-Oct-12	09:53:15	21.32			
23-Oct-12	09:54:15	21.86			
23-Oct-12	09:55:15	20.78			
23-Oct-12	09:56:15	20.78			
23-Oct-12	09:57:15	21.21			
23-Oct-12	09:58:15	21.21			
23-Oct-12	09:59:15	21.32			
23-Oct-12	10:00:15	21.43			
23-Oct-12	10:01:15	21.75			
23-Oct-12	10:02:15	21.75			
23-Oct-12	10:03:15	21.86			
				Average	21.46
The data represented in this table is expressed at 1 minute intervals but the data used in the chart is produced using 5 second intervals					


Scissor 2 Booth 2 - VOC Monitoring					
Date	Time	VOC mg/m ³	Date	Time	VOC mg/m ³
23-Oct-12	10:30:20	12.25	23-Oct-12	11:19:20	13.63
23-Oct-12	10:31:20	12.25	23-Oct-12	11:20:20	13.63
23-Oct-12	10:32:20	12.06	23-Oct-12	11:21:20	13.23
23-Oct-12	10:33:20	12.06	23-Oct-12	11:22:20	13.43
23-Oct-12	10:34:20	12.45	23-Oct-12	11:23:20	13.23
23-Oct-12	10:35:20	13.04	23-Oct-12	11:24:20	13.23
23-Oct-12	10:36:20	12.84	23-Oct-12	11:25:20	13.23
23-Oct-12	10:37:20	12.84	23-Oct-12	11:26:20	12.06
23-Oct-12	10:38:20	12.84	23-Oct-12	11:27:20	12.65
23-Oct-12	10:39:20	12.65	23-Oct-12	11:28:20	12.45
23-Oct-12	10:40:20	12.45	23-Oct-12	11:29:20	12.25
23-Oct-12	10:41:20	13.04	23-Oct-12	11:30:20	12.25
23-Oct-12	10:42:20	13.23			
23-Oct-12	10:43:20	13.23			
23-Oct-12	10:44:20	13.23			
23-Oct-12	10:45:20	13.04			
23-Oct-12	10:46:20	13.04			
23-Oct-12	10:47:20	13.04			
23-Oct-12	10:48:20	12.45			
23-Oct-12	10:49:20	12.45			
23-Oct-12	10:50:20	12.65			
23-Oct-12	10:51:20	12.65			
23-Oct-12	10:52:20	12.65			
23-Oct-12	10:53:20	12.84			
23-Oct-12	10:54:20	12.65			
23-Oct-12	10:55:20	12.45			
23-Oct-12	10:56:20	13.04			
23-Oct-12	10:57:20	13.23			
23-Oct-12	10:58:20	13.43			
23-Oct-12	10:59:20	13.63			
23-Oct-12	11:00:20	13.82			
23-Oct-12	11:01:20	13.23			
23-Oct-12	11:02:20	13.43			
23-Oct-12	11:03:20	13.82			
23-Oct-12	11:04:20	14.41			
23-Oct-12	11:05:20	14.80			
23-Oct-12	11:06:20	15.20			
23-Oct-12	11:07:20	14.61			
23-Oct-12	11:08:20	9.90			
23-Oct-12	11:09:20	14.80			
23-Oct-12	11:10:20	14.80			
23-Oct-12	11:11:20	14.61			
23-Oct-12	11:12:20	14.02			
23-Oct-12	11:13:20	14.02			
23-Oct-12	11:14:20	14.22			
23-Oct-12	11:15:20	14.22			
23-Oct-12	11:16:20	13.82			
23-Oct-12	11:17:20	13.63			
23-Oct-12	11:18:20	14.02			
Average					13.16
The data represented in this table is expressed at 1 minute intervals but the data used in the chart is produced using 5 second intervals					

APPENDIX C


VOC Charts




Average Run Time			Volatile Organic Compound (ppm)			Volatile Organic Compound (mg/m³)		
			Mean	Max	Min	Mean	Max	Min
9:20	to	9:50	12.02	13.80	8.60	19.32	22.18	13.82
9:50	to	10:20	12.37	14.20	10.60	19.87	22.82	17.04



Average Run Time			Volatile Organic Compound (ppm)			Volatile Organic Compound (mg/m³)		
			Mean	Max	Min	Mean	Max	Min
10:25	to	10:55	7.89	13.25	5.45	12.68	21.29	8.76
10:55	to	11:25	8.80	14.20	4.95	14.15	22.82	7.96



Average Run Time			Volatile Organic Compound (ppm)			Volatile Organic Compound (mg/m³)		
			Mean	Max	Min	Mean	Max	Min
9:15	to	9:45	13.33	14.85	10.12	21.43	23.86	16.26
9:45	to	10:15	13.36	13.94	12.93	21.48	22.40	20.78



Average Run Time			Volatile Organic Compound (ppm)			Volatile Organic Compound (mg/m ³)		
			Mean	Max	Min	Mean	Max	Min
10:30	to	11:00	7.96	8.72	5.92	12.79	14.02	9.51
11:00	to	11:30	8.43	9.46	5.55	13.55	15.20	8.92

APPENDIX D

Isocyanate Results

Stack Reference ID		Topcoat Spray Booth 1 (ISOCYANATE)		
		Terex United Kingdom Limited		
		RUN 1		
Filter Reference No	12/135/65			
Date	24th October 2012			
Sample Period	10:00	to	11:00	
Velocity (m/s)	7.39			
Volumetric flowrate of Stack gas (m ³ /hr)	53483			
Average Stack Temp (°C)	19.1			
Temperature Range - ± 5% (°C)	4.50	to	33.71	
Lowest Velocity Reading (m/s)	6.82			
Highest Velocity Reading (m/s)	9.03			
Ratio (less than 3:1)	1.32	:	1	
Oxygen %	11.4			
Carbon Dioxide %	5.60			
Moisture (%)	0.00			
Litres sampled	1197			
Corrected volume sampled - STP (m ³)	1.155			
MDI collected on filter (ug)	<0.07			
MDI collected on filter - Blank (ug)	<0.07			
MDI Concentration, ^ STP, dry gas (mg/m ³)	<0.001			
MDI Concentration, ^ STP, wet gas (mg/m ³)	<0.001			
Total MDI Mass Emission (g/hour)	<0.004			

Stack Reference ID		Topcoat Spray Booth 2 (ISOCYANATE)		
		Terex United Kingdom Limited		
		RUN 1		
Filter Reference No	12/135/65			
Date	24th October 2012			
Sample Period	11:05	to	12:05	
Velocity (m/s)	6.80			
Volumetric flowrate of Stack gas (m ³ /hr)	49207			
Average Stack Temp (°C)	18.8			
Temperature Range - ± 5% (°C)	4.21	to	33.39	
Lowest Velocity Reading (m/s)	6.00			
Highest Velocity Reading (m/s)	7.78			
Ratio (less than 3:1)	1.30	:	1	
Oxygen %	11.4			
Carbon Dioxide %	5.60			
Moisture (%)	0.00			
Litres sampled	982			
Corrected volume sampled - STP (m ³)	0.947			
MDI collected on filter (ug)	<0.07			
MDI collected on filter - Blank (ug)	<0.07			
MDI Concentration, ^ STP, dry gas (mg/m ³)	<0.001			
MDI Concentration, ^ STP, wet gas (mg/m ³)	<0.001			
Total MDI Mass Emission (g/hour)	<0.004			

Stack Reference ID	Topcoat Flash off (ISOCYANATE)		
	Terex United Kingdom Limited		
	RUN 1		
Filter Reference No	12/135/66		
Date	24th October 2012		
Sample Period	12:10	to	13:10
Velocity (m/s)	14.40		
Volumetric flowrate of Stack gas (m ³ /hr)	32974		
Average Stack Temp (°C)	56.0		
Temperature Range - ± 5% (°C)	39.55	to	72.45
Lowest Velocity Reading (m/s)	14.24		
Highest Velocity Reading (m/s)	15.43		
Ratio (less than 3:1)	1.08	:	1
Oxygen %	20.0		
Carbon Dioxide %	0.20		
Moisture (%)	0.00		
Litres sampled	1203		
Corrected volume sampled - STP (m ³)	1.159		
MDI collected on filter (ug)	<0.07		
MDI collected on filter - Blank (ug)	<0.07		
MDI Concentration, ^STP, dry gas (mg/m ³)	<0.001		
MDI Concentration, ^STP, wet gas (mg/m ³)	<0.001		
Total MDI Mass Emission (g/hour)	<0.004		

Stack Reference ID	Topcoat Curing Oven (ISOCYANATE)		
	Terex United Kingdom Limited		
	RUN 1		
Filter Reference No	12/135/63		
Date	24th October 2012		
Sample Period	08:55	to	09:55
Velocity (m/s)	12.23		
Volumetric flowrate of Stack gas (m ³ /hr)	34581		
Average Stack Temp (°C)	37.3		
Temperature Range - ± 5% (°C)	21.79	to	52.82
Lowest Velocity Reading (m/s)	10.06		
Highest Velocity Reading (m/s)	13.06		
Ratio (less than 3:1)	1.30	:	1
Oxygen %	20.0		
Carbon Dioxide %	0.20		
Moisture (%)	0.00		
Litres sampled	1051		
Corrected volume sampled - STP (m ³)	1.015		
MDI collected on filter (ug)	<0.07		
MDI collected on filter - Blank (ug)	<0.07		
MDI Concentration, ^STP, dry gas (mg/m ³)	<0.001		
MDI Concentration, ^STP, wet gas (mg/m ³)	<0.001		
Total MDI Mass Emission (g/hour)	<0.004		

Stack Reference ID		Spray Bake No 1 (ISOCYANATE)		
		Terex United Kingdom Limited		
		RUN 1		
Filter Reference No	12/135/61			
Date	23rd October 2012			
Sample Period	08:10	to	09:10	
Velocity (m/s)	14.14			
Volumetric flowrate of Stack gas (m ³ /hr)	25586			
Average Stack Temp (°C)	28.1			
Temperature Range - ± 5% (°C)	13.00	to	43.10	
Lowest Velocity Reading (m/s)	13.62			
Highest Velocity Reading (m/s)	15.18			
Ratio (less than 3:1)	1.11	:	1	
Oxygen %	20.0			
Carbon Dioxide %	0.20			
Moisture (%)	0.00			
Litres sampled	1356			
Corrected volume sampled - STP (m ³)	1.311			
MDI collected on filter (ug)	<0.07			
MDI collected on filter - Blank (ug)	<0.07			
MDI Concentration, *STP, dry gas (mg/m ³)	<0.001			
MDI Concentration, *STP, wet gas (mg/m ³)	<0.001			
Total MDI Mass Emission (g/hour)	<0.004			

Stack Reference ID		Spray Bake No 2 (ISOCYANATE)		
		Terex United Kingdom Limited		
		RUN 1		
Filter Reference No	12/135/62			
Date	23rd October 2012			
Sample Period	08:05	to	09:05	
Velocity (m/s)	15.14			
Volumetric flowrate of Stack gas (m ³ /hr)	27392			
Average Stack Temp (°C)	30.1			
Temperature Range - ± 5% (°C)	14.90	to	45.20	
Lowest Velocity Reading (m/s)	12.66			
Highest Velocity Reading (m/s)	15.61			
Ratio (less than 3:1)	1.23	:	1	
Oxygen %	20.0			
Carbon Dioxide %	0.20			
Moisture (%)	0.00			
Litres sampled	1469			
Corrected volume sampled - STP (m ³)	1.417			
MDI collected on filter (ug)	<0.07			
MDI collected on filter - Blank (ug)	<0.07			
MDI Concentration, *STP, dry gas (mg/m ³)	<0.001			
MDI Concentration, *STP, wet gas (mg/m ³)	<0.001			
Total MDI Mass Emission (g/hour)	<0.004			