



Coventry City Council

PPC Permit ref: PPC/164
Variation ref: PPC/164/1

Coventry City Council
The Pollution Prevention and Control (England and Wales) Regulations 2000 Regulation 17

VARIATION NOTICE

To: **Tesco Stores Ltd**
Tesco House
Delamare Road
Chesunt
Hertfordshire EN8 9SL

Coventry City Council ("the Council"), in the exercise of the powers conferred upon it by regulation 17 of the Pollution Prevention and Control (England and Wales) Regulations 2000¹ ("the 2000 Regulations") hereby gives you a notice as follows-

The Council has decided to vary the conditions of permit reference PPC/164 granted under regulation 9(1) of the 2000 Regulations in respect of the operation of the installation/mobile plant at:

Tesco Stores Ltd
Filling Station
Phoenix Way
Coventry Arena
Coventry

The variation of the conditions of the permit and date on which they are to take effect are specified in Schedule 1 to this notice. A consolidated permit as varied by this notice is set out in Schedule 2.

Signed on behalf of Coventry City Council

[Redacted signature]

Date..... 21/3/05

Philip Parkes, Principal Environmental Health Officer

An authorised officer of the Council

¹ S.I 2000 No. 1973 to which there are amendments not relevant to this suspension notice.

Schedule 1

Variations to the permit	Date(s) on which the variation Is to take place
<p>1. PPC/164 Page 1 reads 'to operate a Part B installation involving a coating activity as prescribed in Section 6.4 Part B of Schedule 1 of the Regulations'</p> <p>Variation: To operate a Part B installation, unloading petrol into stationary storage tanks, as prescribed in Part B of Section 1.2 of the Regulations</p>	<p>Immediate</p>
<p>2. PPC/164 page 2 reads 'Permit checked by Rachel King'</p> <p>Variation: Permit checked by Philip Parkes</p>	<p>Immediate</p>
<p>3. PPC/164 Condition 1.13 reads 'Adjacent to each vapour return connection point for the storage tank, there shall be a clearly legible and durable notice instructing 'Connect vapour return line before off loading' or similar wording. The sign shall also refer to the maximum number of tanker compartments which may be unloaded simultaneously in accordance with Condition 8'</p> <p>Variation: Adjacent to each vapour return connection point for the storage tank, there shall be a clearly legible and durable notice instructing 'Connect vapour return line before off loading' or similar wording. The sign shall also refer to the maximum number of tanker compartments which may be unloaded simultaneously in accordance with Condition 1.8</p>	<p>Immediate</p>
<p>4. PPC/164 Condition 1.16 reads 'A competent person shall remain near the tanker and keep a constant watch on hoses and connections during unloading. (A competent person is one who has received training in accordance with Clauses 13 and 35 of the Secretary of State's Guidance Note PG1/14(96))</p> <p>Variation: A competent person shall remain near the tanker and keep a constant watch on hoses and connections during unloading. (A competent person is one who has received training in accordance with Clauses 13 and 35 of the Secretary of State's Guidance Note PG1/14(04))</p>	<p>Immediate</p>

Signed on behalf of Coventry City Council

.....
.....

Philip Parkes, Principal Environmental Health Officer

Date..... 21/3/05