



STACK EMISSIONS MEASUREMENTS


WHS Halo (Bowater Doors)

Courtaulds Way, Coventry

Polyfill machine extraction system

**Carried out on
12th April 2011**

Report written by:



Steve Lockwood
Senior Consultant

4th May 2011

Report checked by:



Steve Cletheroe
Senior Site Engineer

4th May 2011



ENVIRONMENT
AGENCY



The personnel carrying out the monitoring work for this exercise are qualified under the MCERTS scheme as follows:

1. Steve Lockwood

Senior Consultant

MCERTS Registration No MM 03 407

Level 2 (team leader)

Technical Endorsements held:

TE1 (Particulate monitoring by isokinetic sampling techniques)

TE4 (Gases / Vapours by instrumental techniques)

Certificate Number: Sira MP 04 217

Date of certification: 12 October 2004

Date of re-certification: 28 September 2009

Renewal date: 12 October 2014

2. Steve Cletheroe

Senior Site Engineer

MCERTS Registration No MM 03 408

Level 1 (technician)

Technical Endorsements held:

TE1 (Particulate monitoring by isokinetic sampling techniques)

Certificate Number: Sira MP 04 226

Date of certification: 12 October 2004

Date of re-certification: 28 September 2009

Renewal date: 12 October 2014

The MCERTS scheme is operated by SIRA Certification Service on behalf of the Environment Agency.

The scheme involves written examinations and interviews and was introduced to ensure that stack monitoring work is carried out to the required standards by suitably qualified personnel.

CONTENTS OF REPORT

- 1 Introduction
- 2 Summary of results
- 3 Emission limits and comments on results

Sampling data

- 4 Isocyanates

Test methods

- 5 Isocyanates

1.0 Introduction

1.1 This exercise consisted of the following test carried out on the Polyfill Machine extraction system.

(a) Measurement of isocyanate emissions using MDHS 25 method.

1.3 The tests were carried out in order to comply with the Permit issued by the Local Authority under the Environmental Protection Act. This report describes the methods used and the test results found.

2.0 Summary of results

2.1 The monitoring exercise returned the following result:

Polyfill Machine	Result	Units
Isocyanates	< 0.0033	mg/m ³

The result is expressed corrected to the following reference conditions :-

273 °K, 101.3 Kpa

3.0 Emission limits and comments on results

3.1 The test result in the table above may be directly compared with any emission limit which the local authority may have set.

3.2 We have not been advised of the emission limit and so cannot offer any comment on the result.

4.0 AIR SAMPLE DATA

Area	Polyfill Machine	Date	12th April 2011
------	------------------	------	-----------------

No	Subject	Area	Time ON	Time OFF	Period minutes	Start flow	End flow	Volume litres	Filter Ref	Analyte	µg in sample	Result mg/m ³
1	Exhaust Stack Emissions	Polyfill Machine	10:32	11:32	60	1.0	1.0	60	WHS 120401	Isocyanates	< 0.2	< 0.0033

Breaks

The sample ran continuously.

Sample description

This was a sample of the air exhausted to the external atmosphere from the Polyfill Machine extraction system. The sample was taken using method MDHS 25, using a combination of an absorbing solution in series with a treated filter. Normal filling activities took place throughout. The machine injects an expanding foam into the interior section of the door. There is a setting up period of around 10 - 15 minutes, followed by a filling and curing period of 16 minutes, therefore an approx. 30 minute cycle. This exercise covered two complete cycles.

Comments

A "less than" figure (shown as < 0.2 in the above table) is quoted when the laboratory are unable to find any isocyanate on the sample. The value quoted shows the minimum concentration which could be detected by the method used. This is dependent on the duration of the sample and the detection limit of the analysis method used by the laboratory. Although no isocyanate was detected on the sample, it is not possible to state that the airborne concentration was zero, but simply that it must be less than the minimum detectable level quoted.

5.0 Monitoring method - Isocyanates

- 5.1 The test method used for this exercise was as described in HSE document MDHS 25. This specifies two options, one which uses a pre-treated filter to absorb the isocyanates, and one which uses an absorbing solution. The pre-treated filter method will absorb isocyanates in both the vapour and particulate phases; however, the efficiency of capture of the particulate phase isocyanate is reduced in cases where very small particles are likely to be present. The absorbing solution is efficient for particulates of all sizes, but is less efficient at capturing the vapour phase isocyanates. If both vapour and particulate phases are present, with the possibility of small size particles being present, then a combination of the filter and solution can be used.
- 5.2 It was decided that the combination of filter and solution should be used for this test.
- 5.3 An SKC sample pump calibrated to run at 1.0 litres per minute is used to draw a sample of air from the exhaust duct. This air is bubbled through the absorbing solution and then passed through the pre-treated absorbing filter. At the end of the test the solution and the filter are placed together in a sample bottle and submitted to an approved laboratory for analysis. The result obtained is therefore the total of all particulate and vapour phase isocyanates
- 5.4 The result quoted shows the overall emission level averaged over the sampling period, which in this case was one hour, covering two complete cycles of the machine.

R.W. VESEY LTD.

DUST CONTROL AND VENTILATION SPECIALISTS
DESIGNERS – CONSULTANTS – CONTRACTORS – EXAMINERS

734, MELTON ROAD, THURMASTON, LEICESTER. LE4 8BD
TEL: 01162 696241 FAX: 01162 696243
EMAIL: info@vesey-airflow.com WEB: www.vesey-airflow.com
REG. No. 2793681



4th May 2011

Our ref: 0411/VOC/JS

Bowater Doors
Water Orton Lane,
Sutton Coldfield,
West Midlands,
B76 9BW.

For the attention of: **Mrs C. Venthen**

Dear Madam,

RE: **THE PRIME CONNECTION - DI-ISOCYANATE SAMPLING**

We thank you for the courtesy extended to our technician during the recent visit to the Prime Connection site on the 12th April 2011 in order to carry out V.O.C sampling on the exhaust stack.

Please find enclosed the exhaust stack sample certificate detailing the result of the V.O.C test that was carried out. This has been tested using the MDHS 25 method.

POLYFILL MACHINE EXTRACTION SYSTEM

V.O.C Isocyanate: <0.0033 mg/m³

We trust that you will find the enclosed certificate comprehensive and satisfactory for your requirements. Should you have any queries, please do not hesitate to contact us.

Yours faithfully,

Julie Stockdale