

Report for Periodic Monitoring of Emissions to Atmosphere

Part 1: **Executive Summary**

Permit Number: **PPC/067 Var Ref: 002**

Operator: **Covrad Heat Transfer Ltd**

Installation: **Coventry**

Emission Points: **Assembly Shop Booth (LH),
Assembly Shop Booth (Mid), Assembly Shop Booth (RH),
Industrial Spray Booth 1 (RH), Industrial Spray Booth 1 (LH),
Industrial Spray Booth 2 (LH) & Industrial Spray Booth 2 (RH)**

Monitoring Dates: **12th - 17th January 2011**

Contract Reference: FTBS14741

Operator: Covrad Heat Transfer Ltd

Address: Sir Henry Parks Road
Canley
Coventry
CV5 6BN

Monitoring Organisation: RPS Consultants Ltd.

Address: Grafton Building, Caswell Science &
Technology Park, Caswell,
Towcester, Northamptonshire, NN12 8EQ.

Report Date: 07 February 2011

Report Approved By: Martin Johnson

Position: Senior Environmental Consultant

MCERTS Registration Number: MM 03 168

Signature:



RPS Consultants Ltd. has produced this report within the term of the contract with the client and taking account of the resources devoted to it by agreement with the client.

We disclaim any responsibility to the client and others in respect of any matters outside the scope of the above. This report is confidential to the client and we accept no responsibility of whatsoever nature to third parties to whom this report, or any part thereof, is made known. Any such party relies on the report at their own risk.

CONTENTS

Part 1: Executive Summary

Section 1 – Monitoring Objectives

Section 2 – Monitoring Results

Section 3 – Operating Information

Section 4 – Monitoring Deviations

Part 2: Supporting Information

Appendix 1 – Staff & Methodology Details

Appendix 2- Assembly Shop Booth (LH) Sampling, Analysis & Uncertainty Data

Appendix 3- Assembly Shop Booth (Mid) Sampling, Analysis & Uncertainty Data

Appendix 4- Assembly Shop Booth (RH) Sampling, Analysis & Uncertainty Data

Appendix 5- Industrial Spray Booth 1 (RH) Sampling, Analysis & Uncertainty Data

Appendix 6- Industrial Spray Booth 1 (LH) Sampling, Analysis & Uncertainty Data

Appendix 7- Industrial Spray Booth 2 (LH) Sampling, Analysis & Uncertainty Data

Appendix 8- Industrial Spray Booth 2 (RH) Sampling, Analysis & Uncertainty Data

Monitoring Objectives

At the request of Bob Holmes of Covrad Heat Transfer Ltd, RPS Consultants Ltd. conducted stack emission monitoring at the Coventry site in January 2011.

The monitoring programme at this installation was carried out to provide data on emissions to atmosphere for comparison with the limits specified in the air emission criteria for this site.

The following tables detail the parameters requested for monitoring at each emission point and the actual monitoring conducted.

Table 1.1

Parameters Requested to be Monitored	Emission Point
	Assembly Shop Booth (LH)
Total Particulate Matter	✓
Specific Requirements	Normal

Notes:

✓ Represents pollutants sampled

Table 1.2

Parameters Requested to be Monitored	Emission Point
	Assembly Shop Booth (Mid)
Total Particulate Matter	✓
Specific Requirements	Normal

Notes:

✓ Represents pollutants sampled

Table 1.3

Parameters Requested to be Monitored	Emission Point
	Assembly Shop Booth (RH)
Total Particulate Matter	✓
Specific Requirements	Normal

Notes:

✓ Represents pollutants sampled

Table 1.4

Parameters Requested to be Monitored	Emission Point
	Industrial Spray Booth 1 (RH)
Total Particulate Matter	✓
Specific Requirements	Normal

Notes:

✓ Represents pollutants sampled

Table 1.5

Parameters Requested to be Monitored	Emission Point
	Industrial Spray Booth 1 (LH)
Total Particulate Matter	✓
Specific Requirements	Normal

Notes:

✓ Represents pollutants sampled

Table 1.6

Parameters Requested to be Monitored	Emission Point
	Industrial Spray Booth 2 (LH)
Total Particulate Matter	✓
Specific Requirements	Normal

Notes:

✓ Represents pollutants sampled

Table 1.7

Parameters Requested to be Monitored	Emission Point
	Industrial Spray Booth 2 (RH)
Total Particulate Matter	✓
Specific Requirements	Normal

Notes:

✓ Represents pollutants sampled

Monitoring Results

Table 2.1 Monitoring results for emission point Assembly Shop Booth (LH), Carried out on 12/01/2011

Substance Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty (Expressed expanded k=2)	Reference Conditions 273K, 101.3kPa	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter	50	1.5	mg/m ³	0.20	273K, 101.3kPa, Wet	12/01/2011	11:29 - 12:31	BS EN 13284-1:2002	MCERTS	Normal

Table 2.2 Monitoring results for emission point Assembly Shop Booth (Mid), Carried out on 12/01/2011

Substance Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty (Expressed expanded k=2)	Reference Conditions 273K, 101.3kPa	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter	50	1.4	mg/m ³	0.19	273K, 101.3kPa, Wet	12/01/2011	13:41 - 14:43	BS EN 13284-1:2002	MCERTS	Normal

Table 2.3 Monitoring results for emission point Assembly Shop Booth (RH), Carried out on 13/01/2011

Substance Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty (Expressed expanded k=2)	Reference Conditions 273K, 101.3kPa	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter	50	3.4	mg/m ³	0.22	273K, 101.3kPa, Wet	13/01/2011	10:24 - 11:26	BS EN 13284-1:2002	MCERTS	Normal

Table 2.4 Monitoring results for emission point Industrial Spray Booth 1 (RH), Carried out on 14/01/2011

Substance Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty (Expressed expanded k=2)	Reference Conditions 273K, 101.3kPa	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter	50	6.3	mg/m ³	0.29	273K, 101.3kPa, Wet	14/01/2011	14:15 - 15:17	BS EN 13284-1:2002	MCERTS	Normal

Table 2.5 Monitoring results for emission point Industrial Spray Booth 1 (LH), Carried out on 14/01/2011

Substance Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty (Expressed expanded k=2)	Reference Conditions 273K, 101.3kPa	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter	50	2.0	mg/m ³	0.20	273K, 101.3kPa, Wet	14/01/2011	10:17 - 11:19	BS EN 13284-1:2002	MCERTS	Normal

Table 2.6 Monitoring results for emission point Industrial Spray Booth 2 (LH), Carried out on 17/01/2011

Substance Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty (Expressed expanded k=2)	Reference Conditions 273K, 101.3kPa	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter	50	2.8	mg/m ³	0.25	273K, 101.3kPa, Wet	17/01/2011	13:34 - 14:36	BS EN 13284-1:2002	MCERTS	Normal

Table 2.7 Monitoring results for emission point Industrial Spray Booth 2 (RH), Carried out on 17/01/2011

Substance Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty (Expressed expanded k=2)	Reference Conditions 273K, 101.3kPa	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter	50	2.2	mg/m ³	0.23	273K, 101.3kPa, Wet	17/01/2011	11:55 - 12:57	BS EN 13284-1:2002	MCERTS	Normal

Operating Information

Table 3.1 Operating conditions during the monitoring of emission point Assembly Shop Booth (LH) carried out on 12/01/2011

Parameter	Result
Sample Date	12/01/2011
Process Type	Batch
Process Duration	1 Hour
If 'Batch', was monitoring carried out over the whole batch?	No
Abatement/Operational?	Operational
Item Sprayed	1.5 Radiators

Comparison of Operator CEM and Periodic Monitoring Results		
Substance	CEMs Results (mg/m ³)	Periodic Monitoring Results (mg/m ³)
No CEMS Installed/Data Available		

Table 3.2 Operating conditions during the monitoring of emission point Assembly Shop Booth (Mid) carried out on 12/01/2011

Parameter	Result
Sample Date	12/01/2011
Process Type	Batch
Process Duration	1 Hour
If 'Batch', was monitoring carried out over the whole batch?	No
Abatement/Operational?	Operational
Item Sprayed	4 Radiator Parts

Comparison of Operator CEM and Periodic Monitoring Results		
Substance	CEMs Results (mg/m ³)	Periodic Monitoring Results (mg/m ³)
No CEMS Installed/Data Available		

Table 3.3 Operating conditions during the monitoring of emission point Assembly Shop Booth (RH) carried out on 13/01/2011

Parameter	Result
Sample Date	13/01/2011
Process Type	Batch
Process Duration	1 Hour
If 'Batch', was monitoring carried out over the whole batch?	No
Abatement/Operational?	Operational
Item Sprayed	3 Radiators Sprayed

Comparison of Operator CEM and Periodic Monitoring Results		
Substance	CEMs Results (mg/m ³)	Periodic Monitoring Results (mg/m ³)
No CEMS Installed/Data Available		

Table 3.4 Operating conditions during the monitoring of emission point Industrial Spray Booth 1 (RH) carried out on 14/01/2011

Parameter	Result
Sample Date	14/01/2011
Process Type	Batch
Process Duration	1 Hour
If 'Batch', was monitoring carried out over the whole batch?	No
Abatement/Operational?	Operational
Item Sprayed	1 x Radiator, 3 x Coolers

Comparison of Operator CEM and Periodic Monitoring Results		
Substance	CEMs Results (mg/m ³)	Periodic Monitoring Results (mg/m ³)
No CEMS Installed/Data Available		

Table 3.5 Operating conditions during the monitoring of emission point Industrial Spray Booth 1 (LH) carried out on 14/01/2011

Parameter	Result
Sample Date	14/01/2011
Process Type	Batch
Process Duration	1 Hour
If 'Batch', was monitoring carried out over the whole batch?	No
Abatement/Operational?	Operational
Item Sprayed	7 x Small Coolers

Comparison of Operator CEM and Periodic Monitoring Results		
Substance	CEMs Results (mg/m ³)	Periodic Monitoring Results (mg/m ³)
No CEMS Installed/Data Available		

Table 3.6 Operating conditions during the monitoring of emission point Industrial Spray Booth 2 (LH) carried out on 17/01/2011

Parameter	Result
Sample Date	17/01/2011
Process Type	Batch
Process Duration	1 Hour
If 'Batch', was monitoring carried out over the whole batch?	Yes
Abatement/Operational?	Operational
Items Sprayed	3 Radiators

Comparison of Operator CEM and Periodic Monitoring Results		
Substance	CEMs Results (mg/m ³)	Periodic Monitoring Results (mg/m ³)
No CEMS Installed/Data Available		

Table 3.7 Operating conditions during the monitoring of emission point Industrial Spray Booth 2 (RH) carried out on 17/01/2011

Parameter	Result
Sample Date	17/01/2011
Process Type	Batch
Process Duration	1 Hour
If 'Batch', was monitoring carried out over the whole batch?	No
Abatement/Operational?	Not Installed
Item Sprayed	4 x Small Coolers & 1 Radiator

Comparison of Operator CEM and Periodic Monitoring Results		
Substance	CEMs Results (mg/m ³)	Periodic Monitoring Results (mg/m ³)
No CEMS Installed/Data Available		

Monitoring Deviations

Table 4.1 Monitoring Deviations for Emission Point Assembly Shop Booth (LH)

Pollutant	Substance Deviations	Monitoring Deviations	Other Relevant Issues
Total Particulate Matter	None	None	None

Table 4.2 Monitoring Deviations for Emission Point Assembly Shop Booth (Mid)

Pollutant	Substance Deviations	Monitoring Deviations	Other Relevant Issues
Total Particulate Matter	None	None	None

Table 4.3 Monitoring Deviations for Emission Point Assembly Shop Booth (RH)

Pollutant	Substance Deviations	Monitoring Deviations	Other Relevant Issues
Total Particulate Matter	None	None	None

Table 4.4 Monitoring Deviations for Emission Point Industrial Spray Booth 1 (RH)

Pollutant	Substance Deviations	Monitoring Deviations	Other Relevant Issues
Total Particulate Matter	None	None	None

Table 4.5 Monitoring Deviations for Emission Point Industrial Spray Booth 1 (LH)

Pollutant	Substance Deviations	Monitoring Deviations	Other Relevant Issues
Total Particulate Matter	None	None	None

Table 4.6 Monitoring Deviations for Emission Point Industrial Spray Booth 2 (LH)

Pollutant	Substance Deviations	Monitoring Deviations	Other Relevant Issues
Total Particulate Matter	None	None	None

Table 4.7 Monitoring Deviations for Emission Point Industrial Spray Booth 2 (RH)

Pollutant	Substance Deviations	Monitoring Deviations	Other Relevant Issues
Total Particulate Matter	None	None	None

Report for Periodic Monitoring of Emissions to Atmosphere

Part 2: **Supporting Information**
Permit Number: **PPC/067 Var Ref: 002**
Operator: **Covrad Heat Transfer Ltd**
Installation: **Coventry**
Emission Points: **Assembly Shop Booth (LH),
Assembly Shop Booth (Mid), Assembly Shop Booth (RH),
Industrial Spray Booth 1 (RH), Industrial Spray Booth 1 (LH),
Industrial Spray Booth 2 (LH) & Industrial Spray Booth 2 (RH)**
Monitoring Dates: **12th – 17th January 2011**

Contract Reference: FTBS14741
Operator: Covrad Heat Transfer Ltd
Address: Sir Henry Parks Road
Canley
Coventry
CV5 6BN
Monitoring Organisation: RPS Consultants Ltd.
Address: Grafton Building, Caswell Science &
Technology Park, Caswell,
Towcester, Northamptonshire, NN12 8EQ.
Report Date: 07 February 2011
Report Approved By: Martin Johnson
Position: Senior Environmental Consultant
MCERTS Registration Number: MM 03 168

Signature:



RPS Consultants Ltd. has produced this report within the term of the contract with the client and taking account of the resources devoted to it by agreement with the client.

We disclaim any responsibility to the client and others in respect of any matters outside the scope of the above. This report is confidential to the client and we accept no responsibility of whatsoever nature to third parties to whom this report, or any part thereof, is made known. Any such party relies on the report at their own risk.

CONTENTS

Part 1: Executive Summary

Section 1 – Monitoring Objectives

Section 2 – Monitoring Results

Section 3 – Operating Information

Section 4 – Monitoring Deviations

Part 2: Supporting Information

Appendix 1 – Staff & Methodology Details

Appendix 2- Assembly Shop Booth (LH) Sampling, Analysis & Uncertainty Data

Appendix 3- Assembly Shop Booth (Mid) Sampling, Analysis & Uncertainty Data

Appendix 4- Assembly Shop Booth (RH) Sampling, Analysis & Uncertainty Data

Appendix 5- Industrial Spray Booth 1 (RH) Sampling, Analysis & Uncertainty Data

Appendix 6- Industrial Spray Booth 1 (LH) Sampling, Analysis & Uncertainty Data

Appendix 7- Industrial Spray Booth 2 (LH) Sampling, Analysis & Uncertainty Data

Appendix 8- Industrial Spray Booth 2 (RH) Sampling, Analysis & Uncertainty Data

APPENDIX 1: General Information

Monitoring Organisation Staff Details

Table 5.1 Sampling Personnel

Sampling Personnel	Position	MCERTS Level	Technical Endorsements	MCERTS Registration Number
Katie Brewis	Consultant	Level 2	TE1, TE2, TE3, TE4	MM 07 876
Richard Carter	Consultant	Level 2	TE1, TE2, TE3, TE4	MM 07 861

Table 5.2 Report Author

Report Author	Position	MCERTS Level	Technical Endorsements	MCERTS Registration Number
Richard Carter	Consultant	Level 2	TE1, TE2, TE3, TE4	MM 07 861

Table 5.3 Report Reviewer

Report Reviewer	Position	MCERTS Level	Technical Endorsements	MCERTS Registration Number
Martin Johnson	Senior Environmental Consultant	Level 2	TE1, TE2, TE3, TE4	MM 03 168

Monitoring Organisation Method Details

Table 6.1 Monitoring Methods

Emission Parameter	Standard Method	Monitoring Procedure No.	Monitoring Accreditation	Analysis	Analysis Procedure No.	Analytical Laboratory	Analysis Accreditation
Practical Considerations Prior to Monitoring	N/A	RPSCE/1/1	UKAS	N/A	N/A	N/A	N/A
Gas Flows	BS-EN 13284-1:2001	RPSCE/1/2	MCERTS	N/A	N/A	N/A	N/A
Gas Temperatures	BS-EN 13284-1:2001	RPSCE/1/2	MCERTS	N/A	N/A	N/A	N/A
Low Concentration Total Particulate Matter	BS EN 13284-1:2002	RPSCE/1/7c	MCERTS	Gravimetric	D9	RPS Laboratories	UKAS

Table 7.1 – Checklist Used

Equipment Checklist Used	File Location Address
FTBS14741 Checklist	FTBS14741 Electronic & Work File

APPENDIX 2:
Assembly Shop Booth (LH) Sampling, Analysis & Uncertainty Data

Company Name: Covrad Heat Transfer Ltd Date: 12/01/11
Site Ref: Coventry Run: TPM
Sampling Point Ref: Assembly Shop Booth (LH)
Project Ref: FTBS14741

Traverse Point No.	Port A			Port B		
	Δp , mm H ₂ O	Root Δp	Stack Temp °C	Δp , mm H ₂ O	Root Δp	Stack Temp °C
1	7.4	2.720	10	7.6	2.757	10
2	8.6	2.933	10	8	2.828	11
3						
4						
5						
6						
7						
8						
9						
10						
Minimum	7.4	2.720	10	7.6	2.757	10
Maximum	8.6	2.933	10	8.0	2.828	11
Mean	8.0	2.826	10.0	7.8	2.793	10.5
Sum	16	5.653	20	15.6	5.585	21
Total Sum						

Max. pitot press. =	8.6
Min. pitot press. =	7.4
Ratio Max:Min =	1.2 :1

Gas Data	
Oxygen %	21.0
CO ₂ %	0.04
CO %	

Oxygen Correction	
Required Correction Value	0
Actual Oxygen Factor	1
Enter 0 if correction is not required	

BS EN 13284-1 & M1 Sample Point Requirements	Requirement Met?
Duct gas flow: angle with regard to duct access <15°?	Y
Duct Gas Flow Negative Velocity: Not Permitted	Y
Duct Gas Flow: Ratio of max to min velocity <3:1?	Y
Working Area > 5m ² ?	Y
Handrails with removable chains / self closing gates across the top of the ladder?	Y
Handrails (approx 0.5 and 1.0 m high) and vertical baseboards (approx 0.25m high)?	Y
Scaffold Built to 'Heavy Duty' Scaffold Rating or at least 2.5kN/m ² loading	Y
Handrails not restricting access to ports?	Y
Room opposite sampling port equal or greater than the length of the sampling probe plus 1 metre?	Y
Sufficient Power (Waterproof 110V BS4343 Standard) close or on the platform?	Y

Company Name: Covrad Heat Transfer Ltd In-stack Filter? Bar. Press mm Hg K Factor Ambient Temp. Leak Rate (fin / %)
 Site Ref: Coventry Cp Dn used Start Time Leak Rate (start / %)
 Date: 12/01/11 Operators Bws% Nozzle No. Stop Time Box/Probe setting
 Run: TPM Meter Correction Yd
 Project Ref: FTBS14741

Sample Filter Weights

	Reference	Laboratory	Increase, mg
Filter	67881	RPS	0.84
Probe Washings	T120187	RPS	1.4

Sample Filter Blank Weighings

	Reference	Laboratory	Increase, mg
Filter	67879	RPS	0.17
Probe Wash	T120186	RPS	0.5

Impinger Weights

Weights	Initial	Final	Increase, g
Impinger 1	714.9	709	-5.9
Impinger 2			0.0
Impinger 3			0.0
Impinger 4			0.0
Impinger 5			0.0
Silica Gel	870	886.9	16.9
Total			11.0

Sample Point	Clock Time min	Pitot Δ p, mm H ₂ O	Stack Temp, °C	Orifice Δ H, mm H ₂ O		Gas Meter Reading m ³	Temp at Gas Meter Outlet °C	Condenser Temp, °C	Filter Box Temp °C	Probe Temp °C	Pump Vacuum Inches Hg	Impinger Stern Temp. °C	Root Δ p.
				Desired	Actual								
1	0	7.0	10	62.4	62.4	1455050	13				2.5	10	2.646
	5	7.0	10	62.4	62.4		15				2.5	10	2.646
	10	7.0	10	62.4	62.4		16				2.5	9	2.646
	15	7.0	10	62.4	62.4		16				2.5	9	2.646
	20	7.6	10	67.8	67.8		17				3	10	2.757
25	7.6	10	67.8	67.8	18				3	10	2.757	Endpoint	
30													
1	0	7.4	10	66.0	66.0	1456660.2	18				3	11	2.720
	5	7.6	10	67.8	67.8		19				3	11	2.757
	10	7.6	11	67.8	67.8		19				3	12	2.757
	15	7.6	12	67.8	67.8		19				3	12	2.757
	20	7.6	12	67.8	67.8		19				3	12	2.757
25	7.4	12	66.0	66.0	19				3	12	2.720	Endpoint	
30													
	60.00	7.4	10.6	65.7	65.7	1.610	17.3	#DIV/0!	#DIV/0!	#DIV/0!	2.8	10.7	2.7

Company Name: Covrad Heat Transfer Ltd
Site Ref: Coventry
Project Ref: FTBS14741

Date: 12/01/11

Sampling Point Ref: Assembly Shop Booth (LH)	Run: TPM
Meter Volume Sampled, acm	1.610
Sample Run Start Time	11:29
Sample Run End Time	12:31
Total Actual Sampling Time, min	60.0
Barometric Pressure, mm Hg	738.00
Stack Pressure, mm Hg	738.21
Average Stack Temp, °C	10.6
Meter Volume at Wet STP, scm	1.459
Stack Moisture Content, %	0.9
Average Stack Velocity, m/sec	9.037
Stack Flow Rate, scms wet, STP	4.245
Nozzle Diameter, mm	7.98
% Isokinetic Variation	95.7
Total Mass of Particulate, mg	2.2
Percentage of Total Particulate Collected on Filter	37.5
Stack Particulate Concentration, mg/m³	1.5
Particulate Mass rate, kg/hour	0.023
Emission Limit value	50

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m ³	0.5
Total Weight Gain, mg (Sample Train Blank)	0.7
Blank Result Less than 10% of Limit Value	Y

Uncertainty Calculation for Total Particulate Matter to BS EN 13284-1

Determined Concentration	1.5	mg/m ³ (at Reference Cond)
--------------------------	-----	---------------------------------------

Measured Values

Sampled Volume	1.6102	m ³
Sampled gas Temperature	290.3333333	K
Sampled gas Pressure	98.43	kPa
Sampled gas Humidity	0	% by volume
Oxygen content	21	% by volume
Mass	2.24	mg

Leak	0.00	%
Uncollected Mass	0	mg

Standard Uncertainties for Measured Values

Sampled Volume	0.001	m ³
Sampled gas Temperature	2	K
Sampled gas Pressure	1	kPa
Sampled gas Humidity	1	% by volume
Oxygen content	0.1	% by volume
Mass	0.14152385	mg

Uncertainty Calculation for Volume Correction				Uncertainty Calculation for Oxygen Correction			
Volume Correction Factor	0.914			Oxygen Correction Factor	1.0000		
	Sensitivity Coefficient		Uncertainty, U_v		Sensitivity Coefficient		Uncertainty, U_o
Sampled gas Temperature	0.0031		0.0063	Oxygen Measurement	N/A		N/A
Sampled gas Pressure	0.0093		0.0093				
Sampled gas Humidity	0.0091		0.0091				
		Sqrt (U_v)²	0.0145				
		Total U_v	0.023			Total U_o	N/A

Uncertainty Contributions (Itemised)					
	Value		Sensitivity coefficient	Uncertainty Contribution	
				Concentration	%
Volume Correction	1.445	m ³	1.06	0.02 mg.m ⁻³	1.61 %
Mass (weighing)	2.24	mg	0.69	0.10 mg.m ⁻³	6.32 %
Oxygen Correction	N/A		0.00	0.00 mg.m ⁻³	0.00 %
System Leak	0.00	mg.m ⁻³	1.00	0.00 mg.m ⁻³	0.00 %
Uncollected Mass	0.00	mg	0.69	0.00 mg.m ⁻³	0.00 %
			Total Uncertainty	0.10 mg.m⁻³	

Uncertainty Result	
(Uncertainty has been expanded with a coverage factor of 2 (k=2))	
Expanded Uncertainty =	0.20 mg.m⁻³
=>	13.04 % of Result
=>	0.00 % of ELV

APPENDIX 3:
Assembly Shop Booth (Mid) Sampling, Analysis & Uncertainty Data

Company Name: Covrad Heat Transfer Ltd Date: 12/01/11
Site Ref: Coventry Run: TPM
Sampling Point Ref: Assembly Shop Booth (Mid)
Project Ref: FTBS14741

Traverse Point No.	Port A			Port B		
	Δp , mm H ₂ O	Root Δp	Stack Temp °C	Δp , mm H ₂ O	Root Δp	Stack Temp °C
1	6.6	2.569	10	5	2.236	10
2	6.8	2.608	10	5.4	2.324	9
3						
4						
5						
6						
7						
8						
9						
10						
Minimum	6.6	2.569	10	5.0	2.236	9
Maximum	6.8	2.608	10	5.4	2.324	10
Mean	6.7	2.588	10.0	5.2	2.280	9.5
Sum	13.4	5.177	20	10.4	4.560	19
Total Sum						

Max. pitot press. = 6.8
Min. pitot press. = 5.0
Ratio Max:Min = 1.4 :1

Gas Data	
Oxygen %	21.0
CO ₂ %	0.04
CO %	

Oxygen Correction	
Required Correction Value	0
Actual Oxygen Factor	1
Enter 0 if correction is not required	

BS EN 13284-1 & M1 Sample Point Requirements	Requirement Met?
Duct gas flow: angle with regard to duct access <15°?	Y
Duct Gas Flow Negative Velocity: Not Permitted	Y
Duct Gas Flow: Ratio of max to min velocity <3:1?	Y
Working Area > 5m ² ?	Y
Handrails with removable chains / self closing gates across the top of the ladder?	Y
Handrails (approx 0,5 and 1,0 m high) and vertical baseboards (approx 0,25m high)?	Y
Scaffold Built to 'Heavy Duty' Scafftag Rating or at least 2.5kN/m ² loading	Y
Handrails not restricting access to ports?	Y
Room opposite sampling port equal or greater than the length of the sampling probe plus 1 metre?	Y
Sufficient Power (Waterproof 110V BS4343 Standard) close or on the platform?	Y

Company Name: Covrad Heat Transfer Ltd In-stack Filter? Bar. Press mm Hg K Factor Ambient Temp. Leak Rate (fin / %)
 Site Ref: Coventry Cp Dn used Start Time Leak Rate (start / %)
 Sampling Point Ref: Assembly Shop Booth Outstack Filter? Date: 12/01/11 Nozzle No. Stop Time Box/Probe setting
 Run: TPM Operators Bws% Meter Correction Yd
 Project Ref: FTBS14741

Sample Filter Weights

	Reference	Laboratory	Increase, mg
Filter	67873	RPS	0.88
Probe Washings	T120189	RPS	1.4

Sample Filter Blank Weighings

	Reference	Laboratory	Increase, mg
Filter	67882	RPS	0.15
Probe Wash	T120188	RPS	0.9

Impinger Weights

Weights	Initial	Final	Increase, g
Impinger 1	709	702.2	-6.8
Impinger 2			0.0
Impinger 3			0.0
Impinger 4			0.0
Impinger 5			0.0
Silica Gel	886.9	903.5	16.6
Total			9.8

Sample Point	Clock Time min	Pitot Δ p, mm H ₂ O	Stack Temp, °C	Orifice Δ H, mm H ₂ O		Gas Meter Reading m ³	Temp at Gas Meter Outlet °C	Condenser Temp, °C	Filter Box Temp °C	Probe Temp °C	Pump Vacuum Inches Hg	Impinger Stern Temp. °C	Root Δ p,
				Desired	Actual								
1	0	5.0	10	76.1	76.1	1456666.6	17				3	7	2.236
	5	5.0	10	76.1	76.1		17				3	7	2.236
	10	5.0	10	76.1	76.1		17				3	7	2.236
	15	4.4	10	67.0	67.0		18				2.5	8	2.098
	20	4.6	11	70.0	70.0		19				2.5	8	2.145
25	4.4	11	67.0	67.0	19				2.5	8	2.098		
Endpoint	30												
2	0	5.0	11	76.1	76.1	1458419	19				2.5	8	2.236
	5	5.0	11	76.1	76.1		19				2.5	9	2.236
	10	5.2	11	79.1	79.1		20				2.5	9	2.280
	15	5.0	12	76.1	76.1		20				2.5	9	2.236
	20	5.2	12	79.1	79.1		20				2.5	9	2.280
25	5.0	12	76.1	76.1	20				2.5	9	2.236		
Endpoint	30												
	60.00	4.9	10.9	74.6	74.6	1.752	18.8	#DIV/0!	#DIV/0!	#DIV/0!	2.6	8.2	2.2

Company Name: Covrad Heat Transfer Ltd
Site Ref: Coventry
Project Ref: FTBS14741

Date: 12/01/11

Sampling Point Ref: Assembly Shop Booth (Mid)	Run: TPM
Meter Volume Sampled, acm	1.752
Sample Run Start Time	13:41
Sample Run End Time	14:43
Total Actual Sampling Time, min	60.0
Barometric Pressure, mm Hg	738.00
Stack Pressure, mm Hg	737.90
Average Stack Temp, °C	10.9
Meter Volume at Wet STP, scm	1.579
Stack Moisture Content, %	0.8
Average Stack Velocity, m/sec	7.373
Stack Flow Rate, scms wet, STP	3.458
Nozzle Diameter, mm	9.10
% Isokinetic Variation	97.8
Total Mass of Particulate, mg	2.3
Percentage of Total Particulate Collected on Filter	38.6
Stack Particulate Concentration, mg/m³	1.4
Particulate Mass rate, kg/hour	0.018
Emission Limit value	50

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m ³	0.7
Total Weight Gain, mg (Sample Train Blank)	1.1
Blank Result Less than 10% of Limit Value	Y

Uncertainty Calculation for Total Particulate Matter to BS EN 13284-1

Determined Concentration	1.4	mg/m ³ (at Reference Cond)
--------------------------	-----	---------------------------------------

Measured Values

Sampled Volume	1.7524	m ³
Sampled gas Temperature	291.75	k
Sampled gas Pressure	98.38	kPa
Sampled gas Humidity	0	% by volume
Oxygen content	21	% by volume
Mass	2.28	mg

Leak	0.20	%
Uncollected Mass	0	mg

Standard Uncertainties for Measured Values

Sampled Volume	0.001	m ³
Sampled gas Temperature	2	k
Sampled gas Pressure	1	kPa
Sampled gas Humidity	1	% by volume
Oxygen content	0.1	% by volume
Mass	0.14152385	mg

Uncertainty Calculation for Volume Correction			Uncertainty Calculation for Oxygen Correction		
Volume Correction Factor	0.909		Oxygen Correction Factor	1.0000	
	Sensitivity Coefficient	Uncertainty, U_v		Sensitivity Coefficient	Uncertainty, U_o
Sampled gas Temperature	0.0031	0.0062	Oxygen Measurement	N/A	N/A
Sampled gas Pressure	0.0092	0.0092			
Sampled gas Humidity	0.0091	0.0091			
	Sqrt (U_v)²	0.0144			
	Total U_v	0.025		Total U_o	N/A

Uncertainty Contributions (Itemised)					
	Value		Sensitivity coefficient	Uncertainty Contribution	
				Concentration	%
Volume Correction	1.566	m ³	0.92	0.02 mg.m ⁻³	1.61 %
Mass (weighing)	2.28	mg	0.63	0.09 mg.m ⁻³	6.21 %
Oxygen Correction	N/A		0.00	0.00 mg.m ⁻³	0.00 %
System Leak	0.00	mg.m ⁻³	1.00	0.00 mg.m ⁻³	0.12 %
Uncollected Mass	0.00	mg	0.63	0.00 mg.m ⁻³	0.00 %
			Total Uncertainty	0.09 mg.m⁻³	

Uncertainty Result		(Uncertainty has been expanded with a coveragefactor of 2 (K=2))	
Expanded Uncertainty =	0.19	mg.m⁻³	
=>	12.83	% of Result	
=>	0.00	% of ELV	

APPENDIX 4:
Assembly Shop Booth (RH) Sampling, Analysis & Uncertainty Data

Company Name: Covrad Heat Transfer Ltd Date: 13/01/11
Site Ref: Coventry Run: TPM
Sampling Point Ref: Assembly Shop Booth (RH)
Project Ref: FTBS14741

Traverse Point No.	Port A			Port B		
	Δp , mm H ₂ O	Root Δp	Stack Temp °C	Δp , mm H ₂ O	Root Δp	Stack Temp °C
1	4.6	2.145	9	5.4	2.324	11
2	6	2.449	11	4	2.000	10
3						
4						
5						
6						
7						
8						
9						
10						
Minimum	4.6	2.145	9	4.0	2.000	10
Maximum	6.0	2.449	11	5.4	2.324	11
Mean	5.3	2.297	10.0	4.7	2.162	10.5
Sum	10.6	4.594	20	9.4	4.324	21
Total Sum						

Max. pitot press. =	6.0
Min. pitot press. =	4.0
Ratio Max:Min =	1.5 :1

Gas Data	
Oxygen %	21.0
CO ₂ %	0.04
CO %	

Oxygen Correction	
Required Correction Value	0
Actual Oxygen Factor	1
Enter 0 if correction is not required	

BS EN 13284-1 & M1 Sample Point Requirements	Requirement Met?
Duct gas flow: angle with regard to duct access <15°?	Y
Duct Gas Flow Negative Velocity: Not Permitted	Y
Duct Gas Flow: Ratio of max to min velocity <3:1?	Y
Working Area > 5m ² ?	Y
Handrails with removable chains / self closing gates across the top of the ladder?	Y
Handrails (approx 0,5 and 1,0 m high) and vertical baseboards (approx 0,25m high)?	Y
Scaffold Built to 'Heavy Duty' Scafftag Rating or at least 2.5kN/m ² loading	Y
Handrails not restricting access to ports?	Y
Room opposite sampling port equal or greater than the length of the sampling probe plus 1 metre?	Y
Sufficient Power (Waterproof 110V BS4343 Standard) close or on the platform?	Y

Company Name: Covrad Heat Transfer Ltd In-stack Filter? Bar. Press mm Hg K Factor Ambient Temp. Leak Rate (fin / %)
 Site Ref: Coventry Cp Dn used Start Time Leak Rate (start / %)
 Sampling Point Ref: Assembly Shop Booth Outstack Filter? Date: 13/01/11 Nozzle No. Stop Time Box/Probe setting
 Run: TPM Operators Bws% Meter Correction Yd

Sample Filter Weights

	Reference	Laboratory	Increase, mg
Filter	67877	RPS	2.8
Probe Washings	T120191	RPS	2.3

Sample Filter Blank Weighings

	Reference	Laboratory	Increase, mg
Filter	67876	RPS	0.21
Probe Wash	T120190	RPS	0.5

Impinger Weights

Weights	Initial	Final	Increase, g
Impinger 1	702.2	695.4	-6.8
Impinger 2			0.0
Impinger 3			0.0
Impinger 4			0.0
Impinger 5			0.0
Silica Gel	903.5	914.5	11.0
Total			4.2

Sample Point	Clock Time min	Pitot Δ p, mm H ₂ O	Stack Temp, °C	Orifice Δ H, mm H ₂ O		Gas Meter Reading m ³	Temp at Gas Meter Outlet °C	Condenser Temp, °C	Filter Box Temp °C	Probe Temp °C	Pump Vacuum Inches Hg	Impinger Stern Temp. °C	Root Δ p.
				Desired	Actual								
1	0	4.4	9	67.6	67.6	1458429.8	18				3	9	2.098
	5	4.4	9	67.6	67.6		18				3	7	2.098
	10	4.4	9	67.6	67.6		18				3	7	2.098
	15	4.4	9	67.6	67.6		19				3	7	2.098
	20	4.4	10	67.6	67.6		19				3	8	2.098
25	4.8	11	73.7	73.7	20				3	8	2.191		
Endpoint	30												
2	0	4.8	10	73.7	73.7	1460115.8	20				3	9	2.191
	5	4.8	10	73.7	73.7		21				3	9	2.191
	10	4.8	10	73.7	73.7		21				3	8	2.191
	15	4.8	11	73.7	73.7		21				3	8	2.191
	20	4.8	11	73.7	73.7		21				3	8	2.191
25	4.4	11	67.6	67.6	#REF!				3	8	2.098		
Endpoint	30												
	60.00	4.6	10.0	70.7	70.7	1.686	19.8	#DIV/0!	#DIV/0!	#DIV/0!	3.0	8.0	2.1

Company Name: Covrad Heat Transfer Ltd
Site Ref: Coventry
Project Ref: FTBS14741

Date: 13/01/11

Sampling Point Ref: Assembly Shop Booth (RH)	Run: TPM
Meter Volume Sampled, acm	1.686
Sample Run Start Time	10:24
Sample Run End Time	11:26
Total Actual Sampling Time, min	60.0
Barometric Pressure, mm Hg	738.00
Stack Pressure, mm Hg	738.29
Average Stack Temp, °C	10.0
Meter Volume at Wet STP, scm	1.506
Stack Moisture Content, %	0.3
Average Stack Velocity, m/sec	7.125
Stack Flow Rate, scms wet, STP	3.354
Nozzle Diameter, mm	9.10
% Isokinetic Variation	96.2
Total Mass of Particulate, mg	5.1
Percentage of Total Particulate Collected on Filter	54.9
Stack Particulate Concentration, mg/m³	3.4
Particulate Mass rate, kg/hour	0.041
Emission Limit value	50

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m ³	0.5
Total Weight Gain, mg (Sample Train Blank)	0.7
Blank Result Less than 10% of Limit Value	Y

Uncertainty Calculation for Total Particulate Matter to BS EN 13284-1

Determined Concentration	3.4	mg/m ³ (at Reference Cond)
--------------------------	-----	---------------------------------------

Measured Values

Sampled Volume	1.686	m ³
Sampled gas Temperature	292.75	K
Sampled gas Pressure	98.44	kPa
Sampled gas Humidity	0	% by volume
Oxygen content	21	% by volume
Mass	5.1	mg

Leak	0.20	%
Uncollected Mass	0	mg

Standard Uncertainties for Measured Values

Sampled Volume	0.001	m ³
Sampled gas Temperature	2	K
Sampled gas Pressure	1	kPa
Sampled gas Humidity	1	% by volume
Oxygen content	0.1	% by volume
Mass	0.14152385	mg

Uncertainty Calculation for Volume Correction			Uncertainty Calculation for Oxygen Correction		
Volume Correction Factor	0.906		Oxygen Correction Factor	1.0000	
	Sensitivity Coefficient	Uncertainty, U_v		Sensitivity Coefficient	Uncertainty, U_o
Sampled gas Temperature	0.0031	0.0062	Oxygen Measurement	N/A	N/A
Sampled gas Pressure	0.0092	0.0092			
Sampled gas Humidity	0.0091	0.0091			
	Sqrt (U_v)²	0.0143			
	Total U_v	0.024		Total U_o	N/A

Uncertainty Contributions (Itemised)					
	Value		Sensitivity coefficient	Uncertainty Contribution	
				Concentration	%
Volume Correction	1.501	m ³	2.26	0.05 mg.m ⁻³	1.61 %
Mass (weighing)	5.10	mg	0.66	0.09 mg.m ⁻³	2.77 %
Oxygen Correction	N/A		0.00	0.00 mg.m ⁻³	0.00 %
System Leak	0.00	mg.m ⁻³	1.00	0.00 mg.m ⁻³	0.12 %
Uncollected Mass	0.00	mg	0.66	0.00 mg.m ⁻³	0.00 %
			Total Uncertainty	0.11 mg.m⁻³	

Uncertainty Result		(Uncertainty has been expanded with a coverage factor of 2 (K=2))	
Expanded Uncertainty =	0.22	mg.m⁻³	
=>	6.42	% of Result	
=>	0.00	% of ELV	

**APPENDIX 5:
Industrial Spray Booth 1 (RH) Sampling, Analysis & Uncertainty Data**

Company Name: Covrad Heat Transfer Ltd Date: 14/01/11
Site Ref: Coventry Run: TPM
Sampling Point Ref: Industrial Spary Booth 1 (RH)
Project Ref: FTBS14741

Stack Static press mm H ₂ O:	5.8	Stack Diamter (m)	0.59			
		Stack Area (m ²):	0.273			
Traverse Point No.	Port A			Port B		
	Δ p, mm H ₂ O	Root Δ p	Stack Temp °C	Δ p, mm H ₂ O	Root Δ p	Stack Temp °C
1	15.6	3.950	18	13.8	3.715	19
2	3.6	1.897	18	3.8	1.949	17
3						
4						
5						
6						
7						
8						
9						
10						
Minimum	3.6	1.897	18	3.8	1.949	17
Maximum	15.6	3.950	18	13.8	3.715	19
Mean	9.6	2.924	18.0	8.8	2.832	18.0
Sum	19.2	5.847	36	17.6	5.664	36
Total Sum						

Max. pitot press. = 15.6
Min. pitot press. = 3.6
Ratio Max:Min = 4.3 :1

Gas Data

Oxygen %	21.0
CO ₂ %	0.04
CO %	

Oxygen Correction

Required Correction Value	0
Actual Oxygen Factor	1
Enter 0 if correction is not required	

BS EN 13284-1 & M1 Sample Point Requirements	Requirement Met?
Duct gas Flow: angle with regard to duct access <15°?	Y
Duct Gas Flow Negative Velocity: Not Permitted	Y
Duct Gas Flow: Ratio of max to min velocity <3:1?	Y
Working Area > 5m ² ?	Y
Handrails with removable chains / self closing gates across the top of the ladder?	Y
Handrails (approx 0,5 and 1,0 m high) and vertical baseboards (approx 0,25m high)?	Y
Scaffold Built to 'Heavy Duty' Scafftag Rating or at least 2.5kN/m ² loading	Y
Handrails not restricting access to ports?	Y
Room opposite sampling port equal or greater than the length of the sampling probe plus 1 metre?	Y
Sufficient Power (Waterproof 110V BS4343 Standard) close or on the platform?	Y

Company Name: Covrad Heat Transfer Ltd In-stack Filter? Bar. Press mm Hg K Factor Ambient Temp. Leak Rate (fin / %)
 Site Ref: Coventry Cp Dn used Start Time Leak Rate (start / %)
 Date: 14/01/11 Operators Bws% Nozzle No. Stop Time Box/Probe setting
 Run: TPM Meter Correction Yd
 Project Ref: FTBS14741

Sample Filter Weights

	Reference	Laboratory	Increase, mg
Filter	67964	RPS	5.97
Probe Washings	T120024	RPS	2.6

Sample Filter Blank Weighings

	Reference	Laboratory	Increase, mg
Filter	67960	RPS	0.04
Probe Wash	T120023	RPS	0.8

Impinger Weights

Weights	Initial	Final	Increase, g
Impinger 1	890.9	883.4	-7.5
Impinger 2			0.0
Impinger 3			0.0
Impinger 4			0.0
Impinger 5			0.0
Silica Gel	876.5	893.6	17.1
Total			9.6

Sample Point	Clock Time min	Pitot Δ p, mm H ₂ O	Stack Temp, °C	Orifice Δ H, mm H ₂ O		Gas Meter Reading m ³	Temp at Gas Meter Outlet °C	Condenser Temp, °C	Filter Box Temp °C	Probe Temp °C	Pump Vacuum Inches Hg	Impinger Stern Temp. °C	Root Δ p,
				Desired	Actual								
1	0	9.6	17	85.9	85.9	1461852.6	16				4.5	16	3.098
	5	9.6	17	85.9	85.9		16				5	16	3.098
	10	8.8	17	78.7	78.7		17				5	17	2.966
	15	4.2	17	37.6	37.6		17				2.5	17	2.049
	20	4.0	17	35.8	35.8		17				2	17	2.000
25	4.0	17	35.8	35.8	17				2	17	2.000		
Endpoint	30												
2	0	10.4	17	93.0	93.0	1463364.1	17				6	17	3.225
	5	10.4	17	93.0	93.0		17				6	17	3.225
	10	10.4	18	93.0	93.0		17				6	17	3.225
	15	4.4	18	39.4	39.4		17				2	17	2.098
	20	4.4	18	39.4	39.4		17				2	17	2.098
25	4.0	18	35.8	35.8	17				2	17	2.000		
Endpoint	30												
	60.00	7.0	17.3	62.8	62.8	1.512	16.8	#DIV/0!	#DIV/0!	#DIV/0!	3.8	16.8	2.6

Company Name: Covrad Heat Transfer Ltd
Site Ref: Coventry
Project Ref: FTBS14741

Date: 14/01/11

Sampling Point Ref: Industrial Spary Booth 1 (RH)	Run: TPM
Meter Volume Sampled, acm	1.512
Sample Run Start Time	14:15
Sample Run End Time	15:17
Total Actual Sampling Time, min	60.0
Barometric Pressure, mm Hg	738.00
Stack Pressure, mm Hg	738.43
Average Stack Temp, °C	17.3
Meter Volume at Wet STP, scm	1.370
Stack Moisture Content, %	0.9
Average Stack Velocity, m/sec	8.726
Stack Flow Rate, scms wet, STP	2.178
Nozzle Diameter, mm	7.98
% Isokinetic Variation	95.3
Total Mass of Particulate, mg	8.6
Percentage of Total Particulate Collected on Filter	69.7
Stack Particulate Concentration, mg/m³	6.3
Particulate Mass rate, kg/hour	0.049
Emission Limit value	50

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m ³	0.6
Total Weight Gain, mg (Sample Train Blank)	0.8
Blank Result Less than 10% of Limit Value	Y

Uncertainty Calculation for Total Particulate Matter to BS EN 13284-1

Determined Concentration	6.3	mg/m ³ (at Reference Cond)
--------------------------	-----	---------------------------------------

Measured Values

Sampled Volume	1.5115	m ³
Sampled gas Temperature	289.8333333	k
Sampled gas Pressure	98.45	kPa
Sampled gas Humidity	0	% by volume
Oxygen content	21	% by volume
Mass	8.57	mg

Leak	0.00	%
Uncollected Mass	0	mg

Standard Uncertainties for Measured Values

Sampled Volume	0.001	m ³
Sampled gas Temperature	2	k
Sampled gas Pressure	1	kPa
Sampled gas Humidity	1	% by volume
Oxygen content	0.1	% by volume
Mass	0.14152385	mg

Uncertainty Calculation for Volume Correction			Uncertainty Calculation for Oxygen Correction		
Volume Correction Factor	0.915		Oxygen Correction Factor	1.0000	
	Sensitivity Coefficient	Uncertainty, U_v		Sensitivity Coefficient	Uncertainty, U_o
Sampled gas Temperature	0.0032	0.0063	Oxygen Measurement	N/A	N/A
Sampled gas Pressure	0.0093	0.0093			
Sampled gas Humidity	0.0092	0.0092			
	Sqrt (U_v)²	0.0145			
	Total U_v	0.022		Total U_o	N/A

Uncertainty Contributions (Itemised)					
	Value		Sensitivity coefficient	Uncertainty Contribution	
				Concentration	%
Volume Correction	1.358	m ³	4.60	0.10 mg.m ⁻³	1.61 %
Mass (weighing)	8.57	mg	0.73	0.10 mg.m ⁻³	1.65 %
Oxygen Correction	N/A		0.00	0.00 mg.m ⁻³	0.00 %
System Leak	0.00	mg.m ⁻³	1.00	0.00 mg.m ⁻³	0.00 %
Uncollected Mass	0.00	mg	0.73	0.00 mg.m ⁻³	0.00 %
			Total Uncertainty	0.14 mg.m⁻³	

Uncertainty Result	
(Uncertainty has been expanded with a coveragefactor of 2 (K=2))	
Expanded Uncertainty =	0.29 mg.m⁻³
=>	4.62 % of Result
=>	0.00 % of ELV

**APPENDIX 6:
Industrial Spray Booth 1 (LH) Sampling, Analysis & Uncertainty Data**

Company Name: Covrad Heat Transfer Ltd Date: 14/01/11
Site Ref: Coventry Run: TPM
Sampling Point Ref: Industrial Spray Booth 1 (LH)
Project Ref: FTBS14741

Stack Static press mm H ₂ O:	19.8	Stack Diameter (m)	0.60			
		Stack Area (m ²):	0.283			
Traverse Point No.	Port A			Port B		
	Δ p, mm H ₂ O	Root Δ p	Stack Temp °C	Δ p, mm H ₂ O	Root Δ p	Stack Temp °C
1	4.4	2.098	20	19	4.359	15
2	6.6	2.569	20	19	4.359	2
3						
4						
5						
6						
7						
8						
9						
10						
Minimum	4.4	2.098	20	19.0	4.359	2
Maximum	6.6	2.569	20	19.0	4.359	15
Mean	5.5	2.333	20.0	19.0	4.359	8.5
Sum	11	4.667	40	38	8.718	17
Total Sum						

Max. pitot press. = 19.0
Min. pitot press. = 4.4
Ratio Max:Min = 4.3 :1

Gas Data

Oxygen %	21.0
CO ₂ %	0.04
CO %	

Oxygen Correction

Required Correction Value	0
Actual Oxygen Factor	1
Enter 0 if correction is not required	

BS EN 13284-1 & M1 Sample Point Requirements	Requirement Met?
Duct gas flow: angle with regard to duct access <15°?	Y
Duct Gas Flow Negative Velocity: Not Permitted	Y
Duct Gas Flow: Ratio of max to min velocity <3:1?	Y
Working Area > 5m ² ?	Y
Handrails with removable chains / self closing gates across the top of the ladder?	Y
Handrails (approx 0,5 and 1,0 m high) and vertical baseboards (approx 0,25m high)?	Y
Scaffold Built to 'Heavy Duty' Scafftag Rating or at least 2.5kN/m ² loading	Y
Handrails not restricting access to ports?	Y
Room opposite sampling port equal or greater than the length of the sampling probe plus 1 metre?	Y
Sufficient Power (Waterproof 110V BS4343 Standard) close or on the platform?	Y

Company Name: Covrad Heat Transfer Ltd In-stack Filter? Bar. Press mm Hg K Factor Ambient Temp. Leak Rate (fin / %)
 Site Ref: Coventry Cp Dn used Start Time Leak Rate (start / %)
 Date: 14/01/11 Operators Bws% Nozzle No. Stop Time Box/Probe setting
 Run: TPM Meter Correction Yd
 Project Ref: FTBS14741

Sample Filter Weights

	Reference	Laboratory	Increase, mg
Filter	67875	RPS	1.7
Probe Washings	T120193	RPS	1.4

Sample Filter Blank Weighings

	Reference	Laboratory	Increase, mg
Filter	67874	RPS	0.14
Probe Wash	T120192	RPS	1

Impinger Weights

Weights	Initial	Final	Increase, g
Impinger 1	925.1	889.3	-35.8
Impinger 2			0.0
Impinger 3			0.0
Impinger 4			0.0
Impinger 5			0.0
Silica Gel	914.3	959.8	45.5
Total			9.7

Sample Point	Clock Time min	Pitot Δ p, mm H ₂ O	Stack Temp, °C	Orifice Δ H, mm H ₂ O		Gas Meter Reading m ³	Temp at Gas Meter Outlet °C	Condenser Temp, °C	Filter Box Temp °C	Probe Temp °C	Pump Vacuum Inches Hg	Impinger Stern Temp. °C	Root Δ p,
				Desired	Actual								
1	0	4.0	17	60.2	60.2	1460139.6	17				2	18	2.000
	5	4.0	18	60.2	60.2		18				2	18	2.000
	10	4.0	19	60.2	60.2		19				2	18	2.000
	15	4.8	19	72.2	72.2		19				2	18	2.191
	20	4.8	19	72.2	72.2		19				2	18	2.191
25	4.8	19	72.2	72.2	19				2	18	2.191		
Endpoint	30												
2	0	6.0	19	90.3	90.3	1461839.2	19				4	18	2.449
	5	6.0	19	90.3	90.3		19				4	18	2.449
	10	6.0	19	90.3	90.3		19				3	18	2.449
	15	4.0	19	60.2	60.2		19				3	18	2.000
	20	4.0	19	60.2	60.2		19				3	18	2.000
25	4.2	19	63.2	63.2	19				3	18	2.049		
Endpoint	30												
	60.00	4.7	18.8	71.0	71.0	1.700	18.8	#DIV/0!	#DIV/0!	#DIV/0!	2.7	18.0	2.2

Company Name: Covrad Heat Transfer Ltd
Site Ref: Coventry
Project Ref: FTBS14741

Date: 14/01/11

Sampling Point Ref: Industrial Spray Booth 1 (LH)	Run: TPM
Meter Volume Sampled, acm	1.700
Sample Run Start Time	10:17
Sample Run End Time	11:19
Total Actual Sampling Time, min	60.0
Barometric Pressure, mm Hg	738.00
Stack Pressure, mm Hg	739.46
Average Stack Temp, °C	18.8
Meter Volume at Wet STP, scm	1.531
Stack Moisture Content, %	0.8
Average Stack Velocity, m/sec	7.302
Stack Flow Rate, scms wet, STP	1.879
Nozzle Diameter, mm	9.10
% Isokinetic Variation	98.2
Total Mass of Particulate, mg	3.1
Percentage of Total Particulate Collected on Filter	54.8
Stack Particulate Concentration, mg/m³	2.0
Particulate Mass rate, kg/hour	0.014
Emission Limit value	50

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m ³	0.7
Total Weight Gain, mg (Sample Train Blank)	1.1
Blank Result Less than 10% of Limit Value	Y

Uncertainty Calculation for Total Particulate Matter to BS EN 13284-1

Determined Concentration	2.0	mg/m ³ (at Reference Cond)
--------------------------	-----	---------------------------------------

Measured Values

Sampled Volume	1.6996	m ³
Sampled gas Temperature	291.75	K
Sampled gas Pressure	98.59	kPa
Sampled gas Humidity	0	% by volume
Oxygen content	21	% by volume
Mass	3.1	mg

Leak	0.15	%
Uncollected Mass	0	mg

Standard Uncertainties for Measured Values

Sampled Volume	0.001	m ³
Sampled gas Temperature	2	K
Sampled gas Pressure	1	kPa
Sampled gas Humidity	1	% by volume
Oxygen content	0.1	% by volume
Mass	0.14152385	mg

Uncertainty Calculation for Volume Correction			Uncertainty Calculation for Oxygen Correction		
Volume Correction Factor	0.911		Oxygen Correction Factor	1.0000	
	Sensitivity Coefficient	Uncertainty, U_v		Sensitivity Coefficient	Uncertainty, U_o
Sampled gas Temperature	0.0031	0.0062	Oxygen Measurement	N/A	N/A
Sampled gas Pressure	0.0092	0.0092			
Sampled gas Humidity	0.0091	0.0091			
	Sqrt (U_v)²	0.0144			
	Total U_v	0.024		Total U_o	N/A

Uncertainty Contributions (Itemised)					
	Value		Sensitivity coefficient	Uncertainty Contribution	
				Concentration	%
Volume Correction	1.519	m ³	1.33	0.03 mg.m ⁻³	1.61 %
Mass (weighing)	3.10	mg	0.65	0.09 mg.m ⁻³	4.57 %
Oxygen Correction	N/A		0.00	0.00 mg.m ⁻³	0.00 %
System Leak	0.00	mg.m ⁻³	1.00	0.00 mg.m ⁻³	0.09 %
Uncollected Mass	0.00	mg	0.65	0.00 mg.m ⁻³	0.00 %
			Total Uncertainty	0.10 mg.m⁻³	

Uncertainty Result	
(Uncertainty has been expanded with a coverage factor of 2 (K=2))	
Expanded Uncertainty =	0.20 mg.m⁻³
=>	9.68 % of Result
=>	0.00 % of ELV

**APPENDIX 7:
Industrial Spray Booth 2 (LH) Sampling, Analysis & Uncertainty Data**

Company Name: Covrad Heat Transfer Ltd Date: 17/01/11
Site Ref: Coventry Run: TPM
Sampling Point Ref: Industrial Spray Booth 2 (LH)
Project Ref: FTBS14741

Stack Static press mm H ₂ O:	-3	Stack Diameter (m)	0.59			
		Stack Area (m ²):	0.273			
Traverse Point No.	Port A			Port B		
	Δ p, mm H ₂ O	Root Δ p	Stack Temp °C	Δ p, mm H ₂ O	Root Δ p	Stack Temp °C
1	13.2	3.633	19	13	3.606	19
2	15.6	3.950	19	17	4.123	19
3						
4						
5						
6						
7						
8						
9						
10						
Minimum	13.2	3.633	19	13.0	3.606	19
Maximum	15.6	3.950	19	17.0	4.123	19
Mean	14.4	3.791	19.0	15.0	3.864	19.0
Sum	28.8	7.583	38	30	7.729	38
Total Sum						

Max. pitot press. = 17.0
Min. pitot press. = 13.0
Ratio Max:Min = 1.3 :1

Gas Data

Oxygen %	21.0
CO ₂ %	0.04
CO %	

Oxygen Correction

Required Correction Value	0
Actual Oxygen Factor	1
Enter 0 if correction is not required	

BS EN 13284-1 & M1 Sample Point Requirements	Requirement Met?
Duct gas flow: angle with regard to duct access <15°?	Y
Duct Gas Flow Negative Velocity: Not Permitted	Y
Duct Gas Flow: Ratio of max to min velocity <3:1?	Y
Working Area > 5m ² ?	Y
Handrails with removable chains / self closing gates across the top of the ladder?	Y
Handrails (approx 0,5 and 1,0 m high) and vertical baseboards (approx 0,25m high)?	Y
Scaffold Built to 'Heavy Duty' Scafftag Rating or at least 2.5kN/m ² loading	Y
Handrails not restricting access to ports?	Y
Room opposite sampling port equal or greater than the length of the sampling probe plus 1 metre?	Y
Sufficient Power (Waterproof 110V BS4343 Standard) close or on the platform?	Y

Company Name: Covrad Heat Transfer Ltd In-stack Filter? Bar. Press mm Hg K Factor Ambient Temp. Leak Rate (fin / %)
 Site Ref: Coventry Outstack Filter? Cp Dn used Start Time Leak Rate (start / %)
 Date: 17/01/11 Operators Bws% Nozzle No. Stop Time Box/Probe setting
 Run: TPM Meter Correction Yd
 Project Ref: FTBS14741

Sample Filter Weights

	Reference	Laboratory	Increase, mg
Filter	67961	RPS	1.4
Probe Washings	T120026	RPS	2

Sample Filter Blank Weighings

	Reference	Laboratory	Increase, mg
Filter	67976	RPS	0.04
Probe Wash	T120025	RPS	0.5

Impinger Weights

Weights	Initial	Final	Increase, g
Impinger 1	880	695.6	-184.4
Impinger 2			0.0
Impinger 3			0.0
Impinger 4			0.0
Impinger 5			0.0
Silica Gel	906.8	1091.6	184.8
Total			0.4

Sample Point	Clock Time min	Pitot Δ p, mm H ₂ O	Stack Temp, °C	Orifice Δ H, mm H ₂ O		Gas Meter Reading m ³	Temp at Gas Meter Outlet °C	Condenser Temp, °C	Filter Box Temp °C	Probe Temp °C	Pump Vacuum Inches Hg	Impinger Stern Temp. °C	Root Δ p,
				Desired	Actual								
1	0	12.0	16	34.5	34.5	1465177.1	14				2	9	3.464
	5	12.2	16	35.0	35.0		12				2	11	3.493
	10	12.2	16	35.0	35.0		10				2	11	3.493
	15	18.8	17	54.0	54.0		10				2	14	4.336
	20	19.0	16	54.5	54.5		10				5	18	4.359
25	19.0	16	54.5	54.5	11				5	18	4.359		
Endpoint	30												
1	0	12.5	16	35.9	35.9	1466484	11				3	18	3.536
	5	12.5	16	35.9	35.9		12				3	17	3.536
	10	12.5	16	35.9	35.9		12				3	17	3.536
	15	18.4	17	52.8	52.8		14				4	11	4.290
	20	18.4	17	52.8	52.8		12				4	11	4.290
25	18.4	17	52.8	52.8	12				4	11	4.290		
Endpoint	30												
	60.00	15.5	16.3	44.5	44.5	1.307	11.7	#DIV/0!	#DIV/0!	#DIV/0!	3.3	13.8	3.9

Company Name: Covrad Heat Transfer Ltd
Site Ref: Coventry
Project Ref: FTBS14741

Date: 17/01/11

Sampling Point Ref: Industrial Spray Booth 2 (LH)	Run: TPM
Meter Volume Sampled, acm	1.307
Sample Run Start Time	13:34
Sample Run End Time	14:36
Total Actual Sampling Time, min	60.0
Barometric Pressure, mm Hg	746.00
Stack Pressure, mm Hg	745.78
Average Stack Temp, °C	16.3
Meter Volume at Wet STP, scm	1.207
Stack Moisture Content, %	0.0
Average Stack Velocity, m/sec	13.080
Stack Flow Rate, scms wet, STP	3.309
Nozzle Diameter, mm	6.07
% Isokinetic Variation	95.6
Total Mass of Particulate, mg	3.4
Percentage of Total Particulate Collected on Filter	41.2
Stack Particulate Concentration, mg/m³	2.8
Particulate Mass rate, kg/hour	0.034
Emission Limit value	50

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m ³	0.4
Total Weight Gain, mg (Sample Train Blank)	0.5
Blank Result Less than 10% of Limit Value	Y

Uncertainty Calculation for Total Particulate Matter to BS EN 13284-1

Determined Concentration	2.8	mg/m ³ (at Reference Cond)
--------------------------	-----	---------------------------------------

Measured Values

Sampled Volume	1.3069	m ³
Sampled gas Temperature	294.6666667	k
Sampled gas Pressure	99.43	kPa
Sampled gas Humidity	0	% by volume
Oxygen content	21	% by volume
Mass	3.4	mg

Leak	0.30	%
Uncollected Mass	0	mg

Standard Uncertainties for Measured Values

Sampled Volume	0.001	m ³
Sampled gas Temperature	2	k
Sampled gas Pressure	1	kPa
Sampled gas Humidity	1	% by volume
Oxygen content	0.1	% by volume
Mass	0.14152385	mg

Uncertainty Calculation for Volume Correction				Uncertainty Calculation for Oxygen Correction			
Volume Correction Factor	0.941			Oxygen Correction Factor	1.0000		
	Sensitivity Coefficient		Uncertainty, U_v		Sensitivity Coefficient		Uncertainty, U_o
Sampled gas Temperature	0.0033		0.0066	Oxygen Measurement	N/A		N/A
Sampled gas Pressure	0.0095		0.0095				
Sampled gas Humidity	0.0094		0.0094				
	Sqrt (U_v)²		0.0149				
	Total U_v		0.019		Total U_o		N/A

Uncertainty Contributions (Itemised)						
	Value		Sensitivity coefficient	Uncertainty Contribution		
				Concentration	%	
Volume Correction	1.207	m ³	2.33	0.05	mg.m ⁻³	1.62 %
Mass (weighing)	3.40	mg	0.83	0.12	mg.m ⁻³	4.16 %
Oxygen Correction	N/A		0.00	0.00	mg.m ⁻³	0.00 %
System Leak	0.00	mg.m ⁻³	1.00	0.00	mg.m ⁻³	0.17 %
Uncollected Mass	0.00	mg	0.83	0.00	mg.m ⁻³	0.00 %
			Total Uncertainty	0.13	mg.m⁻³	

Uncertainty Result		(Uncertainty has been expanded with a coveragefactor of 2 (K=2))	
Expanded Uncertainty =	0.25	mg.m ⁻³	
=>	8.94	% of Result	
=>	0.00	% of ELV	

**APPENDIX 8:
Industrial Spray Booth 2 (RH) Sampling, Analysis & Uncertainty Data**

Company Name: Covrad Heat Transfer Ltd Date: 17/01/11
Site Ref: Coventry Run: TPM
Sampling Point Ref: Industrial Spray Booth 2 (RH)
Project Ref: FTBS14741

Stack Static press mm H ₂ O:	-5	Stack Diameter (m)	0.59			
		Stack Area (m ²):	0.273			
Traverse Point No.	Port A			Port B		
	Δ p, mm H ₂ O	Root Δ p	Stack Temp °C	Δ p, mm H ₂ O	Root Δ p	Stack Temp °C
1	10.5	3.240	14	14.2	3.768	14
2	19	4.359	14	20.4	4.517	14
3						
4						
5						
6						
7						
8						
9						
10						
Minimum	10.5	3.240	14	14.2	3.768	14
Maximum	19.0	4.359	14	20.4	4.517	14
Mean	14.8	3.800	14.0	17.3	4.142	14.0
Sum	29.5	7.599	28	34.6	8.285	28
Total Sum						

Max. pitot press. = 20.4
Min. pitot press. = 10.5
Ratio Max:Min = 1.9 :1

Gas Data

Oxygen %	21.0
CO ₂ %	0.04
CO %	

Oxygen Correction

Required Correction Value	0
Actual Oxygen Factor	1
Enter 0 if correction is not required	

BS EN 13284-1 & M1 Sample Point Requirements	Requirement Met?
Duct gas flow: angle with regard to duct access <15°?	Y
Duct Gas Flow Negative Velocity: Not Permitted	Y
Duct Gas Flow: Ratio of max to min velocity <3:1?	Y
Working Area > 5m ² ?	Y
Handrails with removable chains / self closing gates across the top of the ladder?	Y
Handrails (approx 0,5 and 1,0 m high) and vertical baseboards (approx 0,25m high)?	Y
Scaffold Built to 'Heavy Duty' Scafftag Rating or at least 2.5kN/m ² loading	Y
Handrails not restricting access to ports?	Y
Room opposite sampling port equal or greater than the length of the sampling probe plus 1 metre?	Y
Sufficient Power (Waterproof 110V BS4343 Standard) close or on the platform?	Y

Company Name: Covrad Heat Transfer Ltd In-stack Filter? Bar. Press mm Hg K Factor Ambient Temp. Leak Rate (fin / %)
 Site Ref: Coventry Cp Dn used Start Time Leak Rate (start / %)
 Date: 17/01/11 Operators Bws% Nozzle No. Stop Time Box/Probe setting
 Run: TPM Meter Correction Yd
 Project Ref: FTBS14741

Sample Filter Weights

	Reference	Laboratory	Increase, mg
Filter	67963	RPS	1.1
Probe Washings	T120195	RPS	1.68

Sample Filter Blank Weighings

	Reference	Laboratory	Increase, mg
Filter	67962	RPS	0.04
Probe Wash	T120194	RPS	1.1

Impinger Weights

Weights	Initial	Final	Increase, g
Impinger 1	883.4	880	-3.4
Impinger 2			0.0
Impinger 3			0.0
Impinger 4			0.0
Impinger 5			0.0
Silica Gel	893.6	906.8	13.2
Total			9.8

Sample Point	Clock Time min	Pitot Δ p, mm H ₂ O	Stack Temp, °C	Orifice Δ H, mm H ₂ O		Gas Meter Reading m ³	Temp at Gas Meter Outlet °C	Condenser Temp, °C	Filter Box Temp °C	Probe Temp °C	Pump Vacuum Inches Hg	Impinger Stern Temp. °C	Root Δ p,
				Desired	Actual								
1	0	13.0	14	38.2	38.2	1463763	14				4	12	3.606
	5	13.2	12	38.8	38.8		15				4	9	3.633
	10	13.0	14	38.2	38.2		15				4	9	3.606
	15	18.0	14	52.9	52.9		14				4	9	4.243
	20	18.0	14	52.9	52.9		14				4	9	4.243
25	18.0	14	52.9	52.9	14				4.5	9	4.243		
Endpoint	30												
2	0	13.4	14	39.4	39.4	1465155.5	14				4	9	3.661
	5	13.4	14	39.4	39.4		14				4	9	3.661
	10	13.4	14	39.4	39.4		14				4	9	3.661
	15	15.8	14	46.5	46.5		13				4	10	3.975
	20	17.4	14	51.2	51.2		13				4	10	4.171
25	17.4	14	51.2	51.2	13				4	10	4.171		
Endpoint	30												
	60.00	15.3	13.8	45.1	45.1	1.393	13.9	#DIV/0!	#DIV/0!	#DIV/0!	4.0	9.5	3.9

Company Name: Covrad Heat Transfer Ltd
Site Ref: Coventry
Project Ref: FTBS14741

Date: 17/01/11

Sampling Point Ref: Industrial Spray Booth 2 (RH)	Run: TPM
Meter Volume Sampled, acm	1.393
Sample Run Start Time	11:55
Sample Run End Time	12:57
Total Actual Sampling Time, min	60.0
Barometric Pressure, mm Hg	746.00
Stack Pressure, mm Hg	745.63
Average Stack Temp, °C	13.8
Meter Volume at Wet STP, scm	1.288
Stack Moisture Content, %	0.9
Average Stack Velocity, m/sec	13.017
Stack Flow Rate, scms wet, STP	3.321
Nozzle Diameter, mm	6.07
% Isokinetic Variation	101.6
Total Mass of Particulate, mg	2.8
Percentage of Total Particulate Collected on Filter	39.6
Stack Particulate Concentration, mg/m³	2.2
Particulate Mass rate, kg/hour	0.026
Emission Limit value	50

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m ³	0.9
Total Weight Gain, mg (Sample Train Blank)	1.1
Blank Result Less than 10% of Limit Value	Y

Uncertainty Calculation for Total Particulate Matter to BS EN 13284-1

Determined Concentration	2.2	mg/m ³ (at Reference Cond)
--------------------------	-----	---------------------------------------

Measured Values

Sampled Volume	1.3925	m ³
Sampled gas Temperature	286.9166667	k
Sampled gas Pressure	99.42	kPa
Sampled gas Humidity	0	% by volume
Oxygen content	21	% by volume
Mass	2.78	mg

Leak	0.10	%
Uncollected Mass	0	mg

Standard Uncertainties for Measured Values

Sampled Volume	0.001	m ³
Sampled gas Temperature	2	k
Sampled gas Pressure	1	kPa
Sampled gas Humidity	1	% by volume
Oxygen content	0.1	% by volume
Mass	0.14152385	mg

Uncertainty Calculation for Volume Correction			Uncertainty Calculation for Oxygen Correction		
Volume Correction Factor	0.934		Oxygen Correction Factor	1.0000	
	Sensitivity Coefficient	Uncertainty, U_v		Sensitivity Coefficient	Uncertainty, U_o
Sampled gas Temperature	0.0033	0.0065	Oxygen Measurement	N/A	N/A
Sampled gas Pressure	0.0094	0.0094			
Sampled gas Humidity	0.0093	0.0093			
	Sqrt (U_v)²	0.0148			
	Total U_v	0.021		Total U_o	N/A

Uncertainty Contributions (Itemised)					
	Value		Sensitivity coefficient	Uncertainty Contribution	
				Concentration	%
Volume Correction	1.276	m ³	1.69	0.03 mg.m ⁻³	1.61 %
Mass (weighing)	2.78	mg	0.78	0.11 mg.m ⁻³	5.09 %
Oxygen Correction	N/A		0.00	0.00 mg.m ⁻³	0.00 %
System Leak	0.00	mg.m ⁻³	1.00	0.00 mg.m ⁻³	0.06 %
Uncollected Mass	0.00	mg	0.78	0.00 mg.m ⁻³	0.00 %
			Total Uncertainty	0.12 mg.m⁻³	

Uncertainty Result		(Uncertainty has been expanded with a coveragefactor of 2 (K=2))	
Expanded Uncertainty =	0.23	mg.m ⁻³	
=>	10.68	% of Result	
=>	0.00	% of ELV	

Certificate of Analysis



Test Certificate

Date 31/01/2011

Client	RPS Towcester Grafton Building Caswell Science & Technology Park Caswell, Towcester Northants NN12 8EQ	Order No.	FTBS 14741
		Certificate No.	WK11-0298
		Issue No.	1
Contact	Katie Brewis	Date Received	20/01/2011
Description	14 filters & 14 solutions for TPM	Technique	Gravimetric

Sample No.	Method	Result
633765	067879	
Total particulate matter		0.17 mg
		D9(U)
633766	T120186	
Total particulate matter		<0.5 mg
		D9(U)
633767	067881	
Total particulate matter		0.84 mg
		D9(U)
633768	T120187	
Total particulate matter		1.4 mg
		D9(U)
633769	067882	
Total particulate matter		0.15 mg
		D9(U)
633770	T120188	
Total particulate matter		0.9 mg
		D9(U)
633771	067873	
Total particulate matter		0.88 mg
		D9(U)
633772	T120189	
Total particulate matter		1.4 mg
		D9(U)
633773	067876	
Total particulate matter		0.21 mg
		D9(U)
633774	T120190	
Total particulate matter		<0.5 mg
		D9(U)
633775	067877	
Total particulate matter		2.80 mg
		D9(U)
633776	T120191	
Total particulate matter		2.3 mg
		D9(U)

Page 1 of 3

RPS Laboratories Ltd, Unit 12, Waters Edge Business Park, Modwen Road, Salford, M5 3EZ
Tel: (0161) 872 2443 Fax: (0161) 877 3959



Test Certificate

Date 31/01/2011

Client	RPS Towcester		Certificate No.	WK11-0298
			Issue No.	1
Sample No.	633777	067874	Method	
Total particulate matter		0.14 mg	D9(U)	
Sample No.	633778	T120192	Method	
Total particulate matter		1.0 mg	D9(U)	
Sample No.	633779	067875	Method	
Total particulate matter		1.70 mg	D9(U)	
Sample No.	633780	T120193	Method	
Total particulate matter		1.4 mg	D9(U)	
Sample No.	633781	067960	Method	
Total particulate matter		<0.04 mg	D9(U)	
Sample No.	633782	T120023	Method	
Total particulate matter		0.8 mg	D9(U)	
Sample No.	633783	067964	Method	
Total particulate matter		5.97 mg	D9(U)	
Damaged filter				
Sample No.	633784	T120024	Method	
Total particulate matter		2.6 mg	D9(U)	
Sample No.	633785	067962	Method	
Total particulate matter		0.04 mg	D9(U)	
Sample No.	633786	T120194	Method	
Total particulate matter		1.1 mg	D9(U)	
Sample No.	633787	067963	Method	
Total particulate matter		1.68 mg	D9(U)	
Sample No.	633788	T120195	Method	
Total particulate matter		1.9 mg	D9(U)	
Sample No.	633789	067976	Method	
Total particulate matter		<0.04 mg	D9(U)	
Sample No.	633790	T120025	Method	
Total particulate matter		0.5 mg	D9(U)	
Sample No.	633791	067961	Method	
Total particulate matter		1.42 mg	D9(U)	
Sample No.	633792	T120026	Method	
Total particulate matter		2.0 mg	D9(U)	

Page 2 of 3

RPS Laboratories Ltd, Unit 12, Waters Edge Business Park, Modwen Road, Salford, M5 3EZ
Tel: (0161) 872 2443 Fax: (0161) 877 3959



Test Certificate

Date 31/01/2011

Client	RPS Towcester	Certificate No.	WK11-0298
		Issue No.	1

Tested By Ceri Wanklyn Date 28/01/2011

Approved By [Redacted] Date 31/01/2011

Joanna Dewhurst
Laboratory Manager

For and on authority of RPS Laboratories Ltd.
RPS Laboratories terms and conditions apply - a copy is available on request.

Method Symbols (U) Analysis is UKAS Accredited
(N) Analysis is not UKAS Accredited

Concentration values (mg/m³ and ppm) are provided to assist with interpretation only, they are not covered by the scope of UKAS accreditation

Analysis carried out on samples 'as received'

This document may not be reproduced other than in full, except with the written approval of the issuing laboratory.